



Source Water Assessment

A Hydrogeologic Susceptibility and Vulnerability Assessment for Long Rifle Lodge Drinking Water System, Chickaloon, Alaska Long Rifle Lodge # 226290

DRINKING WATER PROTECTION PROGRAM REPORT 247
Alaska Department of Environmental Conservation

Source Water Assessment for Long Rifle Lodge Drinking Water System, Mile 102.2 Glenn Highway, Alaska Long Rifle Lodge # 226290

By Shannon & Wilson, Inc.

DRINKING WATER PROTECTION PROGRAM REPORT 247

The Drinking Water Protection Program is producing Source Water Assessments in compliance with the Safe Drinking Water Act Amendments of 1996. Each assessment includes a delineation of the source water area, an inventory of potential and existing contaminant sources that may impact the water, a risk ranking for each of these contaminants, and an evaluation of the potential vulnerability of these drinking water sources.

These assessments are intended to provide public water systems owners/operators, communities, and local governments with the best available information that may be used to protect the quality of their drinking water. The assessments combine information obtained from various sources, including the U.S. Environmental Protection Agency, Alaska Department of Environmental Conservation (ADEC), public water system owners/operators, and other public information sources. The results of this assessment are subject to change if additional data becomes available. If you have any additional information that may affect the results of this assessment, please contact the Program Coordinator of DWPP, (907) 269-7521.

CONTENTS

	Page		Page
Executive Summary	1	Inventory of Potential and Existing	
Introduction	1	Contaminant Sources	3
Description of the Matanuska River Valley Long Rifle Lodge Public Drinking	2	Ranking of Contaminant Risks Vulnerability of Long Rifle Lodge	3
Water System	2	Drinking Water Source	4
Long Rifle Lodge Protection Area	2	Summary	4
		References Cited	6
	TABI	ES	

Table 1 -	Definition	of Zones
-----------	------------	----------

- Table 2 Natural Susceptibility Susceptibility of the Wellhead and Aquifer to Contamination
- Table 3 Contaminant Risks
- Table 4 Overall Vulnerability of Long Rifle Lodge to Contamination by Category

ILLUSTRATIONS

FIGURE	1. Index map showing the location of the Matanuska River Valley	Page 1
	APPENDICES	

APPENDIX

- A. Long Rifle Lodge Drinking Water Protection Area (Map 1)
- B. Contaminant Source Inventory for Long Rifle Lodge (Table 1)

Contaminant Source Inventory and Risk Ranking for Long Rifle Lodge -Bacteria and Viruses (Table 2)

Contaminant Source Inventory and Risk Ranking for Long Rifle Lodge -Nitrates/Nitrites (Table 3)

Contaminant Source Inventory and Risk Ranking for Long Rifle Lodge -Volatile Organic Chemicals (Table 4)

- C. Long Rifle Lodge Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map 2)
- D. Vulnerability Analysis for Contaminant Source Inventory and Risk Ranking for Long Rifle Lodge Public Drinking Water Source (Charts 1 – 7)

Source Water Assessment for Long Rifle Lodge Source of Public Drinking Water, Mile 102.2 Glenn Highway, Alaska

By Shannon & Wilson, Inc.

Drinking Water Protection Program Alaska Department of Environmental Conservation

EXECUTIVE SUMMARY

The Long Rifle Lodge is a Class B (transient/non-community) water system consisting of two wells, located at Mile 102.2 of the Glenn Highway, east of Chickaloon, Alaska. Identified potential and current sources of contaminants for Long Rifle Lodge public drinking water source include: aboveground heating oil tanks, and large capacity and single-family septic systems. These identified potential and existing sources of contamination are considered sources of bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals. Overall, the public water sources for Long Rifle Lodge received a vulnerability rating of Low for volatile organic chemicals, Medium for bacteria and viruses, and High for nitrates and nitrites.

INTRODUCTION

The Alaska Department of Environmental Conservation (ADEC) is completing source water assessments for all public drinking water sources in the State of Alaska. The purpose of this assessment is to provide owners and/or operators, communities, and local governments with information they can use to preserve the quality of Alaska's public drinking water supplies. The results of this source water assessment can be used to decide where voluntary protection efforts are needed and feasible, and also what efforts will be most effective in reducing contaminant risks to your water system. Shannon & Wilson has been contracted to perform these assessments under the supervision of ADEC.




Figure 1. Index map showing the location of the Matanuska River Valley

This source water assessment combines a review of the natural conditions at the site and the potential and existing contaminant risks. These are combined to determine the overall vulnerability of the drinking water source to contamination.

DESCRIPTION OF THE MATANUSKA RIVER VALLEY, ALASKA

Location

The Matanuska River Valley is a narrow incised valley coarsing through the Talkeetna Mountains from the terminus of the Matanuska Glacier to Knik Arm. The Matanuska River Valley is shown in Figure 1. The area is located in the Matanuska-Susitna (Mat-Su) Borough and flows by the town of Palmer, Alaska.

Glacial and alluvial forces have shaped the Matanuska River Valley. These forces have resulted in the relatively narrow, incised river valley as the river cuts through the Talkeetna Mountains and a broad meandering river valley as the river exits the mountains. Landforms in the river valley are typified by the steep valley walls, bedrock outcrops, the river floodplains, and lakes and streams.

Precipitation

While the upper portion of the Matanuska River Valley likely experiences higher amounts of precipitation, Palmer averages about 16 inches of precipitation per year, including about 59 inches of snow.

Topography and Drainage

The area topography varies from about 300 feet to 400 feet within the river floodplain to several thousand feet on the surrounding ridges and mountain flanks.

Groundwater

Although the quality can vary significantly in a short distance, groundwater supplies are generally abundant in the areas along the river. Many homes and businesses in the area rely on individual wells for their water supply. Most of these wells are shallow with depths of less than 100 feet to 200 feet. Static water levels in many of these wells are less than 15 feet below the surface. The coarse, alluvial, sandy gravel in the floodplains of the areas streams and rivers provides a large aquifer even in the winter when infiltration is low.

Geology and Soils

Most of the soils in the area provide good sources of sand, gravel and topsoil. The deposition of silt, clay

and organic muck in old lakes, oxbows and depressions means that some areas have soil conditions that vary over relatively short distances. Bedrock outcrops and shallow bedrock are common along the margins of the river floodplain.

LONG RIFLE LODGE PUBLIC DRINKING WATER SYSTEM

Long Rifle Lodge is a Class B (transient/non-community) water system. The system consists of two wells at Mile 102.2 of the Glenn Highway.

According to the most recent ADEC Sanitary Survey, (6/26/99) completed for the water system, it is unknown when the installation of Well No. 1 occurred. Well No. 1 was drilled to a total depth of approximately 65 feet below ground surface and was completed with 6-inch well casing. The installation of Well No. 2 occurred on May 23, 1978, and was drilled to a total depth of approximately 250 feet below ground surface and was completed with 6-inch well casing. The Sanitary Survey indicates the wells were installed with caps providing a sanitary seal. A properly installed sanitary seal may provide protection against contaminants from entering the source waters at the well casing. The land surface is also appropriately sloped away from the wells providing surface water drainage. The wells were not grouted according to ADEC regulations. Proper provides added protection grouting against contaminants traveling along the well casing and into source waters.

This system operates year-round and serves no residents and more than 25 non-residents through one service connection.

LONG RIFLE LODGE DRINKING WATER PROTECTION AREA

In order to evaluate whether a drinking water source is at risk, we must first evaluate what are the most likely pathways for surface contamination to reach the groundwater. Some areas are more likely to allow contamination to reach the well than others. These areas are determined by looking at the characteristics of the soil, groundwater, aquifer, and well.

The most probable area for contamination to reach the drinking water well is the area that contributes water to the well, the groundwater recharge area. This area is designated as the Drinking Water Protection Area (DWPA). Because a release of contaminants within the DWPA are most likely to impact the drinking water well, this area will serve as the focus for voluntary protection efforts.

An analytical calculation was used to determine the size and shape of the DWPA. The input parameters describing the attributes of the aquifer in this calculation were adopted from the U.S. Geological Survey (Patrick, Brabets, and Glass, 1989), and State of Alaska Department of Water Resources. Additional methods were also used to take into account any uncertainties in groundwater flow and aquifer characteristics to arrive at a meaningful DWPA (Please refer to the Guidance Manual for Class B Public Water Systems for additional information).

The DWPAs established for wells by the ADEC are separated into four zones. These zones correspond to differences in the time-of-travel (TOT) of the water moving through the aquifer to the well. The time of travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. The following is a summary of the four DWPA zones and the calculated TOT for each:

Table 1. Definition of Zones

Zone	Definition
A	¹ / ₄ the distance for the 2 year TOT
В	Less than the 2 year TOT
C	Less Than the 5 year TOT
D	Less than the 10 year TOT
D	Less than the 10 year TOT

As an example, water moving through the aquifer in Zone B will reach the well in less than 2 years from the time it crosses the outer limit of Zone B.

Zone A also incorporates the area downgradient from the well to take into account the area of the aquifer that is influenced by pumping of the well. Water within the aquifer in Zone A will reach the well in several hours to several months.

The Drinking Water Protection Program has completed an inventory of potential and existing sources of contamination within the Long Rifle Lodge DWPA. This inventory was completed through a search of agency records and other publicly available information. Potential sources of contamination to the drinking water aquifer include a wide range of categories and types. Potential drinking water contaminants are found within agricultural, residential, commercial, and industrial areas, but can also occur within areas that have little or no development.

For the basis of all Class B public water system assessments, three categories of drinking water contaminants were inventoried, they include:

- Bacteria and viruses:
- Nitrates and/or nitrites: and

• Volatile organic chemicals.

Inventoried potential sources of contamination within Zones A through Zone D were associated with residential and commercial activities. The sources are summarized in the tables in Appendix B.

RANKING OF CONTAMINANT RISKS

Once the potential and existing sources of contamination have been identified, they are sorted and ranked according to what type and level of risk they represent. Ranking of contaminant risks for a "potential" or "existing" source of contamination is a function of toxicity and volumes of specific contaminants associated with that source. Further, contaminant risks are a function of the number and density of those types of contaminant sources as well as the proximity of those sources to the well.

VULNERABILITY OF LONG RIFLE LODGE DRINKING WATER SOURCE

Vulnerability of a drinking water source to contamination is a combination of two factors:

- Natural susceptibility; and
- Contaminant risks.

Each of the three categories of drinking water contaminants has been analyzed and an overall vulnerability score of 0 to 100 is ultimately assigned:

Natural Susceptibility (0 - 50 points)

+

Contaminant Risks (0 - 50 points)

=

Vulnerability of the Drinking Water Source to Contamination (0 - 100).

A score for the Natural Susceptibility is achieved by analyzing the properties of the well and the aquifer.

Susceptibility of the Wellhead (0 - 25 Points)

+

Susceptibility of the Aquifer (0 - 25 Points)

=

Natural Susceptibility (Susceptibility of the Well) (0-50 Points)

The wells for Long Rifle Lodge are completed in an unconfined aquifer setting. Because an unconfined aquifer is recharged by surface water and precipitation that migrates downward from the surface, contaminants

at the surface have the potential to adversely impact this aquifer. Table 2 shows the Overall Susceptibility score and rating for Long Rifle Lodge.

Table 2. Natural Susceptibility - Susceptibility of the Wellhead and Aquifer to Contamination

Susceptibility of the	Score 5	Rating Low
Wellhead Susceptibility of the	13	Medium
Aquifer Natural Susceptibility	18	Low

Contaminant risks to a drinking water source depend on the type, number or density, and distribution of contaminant sources. This data has been derived from an examination of existing or historical contamination that has been detected at the drinking water source through routine sampling. It also evaluates potential sources of contamination. Table 3 summarizes the Contaminant Risks for each category of drinking water contaminants.

Table 3. Contaminant Risks

Category	Score	Rating
Bacteria and Viruses	30	High
Nitrates and/or Nitrites	43	Very High
Volatile Organic Chemicals	17	Low

Appendix D contains eight charts, which together form the 'Vulnerability Analysis' for a source water assessment for a public drinking water source. Chart 1 analyzes the 'Susceptibility of the Wellhead' to contamination by looking at the construction of the well and its surrounding area. Chart 2 analyzes the 'Susceptibility of the Aquifer' to contamination by looking at the naturally-occurring attributes of the water source and influences on the groundwater system that might lead to contamination. Chart 3 analyzes 'Contaminant Risks' for the drinking water source with respect to bacteria and viruses. The 'Contaminant Risks' portion of the analysis considers potential sources of contaminants as well as a review of contamination that has or may have occurred, but has not arrived or been detected at the well. Lastly, Chart 4 contains the 'Vulnerability Analysis for Bacteria and Viruses.' Charts 5 through 8 contain the Contaminant Risks and Vulnerability Analyses for nitrates and nitrites and volatile organic chemicals, respectively.

Table 4 contains the overall vulnerability scores (0-100) and ratings for each of the three categories of drinking water contaminants. Note: scores are rounded off to the nearest five.

Table 4. Overall Vulnerability of Long Rifle Lodge to Contamination by Category

Category	Score	Rating
Bacteria and Viruses	50	Medium
Nitrates and Nitrites	60	High
Volatile Organic Chemicals	35	Low

Tables 2 through 4 in Appendix B contain the ranking of potential and existing sources of contamination with respect to bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals.

The aboveground heating oil tanks, and large-capacity and single-family tanks create a risk increase for the bacteria and viruses, nitrates and nitrites, and volatile organic compounds.

Only a small amount of bacteria and viruses are required to endanger public health. Bacteria and viruses have not been detected during recent water sampling of the system at Long Rifle Lodge.

Nitrates and/or nitrites are found in natural background concentration at this site, as elsewhere throughout Alaska. Nitrate concentrations in uncontaminated groundwater are typically less than 2 milligrams per liter (mg/L) and are derived primarily from the decomposition of organic matter in soils, adopted from the U.S. Geological Survey (Wang, et al., 2000).

Sampling history for Long Rifle Lodge well indicates that low concentrations of nitrate have been detected (see Chart 5 - Contaminant Risks for Nitrates and/or Nitrites in Appendix D). The maximum existing nitrate concentration is approximately 0.57 mg/L or 6% of the Maximum Contaminant Level (MCL) of 10 mg/L. The MCL is the maximum level of contaminant that is allowed to exist in drinking water and still be consumed by humans without harmful health effects. Due to the high solubility and weak retention by soil, nitrates are very mobile, moving at approximately the same rate as water. Though existing nitrate contamination was detected at the site, concentrations remain at safe levels with respect to human health.

The aboveground heating oil tanks, and large-capacity and single-family tanks located in Zones A, B, and C form the greatest risk for volatile organic chemicals.

SUMMARY

A Source Water Assessment has been completed for the sources of public drinking water serving Long Rifle Lodge. The overall vulnerability of this source to contamination is **Low** for volatile organic chemicals, **Medium** for bacteria and viruses, and **High** for nitrates and nitrites. This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of Long Rifle Lodge to protect public health. It is anticipated that Source Water Assessments will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of Long Rifle Lodge public drinking water source.


REFERENCES CITED

- Wang, B., Strelakos, P.M., and Jokela, J.B., 2000, Nitrate source indicators in ground water of the scimitar subdivision, Peters Creek Area, Anchorage, Alaska: US Geological Survey Water-Resources Investigations Report 00-4137.
- Weather Underground, June 18, 2002, Web extension to the *Western Regional Climate Center* [WWW document]. URL http://www.wunderground.com

APPENDIX A

Long Rifle Lodge Drinking Water Protection Area (Map 1)

Drinking Water Protection Areas for Long Rifle Lodge



APPENDIX B

Contaminant Source Inventory and Risk Ranking for Long Rifle Lodge (Tables 1-4)

Contaminant Source Inventory for Long Rifle Lodge

PWSID 226290.001

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Location	Map Number	Comments
Tanks, heating oil, nonresidential (aboveground)	T14	T14-1	A	Long Rifle Lodge	3	
Tanks, heating oil, nonresidential (aboveground)	T14	T14-2	A	Long Rifle Lodge	3	
Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method)	D10	D10-1	В	Long Rifle Lodge	3	
Septic systems (serves one single-family home)	R02	R2-1	В	Long Rifle Lodge	3	
Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method)	D10	D10-2	C	East of Long Rifle Lodge	3	
Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method)	D10	D10-3	С	East of Long Rifle Lodge	3	

Contaminant Source Inventory and Risk Ranking for

Table 2

PWSID 226290.001

Long Rifle Lodge

Sources of Bacteria and Viruses

	Contaminant	!		Risk Ranking	Overall Rank		Мар	
Contaminant Source Type	Source ID	CS ID tag	Zone	for Analysis	after Analysis	Location	Number	Comments
Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method)	D10	D10-1	В	High	1	Long Rifle Lodge	3	
Septic systems (serves one single-family home)	R02	R2-1	В	Low	2	Long Rifle Lodge	3	

Table 3

Long Rifle Lodge

Sources of Nitrates/Nitrites

	Contaminant	CC ID	77	U	Overall Rank	.	Map	G .
Contaminant Source Type	Source ID	CS ID tag	Zone	for Analysis	after Analysis	Location	Number	Comments
Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method)	D10	D10-1	В	High	1	Long Rifle Lodge	3	
Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method)	D10	D10-2	C	High	2	East of Long Rifle	3	
Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method)	D10	D10-3	C	High	3	East of Long Rifle	3	
Septic systems (serves one single-family home)	R02	R2-1	В	Low	4	Long Rifle Lodge	3	

Table 4

Long Rifle Lodge

Sources of Volatile Organic Chemicals

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Risk Ranking for Analysis	Overall Rank after Analysis	Location	Map Number	Comments
Tanks, heating oil, nonresidential (aboveground)	T14	T14-1	A	Low	1	Long Rifle Lodge	3	
Tanks, heating oil, nonresidential (aboveground)	T14	T14-2	A	Low	2	Long Rifle Lodge	3	
Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method)	D10	D10-1	В	Low	3	Long Rifle Lodge	3	
Septic systems (serves one single-family home)	R02	R2-1	В	Low	4	Long Rifle Lodge	3	
Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method)	D10	D10-2	С	Low	5	East of Long Rifle	3	
Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method)	D10	D10-3	С	Low	6	East of Long Rifle	3	


APPENDIX C

Long Rifle Lodge
Drinking Water Protection Area
and Potential and Existing Contaminant Sources
(Maps 2-3)

Drinking Water Protection Areas for Long Rifle Lodge and Potential and Existing Sources of Contamination Long Rifle Lodge Well // MSB Roads **Smaller Rivers** / Main Rivers /\/ Lakes **25 Meter Contours MSB Land Parcels Zone A Protection Area** Several Months Travel Time **Zone B Protection Area** Less than 2-Years Travel Time GLENN HWY **Zone C Protection Area** Less than 5-Years Travel Time **Zone D Protection Area** Less than 10-Years Travel Time GLACIER POINT DR PWSID 226290.001 1,050 2,100 Feet 2,100

Map 2

Drinking Water Protection Areas for Long Rifle Lodge and Potential and Existing Sources of Contamination




APPENDIX D


Vulnerability Analysis for Long Rifle Lodge Public Drinking Water Source (Charts 1-8)


Susceptibility initially assumed to be low. Susceptibility of wellhead = 0 ptsNO Is the well Increase susceptibility 5 pts + 5 pts properly grouted? Is the well Increase susceptibility 20 pts + 0 pts capped? YES YES Susceptibility of wellhead Low 5 pts YES Increase susceptibility: Is the well 10 pts: suspected floodplain pts within a Wellhead Susceptibility Ratings 20 pts: known floodplain floodplain? 20 to 25 pts very high 15 to < 20 pts high 10 to < 15 pts medium NO < 10 pts low Is the land surface sloped Increase susceptibility 5 pts + 0 pts away from the well?

Chart 1. Susceptibility of the wellhead - Long Rifle Lodge


Chart 2. Susceptibility of the aquifer - Long Rifle Lodge









Page 2 of 2





Page 1 of 6

Chart 5. Contaminant risks for Long Rifle Lodge - Nitrates and Nitrites





Risk Levels for Contaminant Sources identified in Zones A, B and C							
	Zone A	Zones B&C	Total				
Very Highs(s)	0	0	0				
High(s)	0	3	3				
Medium(s)	0	0	0				
Low(s)	0	1	1				

	LOW 10 pts	MEDIUM 20 pts	HIGH 30 pts	VERY HIGH 40 pts
LOW	* 10 sources + 10 pts	≥ 10 sources + 5 pts	≥ 20 sources + 5 pts	
MEDIUM		≥ 2 sources + 5 pts	≥ 5 sources + 5 pts	≥ 10 sources + 5 pts
HIGH			≥ 1 source + 10 pts	≥ 2 sources + 10 pts
VERY HIGH				≥ 1 source + 10 pts


|--|


Note: Septic systems, sewerlines, and roads are each assigned a risk ranking for each individual contaminant source in the CSI. The VA, however, counts these contaminant sources as a group and assigns a calculated number of either "lows" or "mediums" based on the density.






Page 3 of 6





Page 1 of 6

Chart 7. Contaminant risks for Long Rifle Lodge - Volatile Organic Chemicals





Risk Levels for Contam	inant Sources	identified in Zone	s A, B and C	
	Zone A	Zones B&C	Total	
Very Highs(s)	0	0	0	
High(s)	0	0	0	
Medium(s)	0	0	0	
Low(s)	2	4	6	

	LOW 10 pts	MEDIUM 20 pts	HIGH 30 pts	VERY HIGH 40 pts
LOW	* 10 sources + 10 pts	≥ 10 sources + 5 pts	≥ 20 sources + 5 pts	
MEDIUM		≥ 2 sources + 5 pts	≥ 5 sources + 5 pts	≥ 10 sources + 5 pts
HIGH			≥ 1 source + 10 pts	≥ 2 sources + 10 pts
VERY HIGH				≥ 1 source + 10 pts

|--|

Note: Septic systems, sewerlines, and roads are each assigned a risk ranking for each individual contaminant source in the CSI. The VA, however, counts these contaminant sources as a group and assigns a calculated number of either "lows" or "mediums" based on the density.





Page 3 of 6

