



Source Water Assessment

A Hydrogeologic Susceptibility and
Vulnerability Assessment for
Glacier Bay Country Inn
Public Drinking Water System,
Gustavus, Alaska
PWSID # 131110.001

DRINKING WATER PROTECTION REPORT 1608

Alaska Department of Environmental Conservation

February, 2009

Source Water Assessment for Glacier Bay Country Inn Public Drinking Water System, Gustavus, Alaska PWSID# 131110.001

DRINKING WATER PROTECTION REPORT 1608

The Drinking Water Protection (DWP) section of the Drinking Water Program is producing Source Water Assessments in compliance with the Safe Drinking Water Act Amendments of 1996. Each assessment includes a delineation of the source water area, an inventory of potential and existing contaminant sources that may impact the water, a risk ranking for each of these contaminants, and an evaluation of the potential vulnerability of these drinking water sources.

These assessments are intended to provide public water systems owners/operators, communities, and local governments with the best available information that may be used to protect the quality of their drinking water. The assessments combine information obtained from various sources, including the U.S. Environmental Protection Agency, Alaska Department of Environmental Conservation (DEC), public water system owners/operators, and other public information sources. The results of this assessment are subject to change if additional data becomes available. It is anticipated this assessment will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of public drinking water source. If you have any additional information that may affect the results of this assessment, please contact the DWP staff at the following toll-free number 1-866-956-7656.

February, 2009

CONTENTS

	Page		
Executive Summary.....	1	Ranking of Contaminant Risks	2
Glacier Bay Country Inn		Vulnerability of Glacier Bay Country Inn	
Public Drinking Water System	1	Drinking Water System.....	2
Glacier Bay Country Inn		References	5
Drinking Water Protection Area.....	1	Appendix A	7
Inventory of Potential and			
Existing Contaminant Sources.....	2		

TABLES

Table 1. Definition of Zones.....	2
Table 2. Susceptibility	3
Table 3. Contaminant Risks.....	3
Table 4. Overall Vulnerability.....	4

APPENDICES

APPENDIX	A. Glacier Bay Country Inn Drinking Water Protection Area (Map A)
----------	---

Source Water Assessment for Glacier Bay Country Inn

Source of Public Drinking Water, Gustavus, Alaska

Drinking Water Protection

Alaska Department of Environmental Conservation

EXECUTIVE SUMMARY

The public water system for Glacier Bay Country Inn is a Class B (transient/non-community) water system consisting of one well located about 2.5 miles west of the airport in Gustavus, Alaska. The wellhead received a susceptibility rating of **Very High** and the aquifer received a susceptibility rating of **High**. Combining these two ratings produces a **Very High** rating for the natural susceptibility of the well. There were no identified potential and current sources of contaminants for Glacier Bay Country Inn public drinking water source. Overall, the public water sources for Glacier Bay Country Inn received a vulnerability rating of **Medium** for the following contaminant categories: bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals. The medium ratings can be attributed mostly to the lack of identified potential and existing sources of contamination. It should be noted, however, that the contaminant source inventory is based on existing data at the time of this report and may not be an accurate reflection of changing field conditions. If potential or existing sources of contamination are identified on site, please notify the Alaska Department of Environmental Conservation (DEC) so that the inventory can be updated to be more reflective of current conditions. A medium rating should not discourage preventative measures such as development and implementation of protection efforts from future or intermittent potential sources of contamination.

This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of Valley Open Bible Fellowship to protect public health.

GLACIER BAY COUNTRY INN PUBLIC DRINKING WATER SYSTEM

The Glacier Bay Country Inn public water system is a Class B (transient/non-community) water system. The system consists of one well located about 2.5 miles west of the airport in Gustavus, Alaska (see Map A in Appendix A). Gustavus is located 48 air miles northwest of Juneau. It is bounded on three sides by Glacier Bay National Park and the waters of Icy Passage on the fourth. The population of Gustavus is 442 and is partially seasonal (ADCCED, 2008).

Half of the year-round homes in Gustavus are plumbed with their own water wells and septic systems. A community well offering treated water is available for others. Electricity is provided by Gustavus Electric Company and a permitted landfill is available for refuse (ADCCED, 2008).

According to the sanitary survey for this system (07/18/1996), the well extends approximately 35 feet below the ground surface and is completed in an unconfined aquifer.

This system operates from May through September and serves 5 residents and 26 non-residents through one service connection.

GLACIER BAY COUNTRY INN DRINKING WATER PROTECTION AREA

In order to evaluate whether a drinking water source is at risk, we must first evaluate what are the most likely pathways for surface contamination to reach the groundwater. These areas are determined by looking at the characteristics of the soil, groundwater, aquifer, and well.

The most probable area for contamination to reach the drinking water well is the drinking water protection area. The drinking water protection area is the area circling the well (the area influenced by pumping) and also the area upgradient of the well, usually forming a parabola shape. Because releases of contaminants within the protection area are most likely to impact the well, this area will serve as the focus for voluntary protection efforts.

There are many different methods for calculating the size of protection areas. Drinking Water Protection (DWP) uses a combination of two simple groundwater flow equations, the Thiem and uniform flow equations for all groundwater wells screened in unconsolidated material. The orientation of the protection zone is then drawn using a water table elevation map (if available) or a land surface elevation map of the area. The protection zone calculated by DWP is an estimate using the available information and resources, and may differ slightly from the actual capture zone. Because of uncertainties and changing site conditions, a factor of safety is added to the protection zone to form the drinking water protection area for the well.

The parameters used to calculate the shape of this protection zone are general for the whole alluvial plain and were obtained from various United States Geological Survey (USGS) reports, area well logs, and the Groundwater textbook by Freeze and Cherry (Freeze and Cherry, 1979).

The protection areas established for wells by the DEC are usually separated into two zones, limited by the watershed. These zones correspond to differences in the time-of-travel (TOT) of the water moving through the aquifer to the well. An analytical calculation was used to determine the size and shape of the protection area.

The time-of-travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. The following is a summary of the two protection area zones for wells and the calculated time-of-travel for each:

Table 1. Definition of Zones

Zone	Definition
A	Several months time-of-travel
B	Less than the 2 year time-of-travel

The drinking water protection area for Glacier Bay Country Inn was determined using an analytical calculation and includes Zones A and B (see Map A in Appendix A).

INVENTORY OF POTENTIAL AND EXISTING CONTAMINANT SOURCES

Drinking Water Protection has completed an inventory of potential and existing sources of contamination within the Glacier Bay Country Inn drinking water protection area. This inventory was completed through a search of agency records and other publicly available information. Potential sources of contamination to the drinking water aquifer include a wide range of categories and types. Potential drinking water contaminants are found within agricultural, residential, commercial, and industrial areas, but can also occur within areas that have little or no development.

For the basis of all Class B public water system assessments, the following three categories of drinking water contaminants were inventoried:

- Bacteria and viruses;
- Nitrates and/or nitrites;
- Volatile organic chemicals

There were no known sources of contaminants identified within the protection area for this system at the time the inventory was taken.

RANKING OF CONTAMINANT RISKS

Once the potential and existing sources of contamination have been identified, they are assigned a ranking according to what type and level of risk they represent. Ranking of contaminant risks for a “potential” or “existing” source of contamination is a function of toxicity and volumes of specific contaminants associated with that source. Rankings include:

- Low;
- Medium;
- High; and
- Very High.

There were no known contaminant sources identified within the protection area for this system at the time the inventory was taken, therefore no rankings were assigned.

VULNERABILITY OF GLACIER BAY COUNTRY INN DRINKING WATER SYSTEM

Vulnerability of a drinking water source to contamination is a combination of two factors:

- Natural Susceptibility; and
- Contaminant Risks.

A score for the Natural Susceptibility of the well is reached by considering the properties of the well and the aquifer.

Susceptibility of the Wellhead (0-25 Points)

+

Susceptibility of the Aquifer (0-25 Points)

=

Natural Susceptibility of the Well (0-50 Points)

A ranking is assigned for the Natural Susceptibility according to the point score:

Natural Susceptibility Ratings	
40-50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

Factors contributing to the susceptibility of the wellhead are: whether the sanitary seal is in place, protection from flooding, and if the well casing is properly grouted.

The wellhead for the Glacier Bay Country Inn received a **Very High** susceptibility rating. The most recent sanitary survey (07/18/1996) indicates that the land surface is sloped away from the well, but no sanitary seal is installed on the well and the well is not grouted according to DEC regulations. Sanitary seals prevent potential contaminants from entering the well, while sloping of the land surface away from the wellhead provides adequate surface water drainage, and concrete or grouting around the wellhead helps to prevent potential contaminants from traveling down the outside of the well casing.

Factors contributing to the susceptibility of the aquifer are: whether the aquifer is confined or unconfined, whether the well is completed in unconsolidated or fractured bedrock, whether wells and bore holes are penetrating the aquifer and, if applicable, the confining layer.

The Glacier Bay Country Inn system draws water from an unconfined aquifer consisting of unconsolidated materials. It received a **High** susceptibility rating because of its unconfined status and very shallow depth to water. Because an unconfined aquifer is recharged by surface water and precipitation that migrates downward from the surface, it is susceptible to contamination from outside sources. Shallow aquifers provide less protection from this downward migration.

Table 2 summarizes the Susceptibility scores and ratings for the Glacier Bay Country Inn system.

Table 2. Susceptibility

	Score	Rating
Susceptibility of the Wellhead	25	Very High
Susceptibility of the Aquifer	18	High
Natural Susceptibility	43	Very High

Contaminant risks are derived from an evaluation of the routine sampling results of the water system and the presence of potential sources of contamination. Contaminant risks to a drinking water source depend on the type and distribution of contaminant sources. Flow charts are used to assign a point score, and ratings are assigned in the same way as for the natural susceptibility:

Contaminant Risk Ratings	
40-50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

Table 3 summarizes the Contaminant Risks for each category of drinking water contaminants for the Glacier Bay Country Inn system.

Table 3. Contaminant Risks

Category	Score	Rating
Bacteria and Viruses	10	Low
Nitrates and/or Nitrites	0	Low
Volatile Organic Chemicals	0	Low

Finally, an overall vulnerability score is assigned for each water system by combining each of the contaminant risk scores with the natural susceptibility score:

$$\begin{aligned}
 &\text{Natural Susceptibility (0-50 Points)} \\
 &\quad + \\
 &\quad \text{Contaminant Risks (0-50 Points)} \\
 &\quad = \\
 &\text{Vulnerability of the Drinking Water Source to} \\
 &\quad \text{Contamination (0-100 Points)}
 \end{aligned}$$

Again, rankings are assigned according to a point score:

Overall Vulnerability Ratings	
80-100 pts	Very High
60 to < 80 pts	High
40 to < 60 pts	Medium
< 40 pts	Low

Table 4 contains the overall vulnerability scores (0-100) and ratings for each of the three categories of drinking water contaminants for the Glacier Bay Country Inn system. Note: scores are rounded off to the nearest five.

Table 4. Overall Vulnerability

Category	Score	Rating
Bacteria and Viruses	55	Medium
Nitrates and/or Nitrites	45	Medium
Volatile Organic Chemicals	45	Medium

Bacteria and Viruses

The contaminant risk for bacteria and viruses is **Low** with no known contaminant sources posing any risk to the drinking water well.

Coliforms (a bacteria) are found naturally in the environment and while not necessarily a direct health threat, they are an indicator of other potentially harmful bacteria in the water, more specifically fecal coliforms and E. coli. These bacteria only come from human and animal fecal waste and can cause diarrhea, cramps, nausea, headaches, and other symptoms (EPA, 2008).

Only a small number of bacteria and viruses are required to endanger public health. Positive samples for bacteria and viruses increase the overall vulnerability of the drinking water source, indicating that the source is susceptible to bacteria and virus contamination. Bacteria and viruses have not recently been detected within the last 5 years of sampling of the system at Glacier Bay Country Inn (data reviewed in April, 2008).

After combining the contaminant risk for bacteria and viruses with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

Nitrates and Nitrites

The contaminant risk for nitrates and nitrites is **Low** with no known contaminant sources posing any risk to the drinking water well.

Sampling history for Glacier Bay Country Inn well indicates that nitrates have not been detected in the water within the last 5 years of sampling (data reviewed in April, 2008).

After combining the contaminant risk for nitrates and nitrites with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

Volatile Organic Chemicals

The contaminant risk for volatile organic chemicals is **Low** with no known contaminant sources posing any risk to the drinking water well.

The drinking water at Glacier Bay Country Inn has not recently been sampled for volatile organic chemicals (data reviewed in April, 2008).

After combining the contaminant risk for volatile organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.


Using the Source Water Assessment

This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of Glacier Bay Country Inn to protect public health. It is anticipated that Source Water Assessments will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of Glacier Bay Country Inn drinking water source.

APPENDIX A

Glacier Bay Country Inn Drinking Water Protection Area Location Map (Map A)

Public Water Well System for PWS #131110.001 Glacier Bay Country Inn



Legend

- Class B Public Water System Well
- Groundwater Protection Zones
 - Zone A Protection Area - Several Months Travel Time
 - Zone B Protection Area - 2 Years Travel Time

Data Sources:
Contaminant Sources, Public Water System Wells, Alaska Department of Environmental Conservation (ADEC)

All other data:
United States Geological Survey (USGS)

Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class B Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or validity of the data provided.

