



Source Water Assessment

A Hydrogeologic Susceptibility and
Vulnerability Assessment for
Lower Kalskag Water System
Drinking Water System,
Lower Kalskag, Alaska

PWSID # 270697.001

April 2004

DRINKING WATER PROTECTION PROGRAM REPORT 1097a
Alaska Department of Environmental Conservation

Source Water Assessment for Lower Kalskag Water System Drinking Water System Lower Kalskag, Alaska

PWSID # 270697.001

DRINKING WATER PROTECTION PROGRAM REPORT 1097a

The Drinking Water Protection Program (DWPP) is producing Source Water Assessments in compliance with the Safe Drinking Water Act Amendments of 1996. Each assessment includes a delineation of the source water area, an inventory of potential and existing contaminant sources that may impact the water, a risk ranking for each of these contaminants, and an evaluation of the potential vulnerability of these drinking water sources.

These assessments are intended to provide public water systems owners/operators, communities, and local governments with the best available information that may be used to protect the quality of their drinking water. The assessments combine information obtained from various sources, including the U.S. Environmental Protection Agency, Alaska Department of Environmental Conservation (ADEC), public water system owners/operators, and other public information sources. The results of this assessment are subject to change if additional data becomes available. It is anticipated this assessment will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of public drinking water source. If you have any additional information that may affect the results of this assessment, please contact the Program Coordinator of DWPP, (907) 269-7521.

CONTENTS

EXECUTIVE SUMMARY	1
PUBLIC DRINKING WATER SYSTEM	1
DRINKING WATER PROTECTION AREA	2
	INVENTORY OF POTENTIAL AND EXISTING CONTAMINANT SOURCES2
	RANKING OF CONTAMINANT RISKS2
	VULNERABILITY OF DRINKING WATER SYSTEM3

TABLES

Table 1. Definition of Zones	2
Table 2. Susceptibility	3
Table 3. Contaminant Risks	4
Table 4. Overall Vulnerability	4

APPENDICES

APPENDIX	<p>A. Lower Kalskag Water System Drinking Water Protection Area (Map A)</p> <p>B. Contaminant Source Inventory for Lower Kalskag Water System (Table 1) Contaminant Source Inventory and Risk Ranking for Lower Kalskag Water System – Bacteria and Viruses (Table 2) Contaminant Source Inventory and Risk Ranking for Lower Kalskag Water System – Nitrates/Nitrites (Table 3) Contaminant Source Inventory and Risk Ranking for Lower Kalskag Water System – Volatile Organic Chemicals (Table 4) Contaminant Source Inventory and Risk Ranking for Lower Kalskag Water System – Heavy Metals, Cyanide and Other Inorganic Chemicals (Table 5) Contaminant Source Inventory and Risk Ranking for Lower Kalskag Water System – Synthetic Organic Chemicals (Table 6) Contaminant Source Inventory and Risk Ranking for Lower Kalskag Water System – Other Organic Chemicals (Table 7)</p> <p>C. Lower Kalskag Water System Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)</p> <p>D. Vulnerability Analysis for Contaminant Source Inventory and Risk Ranking for Lower Kalskag Water System Public Drinking Water Source (Charts 1 – 14)</p>
----------	---

Source Water Assessment for Lower Kalskag Water System Source of Public Drinking Water, Lower Kalskag, Alaska

Drinking Water Protection Program Alaska Department of Environmental Conservation

EXECUTIVE SUMMARY

The Lower Kalskag Water System has two Public Water System (PWS) wells. The well (PWS No. 270697.001) has been used as a drinking water source since it was drilled in 1983. This source water assessment report is exclusively limited to PWSID #270697.001.

The well is a Class A (community and non-transient non-community) water system located on Main Street in Lower Kalskag, Alaska. Available records indicate that there is secondary storage of drinking water, with a combined capacity of 10,000-gallons, and that the drinking water source is treated with calcium hypochlorite. This system operates year round and serves approximately 302 residents through 37 service connections. The wellhead received a susceptibility rating of **Very High** and the aquifer received a susceptibility rating of **Very High**. Combining these two ratings produce a **Very High** rating for the natural susceptibility of the well.

Identified potential and current sources of contaminants for the public drinking water source include: domestic wastewater treatment plant disposal ponds/lagoons, landfills, aboveground fuel tanks, water supply wells, cemeteries, municipal or city parks, petroleum product bulk station/terminals, roads, electric power generation, firehouses, medical/veterinary facilities, and an airport. These identified potential and existing sources of contamination are considered as sources of bacteria and viruses, nitrates and/or nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, synthetic organic chemicals, and other organic chemicals contaminant categories.

Overall, the water well received a vulnerability rating of **Very High** for bacteria and viruses, nitrates and nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, synthetic organic chemicals, and other organic chemicals contaminant categories.

PUBLIC DRINKING WATER SYSTEM

The Lower Kalskag Water System well is a Class A (community/non-transient/non-community) public water system. The system is located on Main Street in Lower Kalskag, Alaska (Sec. 2, T16N, R62W, Seward Meridian; see Map A of Appendix A). Lower Kalskag is located on the north bank of the Kuskokwim River, about 2 miles down river from Kalskag. The village lies 26 miles west of Aniak, 89 miles northeast of Bethel, and 350 miles west of Anchorage. The community has a population of 267 (ADCED, 2003). Average annual precipitation in Lower Kalskag is 19 inches, including approximately 60 inches of snowfall. Temperatures can be as extreme as -55 to 87°F.

The community of Lower Kalskag obtains most of their water supply from community wells. Many of the households are served by the piped sewage collection system and the remaining households have individual septic tanks (ADCED, 2003). Lower Kalskag receives electrical power from AVEC, a REA Co-Op. Power generating facilities are fueled by diesel. Refuse is collected by individuals and either transported to the landfill or burned (ADCED, 2003).

According to information supplied by ADEC for the Lower Kalskag Water System PWS, the depth of the primary water well is 40 feet below the ground surface. Based on available construction details for surrounding wells, it is assumed that the well is screened in an unconfined aquifer. The well is located within a floodplain.

Information acquired from a November 2002 sanitary survey for the public water system indicated that the land surface was sloped away from the well. Generally, land surfaces that slope away from the wellhead promote surface water drainage, which reduces the potential of contaminant migration down the well casing annulus. The sanitary survey indicates that the well is not grouted according to ADEC regulations. Proper grouting provides added protection against contaminants traveling along the well casing annulus and into source waters.

The Lower Kalskag area is located on a flat former floodplain of the Kuskokwim River and the topographic relief in the area is less than 20 feet. Soils information is limited. Generally, the soils consist of sandy silt overlying sand and fine gravels. Lower Kalskag is located in an area that is considered a discontinuous permafrost zone and the permafrost masses are small, thin and generally isolated (U.S. Department of Health and Human Services, et. al, 1983).

DRINKING WATER PROTECTION AREA

In order to evaluate whether a drinking water source is at risk, we must first evaluate what are the most likely pathways for surface contamination to reach the groundwater. These areas are determined by looking at the characteristics of the soil, groundwater, aquifer, and well.

The most probable area for contamination to reach the drinking water well is the area that contributes water to the well, the groundwater recharge area. This area is designated as the drinking water protection area (DWPA). Because releases of contaminants within the protection area are most likely to impact the drinking water well, this area will serve as the focus for voluntary protection efforts. An analytical calculation was used to determine the size and shape of the DWPA for the Lower Kalskag Water System PWS. The input parameters describing the attributes of the aquifer in this calculation were adopted from Groundwater (Freeze and Cherry, 1979). Available geology and groundwater contours were also considered to take into account any uncertainties in groundwater flow and aquifer characteristics to arrive at a meaningful protection area.

The protection areas established for wells by the ADEC are usually separated into four zones, limited by the watershed. These zones correspond to differences in the time-of-travel (TOT) of the water moving through the aquifer to the well (Please refer to the Guidance Manual for Class A Public Water Systems for additional information).

The time of travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. The following is a summary of the four protection area zones for wells and the calculated time-of-travel for each:

Table 1. Definition of Zones

Zone	Definition
A	¼ the distance for the 2-yr. time-of-travel

B	Less than the 2 year time-of-travel
C	Less Than the 5 year time-of-travel
D	Less than the 10 year time-of-travel

The DWPA for the Lower Kalskag Water System PWS was determined using an analytical calculation and includes Zones A, B, C, and D (See Map A of Appendix A).

INVENTORY OF POTENTIAL AND EXISTING CONTAMINANT SOURCES

The Drinking Water Protection Program has completed an inventory of potential and existing sources of contamination within the Lower Kalskag Water System DWPA. This inventory was completed through a search of agency records and other publicly available information. Potential sources of contamination to the drinking water aquifer include a wide range of categories and types. Potential drinking water contaminants are found within agricultural, residential, commercial, and industrial areas, but can also occur within areas that have little or no development.

For the basis of all Class A public water system assessments, six categories of drinking water contaminants were inventoried. They include:

- Bacteria and viruses,
- Nitrates and/or nitrites,
- Volatile organic chemicals,
- Heavy metals, cyanide and other inorganic chemicals,
- Synthetic organic chemicals,
- Other organic chemicals.

The sources are displayed on Map C of Appendix C and summarized in Table 1 of Appendix B.

RANKING OF CONTAMINANT RISKS

Once the potential and existing sources of contamination have been identified, they are assigned a ranking according to what type and level of risk they represent. Ranking of contaminant risks for a “potential” or “existing” source of contamination is a function of toxicity and volumes of specific contaminants associated with that source. Rankings include:

- Low,
- Medium,
- High, and
- Very High.

The time-of-travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. Bacteria and Viruses are only inventoried in Zones A and B because of their short life span. Only “Very High” and “High” rankings are inventoried within the outer Zone D due to the probability of contaminant dilution by the time the contaminants get to the well. Tables 2 through 4 in Appendix B contain the ranking of potential and existing sources of contamination with respect to bacteria and viruses, nitrates and/or nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, synthetic organic chemicals, and other organic chemicals.

VULNERABILITY OF THE DRINKING WATER SYSTEM

Vulnerability of a drinking water source to contamination is a combination of two factors:

- Natural susceptibility, and
- Contaminant risks.

Appendix D contains fourteen charts, which together form the ‘Vulnerability Analysis’ for a source water assessment for a public drinking water source. Chart 1 analyzes the ‘Susceptibility of the Wellhead’ to contamination by looking at the construction of the well and its surrounding area. Chart 2 analyzes the ‘Susceptibility of the Aquifer’ to contamination by looking at the naturally occurring attributes of the water source and influences on the groundwater system that might lead to contamination. Chart 3 analyzes ‘Contaminant Risks’ for the drinking water source with respect to bacteria and viruses. The ‘Contaminant Risks’ portion of the analysis considers potential sources of contaminants as well as a review of contamination that has or may have occurred, but has not arrived or been detected at the well. Chart 4 contains the ‘Vulnerability Analysis for Bacteria and Viruses’. Charts 5 through 14 contain the Contaminant Risks and Vulnerability Analyses for nitrates and nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, synthetic organic chemicals, and other organic chemicals, respectively.

A score for the Natural Susceptibility is reached by considering the properties of the well and the aquifer.

Susceptibility of the Wellhead (0 – 25 Points)
(Chart 1 of Appendix D)

+

Susceptibility of the Aquifer (0 – 25 Points)
(Chart 2 of Appendix D)

=

Natural Susceptibility (Susceptibility of the Well)
(0 – 50 Points)

A ranking is assigned for the Natural Susceptibility according to the point score:

Natural Susceptibility Ratings	
40 to 50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

The Lower Kalskag Water System’s water well is in an unconfined aquifer. Unconfined aquifers are more susceptible to potential groundwater quality impacts posed by the migration of surface water contaminants downward from the surface. Table 2 shows the susceptibility scores and ratings for this PWS.

Table 2. Susceptibility

	Score	Rating
Susceptibility of the Wellhead	25	Very High
Susceptibility of the Aquifer	25	Very High
Natural Susceptibility	50	Very High

Contaminant risks to a drinking water source depend on the type, number or density, and distribution of contaminant sources. This score has been derived from an examination of existing and historical contamination that has been detected at the drinking water source through routine sampling. It also evaluates potential sources of contamination. Flow charts are used to assign a point score, and ratings are assigned in the same way as for the natural susceptibility:

Contaminant Risk Ratings	
40 to 50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

Table 3 summarizes the Contaminant Risks for each category of drinking water contaminants.

Table 3. Contaminant Risks

Category	Score	Rating
Bacteria and Viruses	50	Very High
Nitrates and/or Nitrites	50	Very High
Volatile Organic Chemicals	50	Very High
Heavy Metals, Cyanide and		
Other Inorganic Chemicals	50	Very High
Synthetic Organic Chemicals	50	Very High
Other Organic Chemicals	50	Very High

Finally, an overall vulnerability score is assigned for each water system by combining each of the contaminant risk scores with the natural susceptibility score:

$$\begin{array}{rcl}
 \text{Natural Susceptibility (0 – 50 points)} & & \\
 + & & \\
 \text{Contaminant Risks (0 – 50 points)} & & \\
 = & & \\
 \text{Vulnerability of the} & & \\
 \text{Drinking Water Source to Contamination (0 – 100).} & &
 \end{array}$$

Again, rankings are assigned according to a point score:

Overall Vulnerability Ratings	
80 to 100 pts	Very High
60 to < 80 pts	High
40 to < 60 pts	Medium
< 40 pts	Low

Table 4 contains the overall vulnerability scores (0 – 100) and ratings for each of the six categories of drinking water contaminants. Note: scores are rounded off to the nearest five.

Table 4. Overall Vulnerability

Category	Score	Rating
Bacteria and Viruses	100	Very High
Nitrates and Nitrites	100	Very High
Volatile Organic Chemicals	100	Very High
Heavy Metals, Cyanide and		
Other Inorganic Chemicals	100	Very High
Synthetic Organic Chemicals	100	Very High

Other Organic Chemicals 100 Very High

Bacteria and Viruses

The contaminant risk for bacteria and viruses is **Very High**. The risk is primarily attributed to the presence of domestic wastewater treatment plant disposal ponds/lagoons and landfills in Zones A and B (see Table 2 – Appendix B).

Coliforms (a bacteria) are found naturally in the environment and although they aren't necessarily a health threat, they are an indicator of other potentially harmful bacteria in the water, more specifically, fecal coliforms and E. coli, which only come from human and animal fecal waste. Harmful bacteria can cause diarrhea, cramps, nausea, headaches, or other symptoms (EPA, 2003).

Positive bacteria counts have been reported in recent (within five years) sampling events (See Chart 3 – Contaminant Risks for Bacteria and Viruses in Appendix D). Only a small amount of bacteria and viruses are required to endanger public health.

After combining the contaminant risk for bacteria and viruses with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Very High**.

Nitrates and Nitrites

The contaminant risk for nitrates and nitrites is **Very High**. The risk to this source of public drinking water is primarily attributed to the presence of domestic wastewater treatment plant disposal ponds/lagoons and landfills in Zones A and B (see Table 3 – Appendix B).

Nitrates are very mobile, moving at approximately the same rate as water. The sampling history for this well indicates that low levels of nitrates have been detected in recent sampling events. However, the reported concentrations of nitrates do not exceed the maximum contaminant level (MCL) of 10 mg/L. Nitrate concentrations in uncontaminated groundwater are typically less than 2 mg/L; therefore, nitrate concentrations above 2 mg/L may be indicative of man-made sources (See Chart 5 - Contaminant Risks for Nitrates and/or Nitrites in Appendix D).

Nitrate levels are often derived from the decomposition of organic matter in soils. Although the nitrate source is unknown, such occurrences may be attributed to septic systems or other sources. After combining the contaminant risk for nitrates and nitrites with the natural susceptibility of the well, the

overall vulnerability of the well to nitrate and nitrite contamination is **Very High**.

Volatile Organic Chemicals

The contaminant risk for volatile organic chemicals is **Very High**. The risk is primarily attributed to the presence of landfills, petroleum product bulk station/terminals, and an airport in Zones A and B. Numerous other potential contaminant sources are also found within the protection area (see Table 4 – Appendix B).

All recent sampling data for VOCs were below the detection levels (See Chart 7 – Contaminant Risks for Volatile Organic Chemicals in Appendix D).

After combining the contaminant risk for volatile organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Very High**.

Heavy Metals, Cyanide and Other Inorganic Chemicals

The contaminant risk for heavy metals, cyanide and other inorganic chemicals is **Very High**. The risk is primarily attributed to the presence of landfills located in Zones A and B. Numerous other potential contaminant sources are also found within the protection area (see Table 5 – Appendix B).

Based on review of recent sampling records for this public water system, high levels of lead have been detected in recent sampling history. The concentration of lead exceeded the MCL of 0.015 mg/L (see Chart 8 – Contaminant Risks for Heavy Metals, Cyanide, and Other Inorganic Chemicals in Appendix D).

After combining the contaminant risk for heavy metals, cyanide and other inorganic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Very High**.

Synthetic Organic Chemicals

The contaminant risk for synthetic organic chemicals is **Very High**. The risk is primarily attributed to the presence of landfills located in Zones A and B. Numerous other potential contaminant sources are also found within the protection area (see Table 6 – Appendix B).

No recent sampling data was available in ADEC records for the Lower Kalskag Water System (See Chart 11 – Contaminant Risks for Synthetic Organic Chemicals in Appendix D).

After combining the contaminant risk for synthetic organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Very High**.

Other Organic Chemicals

The contaminant risk for other organic chemicals is **Very High**. The risk is primarily attributed to the presence of landfills, petroleum product bulk station/terminals, and electric power generation located in Zones A and B. Numerous other potential contaminant sources are also found within the protection area (see Table 7 – Appendix B).

No recent sampling data was available in ADEC records for the Lower Kalskag Water System (See Chart 13 – Contaminant Risks for Other Organic Chemicals in Appendix D).

After combining the contaminant risk for other organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Very High**.

Using the Source Water Assessment

This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of the community of Lower Kalskag to protect public health. It is anticipated that Source Water Assessments will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of the drinking water source.

REFERENCES

- Alaska Department of Community and Economic Development (ADCED), 2003 [WWW document]. URL: http://www.dced.state.ak.us/cbd/commdb/CF_COMDB.htm
- Alaska Department of Environmental Conservation, Contaminated Sites Database, 2003 [WWW database], URL http://www.state.ak.us/dec/dspar/csites/cs_search.htm
- Alaska Department of Environmental Conservation, Leaking Underground Storage Tank Database, 2003 [WWW database], URL http://www.dec.state.ak.us/spar/stp/ust/search/fac_search.asp
- Freeze, R. A., and Cherry, J.A. 1979, Groundwater, Prentice-Hall, Englewood Cliffs, New Jersey
- United States Department of Health and Human Services, et.al, 1983. Final Report, Sanitation Facilities Construction for Aniak, Alaska, Project No. AN-80-222.
- United States Environmental Protection Agency (EPA), 2002 [WWW document]. URL <http://www.epa.gov/safewater/mcl.html>.

APPENDIX A

Drinking Water Protection Area Location Map (Map A)

Public Water Well System for PWS #270697.001 Lower Kalskag Water System



LEGEND

Public Water System Well

Hydrography/Physical

- Parcels
- Stream
- Lake or Pond
- Contours

Transportation

- Primary Route (Class 1)
- Secondary Route (Class 2)
- Road (Class 3)
- Road (Class 4)
- Road (Class 5, Four-wheel drive)

Groundwater Protection Zones

- Zone A Protection Area- Several Months Travel Time
- Zone B Protection Area- 2 Years Travel Time
- Zone C Protection Area- 5 Years Travel Time
- Zone D Protection Area- 10 Years Travel Time


Data Sources:
Contaminant Sources, Public Water System Wells, Contours
Alaska Department of Environmental Conservation (ADEC)

Critical Facilities, Federal Emergency Management Agency (FEMA)

All other data:
United States Geological Survey (USGS)

Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class A Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or validity of the data provided.



0 2 4 8 12 16 Miles

Lower Kalskag Water System
PWS 270697.001

Appendix A Map A

APPENDIX B

Contaminant Source Inventory and Risk Ranking (Tables 1-7)

Table 1

**Contaminant Source Inventory for
Lower Kalskag Water System**

PWSID 270697.001

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Map Number	Comments
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-01	A	C	
Landfills (municipal; Class III)	D51	D51-01	A	C	
Landfills (municipal; Class III)	D51	D51-02	A	C	
Tanks, diesel (above ground)	T06	T06-01	A	C	Generator
Tanks, heating oil, nonresidential (aboveground)	T14	T14-01	A	C	AVEC Power Plant
Tanks, heating oil, nonresidential (aboveground)	T14	T14-02	A	C	Clinic
Tanks, heating oil, nonresidential (aboveground)	T14	T14-03	A	C	Store
Tanks, heating oil, nonresidential (aboveground)	T14	T14-04	A	C	Telephone
Tanks, heating oil, nonresidential (aboveground)	T14	T14-05	A	C	Church
Tanks, heating oil, nonresidential (aboveground)	T14	T14-06	A	C	Church
Tanks, heating oil, nonresidential (aboveground)	T14	T14-07	A	C	Community Hall
Tanks, heating oil, nonresidential (aboveground)	T14	T14-08	A	C	Fire Station
Tanks, heating oil, nonresidential (aboveground)	T14	T14-09	A	C	Post Office
Tanks, heating oil, nonresidential (aboveground)	T14	T14-10	A	C	George Morgan Jr./Sr. High School
Tanks, heating oil, nonresidential (aboveground)	T14	T14-11	A	C	Zackar Levi Elementary School
Water supply wells	W09	W09-01	A	C	2 water supply wells in Zone A
Cemeteries	X01	X01-01	A	C	
Cemeteries	X01	X01-02	A	C	
Municipal or city parks (with green areas)	X04	X04-01	A	C	Recreational Platform
Petroleum product bulk station/terminals	X11	X11-01	A	C	AVEC
Petroleum product bulk station/terminals	X11	X11-02	A	C	School
Highways and roads, dirt/gravel	X24	X24-01	A	C	Assume 1-20 roads in Zone A
Electric power generation (fossil fuels)	X36	X36-01	A	C	AVEC Power Plant
Firehouses	X38	X38-01	A	C	

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Map Number</i>	<i>Comments</i>
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-01	A	C	Clinic
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-02	B	C	
Landfills (municipal; Class III)	D51	D51-03	B	C	
Tanks, heating oil, nonresidential (aboveground)	T14	T14-12	B	C	AVEC
Tanks, heating oil, nonresidential (aboveground)	T14	T14-13	B	C	Catherine Alexie Health Clinic
Tanks, heating oil, nonresidential (aboveground)	T14	T14-14	B	C	Ausdahl Mercantile
Tanks, heating oil, nonresidential (aboveground)	T14	T14-15	B	C	Kalskag Store
Tanks, heating oil, nonresidential (aboveground)	T14	T14-16	B	C	Church
Tanks, heating oil, nonresidential (aboveground)	T14	T14-17	B	C	City Multi-purpose Facility
Tanks, heating oil, nonresidential (aboveground)	T14	T14-18	B	C	City Public Safety Office
Tanks, heating oil, nonresidential (aboveground)	T14	T14-19	B	C	City Office
Tanks, heating oil, nonresidential (aboveground)	T14	T14-20	B	C	Police Station
Tanks, heating oil, nonresidential (aboveground)	T14	T14-21	B	C	Post Office
Tanks, heating oil, nonresidential (aboveground)	T14	T14-22	B	C	Joseph & Olinga Gregory Elementary School
Municipal or city parks (with green areas)	X04	X04-02	B	C	Community Gardens
Petroleum product bulk station/terminals	X11	X11-03	B	C	Ausdahl Mercantile
Petroleum product bulk station/terminals	X11	X11-04	B	C	City
Petroleum product bulk station/terminals	X11	X11-05	B	C	Ken Morgan
Petroleum product bulk station/terminals	X11	X11-06	B	C	School
Petroleum product bulk station/terminals	X11	X11-07	B	C	Village Corp. Store
Airports	X14	X14-01	B	C	
Highways and roads, dirt/gravel	X24	X24-02	B	C	Assume 1-20 roads in Zone B
Electric power generation (fossil fuels)	X36	X36-02	B	C	AVEC
Firehouses	X38	X38-02	B	C	City Public Safety Office
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-02	B	C	Catherine Alexie Health Clinic
Cemeteries	X01	X01-03	C	C	

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Map Number</i>	<i>Comments</i>
Highways and roads, dirt/gravel	X24	X24-03	C	C	Assume 1-20 roads in Zone C

Table 2

*Contaminant Source Inventory and Risk Ranking for
Lower Kalskag Water System
Sources of Bacteria and Viruses*

PWSID 270697.001

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-01	A	High	C	
Landfills (municipal; Class III)	D51	D51-01	A	High	C	
Landfills (municipal; Class III)	D51	D51-02	A	High	C	
Municipal or city parks (with green areas)	X04	X04-01	A	Medium	C	Recreational Platform
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assume 1-20 roads in Zone A
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-01	A	Medium	C	Clinic
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-02	B	High	C	
Landfills (municipal; Class III)	D51	D51-03	B	High	C	
Municipal or city parks (with green areas)	X04	X04-02	B	Medium	C	Community Gardens
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	Assume 1-20 roads in Zone B
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-02	B	Medium	C	Catherine Alexie Health Clinic
Highways and roads, dirt/gravel	X24	X24-03	C	Low	C	Assume 1-20 roads in Zone C

Table 3

*Contaminant Source Inventory and Risk Ranking for
Lower Kalskag Water System
Sources of Nitrates/Nitrites*

PWSID 270697.001

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-01	A	High	C	
Landfills (municipal; Class III)	D51	D51-01	A	Very High	C	
Landfills (municipal; Class III)	D51	D51-02	A	Very High	C	
Cemeteries	X01	X01-01	A	Medium	C	
Cemeteries	X01	X01-02	A	Medium	C	
Municipal or city parks (with green areas)	X04	X04-01	A	Medium	C	Recreational Platform
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assume 1-20 roads in Zone A
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-01	A	Low	C	Clinic
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-02	B	High	C	
Landfills (municipal; Class III)	D51	D51-03	B	Very High	C	
Municipal or city parks (with green areas)	X04	X04-02	B	Medium	C	Community Gardens
Airports	X14	X14-01	B	Low	C	
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	Assume 1-20 roads in Zone B
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-02	B	Low	C	Catherine Alexie Health Clinic
Cemeteries	X01	X01-03	C	Medium	C	
Highways and roads, dirt/gravel	X24	X24-03	C	Low	C	Assume 1-20 roads in Zone C

Table 4

*Contaminant Source Inventory and Risk Ranking for
Lower Kalskag Water System
Sources of Volatile Organic Chemicals*

PWSID 270697.001

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-01	A	Low	C	
Landfills (municipal; Class III)	D51	D51-01	A	High	C	
Landfills (municipal; Class III)	D51	D51-02	A	High	C	
Tanks, diesel (above ground)	T06	T06-01	A	Medium	C	Generator
Tanks, heating oil, nonresidential (aboveground)	T14	T14-01	A	Low	C	AVEC Power Plant
Tanks, heating oil, nonresidential (aboveground)	T14	T14-02	A	Low	C	Clinic
Tanks, heating oil, nonresidential (aboveground)	T14	T14-03	A	Low	C	Store
Tanks, heating oil, nonresidential (aboveground)	T14	T14-04	A	Low	C	Telephone
Tanks, heating oil, nonresidential (aboveground)	T14	T14-05	A	Low	C	Church
Tanks, heating oil, nonresidential (aboveground)	T14	T14-06	A	Low	C	Church
Tanks, heating oil, nonresidential (aboveground)	T14	T14-07	A	Low	C	Community Hall
Tanks, heating oil, nonresidential (aboveground)	T14	T14-08	A	Low	C	Fire Station
Tanks, heating oil, nonresidential (aboveground)	T14	T14-09	A	Low	C	Post Office
Tanks, heating oil, nonresidential (aboveground)	T14	T14-10	A	Low	C	George Morgan Jr./Sr. High School
Tanks, heating oil, nonresidential (aboveground)	T14	T14-11	A	Low	C	Zackar Levi Elementary School
Petroleum product bulk station/terminals	X11	X11-01	A	Very High	C	AVEC
Petroleum product bulk station/terminals	X11	X11-01	A	Low	C	AVEC
Petroleum product bulk station/terminals	X11	X11-02	A	Very High	C	School
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assume 1-20 roads in Zone A
Electric power generation (fossil fuels)	X36	X36-01	A	Medium	C	AVEC Power Plant
Firehouses	X38	X38-01	A	Low	C	
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-01	A	Low	C	Clinic

Table 4 (continued)

**Contaminant Source Inventory and Risk Ranking for
Lower Kalskag Water System
Sources of Volatile Organic Chemicals**

PWSID 270697.001

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Risk Ranking for Analysis	Map Number	Comments
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-02	B	Low	C	
Landfills (municipal; Class III)	D51	D51-03	B	High	C	
Tanks, heating oil, nonresidential (aboveground)	T14	T14-12	B	Low	C	AVEC
Tanks, heating oil, nonresidential (aboveground)	T14	T14-13	B	Low	C	Catherine Alexie Health Clinic
Tanks, heating oil, nonresidential (aboveground)	T14	T14-14	B	Low	C	Ausdahl Mercantile
Tanks, heating oil, nonresidential (aboveground)	T14	T14-15	B	Low	C	Kalskag Store
Tanks, heating oil, nonresidential (aboveground)	T14	T14-16	B	Low	C	Church
Tanks, heating oil, nonresidential (aboveground)	T14	T14-17	B	Low	C	City Multi-purpose Facility
Tanks, heating oil, nonresidential (aboveground)	T14	T14-18	B	Low	C	City Public Safety Office
Tanks, heating oil, nonresidential (aboveground)	T14	T14-19	B	Low	C	City Office
Tanks, heating oil, nonresidential (aboveground)	T14	T14-20	B	Low	C	Police Station
Tanks, heating oil, nonresidential (aboveground)	T14	T14-21	B	Low	C	Post Office
Tanks, heating oil, nonresidential (aboveground)	T14	T14-22	B	Low	C	Joseph & Olinga Gregory Elementary School
Petroleum product bulk station/terminals	X11	X11-03	B	Very High	C	Ausdahl Mercantile
Petroleum product bulk station/terminals	X11	X11-04	B	Very High	C	City
Petroleum product bulk station/terminals	X11	X11-05	B	Very High	C	Ken Morgan
Petroleum product bulk station/terminals	X11	X11-06	B	Very High	C	School
Petroleum product bulk station/terminals	X11	X11-07	B	Very High	C	Village Corp. Store
Airports	X14	X14-01	B	High	C	
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	Assume 1-20 roads in Zone B
Electric power generation (fossil fuels)	X36	X36-02	B	Medium	C	AVEC
Firehouses	X38	X38-02	B	Low	C	City Public Safety Office
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-02	B	Low	C	Catherine Alexie Health Clinic

Table 4 (continued)

*Contaminant Source Inventory and Risk Ranking for
Lower Kalskag Water System
Sources of Volatile Organic Chemicals*

PWSID 270697.001

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Highways and roads, dirt/gravel	X24	X24-03	C	Low	C	Assume 1-20 roads in Zone C

Table 5

*Contaminant Source Inventory and Risk Ranking for
Lower Kalskag Water System
Sources of Heavy Metals, Cyanide and Other Inorganic Chemicals*

PWSID 270697.001

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-01	A	Low	C	
Landfills (municipal; Class III)	D51	D51-01	A	High	C	
Landfills (municipal; Class III)	D51	D51-02	A	High	C	
Tanks, heating oil, nonresidential (aboveground)	T14	T14-01	A	Low	C	AVEC Power Plant
Tanks, heating oil, nonresidential (aboveground)	T14	T14-02	A	Low	C	Clinic
Tanks, heating oil, nonresidential (aboveground)	T14	T14-03	A	Low	C	Store
Tanks, heating oil, nonresidential (aboveground)	T14	T14-04	A	Low	C	Telephone
Tanks, heating oil, nonresidential (aboveground)	T14	T14-05	A	Low	C	Church
Tanks, heating oil, nonresidential (aboveground)	T14	T14-06	A	Low	C	Church
Tanks, heating oil, nonresidential (aboveground)	T14	T14-07	A	Low	C	Community Hall
Tanks, heating oil, nonresidential (aboveground)	T14	T14-08	A	Low	C	Fire Station
Tanks, heating oil, nonresidential (aboveground)	T14	T14-09	A	Low	C	Post Office
Tanks, heating oil, nonresidential (aboveground)	T14	T14-10	A	Low	C	George Morgan Jr./Sr. High School
Tanks, heating oil, nonresidential (aboveground)	T14	T14-11	A	Low	C	Zackar Levi Elementary School
Cemeteries	X01	X01-01	A	Low	C	
Cemeteries	X01	X01-02	A	Low	C	
Municipal or city parks (with green areas)	X04	X04-01	A	Low	C	Recreational Platform
Petroleum product bulk station/terminals	X11	X11-01	A	Low	C	AVEC
Petroleum product bulk station/terminals	X11	X11-01	A	Low	C	AVEC
Petroleum product bulk station/terminals	X11	X11-02	A	Low	C	School
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assume 1-20 roads in Zone A
Electric power generation (fossil fuels)	X36	X36-01	A	Medium	C	AVEC Power Plant
Firehouses	X38	X38-01	A	Low	C	

Table 5 (continued)

*Contaminant Source Inventory and Risk Ranking for
Lower Kalskag Water System
Sources of Heavy Metals, Cyanide and Other Inorganic Chemicals*

PWSID 270697.001

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-01	A	Low	C	Clinic
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-02	B	Low	C	
Landfills (municipal; Class III)	D51	D51-03	B	High	C	
Tanks, heating oil, nonresidential (aboveground)	T14	T14-12	B	Low	C	AVEC
Tanks, heating oil, nonresidential (aboveground)	T14	T14-13	B	Low	C	Catherine Alexie Health Clinic
Tanks, heating oil, nonresidential (aboveground)	T14	T14-14	B	Low	C	Ausdahl Mercantile
Tanks, heating oil, nonresidential (aboveground)	T14	T14-15	B	Low	C	Kalskag Store
Tanks, heating oil, nonresidential (aboveground)	T14	T14-16	B	Low	C	Church
Tanks, heating oil, nonresidential (aboveground)	T14	T14-17	B	Low	C	City Multi-purpose Facility
Tanks, heating oil, nonresidential (aboveground)	T14	T14-18	B	Low	C	City Public Safety Office
Tanks, heating oil, nonresidential (aboveground)	T14	T14-19	B	Low	C	City Office
Tanks, heating oil, nonresidential (aboveground)	T14	T14-20	B	Low	C	Police Station
Tanks, heating oil, nonresidential (aboveground)	T14	T14-21	B	Low	C	Post Office
Tanks, heating oil, nonresidential (aboveground)	T14	T14-22	B	Low	C	Joseph & Olinga Gregory Elementary School
Municipal or city parks (with green areas)	X04	X04-02	B	Low	C	Community Gardens
Petroleum product bulk station/terminals	X11	X11-03	B	Low	C	Ausdahl Mercantile
Petroleum product bulk station/terminals	X11	X11-04	B	Low	C	City
Petroleum product bulk station/terminals	X11	X11-05	B	Low	C	Ken Morgan
Petroleum product bulk station/terminals	X11	X11-06	B	Low	C	School
Petroleum product bulk station/terminals	X11	X11-07	B	Low	C	Village Corp. Store
Airports	X14	X14-01	B	Low	C	
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	Assume 1-20 roads in Zone B
Electric power generation (fossil fuels)	X36	X36-02	B	Medium	C	AVEC

Table 5 (continued)

*Contaminant Source Inventory and Risk Ranking for
Lower Kalskag Water System
Sources of Heavy Metals, Cyanide and Other Inorganic Chemicals*

PWSID 270697.001

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Firehouses	X38	X38-02	B	Low	C	City Public Safety Office
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-02	B	Low	C	Catherine Alexie Health Clinic
Cemeteries	X01	X01-03	C	Low	C	
Highways and roads, dirt/gravel	X24	X24-03	C	Low	C	Assume 1-20 roads in Zone C

Table 6

*Contaminant Source Inventory and Risk Ranking for
Lower Kalskag Water System
Sources of Synthetic Organic Chemicals*

PWSID 270697.001

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-01	A	Low	C	
Landfills (municipal; Class III)	D51	D51-01	A	Very High	C	
Landfills (municipal; Class III)	D51	D51-02	A	Very High	C	
Cemeteries	X01	X01-01	A	Medium	C	
Cemeteries	X01	X01-02	A	Medium	C	
Municipal or city parks (with green areas)	X04	X04-01	A	Low	C	Recreational Platform
Petroleum product bulk station/terminals	X11	X11-01	A	Low	C	AVEC
Petroleum product bulk station/terminals	X11	X11-02	A	Low	C	School
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-01	A	Low	C	Clinic
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-02	B	Low	C	
Landfills (municipal; Class III)	D51	D51-03	B	Very High	C	
Municipal or city parks (with green areas)	X04	X04-02	B	Low	C	Community Gardens
Petroleum product bulk station/terminals	X11	X11-03	B	Low	C	Ausdahl Mercantile
Petroleum product bulk station/terminals	X11	X11-04	B	Low	C	City
Petroleum product bulk station/terminals	X11	X11-05	B	Low	C	Ken Morgan
Petroleum product bulk station/terminals	X11	X11-06	B	Low	C	School
Petroleum product bulk station/terminals	X11	X11-07	B	Low	C	Village Corp. Store
Airports	X14	X14-01	B	Medium	C	
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-02	B	Low	C	Catherine Alexie Health Clinic
Cemeteries	X01	X01-03	C	Medium	C	

Table 7

*Contaminant Source Inventory and Risk Ranking for
Lower Kalskag Water System
Sources of Other Organic Chemicals*


PWSID 270697.001

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-01	A	Low	C	
Landfills (municipal; Class III)	D51	D51-01	A	Very High	C	
Landfills (municipal; Class III)	D51	D51-02	A	Very High	C	
Petroleum product bulk station/terminals	X11	X11-01	A	High	C	AVEC
Petroleum product bulk station/terminals	X11	X11-02	A	High	C	School
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assume 1-20 roads in Zone A
Electric power generation (fossil fuels)	X36	X36-01	A	High	C	AVEC Power Plant
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-02	B	Low	C	
Landfills (municipal; Class III)	D51	D51-03	B	Very High	C	
Petroleum product bulk station/terminals	X11	X11-03	B	High	C	Ausdahl Mercantile
Petroleum product bulk station/terminals	X11	X11-04	B	High	C	City
Petroleum product bulk station/terminals	X11	X11-05	B	High	C	Ken Morgan
Petroleum product bulk station/terminals	X11	X11-06	B	High	C	School
Petroleum product bulk station/terminals	X11	X11-07	B	High	C	Village Corp. Store
Airports	X14	X14-01	B	Medium	C	
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	Assume 1-20 roads in Zone B
Electric power generation (fossil fuels)	X36	X36-02	B	High	C	AVEC
Highways and roads, dirt/gravel	X24	X24-03	C	Low	C	Assume 1-20 roads in Zone C

APPENDIX C

Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)

Public Water Well System for PWS #270697.001 Lower Kalskag Water System
Showing Potential and Existing Sources of Contamination



LEGEND

⊕ Public Water System Well

Hydrography/Physical

▭ Parcels

~ Stream

▭ Lake or Pond

~ Contours

Transportation

— Primary Route (Class 1)

— Secondary Route (Class 2)

— Road (Class 3)

----- Road (Class 4)

----- Road (Class 5, Four-wheel drive)

Groundwater Protection Zones

▭ Zone A Protection Area— Several Months Travel Time

▭ Zone B Protection Area— 2 Years Travel Time

▭ Zone C Protection Area— 5 Years Travel Time

▭ Zone D Protection Area— 10 Years Travel Time

Existing or Potential Contaminant Sources

▭ Domestic wastewater treatment plant disposal pond/lagoon (D02)

● Landfill (municipal; Class III) (D51)

● Aboveground diesel tank (T06)

● Nonresidential aboveground heating oil tank (T14)

⊕ Cemetery (X01)

▭ Municipal or city park (X04)

▭ Petroleum product bulk station/terminal (X11)

⚡ Electric power generation (fossil fuels) (X36)

● Firehouse (X38)

▭ Medical/veterinary facilities (X40)

▭ Airport (X14)



Data Sources:
Contaminant Sources, Public Water System Wells, Contours
Alaska Department of Environmental Conservation (ADEC)

Critical Facilities, Federal Emergency Management Agency (FEMA)

All other data:
United States Geological Survey (USGS)

Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class A Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or validity of the data provided.



0 2.5 5 10 15 20 Miles

APPENDIX D

Vulnerability Analysis for Public Drinking Water Source (Charts 1-14)

Chart 1. Susceptibility of the wellhead - Lower Kalskag Water System (PWS No. 270697.001)




Chart 2. Susceptibility of the aquifer Lower Kalskag Water System (PWS No. 270697.001)




Chart 3. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Bacteria & Viruses




Chart 3. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Bacteria & Viruses




Chart 4. Vulnerability analysis for Lower Kalskag Water System (PWS No. 270697.001) - Bacteria & Viruses




Chart 5. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Nitrates and Nitrites




Chart 5. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Nitrates and Nitrites




Chart 5. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Nitrates and Nitrites




Chart 6. Vulnerability analysis for Lower Kalskag Water System (PWS No. 270697.001) - Nitrates and Nitrites




Chart 7. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Volatile Organic Chemicals




Chart 7. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Volatile Organic Chemicals




Chart 7. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Volatile Organic Chemicals




Chart 8. Vulnerability analysis for Lower Kalskag Water System (PWS No. 270697.001) - Volatile Organic Chemicals




Chart 9. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals




Chart 9. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals




Chart 9. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals




Chart 10. Vulnerability analysis for Lower Kalskag Water System (PWS No. 270697.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals




Chart 11. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Synthetic Organic Chemicals




Chart 11. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Synthetic Organic Chemicals




Chart 11. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Synthetic Organic Chemicals




Chart 12. Vulnerability analysis for Lower Kalskag Water System (PWS No. 270697.001) - Synthetic Organic Chemicals




Chart 13. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Other Organic Chemicals




Chart 13. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Other Organic Chemicals




Chart 13. Contaminant risks for Lower Kalskag Water System (PWS No. 270697.001) - Other Organic Chemicals




Chart 14. Vulnerability analysis for Lower Kalskag Water System (PWS No. 270697.001) - Other Organic Chemicals

