



Source Water Assessment

A Hydrogeologic Susceptibility and
Vulnerability Assessment for
Katmai Brooks Camp
Drinking Water System,
Katmai National Park, Alaska

PWSID # 260553.002
February 2004

DRINKING WATER PROTECTION PROGRAM REPORT 1159
Alaska Department of Environmental Conservation

Source Water Assessment for Katmai Brooks Camp Drinking Water System Katmai National Park, Alaska

PWSID # 260553.002

DRINKING WATER PROTECTION PROGRAM REPORT 1159

The Drinking Water Protection Program (DWPP) is producing Source Water Assessments in compliance with the Safe Drinking Water Act Amendments of 1996. Each assessment includes a delineation of the source water area, an inventory of potential and existing contaminant sources that may impact the water, a risk ranking for each of these contaminants, and an evaluation of the potential vulnerability of these drinking water sources.

These assessments are intended to provide public water systems owners/operators, communities, and local governments with the best available information that may be used to protect the quality of their drinking water. The assessments combine information obtained from various sources, including the U.S. Environmental Protection Agency, Alaska Department of Environmental Conservation (ADEC), public water system owners/operators, and other public information sources. The results of this assessment are subject to change if additional data becomes available. It is anticipated this assessment will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of public drinking water source. If you have any additional information that may affect the results of this assessment, please contact the Program Coordinator of DWPP, (907) 269-7521.

CONTENTS

EXECUTIVE SUMMARY	1	INVENTORY OF POTENTIAL AND EXISTING	
KATMAI BROOKS CAMP PUBLIC DRINKING		CONTAMINANT SOURCES	2
WATER SYSTEM	1	RANKING OF CONTAMINANT RISKS	2
KATMAI BROOKS CAMP DRINKING WATER		VULNERABILITY OF KATMAI BROOKS CAMP	
PROTECTION AREA	1	DRINKING WATER SYSTEM	2

TABLES

Table 1. Definition of Zones	2
Table 2. Susceptibility	3
Table 3. Contaminant Risks	3
Table 4. Overall Vulnerability	4

APPENDICES

APPENDIX	A. Katmai Brooks Camp Drinking Water Protection Area (Map A)
	B. Contaminant Source Inventory for Katmai Brooks Camp (Table 1)
	Contaminant Source Inventory and Risk Ranking for Katmai Brooks Camp –
	Bacteria and Viruses (Table 2)
	Contaminant Source Inventory and Risk Ranking for Katmai Brooks Camp –
	Nitrates/Nitrites (Table 3)
	Contaminant Source Inventory and Risk Ranking for Katmai Brooks Camp –
	Volatile Organic Chemicals (Table 4)
	C. Katmai Brooks Camp Drinking Water Protection Area and Potential
	and Existing Contaminant Sources (Map C)
	D. Vulnerability Analysis for Contaminant Source Inventory and Risk Ranking for
	Katmai Brooks Camp Public Drinking Water Source (Charts 1 – 8)

Source Water Assessment for Katmai Brooks Camp Source of Public Drinking Water, Katmai National Park, Alaska

Drinking Water Protection Program Alaska Department of Environmental Conservation

EXECUTIVE SUMMARY

Katmai Brooks Camp has two Public Water System (PWS) wells. The well (PWSID# 20553.002) has been used as a drinking water source since it was drilled in 1992. This source water assessment report is exclusively limited to PWSID #260553.002.

The well is a Class B (transient/non-community) water system located between Naknek Lake and Lake Brooks, along the Brooks River, in the Katmai National Park, Alaska. Available records indicate that the secondary storage for this water system is composed of a 36,000-gallon storage tank, and that the water is treated with calcium hypochlorite. This system operates seasonally and serves approximately 45 residents and 200 non-residents through twenty-seven service connections. The wellhead received a susceptibility rating of **Low** and the aquifer received a susceptibility rating of **Very High**. Combining these two ratings produce a **Medium** rating for the natural susceptibility of the well.

Identified potential and current sources of contaminants for the primary public drinking water source include: a laundromat/washeteria, a motor/motor vehicle repair shop, a large capacity septic system, an incinerator, a storage pile/waste impoundment/transfer area, an ADEC recognized leaking underground storage tank (LUST) site, seafood processing, aboveground fuel tanks, a water supply well, a floatplane dock/refueling area, an underground pipeline, and electric power generation. These identified potential and existing sources of contamination are considered as sources of bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals. Overall, the water well received a vulnerability rating of **High** for the bacteria and viruses, nitrates and nitrites, and volatile organic chemicals contaminant categories.

KATMAI BROOKS CAMP PUBLIC DRINKING WATER SYSTEM

The Katmai Brooks Camp well is a Class B (transient/non-community) public water system. The

camp is located between Naknek Lake and Lake Brooks, along the Brooks River, in Katmai National Park, Alaska (Sec. 6, T19S, R39W, Seward Meridian; see Map A of Appendix A). Katmai Brooks Camp is located approximately 70 miles west of King Salmon. Average annual precipitation in the Katmai Brooks Camp area is 26 inches, including approximately 70 inches of snowfall. Temperatures range from 30 to 66°F in summer and 4 to 30°F in winter (ADCED, 2003).

According to information supplied by ADEC for the Katmai Brooks Camp PWS, the depth of the primary water well is 62 feet below the ground surface and is screened in an unconfined aquifer based on available construction details. Unconfined aquifers are likely more susceptible to groundwater impacts resulting from the downward migration of surface contaminants. The well is not located within a floodplain.

Information acquired from a June 1999 sanitary survey for the public water system indicated that the land surface was sloped away from the well. Generally, land surfaces that slope away from the wellhead promote surface water drainage, which reduces potential of contaminant migration down the well casing annulus. The well is grouted according to ADEC regulations. Proper grouting provides added protection against contaminants traveling along the well casing annulus and into source waters.

The entire Bristol Bay area was formerly covered by glaciers and the topography is representative of a postglacial area. Generally, the soils consist of silty sand overlying relatively clean sand. The silty soils are slightly frost-susceptible. Isolated pockets of permafrost are scattered throughout the area (DOWL, 1982).

KATMAI BROOKS CAMP DRINKING WATER PROTECTION AREA

In order to evaluate whether a drinking water source is at risk, we must first evaluate what are the most likely pathways for surface contamination to reach the groundwater. These areas are determined by

looking at the characteristics of the soil, groundwater, aquifer, and well.

The most probable area for contamination to reach the drinking water well is the area that contributes water to the well, the groundwater recharge area. This area is designated as the drinking water protection area (DWPA). Because releases of contaminants within the protection area are most likely to impact the drinking water well, this area will serve as the focus for voluntary protection efforts. An analytical calculation was used to determine the size and shape of the DWPA for the Katmai Brooks Camp PWS. The input parameters describing the attributes of the aquifer in this calculation were adopted from Groundwater (Freeze and Cherry, 1979). Available geology and groundwater contours were also considered to take into account any uncertainties in groundwater flow and aquifer characteristics to arrive at a meaningful protection area.

The protection areas established for wells by the ADEC are usually separated into four zones, limited by the watershed. These zones correspond to differences in the time-of-travel (TOT) of the water moving through the aquifer to the well (Please refer to the Guidance Manual for Class B Public Water Systems for additional information).

The time of travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. The following is a summary of the four protection area zones for wells and the calculated time -of-travel for each:

Table 1. Definition of Zones

Zone	Definition
A	¼ the distance for the 2-yr. time -of-travel
B	Less than the 2 year time-of-travel
C	Less Than the 5 year time -of-travel
D	Less than the 10 year time -of-travel

The DWPA for the Katmai Brooks Camp PWS was determined using an analytical calculation and includes Zones A through D (See Map A of Appendix A).

INVENTORY OF POTENTIAL AND EXISTING CONTAMINANT SOURCES

The Drinking Water Protection Program has completed an inventory of potential and existing sources of contamination within the Katmai Brooks Camp DWPA. This inventory was completed

through a search of agency records and other publicly available information. Potential sources of contamination to the drinking water aquifer include a wide range of categories and types. Potential drinking water contaminants are found within agricultural, residential, commercial, and industrial areas, but can also occur within areas that have little or no development.

For the basis of all Class B public water system assessments, three categories of drinking water contaminants were inventoried. They include:

- Bacteria and viruses,
- Nitrates and/or nitrites,
- Volatile organic chemicals.

The sources are displayed on Map C of Appendix C and summarized in Table 1 of Appendix B.

RANKING OF CONTAMINANT RISKS

Once the potential and existing sources of contamination have been identified, they are assigned a ranking according to what type and level of risk they represent. Ranking of contaminant risks for a “potential” or “existing” source of contamination is a function of toxicity and volumes of specific contaminants associated with that source. Rankings include:

- Low,
- Medium,
- High, and
- Very High.

The time-of-travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. Bacteria and Viruses are only inventoried in Zones A and B because of their short life span. Only “Very High” and “High” rankings are inventoried within the outer Zone D due to the probability of contaminant dilution by the time the contaminants get to the well. Tables 2 through 4 in Appendix B contain the ranking of potential and existing sources of contamination with respect to bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals.

VULNERABILITY OF THE KATMAI BROOKS CAMP DRINKING WATER SYSTEM

Vulnerability of a drinking water source to contamination is a combination of two factors:

- Natural susceptibility, and
- Contaminant risks.

Appendix D contains eight charts, which together form the ‘Vulnerability Analysis’ for a source water assessment for a public drinking water source. Chart 1 analyzes the ‘Susceptibility of the Wellhead’ to contamination by looking at the construction of the well and its surrounding area. Chart 2 analyzes the ‘Susceptibility of the Aquifer’ to contamination by looking at the naturally occurring attributes of the water source and influences on the groundwater system that might lead to contamination. Chart 3 analyzes ‘Contaminant Risks’ for the drinking water source with respect to bacteria and viruses. The ‘Contaminant Risks’ portion of the analysis considers potential sources of contaminants as well as a review of contamination that has or may have occurred, but has not arrived or been detected at the well. Lastly, Chart 4 contains the ‘Vulnerability Analysis for Bacteria and Viruses’. Charts 5 through 8 contain the Contaminant Risks and Vulnerability Analyses for nitrates and nitrites and volatile organic chemicals, respectively.

A score for the Natural Susceptibility is reached by considering the properties of the well and the aquifer.

Susceptibility of the Wellhead (0 – 25 Points)
(Chart 1 of Appendix D)

+

Susceptibility of the Aquifer (0 – 25 Points)
(Chart 2 of Appendix D)

=

Natural Susceptibility (Susceptibility of the Well)
(0 – 50 Points)

A ranking is assigned for the Natural Susceptibility according to the point score:

Natural Susceptibility Ratings	
40 to 50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

The Katmai Brooks Camp’s water well is in an unconfined aquifer. Unconfined aquifers are more susceptible to potential groundwater quality impacts posed by the migration of surface water contaminants downward from the surface. Table 2 shows the susceptibility scores and ratings for this PWS.

Table 2. Susceptibility

	Score	Rating
Susceptibility of the Wellhead	0	Low
Susceptibility of the Aquifer	24	Very High
Natural Susceptibility	24	Medium

Contaminant risks to a drinking water source depend on the type, number or density, and distribution of contaminant sources. This score has been derived from an examination of existing and historical contamination that has been detected at the drinking water source through routine sampling. It also evaluates potential sources of contamination. Flow charts are used to assign a point score, and ratings are assigned in the same way as for the natural susceptibility:

Contaminant Risk Ratings	
40 to 50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

Table 3 summarizes the Contaminant Risks for each category of drinking water contaminants.

Table 3. Contaminant Risks

Category	Score	Rating
Bacteria and Viruses	40	Very High
Nitrates and/or Nitrites	40	Very High
Volatile Organic Chemicals	45	Very High

Finally, an overall vulnerability score is assigned for each water system by combining each of the contaminant risk scores with the natural susceptibility score:

Natural Susceptibility (0 – 50 points)

+

Contaminant Risks (0 – 50 points)

=

Vulnerability of the
Drinking Water Source to Contamination (0 – 100).

Again, rankings are assigned according to a point score:

Overall Vulnerability Ratings	
80 to 100 pts	Very High
60 to < 80 pts	High
40 to < 60 pts	Medium
< 40 pts	Low

Table 4 contains the overall vulnerability scores (0 – 100) and ratings for each of the three categories of drinking water contaminants. Note: scores are rounded off to the nearest five.

Table 4. Overall Vulnerability

Category	Score	Rating
Bacteria and Viruses	65	High
Nitrates and Nitrites	65	High
Volatile Organic Chemicals	70	High

Bacteria and Viruses

The contaminant risk for bacteria and viruses is **Very High**. The risk is primarily attributed to the presence of an injection well in Zone A (see Table 2 – Appendix B).

Positive bacteria counts have not been reported in recent (within five years) sampling events (See Chart 3 – Contaminant Risks for Bacteria and Viruses in Appendix D). Only a small amount of bacteria and viruses are required to endanger public health.

After combining the contaminant risk for bacteria and viruses with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **High**.

Nitrates and Nitrites

The contaminant risk for nitrates and nitrites is **Very High**. The risk to this source of public drinking water is primarily attributed to the presence of an injection well in Zone A (see Table 3 – Appendix B).

Nitrates are very mobile, moving at approximately the same rate as water. The sampling history for this well indicates that nitrates have not been detected in recent sampling events. Nitrate concentrations in uncontaminated groundwater are typically less than 2 mg/L; therefore, nitrate concentrations above 2 mg/L may be indicative of man-made sources (See Chart 5 - Contaminant Risks for Nitrates and/or Nitrites in Appendix D).

After combining the contaminant risk for nit rates and nitrites with the natural susceptibility of the well, the overall vulnerability of the well to nitrate and nitrite contamination is **High**.

Volatile Organic Chemicals

The contaminant risk for volatile organic chemicals is **Very High**. The risk is primarily attributed to the presence of an ADEC recognized LUST site in Zone A. Numerous other potential contaminant sources are also found within the protection area (see Table 4 – Appendix B).

No recent sampling data was available in ADEC records for Katmai Brooks Camp (See Chart 7 – Contaminant Risks for Volatile Organic Chemicals in Appendix D).

After combining the contaminant risk for volatile organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **High**.

Using the Source Water Assessment

This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of Katmai Brooks Camp to protect public health. It is anticipated that Source Water Assessments will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of the drinking water source.

REFERENCES

- Alaska Department of Community and Economic Development (ADCED), 2003 [WWW document]. URL: http://www.dced.state.ak.us/cbd/commdb/CF_COMDB.htm
- Alaska Department of Environmental Conservation, Contaminated Sites Database, 2003 [WWW database], URL http://www.state.ak.us/dec/dspar/csites/cs_search.htm
- Alaska Department of Environmental Conservation, Leaking Underground Storage Tank Database, 2003 [WWW database], URL http://www.dec.state.ak.us/spar/stp/ust/search/fac_search.asp
- DOWL Engineers (DOWL), 1982, Upper Bristol Bay Region Community Planning Profiles.
- Freeze, R. A., and Cherry, J.A. 1979, Groundwater, Prentice-Hall, Englewood Cliffs, New Jersey.
- United States Environmental Protection Agency (EPA), 2002 [WWW document]. URL <http://www.epa.gov/safewater/mcl.html>.

APPENDIX A

Drinking Water Protection Area Location Map (Map A)

Public Water Well System for PWS #260553.002 Katmai Brooks Camp



LEGEND

Public Water System Well

Hydrography/Physical

- Parcels
- Stream
- Lake or Pond
- Contours

Transportation

- Primary Route (Class 1)
- Secondary Route (Class 2)
- Road (Class 3)
- Road (Class 4)
- Road (Class 5, Four-wheel drive)

Groundwater Protection Zones

- Zone A Protection Area- Several Months Travel Time
- Zone B Protection Area- 2 Years Travel Time
- Zone C Protection Area- 5 Years Travel Time
- Zone D Protection Area- 10 Years Travel Time


Data Sources:
Contaminant Sources, Public Water System Wells, Contours
Alaska Department of Environmental Conservation (ADEC)

Critical Facilities, Federal Emergency Management Agency (FEMA)

All other data:
United States Geological Survey (USGS)

Drinking Water Protection Areas based on "Alaska Drinking
Water Protection Program - Guidance Manual for Class B
Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or
validity of the data provided.



Katmai Brooks Camp
PWS 260553.002

Appendix A Map A

APPENDIX B

Contaminant Source Inventory and Risk Rankings (Tables 1-4)

Table 1

**Contaminant Source Inventory for
Katmai Brooks Camp**

PWSID 260553.002

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Map Number	Comments
Laundromats without dry cleaning	C22	C22-01	A	C	Laundry Facility
Motor /motor vehicle repair shops	C31	C31-01	A	C	Maintenance Facility
Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method)	D10	D10-01	A	C	Large capacity septic system
Incinerators (municipal wastes)	D21	D21-01	A	C	
Storage piles, waste impoundment, and transfer areas	D62	D62-01	A	C	Solid Waste Storage
Seafood processing	N10	N10-01	A	C	Fish Cleaning Facility
Tanks, diesel (above ground)	T06	T06-01	A	C	16 diesel ASTs in Zone A
Open Leaking Underground Fuel Storage Tank (LUST) Sites	U07	U07-01	A	C	Katmai National Park - Brooks Camp, RecKey #1991250019703, Event ID 574, Facility ID 2013, diesel fuel overfills, spills, and leaks from USTs at site. Soil contamination found during removal of a 300-gallon diesel fuel tank.
Water supply wells	W09	W09-01	A	C	260553.001 (Zone A)
Floatplane dock/refueling area	X17	X17-01	A	C	Seaplane Base
Pipelines (other industrial)	X29	X29-01	A	C	Underground diesel pipeline
Electric power generation (fossil fuels)	X36	X36-01	A	C	Generator Building

Table 2

*Contaminant Source Inventory and Risk Ranking for
Katmai Brooks Camp
Sources of Bacteria and Viruses*

PWSID 260553.002

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Laundromats without dry cleaning	C22	C22-01	A	Low	C	Laundry Facility
Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method)	D10	D10-01	A	High	C	Large capacity septic system
Incinerators (municipal wastes)	D21	D21-01	A	Medium	C	
Seafood processing	N10	N10-01	A	Medium	C	Fish Cleaning Facility

Table 3

*Contaminant Source Inventory and Risk Ranking for
Katmai Brooks Camp
Sources of Nitrates/Nitrites*

PWSID 260553.002

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Laundromats without dry cleaning	C22	C22-01	A	Low	C	Laundry Facility
Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method)	D10	D10-01	A	High	C	Large capacity septic system
Incinerators (municipal wastes)	D21	D21-01	A	Low	C	
Seafood processing	N10	N10-01	A	Low	C	Fish Cleaning Facility

Table 4

*Contaminant Source Inventory and Risk Ranking for
Katmai Brooks Camp
Sources of Volatile Organic Chemicals*

PWSID 260553.002

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Laundromats without dry cleaning	C22	C22-01	A	Low	C	Laundry Facility
Motor /motor vehicle repair shops	C31	C31-01	A	Medium	C	Maintenance Facility
Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method)	D10	D10-01	A	Low	C	Large capacity septic system
Incinerators (municipal wastes)	D21	D21-01	A	Low	C	
Tanks, diesel (above ground)	T06	T06-01	A	Medium	C	16 diesel ASTs in Zone A
Open Leaking Underground Fuel Storage Tank (LUST) Sites	U07	U07-01	A	High	C	Katmai National Park - Brooks Camp, RecKey #1991250019703, Event I 574, Facility ID 2013, diesel fuel overfills, spills, and leaks from USTs at site. Soil contamination found during removal of a 300-gallon diesel fuel tank.
Floatplane dock/refueling area	X17	X17-01	A	Low	C	Seaplane Base
Electric power generation (fossil fuels)	X36	X36-01	A	Medium	C	Generator Building

APPENDIX C

Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)

Public Water Well System for PWS #260553.002 Katmai Brooks Camp
Showing Potential and Existing Sources of Contamination



LEGEND

Public Water System Well

Hydrography/Physical

- Parcels
- Stream
- Lake or Pond
- Contours

Transportation

- Primary Route (Class 1)
- Secondary Route (Class 2)
- Road (Class 3)
- Road (Class 4)
- Road (Class 5, Four-wheel drive)

Groundwater Protection Zones

- Zone A Protection Area- Several Months Travel Time
- Zone B Protection Area- 2 Years Travel Time
- Zone C Protection Area- 5 Years Travel Time
- Zone D Protection Area- 10 Years Travel Time

Existing or Potential Contaminant Sources

No reported existing or potential contaminant sources are within the Protection Zone.


Data Sources:
Contaminant Sources, Public Water System Wells, Contours
Alaska Department of Environmental Conservation (ADEC)

Critical Facilities, Federal Emergency Management Agency (FEMA)

All other data:
United States Geological Survey (USGS)

Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class B Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or validity of the data provided.



Katmai Brooks Camp
PWS 260553.002

Appendix C Map C



0 0.5 1 2 3 4 Miles

APPENDIX D

Vulnerability Analysis for Public Drinking Water Source (Charts 1-8)

Chart 1. Susceptibility of the wellhead - Katmai Brooks Camp (PWS No. 260553.002)




Chart 2. Susceptibility of the aquifer Katmai Brooks Camp (PWS No. 260553.002)




Chart 3. Contaminant risks for Katmai Brooks Camp (PWS No. 260553.002) - Bacteria & Viruses




Chart 3. Contaminant risks for Katmai Brooks Camp (PWS No. 260553.002) - Bacteria & Viruses




Chart 4. Vulnerability analysis for Katmai Brooks Camp (PWS No. 260553.002) - Bacteria & Viruses




Chart 5. Contaminant risks for Katmai Brooks Camp (PWS No. 260553.002) - Nitrates and Nitrites




Chart 5. Contaminant risks for Katmai Brooks Camp (PWS No. 260553.002) - Nitrates and Nitrites




Chart 5. Contaminant risks for Katmai Brooks Camp (PWS No. 260553.002) - Nitrates and Nitrites




Chart 6. Vulnerability analysis for Katmai Brooks Camp (PWS No. 260553.002) - Nitrates and Nitrites




Chart 7. Contaminant risks for Katmai Brooks Camp (PWS No. 260553.002) - Volatile Organic Chemicals




Chart 7. Contaminant risks for Katmai Brooks Camp (PWS No. 260553.002) - Volatile Organic Chemicals





Chart 7. Contaminant risks for Katmai Brooks Camp (PWS No. 260553.002) - Volatile Organic Chemicals




Chart 8. Vulnerability analysis for Katmai Brooks Camp (PWS No. 260553.002) - Volatile Organic Chemicals

