



---

# Source Water Assessment

A Hydrogeologic Susceptibility and  
Vulnerability Assessment for  
L&PSD Newhalen School  
Drinking Water System,  
Newhalen, Alaska

PWSID # 260634.001

April 2004

DRINKING WATER PROTECTION PROGRAM REPORT 1055  
Alaska Department of Environmental Conservation

# Source Water Assessment for L&PSD Newhalen School Drinking Water System Newhalen, Alaska

PWSID # 260634.001

DRINKING WATER PROTECTION PROGRAM REPORT 1055

The Drinking Water Protection Program (DWPP) is producing Source Water Assessments in compliance with the Safe Drinking Water Act Amendments of 1996. Each assessment includes a delineation of the source water area, an inventory of potential and existing contaminant sources that may impact the water, a risk ranking for each of these contaminants, and an evaluation of the potential vulnerability of these drinking water sources.

These assessments are intended to provide public water systems owners/operators, communities, and local governments with the best available information that may be used to protect the quality of their drinking water. The assessments combine information obtained from various sources, including the U.S. Environmental Protection Agency, Alaska Department of Environmental Conservation (ADEC), public water system owners/operators, and other public information sources. The results of this assessment are subject to change if additional data becomes available. It is anticipated this assessment will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of public drinking water source. If you have any additional information that may affect the results of this assessment, please contact the Program Coordinator of DWPP, (907) 269-7521.

## CONTENTS

EXECUTIVE SUMMARY .....	1	INVENTORY OF POTENTIAL AND EXISTING	
PUBLIC DRINKING WATER SYSTEM .....	1	CONTAMINANT SOURCES .....	2
DRINKING WATER PROTECTION AREA .....	2	RANKING OF CONTAMINANT RISKS .....	2
		VULNERABILITY OF DRINKING WATER	
		SYSTEM .....	3

## TABLES

Table 1. Definition of Zones .....	2
Table 2. Susceptibility .....	3
Table 3. Contaminant Risks .....	4
Table 4. Overall Vulnerability .....	4

## APPENDICES

APPENDIX	A. L&PSD Newhalen School Drinking Water Protection Area (Map A)
	B. Contaminant Source Inventory for L&PSD Newhalen School (Table 1)
	Contaminant Source Inventory and Risk Ranking for L&PSD Newhalen School – Bacteria and Viruses (Table 2)
	Contaminant Source Inventory and Risk Ranking for L&PSD Newhalen School – Nitrates/Nitrites (Table 3)
	Contaminant Source Inventory and Risk Ranking for L&PSD Newhalen School – Volatile Organic Chemicals (Table 4)
	Contaminant Source Inventory and Risk Ranking for L&PSD Newhalen School – Heavy Metals, Cyanide and Other Inorganic Chemicals (Table 5)
	Contaminant Source Inventory and Risk Ranking for L&PSD Newhalen School – Synthetic Organic Chemicals (Table 6)
	Contaminant Source Inventory and Risk Ranking for L&PSD Newhalen School – Other Organic Chemicals (Table 7)
	C. L&PSD Newhalen School Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)
	D. Vulnerability Analysis for Contaminant Source Inventory and Risk Ranking for L&PSD Newhalen School Public Drinking Water Source (Charts 1 – 14)

# Source Water Assessment for L&PSD Newhalen School Source of Public Drinking Water, Newhalen, Alaska

---

## Drinking Water Protection Program Alaska Department of Environmental Conservation

### EXECUTIVE SUMMARY

The L&PSD Newhalen School has one Public Water System (PWS) well. The date of well completion is unknown; however, it is assumed that the well (PWS No. 260634.001) has been used as a drinking water source since that time.

The well is a Class A (community and non-transient non-community) water system located at 1000 School Road in Newhalen, Alaska. Available records indicate that there is no secondary storage of drinking water, other than two pressure tanks, and that the untreated drinking water source is derived directly from the wellhead. This system operates seasonally and serves approximately 76 non-residents through one service connection. The wellhead received a susceptibility rating of **Low** and the aquifer received a susceptibility rating of **Medium**. Combining these two ratings produce a **Low** rating for the natural susceptibility of the well.

Identified potential and current sources of contaminants for the public drinking water source include: Laundromats, domestic wastewater collection systems, nonresidential pit toilets, residential septic systems, above ground fuel tanks, petroleum product bulk station/terminals, roads, electric power generation, and a medical/veterinary facility. These identified potential and existing sources of contamination are considered as sources of bacteria and viruses, nitrates and/or nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, synthetic organic chemicals, and other organic chemicals contaminant categories.

Overall, the water well received a vulnerability rating of **Medium** for the bacteria and viruses, nitrates and nitrites, heavy metals, cyanide and other inorganic chemicals, synthetic organic chemicals contaminant categories, and a vulnerability rating of **High** for volatile organic chemicals and other organic chemical contaminant categories.

### PUBLIC DRINKING WATER SYSTEM

The L&PSD Newhalen School well is a Class A (community/non-transient/non-community) public water system. The system is located at 1000 School Road in Newhalen, Alaska (Sec. 28, T05S, R33W, Seward Meridian; see Map A of Appendix A). Newhalen is located on the north shore of Iliamna Lake at the mouth of the Newhalen River. The community has a population of 156 (ADCED, 2003). Average annual precipitation in Newhalen is 26 inches, including approximately 64 inches of snowfall. Temperatures range from 42 to 62°F in summer and 6 to 30°F in winter. Temperatures can be as extreme as -47 to 91°F.

The community of Newhalen obtains most of their water supply from a community well. Several households are served by the piped sewage collection system and the remaining households have individual septic tanks (ADCED, 2003). Newhalen receives electrical power from the I-N-N Electric Cooperative. The I-N-N Electric Cooperative owns a diesel plant in Newhalen and 50 miles of distribution line to connect three communities (ADCED, 2003).

According to information supplied by ADEC for the L&PSD Newhalen School PWS, the depth of the primary water well is 220 feet below the ground surface. Well construction details are unknown; however, based on well details for surrounding wells, it is assumed the well is screened in a confined aquifer. The well is assumed to not be located within a floodplain.

Information acquired from a May 2003 sanitary survey for the public water system indicated that the land surface was sloped away from the well. Generally, land surfaces that slope away from the wellhead promote surface water drainage, which reduces the potential of contaminant migration down the well casing annulus. The sanitary survey indicates that the well is not grouted according to ADEC regulations. Proper grouting provides added protection against contaminants traveling along the well casing annulus and into source waters.

The Newhalen area is on a lake terrace north of Iliamna Lake, about 30 meters above the present lake surface. The mountains to the southeast contain numerous faults and there are more than 15 volcanic necks or plugs within 50 km of the area. Bedrock is overlain primarily by gravel and sand. Surficial deposits near Newhalen consist of lake terrace and beach ridge deposits. Permafrost in the area is generally found in isolated thin lenses at shallow depths and as relict permafrost at considerable depth (Hall, 1995).

## DRINKING WATER PROTECTION AREA

In order to evaluate whether a drinking water source is at risk, we must first evaluate what are the most likely pathways for surface contamination to reach the groundwater. These areas are determined by looking at the characteristics of the soil, groundwater, aquifer, and well.

The most probable area for contamination to reach the drinking water well is the area that contributes water to the well, the groundwater recharge area. This area is designated as the drinking water protection area (DWPA). Because releases of contaminants within the protection area are most likely to impact the drinking water well, this area will serve as the focus for voluntary protection efforts. An analytical calculation was used to determine the size and shape of the DWPA for the L&PSD Newhalen School PWS. The input parameters describing the attributes of the aquifer in this calculation were adopted from Groundwater (Freeze and Cherry, 1979). Available geology and groundwater contours were also considered to take into account any uncertainties in groundwater flow and aquifer characteristics to arrive at a meaningful protection area.

The protection areas established for wells by the ADEC are usually separated into four zones, limited by the watershed. These zones correspond to differences in the time-of-travel (TOT) of the water moving through the aquifer to the well (Please refer to the Guidance Manual for Class A Public Water Systems for additional information).

The time of travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. The following is a summary of the four protection area zones for wells and the calculated time -of-travel for each:

**Table 1. Definition of Zones**

Zone	Definition
A	¼ the distance for the 2-yr. time -of-travel
B	Less than the 2 year time-of-travel
C	Less Than the 5 year time -of-travel
D	Less than the 10 year time -of-travel

The DWPA for the L&PSD Newhalen School PWS was determined using an analytical calculation and includes Zones A, B, C, and D (See Map A of Appendix A).

## INVENTORY OF POTENTIAL AND EXISTING CONTAMINANT SOURCES

The Drinking Water Protection Program has completed an inventory of potential and existing sources of contamination within the L&PSD Newhalen School DWPA. This inventory was completed through a search of agency records and other publicly available information. Potential sources of contamination to the drinking water aquifer include a wide range of categories and types. Potential drinking water contaminants are found within agricultural, residential, commercial, and industrial areas, but can also occur within areas that have little or no development.

For the basis of all Class A public water system assessments, six categories of drinking water contaminants were inventoried. They include:

- Bacteria and viruses,
- Nitrates and/or nitrites,
- Volatile organic chemicals,
- Heavy metals, cyanide and other inorganic chemicals,
- Synthetic organic chemicals,
- Other organic chemicals.

The sources are displayed on Map C of Appendix C and summarized in Table 1 of Appendix B.

## RANKING OF CONTAMINANT RISKS

Once the potential and existing sources of contamination have been identified, they are assigned a ranking according to what type and level of risk they represent. Ranking of contaminant risks for a “potential” or “existing” source of contamination is a function of toxicity and volumes of specific contaminants associated with that source. Rankings include:

- Low,
- Medium,
- High, and
- Very High.

The time-of-travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. Bacteria and Viruses are only inventoried in Zones A and B because of their short life span. Only “Very High” and “High” rankings are inventoried within the outer Zone D due to the probability of contaminant dilution by the time the contaminants get to the well. Tables 2 through 4 in Appendix B contain the ranking of potential and existing sources of contamination with respect to bacteria and viruses, nitrates and/or nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, synthetic organic chemicals, and other organic chemicals.

## VULNERABILITY OF THE DRINKING WATER SYSTEM

Vulnerability of a drinking water source to contamination is a combination of two factors:

- Natural susceptibility, and
- Contaminant risks.

Appendix D contains fourteen charts, which together form the ‘Vulnerability Analysis’ for a source water assessment for a public drinking water source. Chart 1 analyzes the ‘Susceptibility of the Wellhead’ to contamination by looking at the construction of the well and its surrounding area. Chart 2 analyzes the ‘Susceptibility of the Aquifer’ to contamination by looking at the naturally occurring attributes of the water source and influences on the groundwater system that might lead to contamination. Chart 3 analyzes ‘Contaminant Risks’ for the drinking water source with respect to bacteria and viruses. The ‘Contaminant Risks’ portion of the analysis considers potential sources of contaminants as well as a review of contamination that has or may have occurred, but has not arrived or been detected at the well. Chart 4 contains the ‘Vulnerability Analysis for Bacteria and Viruses’. Charts 5 through 14 contain the Contaminant Risks and Vulnerability Analyses for nitrates and nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, synthetic organic chemicals, and other organic chemicals, respectively.

A score for the Natural Susceptibility is reached by considering the properties of the well and the aquifer.

Susceptibility of the Wellhead (0 – 25 Points)  
(Chart 1 of Appendix D)

+

Susceptibility of the Aquifer (0 – 25 Points)  
(Chart 2 of Appendix D)

=

Natural Susceptibility (Susceptibility of the Well)  
(0 – 50 Points)

A ranking is assigned for the Natural Susceptibility according to the point score:

Natural Susceptibility Ratings	
40 to 50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

The L&PSD Newhalen School’s water well is assumed to be in a confined aquifer. Confined aquifers are less susceptible to potential groundwater quality impacts posed by the migration of surface water contaminants downward from the surface. Table 2 shows the susceptibility scores and ratings for this PWS.

**Table 2. Susceptibility**

	Score	Rating
Susceptibility of the Wellhead	5	Low
Susceptibility of the Aquifer	14	Medium
Natural Susceptibility	19	Low

Contaminant risks to a drinking water source depend on the type, number or density, and distribution of contaminant sources. This score has been derived from an examination of existing and historical contamination that has been detected at the drinking water source through routine sampling. It also evaluates potential sources of contamination. Flow charts are used to assign a point score, and ratings are assigned in the same way as for the natural susceptibility:

Contaminant Risk Ratings	
40 to 50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

Table 3 summarizes the Contaminant Risks for each category of drinking water contaminants.

**Table 3. Contaminant Risks**

Category	Score	Rating
Bacteria and Viruses	25	Medium
Nitrates and/or Nitrites	33	High
Volatile Organic Chemicals	50	Very High
Heavy Metals, Cyanide and		
Other Inorganic Chemicals	25	Medium
Synthetic Organic Chemicals	25	Medium
Other Organic Chemicals	50	Very High

Finally, an overall vulnerability score is assigned for each water system by combining each of the contaminant risk scores with the natural susceptibility score:

$$\begin{array}{r}
 \text{Natural Susceptibility (0 – 50 points)} \\
 + \\
 \text{Contaminant Risks (0 – 50 points)} \\
 = \\
 \text{Vulnerability of the} \\
 \text{Drinking Water Source to Contamination (0 – 100).}
 \end{array}$$

Again, rankings are assigned according to a point score:

Overall Vulnerability Ratings	
80 to 100 pts	Very High
60 to < 80 pts	High
40 to < 60 pts	Medium
< 40 pts	Low

Table 4 contains the overall vulnerability scores (0 – 100) and ratings for each of the six categories of drinking water contaminants. Note: scores are rounded off to the nearest five.

**Table 4. Overall Vulnerability**

Category	Score	Rating
Bacteria and Viruses	45	Medium
Nitrates and Nitrites	50	Medium
Volatile Organic Chemicals	70	High
Heavy Metals, Cyanide and		
Other Inorganic Chemicals	45	Medium
Synthetic Organic Chemicals	45	Medium
Other Organic Chemicals	70	High

#### Bacteria and Viruses

The contaminant risk for bacteria and viruses is **Medium**. The risk is primarily attributed to the presence of domestic wastewater collection systems and medical/veterinary facilities in Zone A (see Table 2 – Appendix B).

No positive bacteria counts have been reported in recent (within five years) sampling events (See Chart 3 – Contaminant Risks for Bacteria and Viruses in Appendix D). Only a small amount of bacteria and viruses are required to endanger public health.

After combining the contaminant risk for bacteria and viruses with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

#### Nitrates and Nitrites

The contaminant risk for nitrates and nitrites is **High**. The risk to this source of public drinking water is primarily attributed to the presence of domestic wastewater collection systems in Zone A (see Table 3 – Appendix B).

Nitrates are very mobile, moving at approximately the same rate as water. The sampling history for this well indicates that nitrates have not been detected in recent sampling events. Nitrate concentrations in uncontaminated groundwater are typically less than 2 mg/L; therefore, nitrate concentrations above 2 mg/L may be indicative of man-made sources (See Chart 5 - Contaminant Risks for Nitrates and/or Nitrites in Appendix D).

Nitrate levels are often derived from the decomposition of organic matter in soils. Although the nitrate source is unknown, such occurrences may be attributed to septic systems or other sources. After combining the contaminant risk for nitrates and nitrites with the natural susceptibility of the well, the overall vulnerability of the well to nitrate and nitrite contamination is **Medium**.

### **Volatile Organic Chemicals**

The contaminant risk for volatile organic chemicals is **Very High**. The risk is primarily attributed to the presence of petroleum product bulk station/terminals located in Zone A. Numerous other potential contaminant sources are also found within the protection area (see Table 4 – Appendix B).

All recent sampling data for VOCs available in ADEC records for the L&PSD Newhalen School were below detection limits (See Chart 7 – Contaminant Risks for Volatile Organic Chemicals in Appendix D).

After combining the contaminant risk for volatile organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **High**.

### **Heavy Metals, Cyanide and Other Inorganic Chemicals**

The contaminant risk for heavy metals, cyanide and other inorganic chemicals is **Medium**. The risk is primarily attributed to the presence of electric power generation located in Zone A. Numerous other potential contaminant sources are also found within the protection area (see Table 5 – Appendix B).

Based on review of recent sampling records for this public water system, moderate levels of copper, lead, and arsenic have been detected, but have not exceeded their respective MCLs of 1.3 mg/L, 0.015 mg/L, and 0.05 mg/L (see Chart 9 – Contaminant Risks for Heavy Metals, Cyanide, and Other Inorganic Chemicals in Appendix D).

The reported concentrations of copper and lead in recent sampling events are not likely to be representative of source water conditions. These two analytes are likely attributed to either the water treatment process or water distribution network; therefore, no risk points were assigned based on the presence of these analytes.

After combining the contaminant risk for heavy metals, cyanide and other inorganic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

### **Synthetic Organic Chemicals**

The contaminant risk for synthetic organic chemicals is **Medium**. The risk is primarily attributed to the presence of domestic wastewater collection systems, septic systems, petroleum product bulk

station/terminals, and a medical/veterinary facility located in Zone A (see Table 6 – Appendix B).

No recent sampling data was available in ADEC records for the L&PSD Newhalen School (See Chart 11 – Contaminant Risks for Synthetic Organic Chemicals in Appendix D).

After combining the contaminant risk for synthetic organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

### **Other Organic Chemicals**

The contaminant risk for other organic chemicals is **Very High**. The risk is primarily attributed to the presence of petroleum product bulk station/terminals and electric power generation located in Zone A. Numerous other potential contaminant sources are also found within the protection area (see Table 7 – Appendix B).

No recent sampling data was available in ADEC records for the L&PSD Newhalen School (See Chart 13 – Contaminant Risks for Other Organic Chemicals in Appendix D).

After combining the contaminant risk for other organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **High**.

### **Using the Source Water Assessment**

This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of the L&PSD Newhalen School and the community of Newhalen to protect public health. It is anticipated that Source Water Assessments will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of the drinking water source.




## REFERENCES

- Alaska Department of Community and Economic Development (ADCED), 2003 [WWW document]. URL: [http://www.dced.state.ak.us/cbd/commdb/CF\\_COMDB.htm](http://www.dced.state.ak.us/cbd/commdb/CF_COMDB.htm)
- Alaska Department of Environmental Conservation, Contaminated Sites Database, 2003 [WWW database], URL [http://www.state.ak.us/dec/dspar/csites/cs\\_search.htm](http://www.state.ak.us/dec/dspar/csites/cs_search.htm)
- Alaska Department of Environmental Conservation, Leaking Underground Storage Tank Database, 2003 [WWW database], URL [http://www.dec.state.ak.us/spar/stp/ust/search/fac\\_search.asp](http://www.dec.state.ak.us/spar/stp/ust/search/fac_search.asp)
- Freeze, R. A., and Cherry, J.A. 1979, Groundwater, Prentice-Hall, Englewood Cliffs, New Jersey.
- Hall, James D. 1995, Overview of Environmental and Hydrogeologic Conditions at Ilimna, U.S. Geological Survey Open File Report 95-346.
- United States Environmental Protection Agency (EPA), 2002 [WWW document]. URL <http://www.epa.gov/safewater/mcl.html>.

## **APPENDIX A**

### **Drinking Water Protection Area Location Map (Map A)**

Public Water Well System for PWS #260634.001 L&PSD Newhalen School



LEGEND

Public Water System Well

Groundwater Protection Zones

- Zone A Protection Area- Several Months Travel Time
- Zone B Protection Area- 2 Years Travel Time
- Zone C Protection Area- 5 Years Travel Time
- Zone D Protection Area- 10 Years Travel Time or Watershed Boundary

Hydrography/Physical


- Parcels
- Stream
- Lake or Pond
- Contours

Data Sources:  
Contaminant Sources, Public Water System Wells, Contours  
Alaska Department of Environmental Conservation (ADEC)

All other data:  
United States Geological Survey (USGS)

Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class A Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or validity of the data provided.



0 0.2 0.4 0.8 1.2 1.6 Miles

## **APPENDIX B**

### **Contaminant Source Inventory and Risk Ranking (Tables 1-7)**

**Table 1****Contaminant Source Inventory for  
L&PSD Newhalen School****PWSID 260634.001**

<b>Contaminant Source Type</b>	<b>Contaminant Source ID</b>	<b>CS ID tag</b>	<b>Zone</b>	<b>Map Number</b>	<b>Comments</b>
Laundromats without dry cleaning	C22	C22-01	A	C	Washeteria
Domestic wastewater collection systems (sewer lines or lift stations)	D01	D01-01	A	C	L&PSD Newhalen School
Pit toilets (vaulted) nonresidential (one or more)	D17	D17-01	A	C	near Newhalen School
Septic systems (serves one single-family home)	R02	R02-01	A	C	Assume 10 or less residential septic systems in Zone A
Tanks, heating oil, residential (above ground)	R08	R08-01	A	C	Assume 10 or less residential heating oil tanks in Zone A
Tanks, heating oil, nonresidential (aboveground)	T14	T14-01	A	C	INN Electric Cooperative
Tanks, heating oil, nonresidential (aboveground)	T14	T14-02	A	C	Newhalen Health Clinic
Petroleum product bulk station/terminals	X11	X11-01	A	C	City Fuel Storage
Petroleum product bulk station/terminals	X11	X11-02	A	C	Clinic Fuel Storage
Petroleum product bulk station/terminals	X11	X11-03	A	C	L&PSD Fuel Storage
Highways and roads, dirt/gravel	X24	X24-01	A	C	Assume 1-20 roads in Zone A
Electric power generation (fossil fuels)	X36	X36-01	A	C	INN Electric Cooperative
Electric power generation (fossil fuels)	X36	X36-02	A	C	L&PSD Newhalen School
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-01	A	C	Newhalen Health Clinic
Highways and roads, dirt/gravel	X24	X24-02	B	C	Assume 1-20 roads in Zone B

**Table 2**

*Contaminant Source Inventory and Risk Ranking for  
L&PSD Newhalen School  
Sources of Bacteria and Viruses*

**PWSID 260634.001**

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Laundromats without dry cleaning	C22	C22-01	A	Low	C	Washeteria
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-01	A	Medium	C	L&PSD Newhalen School
Pit toilets (vaulted) nonresidential (one or more)	D17	D17-01	A	Low	C	near Newhalen School
Septic systems (serves one single-family home)	R02	R02-01	A	Low	C	Assume 10 or less residential septic systems in Zone A
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assume 1-20 roads in Zone A
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-01	A	Medium	C	Newhalen Health Clinic
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	Assume 1-20 roads in Zone B

**Table 3**

*Contaminant Source Inventory and Risk Ranking for  
L&PSD Newhalen School  
Sources of Nitrates/Nitrites*

**PWSID 260634.001**

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Laundromats without dry cleaning	C22	C22-01	A	Low	C	Washeteria
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-01	A	Medium	C	L&PSD Newhalen School
Pit toilets (vaulted) nonresidential (one or more)	D17	D17-01	A	Low	C	near Newhalen School
Septic systems (serves one single-family home)	R02	R02-01	A	Low	C	Assume 10 or less residential septic systems in Zone A
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assume 1-20 roads in Zone A
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-01	A	Low	C	Newhalen Health Clinic
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	Assume 1-20 roads in Zone B



Table 4

*Contaminant Source Inventory and Risk Ranking for  
L&PSD Newhalen School  
Sources of Volatile Organic Chemicals*

PWSID 260634.001

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Laundromats without dry cleaning	C22	C22-01	A	Low	C	Washeteria
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-01	A	Low	C	L&PSD Newhalen School
Septic systems (serves one single-family home)	R02	R02-01	A	Low	C	Assume 10 or less residential septic systems in Zone A
Tanks, heating oil, residential (above ground)	R08	R08-01	A	Medium	C	Assume 10 or less residential heating oil tanks in Zone A
Tanks, heating oil, nonresidential (aboveground)	T14	T14-01	A	Low	C	INN Electric Cooperative
Tanks, heating oil, nonresidential (aboveground)	T14	T14-02	A	Low	C	Newhalen Health Clinic
Petroleum product bulk station/terminals	X11	X11-01	A	Very High	C	City Fuel Storage
Petroleum product bulk station/terminals	X11	X11-02	A	Very High	C	Clinic Fuel Storage
Petroleum product bulk station/terminals	X11	X11-03	A	Very High	C	L&PSD Fuel Storage
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assume 1-20 roads in Zone A
Electric power generation (fossil fuels)	X36	X36-01	A	Medium	C	INN Electric Cooperative
Electric power generation (fossil fuels)	X36	X36-02	A	Medium	C	L&PSD Newhalen School
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-01	A	Low	C	Newhalen Health Clinic
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	Assume 1-20 roads in Zone B



**Table 5**

*Contaminant Source Inventory and Risk Ranking for  
L&PSD Newhalen School  
Sources of Heavy Metals, Cyanide and Other Inorganic Chemicals*

**PWSID 260634.001**

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-01	A	Low	C	L&PSD Newhalen School
Septic systems (serves one single-family home)	R02	R02-01	A	Low	C	Assume 10 or less residential septic systems in Zone A
Tanks, heating oil, nonresidential (aboveground)	T14	T14-01	A	Low	C	INN Electric Cooperative
Tanks, heating oil, nonresidential (aboveground)	T14	T14-02	A	Low	C	Newhalen Health Clinic
Petroleum product bulk station/terminals	X11	X11-01	A	Low	C	City Fuel Storage
Petroleum product bulk station/terminals	X11	X11-02	A	Low	C	Clinic Fuel Storage
Petroleum product bulk station/terminals	X11	X11-03	A	Low	C	L&PSD Fuel Storage
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assume 1-20 roads in Zone A
Electric power generation (fossil fuels)	X36	X36-01	A	Medium	C	INN Electric Cooperative
Electric power generation (fossil fuels)	X36	X36-02	A	Medium	C	L&PSD Newhalen School
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-01	A	Low	C	Newhalen Health Clinic
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	Assume 1-20 roads in Zone B

**Table 6**

*Contaminant Source Inventory and Risk Ranking for  
L&PSD Newhalen School  
Sources of Synthetic Organic Chemicals*

**PWSID 260634.001**

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-01	A	Low	C	L&PSD Newhalen School
Septic systems (serves one single-family home)	R02	R02-01	A	Low	C	Assume 10 or less residential septic systems in Zone A
Petroleum product bulk station/terminals	X11	X11-01	A	Low	C	City Fuel Storage
Petroleum product bulk station/terminals	X11	X11-02	A	Low	C	Clinic Fuel Storage
Petroleum product bulk station/terminals	X11	X11-03	A	Low	C	L&PSD Fuel Storage
Medical/veterinary facilities (doctor or dentist offices, hospitals, nursing homes)	X40	X40-01	A	Low	C	Newhalen Health Clinic

**Table 7**

*Contaminant Source Inventory and Risk Ranking for  
L&PSD Newhalen School  
Sources of Other Organic Chemicals*


**PWSID 260634.001**

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-01	A	Low	C	L&PSD Newhalen School
Septic systems (serves one single-family home)	R02	R02-01	A	Low	C	Assume 10 or less residential septic systems in Zone A
Petroleum product bulk station/terminals	X11	X11-01	A	High	C	City Fuel Storage
Petroleum product bulk station/terminals	X11	X11-02	A	High	C	Clinic Fuel Storage
Petroleum product bulk station/terminals	X11	X11-03	A	High	C	L&PSD Fuel Storage
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assume 1-20 roads in Zone A
Electric power generation (fossil fuels)	X36	X36-01	A	High	C	INN Electric Cooperative
Electric power generation (fossil fuels)	X36	X36-02	A	High	C	L&PSD Newhalen School
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	Assume 1-20 roads in Zone B

## **APPENDIX C**

### **Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)**

Public Water Well System for PWS #260634.001 L&PSD Newhalen School  
Showing Potential and Existing Sources of Contamination



**LEGEND**

Public Water System Well

**Groundwater Protection Zones**

- Zone A Protection Area– Several Months Travel Time
- Zone B Protection Area– 2 Years Travel Time
- Zone C Protection Area– 5 Years Travel Time
- Zone D Protection Area– 10 Years Travel Time or Watershed Boundary

**Hydrography/Physical**

- Parcels
- Stream
- Lake or Pond
- Contours

**Transportation**

- Primary Route (Class 1)
- Secondary Route (Class 2)
- Road (Class 3)
- Road (Class 4)
- Road (Class 5, Four-wheel drive)
- Road Ferry Crossing

**Existing or Potential Contaminant Sources**


- Laundromats without dry cleaning service (C22)
- Tanks, heating oil, non-residential (aboveground) (T14)
- Petroleum product bulk station/terminal (X11)
- Electric power generation (fossil fuels) (X36)
- Medical/veterinary facilities (X40)

**Data Sources:**  
Contaminant Sources, Public Water System Wells, Contours  
Alaska Department of Environmental Conservation (ADEC)

**All other data:**  
United States Geological Survey (USGS)

**Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class A Public Water Systems" published by ADEC**

**URS Corporation does not guarantee the accuracy or validity of the data provided.**






## **APPENDIX D**

### **Vulnerability Analysis for Public Drinking Water Source (Charts 1-14)**

**Chart 1. Susceptibility of the wellhead - L&PSD Newhalen School (PWS No.260634.001)**



**Chart 2. Susceptibility of the aquifer L&PSD Newhalen School (PWS No.260634.001)**









Chart 3. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Bacteria & Viruses



**Chart 3. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Bacteria & Viruses**



**Chart 4. Vulnerability analysis for L&PSD Newhalen School (PWS No.260634.001) - Bacteria & Viruses**



**Chart 5. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Nitrates and Nitrites**





Chart 5. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Nitrates and Nitrites



**Chart 5. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Nitrates and Nitrites**






Chart 6. Vulnerability analysis for L&PSD Newhalen School (PWS No.260634.001) - Nitrates and Nitrites





**Chart 7. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Volatile Organic Chemicals**







**Chart 7. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Volatile Organic Chemicals**




**Chart 7. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Volatile Organic Chemicals**



**Chart 8. Vulnerability analysis for L&PSD Newhalen School (PWS No.260634.001) - Volatile Organic Chemicals**



**Chart 9. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals**



**Chart 9. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals**





Chart 9. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals





Chart 10. Vulnerability analysis for L&PSD Newhalen School (PWS No.260634.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals



**Chart 11. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Synthetic Organic Chemicals**






Chart 11. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Synthetic Organic Chemicals





Chart 11. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Synthetic Organic Chemicals



**Chart 12. Vulnerability analysis for L&PSD Newhalen School (PWS No.260634.001) - Synthetic Organic Chemicals**




Chart 13. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Other Organic Chemicals




Chart 13. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Other Organic Chemicals





Chart 13. Contaminant risks for L&PSD Newhalen School (PWS No.260634.001) - Other Organic Chemicals



**Chart 14. Vulnerability analysis for L&PSD Newhalen School (PWS No.260634.001) - Other Organic Chemicals**

