ALASKA POWER AUTHORITY Anchorage - Fairbanks Transmission Intertie

Economic Feasibility Study Report

April 1979



T

Ţ

Ĩ

INTERNATIONAL ENGINEERING COMPANY, INC.



ROBERT W. RETHERFORD ASSOCIATES

DRAFT



ALASKA POWER AUTHORITY

.

Anchorage - Fairbanks Transmission Intertie **Economic Feasibility Study Report**

DRAFT

April 1979



INTERNATIONAL ENGINEERING COMPANY, INC.



<u>Chapter</u>			Page
	ABBRE	EVIATIONS	ix
1	INTRO	DUCTION	1-1
2	SUMMA	ARY AND CONCLUSIONS	
	2.1	Study Summary	2-1
	2.2	Conclusions	2-4
3	LOAD	FORECASTS FOR RAILBELT AREA	
	3.1	Energy and Demand Forecasts Range	3-1
	3.2	Demand Forecasts for Generation Planning	3-8
	3-3	References	3-10
4	SELEC	CTION OF INTERTIE ROUTE	
	4.1	Review of Earlier Studies	4-1
	4.2	Survey of Alternative Corridors	4-1
	4.3	Preferred Route for Transmission Intertie	4-1
	4.4	Field Investigations	4-4
	4.5	Preliminary Environmental Assessment	4-5
	4.6	References	4-11
5	TRANS	SMISSION LINE DESIGN	
	5.1	Basic Design Requirements	5-1
·	5.2	Selection of Tower Type Used in the Study	5-1
	5.3	Design Loading Assumptions	5-2
· ·	5.4	Tower Weight Estimation	5-2
	•		

.

1

Chapter			Page
5	TRANSM	IISSION LINE DESIGN (Continued)	:
	5.5	Conductor Selection	5-3
	5.6	Power Transfer Capabilities	5-4
	5.7	HVDC Transmission System	5-4
	5,8	References	5-5
6	SYSTEM	EXPANSION PLANS	
	6.1	Generation Planning Criteria	6-1
	6.2	Multi-Area Reliability Study	6-4
	6.3	System Expansion Plans	6-10
· .	6.4	References	6-12
7	FACILI	TY COST ESTIMATES	
	7.1	Transmission Line Costs	7-1
	7.2	Substation Costs	7-4
	7.3	Control and Communications System Costs	7-5
	7.4	Transmission Intertie Facility Costs	7-5
	7.5	Cost of Transmission Losses	7-5
	7.6	Basic for Generating Plant Facility Costs	7-6
	7.7	Generating Plant Fuel Costs	7-7
	7.8	MEA Underlying System Costs	7-8
	7.9	Construction Power Costs for the Upper Susitna Project	7-8
	7.10	References	7-9
8	ECONON	AIC FEASIBILITY ANALYSIS	
	8.1	Methodology	8-1
	8.2	Sensitivity Analysis	8-2
	8.3	Economic Analysis	8-3
	8.4	References	8-8

 \Box

1

1

i '

<u>Chapter</u>		· · ·	Page
9	FINAN	ICIAL PLANNING CONCEPTS	
	9.1	Sources of Funds	9-1
	9.2	Proportional Allocations Between Sources	9-4
	9.3	Allocated Financial Responsibility for Participants	9-6
10	INSTI	TUTIONAL CONSIDERATIONS	
	10.1	Present Institutions and Railbelt Utilities	10-1
	10.2	Alaskan Interconnected Utilities	10-3
	10.3	References	10-5
•			

APPENDIXES

<u>Appendix</u>	·	
A	NOTES ON FUTURE USE OF ENERGY IN ALASKA	A-1
В	TRANSMISSION LINE COSTS ANALYSIS PROGRAM (TLCAP)	
	B.1 General Description	B-1
	B.2 Computer Program Applications for Optimum Transmission Line Costs	B-2
	B.3 TLCAP Sample Outputs	
Ċ	MULTI-AREA RELIABILITY PROGRAM (MAREL)	C-1

iii

 \square

. А.,

1

<u>Appendix</u>		Page
D	DATA AND COST ESTIMATES FOR TRANSMISSION INTERTIE AND GENERATING PLANTS	D-1
	D.1 Data and Cost Estimates for Trans- mission Intertie	D-1
	D.2 Data and Cost Estimates for Gene- rating Plants	D-13
	D.3 Data and Cost Estimates for Supply of Construction Power to Upper Susitna Projec/Sites	D - 24
· · ·	D.4 Alternative Generating Plant Fuel Costs	D-38
E	TRANSMISSION LINE ECONOMIC ANALYSIS PROGRAM	E-1
F	TRANSMISSION LINE FINANCIAL ANALYSIS	F - 1

iv

TABLES

, 1 .

e • • •

Table		Page
3-1	Anchorage-Cook Inlet Area Utility Forecasts	3-11
3-2	Fairbanks-Tanana Valley Area Utility Forecasts	3-12
3-3	Combined Utility Forecasts for Railbelt Area	3-13
3-4	Load Forecasts for Upper Susitna Proj- ect by Alaska Power Administration	3-14
3-5	Load Forecasts for Railbelt Area to Determine Statistical Average Forecasts	3-16
3-6	Load Demand Bandwidth for Railbelt Area Forecasts	3-17
5-1	Conductor Size Selection Criteria	5-6
6-1	Existing Generation Sources, Anchorage- Cook Inlet Area	6-14
6-2	Existing Generation Sources, Fairbanks- Tanana Valley Area	6-15
6-3	Load Model Data, Anchorage Area	6-16
6-4	Load Model Data, Fairbanks Area	6-17
6-5	Loss of Load Probability Index for Study Cases IA and ID	6-18
6-6	Loss of Load Probability Index for Study Case IB	6-19
6-7	Loss of Load Probability Index for Study Case IIA	6-20
7-1	Cost Summary for Intertie Facilities	7-10
7-2	Present Worth of Intertie Losses, 1984-1997 Study Period	7-11

۷

TABLES (Continued)

•

ſ

 $\left[\right]$

ł

ĺ

1

}

Table		Page
7-3	Cost Summary for Generating Facilities	7-12
7-4	Summary of Altenative Generating Plant Fuel Costs	7-13
7-5	Alternative Costs for Construction Power Supply to Watana and Devil Canyon Hydropower Sites during Con- struction of Upper Susitna Project	7-14
8-1 to 8-6	Differential Discounted Value of Base Year (1979) Costs	8-9 to 8-14
9-1	Allocation of Total Project Costs Between Participants to Alaskan Intertie Agreement	9-10
A-1	MEA Statistical Summary - Past, Present and Future	A-4

<u>FIGURES</u>

Figure		
3-1	Comparative Net Energy Generation Fore- cast for Combined Utilities and Indus- trial Load - Railbelt Area	3-18
3-2	Projected Range of Net Energy Genera- tion Forecast for Combined Utilities and Industrial Load, Railbelt Area	3-19
3-3	Projected Range of Net Energy Gener- ation Forecasts for Combined Util- ities and Industrial Load, Anchorage- Cook Inlet Area and Fairbanks-Tanana Valley Area	3-20
3-4	Comparative Annual Peak Demand Fore- casts for Combined Utilities and Industrial Load, Railbelt Area	3-21

FIGURES (Continued)

1

.

ĺ

2

ψ.

Figure		Page
3-5	Projected Range of Annual Peak Demand Forecasts for Combined Utilities and Industrial Load, Railbelt Area	3-22
3-6	Annual Peak Demand Forecasts for Com- bined Utilities and Industrial Load, Anchorage-Cook Inlet Area and Fairbanks- Tanana Valley Area	3-23
3-7	Probability Model Representation of Load Forecast Uncertainty	3-24
3-8	Normal Distribution Probability Plot to Establish Bandwidth for Railbelt Area Forecasts	3-25
3-9	Load Demand Forecasts, Bandwidth: Most Probable +2 Standard Deviations, Anchor- age-Cook Inlet and Fairbanks-Tanana Valley Area Loads	3-26
3-10	Load Demand Forecast Bandwidth: Most Probable +2 Standard Deviations, Rail- belt Area Loads	3-27
4-1	Nenana-Fairbanks-Tanana Transmission System	4-12
4-2	Anchorage-Matanuska-Susitna-Glenallen- Valdez Transmssion System	4-13
4-3	Cook Inlet-Kenai Peninsula Transmission System	4-14
5-1	230 kV Tangent Tower	5-7
5-2	345 kV Tangent Tower	5-8
6-1	Non-Coincident 1975 Peak Demands, Anchorage and Fairbanks Areas	6-21
6-2	Independent System Expansion Plans, Anchorage and Fairbanks Areas	6-22

FIGURES (Continued)

ĺ

Figure		Page
6-3	Interconnected System Expansion Plan, Anchorage-Fairbanks Area without Susitna Project	6-23
6-4	Interconnected System Expansion Plan, Anchorage-Fairbanks Area with Firm Power Transfer	6-24
6-5	Interconnected System Expansion Plan, Anchorage-Fairbanks Area with Upper Susitna Project	6-25
6-6	Case I - Alternative A and B	6-26
(6-7)	Case I - Alternative C	6-27
6-8	Case I - Alternative D	6-28
6-9	Case II	6-29
7-1	Construction Plan for Upper Susitna Project	7-15
B-1	Transmission Line Cost Analysis Program Methodology	B-4
D-1 and D-2	Nomogram Calculates Economy of Scale in Power Plants	D-45 and D-46
D-3	Estimates of Future National Gas Prices	D-47
D-4	Estimates of Future Coal Prices	D-48

ABREVIATIONS

.

	ac	alternating current	LNG	liquid nitrate gas	
	ACF	annual cost of fuel	LOLP	loss of load probability	
	ACSR	aluminium conductor, steel reinforced	MAREL	Multi-Area Reliability, a computer	
	AIA	Alaskan Intertie Agreement	моти	Million Duttick thousel unit	
	AML&P	Anchorage Municipal Light and Power Company	MEA	Matanuska Electrical Association, Inc.	
	APA	Alaska Power Authority	MVA	megavolt-amperes	
	A.R.R.	Alaska Railroad	MW	megawatts	
	AVF	average value factor	NESC	National Electrical Safety Committee	
	bpd	barrels per day	NOx	nitrous oxide	
	BTU	British thermal units	0&M	operations and maintenance	
•	CEA	Chugach Electric Association, Inc.	ORV	off-road vehicle	
	CFC \	Cooperative Finance Corporation	PCF	Plant capacity factor	
	dc	direct current	P.I.	point of intersection	
	DOE	U.S. Department of Energy	PRS	power requirements studies	
	EEI	Edison Electric Institute	PTI	Power Technology, Inc.	
	FFB	Federal Finance Bank	REA	Rural Electrification Administration	
	FGD	flue gas desulphurization	RI	radio interference	
	FOH	forced outage hours	RWRA	Robert W. Retherford Associates, Inc.	
	FMUS	Fairbanks Municipal Utility System	S/C	single circuit	
	ft	feet	SCGT	simple cycle combustion turbine	
	gal	gallon	SIL	surge impedance loading	
	GVEA	Golden Valley Electric Association, Inc.	TLCAP	Transmission Line Cost Analysis	
	GWh	gigawatt-hours (million kilowatt-hours)		Program, a computer program developed by IECO	
	HEA	Homer Electric Association, Inc.	TLEAP	Transmission Line Economic Analysis	
	HVDC	high voltage, direct current		by IECO	
	IAEAT	Interior Alaska Energy Analysis Team	TLFAP	Transmission Line Financial Analysis	
	IEC0	International Engineering Company, Inc.		by IECO	
	IEEE	Institute of Electrical and	tpy	tons per year	
	I SER	Institute for Social and	TVI	television interference	
		Economic Research	USA	United States of America	
	kcmi 1	thousand circular mils	USGS	United States Geological Survey	
	kV	kilovolts	VAR	volt-amperes reactive	
	kVa	kilovolt-amperes			
	kW	kilowatts			

kWh kilowatt-hours

1

 $\left(\right)$

1

ix

CHAPTER 1 INTRODUCTION This report presents a determination of the economic feasibility for a transmission line interconnection between the utility systems of the Anchorage and Fairbanks areas. It includes an objective evaluation of the specific conditions under which the intertie is economically feasible. An interconnection between the two previously independent power systems will reduce total installed generation reserve capacity, provide means for the interchange of energy, reduce spinning reserve requirements, and provide the means for optimum economic dispatch of generating plants on the interconnected system basis. The later integration of the Upper Susitna Hydropower Project into the interconnected Anchorage-Fairbanks power system would serve to increase the benefits already available from early operation of the intertie. The work described in this report was performed under the authority of the 26 October 1978 contract between the Alaska Power Authority and the joint-venture of International Engineering Company, Inc. (IECO) and Robert W. Retherford Associates (RWRA).

Alternative system expansion plans were developed and analyzed during this study for each of the following areas:

- Independent Anchorage area
- Independent Fairbanks area
- Interconnected Anchorage-Fairbanks area
 (generation reserve sharing option)
- Interconnected Anchorage-Fairbanks area
 (generation reserve sharing and firm power transfer option)
- Interconnected Anchorage-Fairbanks area (with inclusion of the Upper Susitna Hydropower Project)

This study confirms the economic feasibility of the Anchorage-Fairbanks transmission line interconnection as well as the possibility of an early implementation date for the project, prior to longer-range development of the Upper Susitna Hydropower Project. This study also establishes additional intertie benefits from the supply of construction power to the sites of the Upper Susitna Hydropower Project. It also evaluated potential benefits from firm power supply to Matanuska Electric Association's system at the intermediate Palmer substation of the intertie. Preliminary financial and management plans for the implementation of the project were developed and are presented in the last two chapters of this report.

An Intertie Advisory Committee, composed of managers of Railbelt area utilities with the chairmanship of the Executive Director of the Alaska Power Authority, was formed. During the performance of this study three Intertie Advisory Committee meetings were held (4 December 1978, 8 January 1979, and 14 February 1979) to review factors related to the intertie and to discuss preliminary findings of this study. The following Railbelt utilities were represented on the Intertie Advisory Committee:

- Anchorage Municipal Light & Power (AML&P).
- Copper Valley Electric Association (CVEA)
- Chugach Electric Association (CEA)
- Fairbanks Municipal Utility System (FMUS)
- Golden Valley Electric Association (GVEA)
- Homer Electric Association (HEA)
- Matanuska Electric Association (MEA)

The Consultants wish to acknowledge the valuable information, comments, and support received from the managers and engineers of the Railbelt utilities, and the Alaska Power Administration during the performance of this economic feasibility study.

CHAPTER 2 SUMMARY AND CONCLUSIONS The purpose of this economic feasibility study is to determine the conditions under which a transmission interconnection between the utility systems of Anchorage and Fairbanks would be economically feasible. Following are the important aspects of work performed and the conclusions of this study.

2.1 STUDY SUMMARY

A. Load Forecasts for Railbelt Area

Load forecast is the basis for system expansion planning. The most recent load forecasts for the utility service areas in the Railbelt area were examined to establish the basis for projection of future trends.

The sum of the most recent forecasts made by the individual utilities in the area has been selected as the upper growth limit to the forecast ranges for the Railbelt area. The median forecast prepared by the Alaska Power Administration, as a revision to the Susitna Project Market Study, was selected as the lower limit. The statistical average of these two forecasts was calculated and used in this study as the "most probable" forecast.

The long-range "most probable" load demand projections in MW for the load areas are:

	Anchorage	Fairbanks	Combined System
1980	573	153	749
1985	977	231	1194
1990	1581	338	1869
1995	2402	477	2842
2000	3446	663	4054

B. Selection of Intertie Route

Alternative transmission corridors considered in previous studies were analyzed as to accessibility, cost of right-of-way, transmission line design, and environmental and aesthetic considerations. The preferred corridor described in the Susitna Report, along the Parks Highway from Anchorage to Fairbanks, was selected for the intertie route. It was selected because of its favorable length, accessibility, and environmental considerations. This corridor was further defined by preparing preliminary layouts. Field trips to important sites along this 323-mile line route were made to confirm the suitability at this corridor for the intertie.

C. Transmission Line Design

To provide a basis for intertie cost estimation, conceptual designs for 230-kV and 345-kV transmission lines and substations were made. The transmission Line Cost Analysis Program (TLCAP), a computer program developed by IECO, was used to select optimum designs. The results favored relatively long spans (1300 feet) and high-strength conductors. Tubular steel, guyed towers and pile-type foundations were selected for both the 230-kV and 345-kV lines as being well suited for Alaska conditions.

D. System Expansion Plans

To determine the intertie's economic feasibility, alternative system expansion plans were prepared with and without the Anchorage-Fairbanks intertie. All system expansion plans were prepared to meet the "most probable" load demand projections. To assume a nearly constant level of generation reliability (LOLP Index) for all system expansion plans, a multi-area reliability (MAREL) computer study was performed. Annual load models for both areas were developed. The load models indicate that there is very little diversity between the loads in the Anchorage and Fairbanks areas.

The 1984-1997 study period was selected to best suit system requirements. The earliest year when the intertie can be operational is 1984. Based on optimistic assumptions, the last generating unit of Upper Susitna Hydropower Project will be on-line in January 1997.

E. Facility Cost Estimates

Cost estimates were developed for alternative system facilities to allow for economic comparisons. All costs were adjusted to January 1979 levels. Transmission line costs were calculated by using the TLCAP program. The same computer program calculated the line losses.

To provide a means for optimum economic dispatch of generating units on the interconnected system basis, costs for control and communication systems were included in the intertie cost estimates. Cost estimates for new generating plant facilities (gas-turbine units and coal-fired steam plants) were based on cost information in the <u>Power Supply Study - 1978</u> report to GVEA, prepared by Stanley Consultants. Appropriate Alaskan construction cost location adjustment factors were applied to derive specific site cost estimates.

Construction power costs for the Susitna Project were calculated. The results indicate a clear advantage for utilizing the intertie as a source of construction power.

F. Economic Feasibility Analysis

The economic feasibility analysis of the intertie was performed using the discounted present-worth method. Facility costs for those new generating plants not affected by the introduction of the intertie were excluded from the analysis. The Transmission Line Economic Analysis Program (TLEAP), a computer program, was used to analyze the sensitivity of different escalation and discount rates on the capital costs of various alternatives. In this analysis, a 7% long-term average annual escalation rate and a 10% discount rate was used for principal investigations.

G. Financial and Institutional Planning

A preliminary financial plan for implementation of the transmission intertie on a progressive basis was developed. The probable composition of institutions and participating utilities for ownership, management, and operating responsibilities is reviewed in this report, and present arrangements and possible future requirements are discussed.

2.2 CONCLUSIONS

The study shows that:

- The 230-kV single circuit intertie, having a 130-MW line loading capability (Case IA) is economically feasible in 1984, based only on benefits due to reduction of generation reserve plant capacity. The present-worth of net benefits is \$7,968,000.
- A considerable increase in benefits is obtained if the 230-kV single circuit intertie (double circuit after 1992), in addition to line capacity allocated to reserve sharing, includes firm

power transfer capability (Case IB). The increase in presentworth net benefits is from \$7,968,000 to \$14,589,000, or an increase of 83 percent. Additional benefits due to supply of construction power to the Upper Susitna Project sites is \$2,943,000, or an added increase of 18 percent.

- The 345-kV single circuit intertie (Case IC) is not economically feasible in 1984 if based only on the benefits due to reduction of installed generation reserve capacity. Further studies, not made, will probably indicate that a 345-kV intertie would be feasible if firm power transfer benefits are included.
- The 230-kV intertie with intermediate substations at Palmer and Healy (Case ID) has the following net benefits:

Study Case	<u>PW of Net Benefits</u>
IA (Reserve sharing only)	\$ 7,968,000
ID (Plus supply to MEA)	\$10,065,000
ID (Plus constr. power supply)	\$13,113,000

- The fully integrated interconnected system operation generates additional benefits which are not quantified in this study. These benefits could be due to:
 - Decrease in spinning reserve requirements by reducing the on-line plant capacity for the combined system.
 - Coordination of maintenance scheduling which would improve combined system security and provide cost savings.

 Economies from optimum dispatch of generating units on the interconnected system basis.

- Expansion plans for the interconnected system with the Upper Susitna Project were developed to determine the effect of this project on the interconnected system expansion plans, the displacement of thermal generating units, and intertie transmission requirements with Susitna Project.
- If an early 230-kV transmission intertie is constructed in 1984, due considerations should be given for constructing the Anchorage-Susitna portion of this intertie for 345-kV and operating it temporarily at 230-kV.
- Generation and interconnection planning is a complex and continuous process. This Intertie Feasibility Study is only a part of the overall power system expansion plans for the Railbelt area. Further intertie studies will be required to establish definitive characteristics for this transmission intertie. These studies should be closely coordinated with the future expansion plans of all utilities in the Railbelt area.

CHAPTER 3

CHAPTER 3

LOAD FORECASTS FOR RAILBELT AREA

3.1 ENERGY AND DEMAND FORECAST RANGE

The basis for establishing a range of future load projections for the Anchorage - Cook Inlet and Fairbanks - Tanana Valley areas, together with a combined forecast for an interconnected system service area in the Railbelt, was obtained from an examination of previous forecasts $\frac{1}{}$ compared in the Battelle Report of March 1978 (Ref. 1). These were examined in relation to a combination of the most recent utility forecasts prepared for the REA and an August 1978 revision of previous forecasts for the Upper Susitna Project, issued by the Alaska Power Administration in December 1975 (Ref. 2).

A. Range of Energy Consumption Resulting from Battelle Study

The Battelle study provides a compendium of previous forecasts and an analysis of assumptions intrinsic to their projections. It attempts to eliminate low probability scenarios and select a range of utility and industrial loads for the intertied Railbelt system. The following summary of annual energy consumption, excluding national defense and noninterconnected users, represents the definitive results of the Battelle study:

	<u>1974</u>		<u>1980 </u>		1990		2000
Annual Consumption-GWh							
Upper Range Limit	1,600		3,400		10,800		22,500
Interval Growth Rate		13.4%		15.3%		10.2%	
Lower Range Limit	1,600		2,600		8,500		16,000
Interval Growth Rate		8.4%		9.6%		4.0%	

 $\frac{1}{2}$ See Section 3.3 for references used in this chapter.

Battelle selected this energy consumption range after carefully evaluating the methodology used in several previous forecasts and relevant assumptions pertaining to economic factors. Two load studies were deemed most appropriate to future load projections for the Railbelt. They are, in order of preference, the Upper Susitna Project Power Market Study by the Alaska Power Administration, and the report <u>Electric Power in Alaska, 1976-1995</u> (Ref 3.) by the Institute for Social and Economic Research (ISER) of the University of Alaska.

1. <u>Forecasts for Anchorage - Cook Inlet Area</u> - From the several load forecasts corresponding to various growth scenarios of the ISER study, Battelle selected Forecasts 2 and 4 as most appropriate for the Anchorage and Cook Inlet area. These forecasts assume limited petroleum development, which was considered to be the most likely prospect. The assumptions underlying the scenario for limited petroleum development are:

- Petroleum Production will be 2 million bpd in 1980, and 3.6 million in 1990.
- A natural gas pipeline will be constructed from Prudhoe Bay through Canada.
- An LNG plant for natural gas from the Gulf of Alaska will be constructed.

The assumptions regarding electrical energy consumption are:

	Sector	Case 2	Case 4
0	Residential	Moderate Electrification	No Growth
0	Commercial/Industrial	Growth as Usual	Minimum Electrification

The ISER study did not include new industrial consumption in forecasts, other than expansion of existing loads served by utilities. However, it did relate utility forecasts to economic scenarios, in which future energy consumption was quantitatively projected according to specified assumptions of petroleum development, population, aggregate income, saturation levels, and average usage per customer.

In 1975 the Alaska Power Administration prepared forecasts for the potential power market of the Upper Susitna Project. The forecasts contained projections of industrial load for existing and possible future installations. Battelle modified these projections to include the following assumptions:

- In addition to gradual expansion of existing refinery capacity, a new 150,000-bpd refinery will be built by 1983.
- An aluminum smelter with a capacity of 300,000 tpy will be constructed, to be on-line by 1985.
- A nuclear fuel enrichment plant, included in previous load projections, was deleted from future industrial load.
- Industrial development in the interior region was assumed to be excluded from the load area of an intertied Railbelt system.

A summary of industrial facilities included in the Battelle forecast for the Anchorage and Cook Inlet area is as follows:

Existing Facilities

Chemical Plant LNG Plant Refinery Timber Mills

New Facilities	
Aluminum Smelter	
LNG Plant	
Refinery	
Timber Mills	

Coal Gasification Plant

Mining and Mineral Processing Plants New City

2. Forecasts for Fairbanks - Tanana Valley Area - A similar evaluation by Battelle defined the most probable forecasts for the Fairbanks and Tanana Valley area. It assumed that industrial development in the interior region will consist largely of self-supplied mining operations in remote areas. Thus, load growth will be attributable only to utility customers in the service areas of the Fairbanks Municipal Utilities System (FMUS) and the Golden Valley Electric Association, Inc. (GVEA).

In the judgment of Battelle, the most likely consumption range for the Fairbanks area is bounded by the mid-range projections of the Upper Susitna Market Study, with mid-range forecasts prepared by the Interior Alaska Energy Analysis Team (IAEAT) (Ref. 4) as the upper bound and the ISER Case 4 as the lower bound.

3. <u>Combined Forecasts for the Railbelt</u> - The Battelle energy and demand forecast range for the combined utility and industrial load of the Railbelt, encompassing the Anchorage - Cook Inlet and Fairbanks -Tanana Valley areas, is shown graphically on Figures 3-1 and 3-4, respectively. These are intended to serve as background comparisons with combined utility forecasts and the revised projections of the Alaska Power Administration for the potential market of the Upper Susitna Project.

B. Forecasts by Utilities and the Alaska Power Administration

The most recent Power Requirements Studies (PRS) of the REA utilities (Ref. 5) in the Anchorage and Fairbanks areas were obtained, together with the most probable load forecasts, as projected for the Anchorage Municipal Light and Power Company (AML&P) and the Fairbanks Municipal Utilities System (FMUS).

Tables 3-1 and 3-2 provide tabulations of utility forecasts and extrapolated projections to the horizon year 2000, for the Anchorage - Cook Inlet area and the Fairbanks - Tanana Valley area, respectively. The Valdez - Copper Valley area is not included in the forecasts for the

Railbelt, as these load areas are assumed not to be interconnected with the intertied Railbelt system until after the completion of the Upper Susitna Project. As the PRS provided load projections for a base year and at two 5-year intervals, interpolations were made on the basis of assumed compound growth between reported values. On the further assumption that growth rates will decline progressively to the horizon year, extrapolations were made of net energy generation with growth rates declining from reported values at 5-year intervals to 2000. These growth rates were applied on the assumption that there will be no abrupt transition to low growth rates. Rather, growth will diminish in gradual steps as markets are saturated and the effects of conservation and price elasticity reflect in future energy consumption levels. Reported load factors were interpolated for intermediate years and the trend extrapolated to the horizon year to obtain projections of annual peak demand.

The utility forecasts were combined for the Anchorage - Cook Inlet area, the Fairbanks - Tanana Valley area, and the total Railbelt. Table 3-3 provides tabulations of net energy generation, load factor, and annual peak diversified demand. It is obtained by the application of coincidence factors to the sum of individual utility peak demands. These load forecasts are shown on Figures 3-1 through 3-6, in comparison with load projections prepared in August 1978 by the Alaska Power Administration for the Upper Susitna Project, as revisions to previous power market forecasts evaluated as part of the Battelle study.

A summary of the Alaska Power Administration load projections is given in Table 3-4. These projections include only utility and industrial load forecasts, on the assumption that national defense installations will not be supplied as part of the interconnected system load. Since the Battelle forecasts also excluded load forecasts for national defense installations, direct comparisons can be made.

The range of load forecasts was based on a \pm 20% spread from projected mid-range growth to 1980. The industrial load projected by Battelle was included in the forecast range on a selective basis. The differential between the "high" and "extra high" forecasts is an additional 280 MW of load, representing an aluminum smelter. The "low" forecast excludes the load projected for the New City.

C. Comparison and Selection of Forecast Range

The forecasts of net energy generation for the Railbelt are shown on Figure 3-1. Curve 1 represents the combination of the most recent forecasts for municipal and REA utilities, as presented in Tables 3-1, 3-2, and 3-3. The forecast aligns closely up to 1990 with the upper bound of the Battelle forecast range. Beyond 1990 the divergence arises from the different assumptions made in regard to growth rates in the 1990-2000 period. The upper bound of the Battelle range exhibits an abrupt change of growth rate, from 15.3% to 10.2%, applied to total energy in the Railbelt, while the combined utilities forecast exhibits a more gradual transition to lower growth rates. Although many economic factors will contribute to lower overall growth rates in energy consumption, a reasonable approach to establishing an upper limit has been taken, in that individual utility forecasts were assumed to decline without abrupt change. This assumption is based on the fairly constant percentage expenditure from disposable income for energy needs, as determined by the study of future consumption patterns in Alaskan service areas (Ref. 6), the results of which are given in an extract from the RWRA report (Ref. 7) presented in Appendix A.

Accordingly, the combined utilities forecast has been selected as the maximum growth limit to the possible range of total energy forecasts for the Railbelt. The median forecast prepared by the Alaska Power Administration, as a revision to the Susitna Project Market Study, has been selected as the lower limit to the forecast range for the Railbelt. This recently prepared forecast exhibits lower growth than the 1975 forecast

for the Susitna Project, and represents a prudent choice for a conservative growth scenario.

Figures 3-2 and 3-3 show the relationship between the combined utilities forecast and the range of forecasts prepared by the Alaska Power Administration. The effect of the aluminum smelter load can be observed as the differential between curves 2C and 3C on Figure 3-2, and curves 2A and 3A on Figure 3-3. The median forecast also excludes the aluminum smelter load but provides for a reasonable realization of the industrial potential in the Anchorage area. In setting the lower limit of the forecast range in the context of the considerable industrial growth potential of this area of Alaska, it is thought that the selected forecast range will provide a good test of the economic feasibility of establishing an interconnection in the Railbelt.

A similar comparison of forecast demand can be made by reference to Figures 3-4, 3-5, and 3-6. The combined utilities demand forecast is below the upper bound of the Battelle range until after 1985 and aligns in fairly close proximity until 1990. Beyond 1990 divergence occurs based upon the assumption discussed previously in relation to energy growth. The median demand forecast for the Susitna Project, prepared by the Alaska Power Administration, exhibits a growth characteristic that roughly parallels the lower bound of the Battelle range between 1985 and 2000. As the low growth limit to the range of demand beyond 1981 selected for the interconnection study, it represents a moderately conservative view of overall growth potential.

Prior to 1981, the short-range combined utilities demand forecast is acceptable as a single demand projection, approximately at Battelle midrange. The demand forecasts for the Susitna Project may be observed in relation to the combined utilities demand forecasts of Figures 3-5 and 3-6. The selected range of demand forecasts represents a moderate to high expectation of a continued growth of the Railbelt economy through the end of the century, this being accentuated by the interconnection of utility systems in the area.

3.2 DEMAND FORECASTS FOR GENERATION PLANNING

Once the range of load forecasts has been established, it remains to select definitive demand forecasts for generation expansion planning. Between the upper limit of the combined utilities forecast and the lower limit, represented by the median forecast by the Alaska Power Administration, lies a range of possible load growth projections, each having a certain probability of realization through time.

A. Probabilistic Representation of Load Forecast Uncertainty

On the assumption that the load forecast range obeys a normal probability distribution, the uncertainty associated with the forecast can be represented by the normal continuous probability curve of Figure 3-7A. The most probable forecast for this symmetrical representation is then the statistical average between the maximum and minimum limits, these being assumed to occur at the \pm 3 standard deviation extremities of the normal bell curve. The statistical average forecasts for the Railbelt area are given in Table 3-5, these being now designated the most probable forecasts for the selected range. The statistical average or mean value is the same as the most probable value, due to the basic assumption regarding the symmetrical shape of the normal probability distribution curve.

The variability of the forecast is defined in terms of standard deviations from a most probable value, with the bandwidth of the forecast taken to be within \pm 2 standard deviations from the most probable value. The degree of uncertainty associated with the forecast range determines this bandwidth, which may be expressed as a 95% chance that the actual peak demand will lie between the limits of the selected bandwidth.

As the uncertainty associated with a load forecast increases with time, the demand value defined by the bandwidth will increase with time; however, the probability of being within the bandwidth will remain constant. The demand values corresponding to this bandwidth are given in Table 3-6, these being obtained from the range of forecasts, as follows:

The demand forecast limits define the range of possible values, such that the actual future peak demand will have a 99.8% probability of being within the upper and lower forecast limits, these being the \pm 3 standard deviation bounds. This can be represented by the probability plot of Figure 3-8, the implicit assumption being that the forecast limits correspond approximately to the 99.9 percentile on the three standard deviation limit. Connection of the extreme percentile limits enables the determination of the bandwidth between the \pm 2 standard deviations limits, as a 2/3 ratio between the high and most probable forecasts at any point in time. The bandwidth is given in terms of demand values, as tabulated in Table 3-6. The probability multipliers given in this table, for the load levels corresponding to the forecast bandwidth, are obtained from the discrete representation of forecast uncertainty shown on Figure 3-7B, this being the usual representation of forecast uncertainty for generation planning studies.

B. <u>Selection of Demand Forecasts for the Railbelt Area</u>

The most probable load demands and forecast bandwidths for the Anchorage -Cook Inlet, Fairbanks - Tanana Valley and the Railbelt areas are shown on Figures 3-9 and 3-10. As the <u>+</u> 2 standard load level limits cross over for the Anchorage - Cook Inlet area, the divergent bandwidth is shown on Figure 3-9 as beginning in 1982. The most probable forecast then appears as a single demand line from 1979 through 1981, which considering the short time projection is quite reasonable. The demand trend is well established for the Anchorage area and can be expected to persist in the immediate short-range time frame.

The long-range load projections are given in Table 3-6, with a total diversified demand for the combined areas of the Railbelt rising to approximately 4000 MW in the year 2000.

3.3 **REFERENCES**

- Battelle Pacific Northwest Laboratories, <u>Alaska Electric Power</u>: <u>An Analysis of Future Requirements and Supply Alternatives for the</u> <u>Railbelt Region</u>, March 1978.
- U.S. Department of the Interior, Alaska Power Administration, <u>Upper</u> <u>Susitna River Hydroelectric Studies</u>, <u>Report on Markets for Project</u> <u>Power</u>, December 1975.
- 3. University of Alaska, Institute for Social and Economic Research, Electric Power in Alaska, 1976-1995, August 1976.
- Interior Alaska Energy Analysis Team, <u>Report of Findings and Recommenda</u>-<u>tions</u>, June 1977.
- 5. Rural Electrification Association, <u>Power Requirements Study for:</u> <u>Alaska 2 - Matanuska Electric Association, Inc., May 1978</u> <u>Alaska 5 - Kenai-Homer Electric Association, Inc., May 1978</u> <u>Alaska 6 - Golden Valley Electric Association, Inc., May 1976</u> <u>Alaska 8 - Chugach Electric Association, Inc., May 1976</u> <u>Alaska 18 - Copper Valley Electric Association, Inc., May 1977</u>.
- E. O. Bracken, Alaska Department of Commerce and Economic Development, <u>Power Demand Estimators, Summary and Assumptions for the Alaska</u> Situation, June 1977.
- 7. Robert W. Retherford Associates, <u>System Planning Report, Matanuska</u> <u>Electric Association, Inc.</u>, January 1979.
- U.S. Department of the Interior, Alaska Power Administration, <u>A Report of the Technical Advisory Committee on Economic Analysis</u> and Load Projections, 1974.
- 9. Federal Power Commission, The 1976 Alaska Power Survey, Vol. 1, 1976.
- U.S. Army Corps of Engineers, <u>South-central Railbelt Area, Alaska</u>, <u>Upper Susitna River Basin Interim Feasibility Report</u>, December 1975.
- 11. U.S. Department of the Interior, Alaska Power Administration, <u>Bradley</u> <u>Lake Project Power Market Analyses</u>, August 1977.
- 12. Tippett and Gee, Consulting Engineers, <u>1976 Power System Study</u>, <u>Chugach Electric Association</u>, Inc., Anchorage, Alaska, March 1976.

TABLE 3-1

ANCHORAGE - COOK INLET AREA UTILITY FORECASTS AND EXTRAPOLATED PROJECTIONS

	Anchorage Municipal Alaska 2 - Matanuska			Alaska 5 - Kenai				Alaska 8 - Chugach							
	Light a	nd Power	Company	Electric	Associat	ion, Inc.	Homer El	ectric Ass	oc., Inc.	<u>Kenai C</u>	ity Light	System	Electric	Associat	ion, Inc.
	Net	Load	Peak	Net	Load	Peak	Net	Load	Peak	Net	Load	Peak	Net	Load	Peak
	Energy	Factor	Demand	Energy	Factor	Demand	Energy	Factor	Demand	Energy	Factor	Demand	Energy	Factor	Demand
Year	(GWh)	(%)	(MW)	(GWh)	(%)	(MW)	(GWh)	(%)	<u>(MW)</u>	(GWh)	(%)	<u>(MW)</u>	(GWN)	(%)	[[47]]
1979	633.6	58.1	124.4	280.4	47.5	67.4	275.2	55.0	57.1	34.4	56.0	7.0	1,108.9	53.0	238.8
1980	699.4	58.1	137.5	332.8	47.0	80.8	336.6	55.0	69.9	37.5	56.0	7.6	1,283.0	54.0	271.2
1981	770.6	57.9	151.8	395.1	46.5	97.0	411.6	55.0	85.4	40.8	56.0	8.3	1.467.8	54.0	310.3
1982	847.3	57.8	167.3	468.0	56.0	116.1	502.0	55.0	104.2	44.4	56.0	9.1	1,679.1	54.0	355.0
1983	929.6	57.7	183.9	559.3	45.0	141.9	572.3	55.0	118.8	48.1	56.0	9.8	1,920.9	54.0	406.1
1984	1,017.5	57.6	201.2	668.3	44.5	171.4	652.4	55.0	135.4	52.1	56.0	10.6	2,197.5	54.0	464.5
1985	1,110.8	57.4	220.8	798.6	44.0	207.2	743.7	55.0	154.4	56.4	56.0	11.5	2,509.0	54.0	530.4
1986	1,209.5	57.3	241.1	954.4	43.5	250.5	847.9	55.0	176.0	61.1	56.0	12.5	2,810.1	54.0	594.1
1987	1.313.2	57.1	262.5	1.140.0	43.0	302.6	967.0	55.0	201.0	66.3	56.0	13.5	3,147.3	54.0	665.3
1988	1,421.6	56.9	285.0	1.322.4	44.0	343.1	1.083.0	55.0	224.8	71.5	56.0	14.6	3,525.0	54.0	745.2
1989	1,534.2	56.8	308.5	1,534.0	45.0	389.1	1,213.0	55.0	251.8	77.0	56.0	15.7	3,948.0	54.0	834.6
1990	1,650.5	56.6	333.0	1,779.4	46.0	441.6	1,358.6	55.0	282.0	83.1	56.0	16.9	4,421.7	55.0	934.7
1991	1,769.8	56.4	358.2	2,064.1	47.0	501.3	1,521.6	55.0	315.8	89.5	56.0	18.2	4,863.9	55.0	1,028.2
1992	1,891.3	56.2	384.1	2,394.4	43.0	569.4	1,704.2	55.0	353.7	96.5	56.0	19.7	5,350.3	55.0	1,131.0
1993	2,014.4	56.0	410.5	2,705.7	49.0	630.3	1,874.6	55.0	389.1	103.5	56.0	21.1	5,885.3	55.0	1,244.1
1994	2,138.0	55.8	437.2	3,057.4	50.0	698.0	2,062.1	55.0	428.0	111.1	56.0	22.6	6,473.9	55.0	1,363.6
1995	2,244.9	55.6	460.9	3,454.9	51.0	773.3	2,268.3	55.0	470.8	119.2	56.0	24.3	7,121.2	55.0	1,505.4
1996	2,357.1	55.4	485.7	3,904.0	52.0	857.0	2,495.1	55.0	517.9	127.9	56.0	26.1	7,690.9	55.0	1,625.8
1997	2,475.0	55.2	511.8	4,411.5	53.0	950.2	2,744.6	55.0	559.7	137.3	56.0	28.0	8,306.2	55.0	1,755.9
1998	2,558.8	55.0	539.4	4,852.7	54.0	1,025.9	2,964.2	55.0	615.2	146.9	56.0	29.9	8,970.7	55.0	1,900.6
1999	2,728.7	54.8	568.4	5,337.9	55.0	1,107.9	3,201.3	55.0	664.4	157.2	56.0	32.0	9,688.3	55.0	2,048.1
2000	2,865.0	54.6	599.0	5,871.7	56.0	1,196.9	3,457.4	55.0	717.6	168.2	56.0	34.3	10,463.4	55.0	2,211.9
				•				- 1. A							

Growth Rates:

Reported	Logistic Curve 3	18.7% (1977-1982) 19.5% (1983-1987)	22.3% (1977-1982) 14.0% (1983-1987)	8.8% (1977-1982) 8.3% (1983-1987)	15.73 (1977-192C) 14.4% (1981-1985)
Projected	5.0% (1995-2000)	16.0% (1983-1992) 13.0% (1993-1997) 10.0% (1998-2000)	12.0% (1958-1992) 10.0% (1993-1997) 8.0% (1998-2000)	7.8% (1988-1992) 7.3% (1993-1997) 7.0% (1998-2000)	12.0% (1986-1990) 10.0% (1991-1995) 8.0% (1996-2000)

TABLE 3-2

	FAIRBANKS	- T/	ANANA VALLEY .	AREA
UTILITY	FORECASTS	AND	EXTRAPOLATED	PROJECTIONS

	Fairbanks Municipal Utilities System			Alaska (Electric	Valley on, Inc.	
	Net	Load	Peak	Net	Load	Peak
	Energy	Factor	Demand	Energy	Factor	Demand
Year	(GWh)	(%)	(MW)	(GWh)	_(%)	(MW)
1979	144.3	50.0	32.9	450.0	46.3	111.0
1980	153.0	50.0	34.9	501.8	46.6	122.9
1981	162.2	50.0	37.0	559.5	46.9	136.2
1982	171.9	50.0	39.2	624.6	47.2	150.9
1983	182.2	50.0	41.6	692.6	47.3	167.1
1984	193.2	50.0	44.1	768.8	47.3	185.5
1985	204.7	50.0	46.7	853.4	47.4	205.5
1986	217.0	50.0	49.5	947.3	47.4	228.1
1987	230.0	50.0	52.5	1,050.0	47.5	252.3
1988	243.9	50.0	55.7	1,155.0	47.5	277.6
1989	258.5	50.0	59.0	1,270.5	47.6	304.7
1990	274.0	50.0	62.6	1,397.6	47.6	335.2
1991	287.7	50.0	65.7	1,537.3	47.7	367.9
1992	302.1	50.0	69.0	1,691.0	47.7	404.7
1993	317.2	50.0	72.4	1,843.2	47.8	440.2
1994	333.0	50.0	76.0	2,009.1	47.8	479.8
1995	349.7	50.0	79.8	2.189.9	47.9	521.0
1996	367.2	50.0	83.8	2.387.0	47.9	568.9
1997	385.5	50.0	88.0	2,601.8	48.0	618.8
1998	404.8	50.0	92.4	2,809.9	48.0	668.3
1999	425.1	50.0	97.1	3,034.7	48.0	721.7
2000	446.3	50.0	101.9	3,277.5	48.0	779.5

<u>Growth Rates</u>:

 \prod

Ì

•

ſ

Reported	6.0% (1978-1990)	11.5% (1977-1982) 11.0% (1983-1987)
Projected	5.0% (1991-2000)	10.0% (1988-1992) 9.0% (1993-1997) 8.0% (1998-2000)

TABLE 3-3

COMBINED UTILITY FORECASTS FOR RAILBELT AREA

	Anchor	Anchorage Cook - Inlet			nks – Tanar	a Valley	Combined Load Areas		
Maria	Net Energy	Load Factor	Peak ₁ / Demand	Net Energy	Load Factor	Peak _{2/} Demand	Net Energy	Load Factor	Peak _{3/} Demand
Year	<u>(Gwn)</u>	(%)	(MW)	(GWN)	(%)	(MW)	<u>(GWh)</u>	(%)	(MW)
1979	2,332.5	56.1	475	594.3	47.6	142	2,926.8	55.3	605
1980	2,689.3	56.4	544	654.8	47.9	156	3,344.1	55.6	686
1981	3,085.9	56.2	627	721.7	48.0	171	3,807.6	55.6	782
1982	3,540.8	56.0	722	795.9	48.3	188	4,336.7	55.5	892
1983	4,030.2	55.7	826	874.8	48.3	207	4,905.0	55.3	1,012
1984	4,587.8	55.5	944	962.0	48.3	227	5,549.8	55.2	1,148
1985	5,218.5	55.2	1,079	1,058.1	48.4	250	6,276.6	55.0	1,302
1986	5,883.0	54.9	1,223	1,164.3	48.4	275	7,047.3	54.8	1,468
1987	6,633.8	54.6	1,387	1,280.0	48.4	302	7,913.8	54.6	1,655
1988	7,423.5	54.7	1,548	1,398.9	48.4	330	8,822.4	54.7	1,840
1989	8,306.2	54.9	1,728	1,529.0	48.5	360	9,835.2	54.9	2,046
1990	9,293.3	55.0	1,928	1,671.6	48.5	394	10,964.9	55.0	2,276
1991	10,308.9	55.2	2,133	1,825.0	48.5	429	12,133.9	55.2	2,511
1992	11,436.7	55.3	2,360	1,993.1	48.5	469	13,429.8	55.3	2,772
1993	12,583.5	55.5	2,587	2,160.4	48.6	507	14,743.9	55.5	3,032
1994	13,842.5	55.7	2,836	2,342.1	48.6	550	16,184.6	55.7	3,318
1995	15,208.5	55.9	3,105	2,539.6	48.6	596	17,748.1	55.9	3,627
1996	16,575.0	56.1	3,372	2,754.2	48.7	646	19,329.2	56.0	3,938
1997	18,074.6	56.3	3,663	2,987.3	48.7	700	21,061.9	56.2	4,276
1998	19,533.3	56.5	3,947	3,214.7	48.7	753	22,748.0	56.4	4,606
1999	21,113.4	56.8	4,244	3,459.8	48.7	811	24,573.2	56.6	4,954
2000	22,825.7	57.0	4,569	3,723.8	48.7	873	265,49.5	56.8	5,333

Diversified Demand for Coincidence Factor: <u>1</u>/ 0.96

ω 1 $\frac{1}{3}$

<u>2</u>/ 0.99

3/ 0.98
TABLE 3-4 Sheet 1 of 2

LOAD FORECAST FOR UPPER SUSITNA PROJECT BY ALASKA POWER ADMINISTRATION

			1977	1980	1985	1990	1995	2000			
1.	ANCHORAGE-COOK INL	ET AREA P	OWER DEI	MAND AND	ENERGY I	REQUIREMEN	ITS				
	(Excluding National Defense)										
	Peak Demand (MW)										
	Utility Loads										
	High Median Low		424	620 570 525	1,000 810 650	2,150 1,500 1,040	3,180 2,045 1,320	7,240 3,370 1,520			
	Industrial Loads										
	Extra high High Median Low	•	25	32 32 32 27	344 64 64 59	399 119 119 70	541 261 199 87	683 403 278 104			
	Total										
•	Extra high High Median Low	•	449	652 652 602 552	1,344 1,064 874 709	1,914 1,634 1,234 890	2,691 2,411 1,699 1,127	3,863 3,583 2,323 1,424			
	Annual Energy (GWh	<u>)</u>						•			
	Utility Loads										
	High Median Low		1,790	2,720 2,500 2,300	4,390 3,530 2,840	6,630 4,880 3,590	9,430 6,570 4,560	13,920 8,960 5,770			
	Industrial Loads										
	Extra high High Median Low		70	170 170 170 141	1,810 340 340 312	2,100 625 630 370	2,840 1,370 1,050 460	3,590 2,120 1,460 550			
	Total	•									
	Extra high High Median Low		1,860	2,890 2,890 2,670 2,441	6,200 4,730 3,870 3,152	8,730 7,255 5,510 3,960	12,270 10,800 7,620 5,020	17,510 16,040 10,420 6,320			

3. - 14

TABLE 3-4 Sheet 2 of 2

{

LOAD FORECAST FOR UPPER SUSITNA PROJECT BY ALASKA POWER ADMINISTRATION

		<u>1977</u>	1980	1985	1990	1995	2000
2.	FAIRBANKS-TANANA VALLEY	AREA POWER	DEMAND	AND ENERG	Y REQUIR	EMENTS	
	(Exc	luding Nat	ional De	efense)			
	Peak Demand (MW)						
	Utility Loads						
	High Median Low	119	158 150 142	244 211 180	358 281 219	495 358 258	685 452 297
	Annual Energy (GWh)						
•	Utility Loads						
	High Median Low	483	690 655 620	1,070 925 790	1,570 1,230 960	2,170 1,570 1,130	3,000 1,980 1,300
3.	COMBINED ANCHORAGE-COOK	INLET AND I	FAIRBAN	(S-TANANA	VALLEY A	REAS	
	<u>Peak Demand (MW)</u>						
	Extra high High Median Low	568	810 810 752 694	1,588 1,308 1,085 889	2,272 1,992 1,515 1,109	3,186 2,906 2,057 1,385	4,548 4,268 2,775 1,721
	<u>Annual Energy (GWh)</u>						
	Extra high High Median Low	2,343	3,580 3,580 3,325 3,061	7,270 5,800 4,795 3,942	10,300 8,825 6,740 4,920	14,440 12,970 9,190 6,150	20,510 19,040 12,400 7,620

TABLE 3 - 5

LOAD DEMAND FORECASTS FOR RAILBELT AREA

TO

DETERMINE STATISTICAL AVERAGE FORECAST

	Anchorage - Cook Inlet			Fairbanks - Tanana Valley			. 0	Combined Load Areas		
Year	Combined	Alaska Power	Statistical	Combined	Alaska Power	Statistical	Combined	Alaska Power	Statistical	
	Utilities	Administration	Average	Utilities	Administration	Average	Utilities	Administration	Average	
	Forecast	Median	Forecast	Forecast	Median	Forecast	Forecast	Median	Forecast	
	(MW)	Forecast (MW)	(MW)	(MW)	Forecast (MW)	(MW)	(MW)	Forecast (MW)	(MW)	
1979	475	546	511	142	139	141	605	685	645	
1980	544	602	573	156	150	153	686	752	719	
1981	627	648	638	171	161	166	782	809	796	
1982	722	698	710	188	172	180	892	870	881	
1983	826	752	789	207	184	196	1012	936	974	
1984	944	810	877	227	197	212	1148	1007	1078	
1985	1079	874	977	250	211	231	1302	1085	1194	
1986	1223	937	1080	275	223	249	1468	1160	1314	
1987	1387	1004	1196	302-	237	270	1655	1241	1448	
1988	1548	1077	1313	330	251	291	1840	1328	1584	
1989	1728	1154	1441	360	265	313	2046	1419	1733	
1990	1928	1234	1581	394	281	338	2276	1515	1896	
1991	2133	1315	1724	429	295	362	2511	1610	2061	
1992	2360	1402	1881	469	310	390	2772	1712	2242	
1993	2587	1495	2041	507	325	416	3032	<u>1820</u>	2426	
1994	2834	1593	2215	550	342	446	3318	1935	2627	
1995	3105	1699	2402	596	358	477	3627	2057	2842	
1996	3372	1809	2591	646	375	511	3938	2184	3061	
1997	3663	1925	2794	700	393	547	4276	2318	3297	
1998	3947	2049	2998	753	412	583	4606	2461	3534	
1999	4244	2182	3213	811	432	622	4954	2614	3784	
2000	4569	2323	3446	873	452	663	5333	2755	_ 4054	

TABLE 3 -6

LOAD DEMAND BANDWIDTH FOR RAILBELT AREA FORECASTS "MOST PROBABLE" FORECAST <u>+</u> 2 STANDARD DEVIATIONS

	Anchorage - Cook Inlet			Fairbanks - Tanana Valley			Combined Load Areas		
Lo	ad Level	Most	Load Level	Load Level	Most	Load Level	Load Level	Most	Load Level
-2	Standard	Probable	+2 Standard	-2 Standard	Probable	+2 Standard	-2 Standard	Probable	+2 Standard
De	viations	Forecast	Deviations	Deviations	Forecast	Deviations	Deviations	Forecast	Deviations
Year	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)	(MW)
1979	535	511	487	140	141	142	671	645	619
1980	592	573	554	151	153	155	741	749	697
1981	644	638	632	163	166	169	805	796	787
1982	702	710	718	175	180	185	874	881	888
1983	765	789	813	188	196	204	949	974	999
1984	832	877	922	202	212	222	1031	1078	1125
1985	908	977	1046	218	231	244	1121	1194	1267
1986	985	1080	1175	232	249	266	1212	1314	1416
1987	1068	1195	1324	248	270	292	1310	1448	1586
1988	1156	1313	1470	264	291	318	1413	1584	1755
1989	1250	1441	1632	281	313	345	1523	1733	1943
1990	1350	1581	1812	300	338	376	1642	1896	2150
1991	1451	1724	1997	317	362	407	1760	2061	2362
1992	1562	1881	2200	337	390	443	1888	2242	2596
1993	1677	2041	2405	355	416	477	2021	2426	2831
1994	1800	2215	2630	377	-446	515	2167	2627	3087
1995	1933	2402	2871	398	477	556	2319	2842	3365
1996	2070	2591	3112	420	511	602	2476	3061	3646
1997	2215	2794	3373	444	547	650	2644	3297	3950
1998	2365	2998	3631	469	583	697	2820	3534	4248
1999	2526	3213	3900	495	622	749	3004	3784	4564
2000	2697	3446	4195	522	663	804	3203	4054	4905
Probability Multipliers	0.0665	0.383	0.0665	0.0665	0.383	0.0665	0.0665	0.383	0.0665



FIGURE 3-1



ω . 19

FIGURE





ר-ט-טרב ה-ט



FIGURE :

{E 3-4



FIGURE 3-5



FIGURE 3-6

PROBABILITY MODEL REPRESENTATION OF LOAD FORECAST UNCERTAINTY



FIGURE 3-7A CONTINUOUS REPRESENTATION



FIGURE 3-7B DISCRETE REPRESENTATION





FIGURE 3-9



LOAD DEMAND FORECAST BANDWIDTH: MOST PROBABLE ± 2 STANDARD DEVIATIONS

ω 27

> FIGURE ယ 10

CHAPTER 4 SELECTION OF INTERTIE ROUTE

CHAPTER 4 SELECTION OF INTERTIE ROUTE

4.1 REVIEW OF EARLIER STUDIES

A number of studies have considered the electrical interconnection of the Fairbanks, South Central, and Anchorage areas (Refs. 1-8). The Susitna Hydroelectric Project Interim Feasibility Report (Ref. 2), hereafter called Susitna Report, reviewed a number of alternative transmission corridors in considerable depth. None of the studies included a specific route for a transmission line. The Susitna Report provides an excellent inventory of topography, geology, soils, vegetation, wildlife, climate, existing development, land ownership status, existing rights-of-way, and scenic quality and recreation values by corridor segments of about 5-mile widths.

4.2 SURVEY OF ALTERNATIVE CORRIDORS

Alternative corridors reviewed for this report were those along or near the Railbelt region between the Anchorage and Fairbanks areas. A reconnaissance (by USGS Quad's and local knowledge) of routes connecting the Railbelt area to Glennallen was also made to provide a basis for estimating the cost of such a connection at a later date.

4.3 PREFERRED ROUTE FOR TRANSMISSION INTERTIE

The preferred corridor described in the Susitna Report was further defined by making an actual preliminary layout of a definitive route (with some alternatives) using engineering techniques. This preliminary routing provides a basis for refining cost estimates, displaying a definitive location for use in studying potential environmental impacts, and providing a specific engineering recommendation for use in right-of-way negotiations.

The preliminary line routing is shown on the accompanying maps, Figures 4-1, 4-2, and 4-3, these being spatially related to the key map on the inside of the front cover of this report. These routes come from a working strip map of 1" = 1 mile (USGS Quad's.) on which these preliminary routes are drawn. The route was plotted by an engineer with nearly 30 years of experience with Alaskan transmission systems. It was also visually inspected throughout much of its length over the Parks Highway from Anchorage to Fairbanks.

The definitive line route was established within the preferred corridor, with due regard to the following restraints, insofar as they could be identified in this preliminary review:

- Avoidance of highway rights-of-way, which are better locations for distribution lines that will be required to serve homes and enterprises served by the highway.
- Avoidance of telephone lines, because of electrical interference problems. (An open-wire telephone circuit exists on the entire length of the Alaska Railroad right-of-way.)
- Avoidance of aircraft landing and takeoff corridors, including all lakes of sufficient size to accommodate small floatplanes. Where lines may cross landing patterns, at least 1/2 mile is allowed from the end of runways or lakes, so that special designs are not required.
- Avoidance of highly subdivided land areas and dwellings.
- Avoidance of crossings over developed agricultural lands.
- Selection of routings that provide for minimum visibility from highways and homes.

- Avoidance of heavily timbered lands.
- Selection of routes that provide for minimum changes in grade as the terrain will allow.
- Parallel alignments with property lines are favored, if not precluded by other considerations.
- Avoidance of sensitive wildlife areas, if practicable, and cooperation in regard to construction and operating restraints where lines pass through such areas.
- Alignments located in reasonable proximity to transportation corridors (roads, railroads, navigable waterways) so that construction, operation, and maintenance routines are not inordinately difficult.

4.4 FIELD INVESTIGATIONS

Principal engineers of the IECO-RWRA team made field trips by helicopter and surface transportation to important sites and typical structures of existing transmission lines in both the Anchorage and Fairbanks areas. Particular attention was given to lines using designs developed especially for Alaskan conditions of muskeg swamp, permafrost, and flood plain. These designs have had more than ten years of successful service, and are the basis for more recent tubular steel structure designs now being installed on Alaska projects.

Actual field records of Resident Engineers and Inspectors on Alaska transmission line construction projects were analyzed along with contractor bids for these projects to provide authoritative basic data on the actual manhours, materials use, and dollar costs of completed transmission lines.

4.5 PRELIMINARY ENVIRONMENTAL ASSESSMENT

A. Description of the Environment

1. <u>Point MacKenzie to Talkeetna</u> - The corridor travels north along the east flank of the Susitna River Valley, an extremely wide and poorly drained plain. Heavy forests of bottomland spruce and poplar, interspersed with muskeg and black spruce, are typical. The soils vary from deep, very poorly drained peat to well-drained gravels and loams, with the welldrained soils being more abundant. Although permafrost is almost absent in this lower part of the Susitna Valley, the poorly drained areas are subject to freezing and heaving in the winter.

A sizeable concentration of moose inhabits the lower Susitna River Valley. This valley also supports black and brown bear and a moderate density of water fowl.

The proposed transmission line route generally follows a "tractor trail" (USGS designation) to three miles northeast of Middle Lake. Here, at the approach to the Nancy Lake area, an alternate route (A) may be used to avoid this area. The proposed route (B) is located in marshes and wetlands, between Papoose Twins and Finger Lakes, across the Little Susitna River. The corridor then travels northward along the east side of Lynx Lake, Rainbow Lake, and Long Lake where it crosses the Willow River. Here alternate routes (A) and (B) rejoin and intersect an existing 115-kV MEA transmission corridor at the Little Willow Junction and a proposed corridor to Anchorage on the east side of Knik Arm. Travelling north, the corridor crosses several major tributaries of the Susitna River including Sheep Creek and the Kashwitna River. In this area the terrain becomes more rolling, and the relative proportion of well-drained soils supporting thick poplar-spruce forests is considerably greater than to the south. The corridor then travels some five miles east of Talkeetna to the Bartlett Hills P.I. (point of intersection).

2. <u>Talkeetna to Gold Creek</u> - From Bartlett Hills P.I. the corridor crosses the Talkeetna River near the confluence of the Talkeetna and Chulitna Rivers, where it follows the west bank of the Chulitna River at a mean elevation of 600 feet. Where the Chulitna River curves eastward, the corridor travels northward, along the Susitna River Valley, through forested uplands, gradually rising to an elevation of 1000 feet. The uplands above the valley support sparser forests, and increasing amounts of permafrost soils are encountered. At the 1000-foot elevation, one to three miles east of the Susitna River, the corridor crosses Lane Creek, MacKenzie Creek, Portage Creek, Deadhorse Creek, and numerous other small tributaries of the Susitna River. It then crosses Gold Creek and the Susitna River, 1-1/2 miles east of A.R.R. Mile 265, to the Susitna Junction, one mile east of A.R.R. Mile 266. At the Susitna Junction, the proposed Devil Canyon-Watana-Glennallen line meets the corridor.

3. <u>Gold Creek to Glennallen</u> - The corridor parallels the Susitna River to the proposed Devil Canyon damsite and then travels east to the proposed Watana damsite. The vegetation in the canyons varies from upland spruce-hardwood to alpine tundra. Soils vary from poorly drained river bottoms to unstable talus. Permafrost occurs in this portion of the corridor. Some localized moose populations are crossed. The corridor passes through low lake areas west of Lake Louise until it intersects the Richardson Highway at Tazlina. From Tazlina the route follows the Richardson Highway into Glennallen.

4. <u>Gold Creek to Cantwell</u> - The transmission corridor travels north some 1 to 3 miles east of the Alaska Railroad between elevation 1500 and 2000 feet. The timber density becomes successively less in this area. This portion of the corridor is a good bear and moose habitat. Shallow permafrost occurs in this portion. The corridor crosses several major and minor tributaries to the Chulitna River including Honolulu Creek, Antimony Creek, Hardage Creek, the East Fork of the Chulitna River, and the Middle Fork of the Chulitna River. The corridor area is of medium scenic quality and is not readily accessible, except at the Denali Highway Crossing.

5. <u>Cantwell to Healy</u> - The corridor rises to the 3200 foot level along the west side of Reindeer Hills and then descends into the Nenana River Valley. It follows the east flank of the Nenana River northward at the 2200 foot level, through sparsely timbered country. This is an area of high scenic quality especially in the canyons. The terrain varies from rolling hills and valleys to high passes and sharp ridges. Habitats of moose, bear, and Dall sheep are traversed. Bedrock is exposed in the canyons. The corridor crosses several tributaries to the Nenana River including Slime Creek, Carlo Creek, Yanert Fork, and Montana Creek, and the Nenana River itself. It also crosses the Alaska Railroad at the Moody Tunnel, near A.R.R. Mile 354 and the Healy River. The boundary of Mt. McKinley National Park is on the west flank of the Nenana River.

Healy to Ester - The corridor leaves Healy and crosses the Parks 6. Highway near Dry Creek. It then roughly parallels the west side of the highway at elevation 1500 feet, crossing several tributaries to the Nenana River. It crosses the GVEA line 1-1/2 miles north of Bear Creek, the Alaska Railroad and the Nenana River at A.R.R. Mile 383, and the Parks Highway. The route then parallels the GVEA line. The corridor crosses the Tanana River at the Tanana P.I. and follows the Tanana River flood plain for several miles until the route again crosses the highway where it travels on the west side of the Bonanza Creek Experimental Forest. The route parallels the GVEA right-of-way the rest of the way to Ester. The Healy to Ester portion of the route passes through some private lands (mining claims, homesteads, etc.), as well as near the towns of Healy, Lignite, and Nenana. An archeological site exists near Dry Creek. Portions of the corridor are heavily forested and provide habitat for moose, caribou, and bear. Poorly drained areas in this corridor are subject to potential permafrost degradation and frost heaving.

B. Environmental Impacts

Construction and maintenance of other Alaskan transmission systems has shown that most negative environmental impacts caused by a transmission system can be minimized. Golden Valley Electric Association, Matanuska Electric Association, and Chugach Electric Association have constructed and are operating several lines on poor soils and under harsh climatic conditions. Except for anticipated slight visual impacts, most environmental impacts caused by a transmission system would be far less than those of many transportation and communication systems. Specific areas to be impacted are discussed below.

1. <u>Ecosystems</u> - The major positive impact will be on human environment, while adverse effects to the other ecosystems will be minimal. The route has been selected to avoid adverse impacts on these ecosystems wherever possible. The human environment will be benefited by the provision of energy, vital to the growing state of Alaska. The development of many potential renewable energy resources will be made feasible by the Anchorage-Fairbanks intertie. The project will contribute to the reduction in costs of electrical energy, improvement in reliability of electrical service, and enhancement of opportunities for renewable energy resources (such as hydro and wind) to displace non-renewable energy resources (such as gas and oil) for the generation of electricity.

Alteration of vegetation patterns will affect wildlife. This corridor traverses many areas of moose concentrations, and moose should benefit from the introduction of brush resulting from regrowth on the clearing. Since the clearing must be maintained, this brush area will last for the lifetime of the project. Animals such as squirrels will suffer loss and displacement. However, their faster reproductive rates will allow their populations to adjust rapidly.

Construction itself will affect wildlife. Larger mammals may temporarily leave the area to return after the construction activity. Smaller animals will suffer individual losses, but should recuperate rapidly once construction is completed. The density of forest in portions of the corridor will allow animals to move only a short distance to avoid contact with construction activities.

Vegetation suppression, by whatever method, will periodically remove cover from along the right-of-way. However, due to the surrounding cover of the uncleared forests, this impact will be insignificant.

2. <u>Recreation</u> - The corridor will approach several recreational and wayside areas in the lower Susitna Valley. The largest of these is the Nancy Lake Recreational Area. The corridor will also approach the Denali State Park, but will be separated from the Park by the Susitna River.

This corridor will provide access to areas previously difficult to reach. The largest such area is that south of Nancy Lake to Point MacKenzie. Dense forest and muskeg limit travel.

Further north the corridor parallels the east border of Mt. McKinley National Park, being separated by the Parks Highway, the Nenana River, and the Alaska Railroad.

3. <u>Cultural Resources</u> - The National Register of Historical and Archaeological Sites lists the following sites which will be approached by the transmission corridor: Knik Village, Dry Creek, and the Tangle Lake Archaeological District. The line will be routed to bypass these areas.

During construction and preconstruction surveys, other archaeological sites may be discovered which may be eligible for nomination to the National Register. This is a positive benefit of the corridor, as archaeological and other cultural resources are often difficult to find in the great Alaska wilderness.

4. <u>Scenic Resources</u> - The southern portion of the corridor does not traverse any areas of good or high quality scenic values. The northern portion is, however, more scenic than the southern portion. In the northern portion the fairly continuous, moderately dense forest will provide ample screening from transportation routes. Further south, the forests are more intermingled with open muskeg. Glimpses of the transmission line will be seen from the highway or railroad through these muskeg areas. South of Nancy Lake the transmission corridor and the transportation corridors diverge, and although cover becomes more sporadic, the line will no longer be visible from the transportation routes. The transmission line will not be visible from most of the Nancy Lake Recreation Area.

As the Alaska Railroad and the transmission corridor approach Gold Creek, the valley becomes more confined, and screening becomes more difficult. However, it appears that the line can be concealed through most of this portion.

The corridor passes through an area recognized as being of good to high scenic quality from Devil Canyon to Healy. The possibility of screening throughout this area varies from moderate in the southern portion around Chulitna, to minimal in the Broad Pass and the upper and lower canyons of the Nenana River. Scenic quality will be impacted, the impact being a function of existing scenic quality and the opportunity for screening. The proposed line design will incorporate weathering tubular steel towers which blend well into the environment. Non-specular conductors might be used where light reflection from the line would cause unacceptable adverse visual impact. Impact in the Nenana Canyon will be high; impact on Broad Pass will be moderate to high; impact elsewhere will be moderate. Two favorable factors mitigate the impact somewhat: 1) the corridor is not visually intact as the Alaska Railroad and the Anchorage-Fairbanks Highway have already reduced scenic quality somewhat; and 2) the major views south of the canyons are to the west, toward the Mt. McKinley massif, whereas the transmission line corridor lies to the east of the transportation routes.

5. <u>Social</u> - Some economic impact can be expected, as flying services, motels, restaurants, and entertainment facilities receive business, not only from the transmission line workers, but from related personnel. Due to the high cost of a low-load tap on a high voltage line, the likelihood of use of the energy by small communities along the corridor is remote. However, in places where the demand could justify such a tap, it would provide a reliable source of electrical energy for growing communities.

C. Special Impact Mitigation Efforts During Construction

Right-of-way clearing will be accomplished by approved methods such as the hydro axe, and chips will be spread along the right-of-way. The line will be screened wherever possible. The towers will be designed to blend into the environment, thereby reducing visual impact.

Movement of men and equipment during construction will be scheduled to avoid excessive damage to the ground cover. This is generally accomplished by winter construction. The tower design will allow movement of men and equipment along the right-of-way centerline, thereby eliminating the need for an access road in addition to the transmission line clearing.

Major river crossings will be required over the Talkeetna River, Tanana River, Healy Creek, and the Susitna River. Minor stream crossings may be made either by fording or ice crossings. Special efforts will be made to avoid siltation of fish streams. Oil will be carefully handled to avoid spillage. Where larger quantities of oil are to be stockpiled, dikes will be constructed to protect against spills.

Since most of the construction will occur far from communities, noise is not anticipated to be a problem. Suitable muffling devices will be used to protect men and wildlife from excessive noise. Prior to and during construction, special efforts will be made to consult with State historical and archaeological authorities, the Soil Conservation Service, the Bureau of Land Management, the Alaska Department of Fish and Game, and the U.S. Forest and Wildlife Service, and any other agencies having jurisdiction over the construction area, in an effort to ensure sound environmental practices.

4.6 REFERENCES

- Robert W. Retherford Associates, <u>North Slope Natural Gas Transport</u> <u>Systems and Their Potential Impact on Electric Power Supply and Uses</u> in Alaska, March 1977.
- U.S. Army Corps of Engineers, <u>Southcentral Railbelt Area, Alaska</u>, <u>Upper Susitna River Basin Interim Feasibility Report</u>, (Appendix I, Part II (G) Marketability Analysis, (H) Transmission System, (I) Environmental Assessment for Transmission Systems, December 1975.
- Kozak, Edwin, under the direction of J. R. Eaton, <u>Performance</u> <u>Characteristics of a 350-Mile Electric Power Transmission Line</u> <u>(Fairbanks to Anchorage)</u>, A project in EE 494, Department of Electrical Engineering, University of Alaska, June 1973.
- 4. Ch2M-Hill, <u>Electric Generation and Transmission Intertie System for</u> Interior and Southcentral Alaska, 1972.
- 5. Federal Power Commission, Alaska Power Survey, 1969.
- Alaska Power Administration, <u>Alaska Railbelt Transmission System</u>, working paper, December 1967.
- 7. The Ralph M. Parsons Company, Central Alaska Power Study, undated.
- 8. The Ralph M. Parsons Company, Alaska Power Feasibility Study, 1962.







CHAPTER 5 TRANSMISSION LINE DESIGN

CHAPTER 5 TRANSMISSION LINE DESIGN

5.1 BASIC DESIGN REQUIREMENTS

Experience in Alaska with both wood-pole H-frame, aluminum lattice guyed-X towers, and tubular steel guyed-X towers with high-strength conductors (such as Drake 795 kcmil ACSR) has demonstrated the excellent performance of lines designed with relatively long spans and flexible structures. This general philosophy has been followed in establishing the input parameters for the Transmission Line Cost Analysis Program (TLCAP) used to optimize line designs for the Anchorage-Fairbanks Intertie study. Sample outputs of TLCAP and descriptions of the program methodology are found in Appendix B.

The results of this computer analysis for 230-kV lines favor relatively long spans (1300 ft) and high-strength conductors (such as Cardinal 954 kcmil ACSR). This confirms the previous Alaskan experience and contributes substantially to a more economical design, as Chapter 7 will illustrate.

5.2 SELECTION OF TOWER TYPE USED IN THE STUDY

Due to rather unique soil conditions in Alaska, with extensive regions of muskeg and permafrost, conventional self-supporting or rigid towers will not provide a satisfactory performance or solution for the proposed intertie. Permafrost and seasonal changes in the soil are known to cause large earth movements at some locations, requiring towers with a high degree of flexibility and capability for handling relatively large foundation movements without appreciable loss of structural integrity.

The guyed tower is exceptionally well suited for these type of conditions. Therefore, the final choice of tower for this study was the hinged-guyed X-type design, which has been considered for both the 230-kV and 345-kV

alternatives. These towers are essentially identical in design to towers presently used on some lines in Alaska, which have proven themselves during more than ten years of service. The design features include hinged connections between the leg members and the foundations which, together with the longitudinal guy system, provides for large flexibility combined with excellent stability in the direction of the line. Transverse stability is provided by the wide leg base which also accounts for relatively small and manageable footing reactions.

The foundations are pile-type, consisting of heavy H-pile beams driven to an expected depth of 20 to 30 feet depending upon the soil conditions.

Tower outlines with general dimensions for the two voltage levels are shown on Figures 5-1 and 5-2.

5.3 DESIGN LOADING ASSUMPTIONS

According to available information and experience on existing lines, heavy icing is not a serious problem in most parts of Alaska. NESC Heavy Loading is presently used for all line designs throughout the Railbelt region. However, there are locations where Light Loading probably could be used. Some line failures have occurred due to exceptionally heavy wind combined with very little or no ice. Such locations should be identified and carefully investigated prior to the final line design.

In this study, NESC Heavy Loading or heavy wind on bare conductor (corresponding to NESC Light Loading) was used, whichever is more severe.

5.4 TOWER WEIGHT ESTIMATION

In order to arrive at realistic tower weights and material costs for the study, actual tower designs for both the 230-kV and the 345-kV

alternatives were obtained from Meyer Industries of Red Wing, Minnesota (Ref. 1). This company has designed similar towers for other lines in Alaska.

Based on these reference designs and additional manual calculations, tower weight formulas were developed to account for variations in tower weight due to changes in tower height and load as a function of the type of conductor used.

5.5 CONDUCTOR SELECTION

Conductor size (see Table 5-1) was selected by the use of the Transmission Line Cost Analysis Program (TLCAP) which was specially developed by IECO for this type of study. Given an appropriate range of conductor types and sizes, span lengths, and other pertinent data, TLCAP determines the most economical conductor-span combination.

The program includes a sag-tension routine which calculates the conductor sag and tension for a given set of criteria. Using this information, the tower height and loads are then determined for each discrete span length. These values are then applied to the tower weight formula with the pertinent overload factors included.

In the process of this analysis, the program also evaluated the effect of the cost of the power losses over a specified number of years. The power losses were minimized by varying the sending and receiving end voltages by \pm 10% and by providing required shunt compensation at both line terminals. Applicable material and labor costs, together with projected escalation rates, were included to enable the program to calculate the total installed cost of the line. A discount rate of 7% per annum was used for the determination of the present worth of transmission line losses.

For this particular study, material and labor costs were obtained from "as built" cost information realized on recently completed (138-kV and 230-kV) lines in Alaska.

5.6 POWER TRANSFER CAPABILITIES

Preliminary transmission line capabilities, based on surge impedance loading (SIL) criteria, were obtained from the National Power Survey Report (Ref. 2). Additional investigations indicate that for the 230-kV alternatives (Cases IA, IB, and ID), the calculated intertie power angle is near 30 degrees. To improve the 230-kV intertie's steady state and transient transmission capability, series capacitors will be necessary. Interconnected power system studies should be performed to determine the final series and shunt compensation requirements. Such studies are outside the scope of this work.

5.7 HVDC TRANSMISSION SYSTEM

Because of its asynchronous nature, the interconnection of two isolated alternating current (ac) systems by a point-to-point HVDC transmission link provides the desired power exchange without being prone to inherent stability problems. Furthermore, HVDC transmission can provide stabilizing power, and be very effective in damping system oscillations. While the state-of-the-art in HVDC technology is advancing, the resulting developments are keeping pace with inflation.

Preliminary investigations have shown that HVDC transmission, using 180kV mono-polar transmission and ground return, is competitive with singlecircuit 230-kV ac transmission in the transfer 130 MW of power over 323 miles. However, if the point-to-point transmission link is required to supply intermediate locations with power (either initially or in the future) then it is unlikely that dc transmission can be competitive with an ac alternative.

5.8 <u>REFERENCES</u>

1

- Letter from ITT Meyer Industries to Robert W. Retherford Associates, Anchorage, Alaska, January 15, 1979.
- FPC Advisory Committee Report No. 6, <u>National Power Survey</u>, Vol. II, p. IV2-12, 1964.

TABLE 5-1

CONDUCTOR SIZE SELECTION CRITERIA

Case and <u>1</u> / Alternative	Interconnection	Voltage <u>(kV + 10%)</u>	Line Length (miles)	Optimum ACSR Conductor (kcmil)	Load ^{2/} Per Circuit (MW)
I A & B	Anchorage-Ester	230 s/c	323	1/c - 954	130
I C	Anchorage-Ester	345 s/c	323	2/c - 715	380
I D	Anchorage-Palmer Healy-Ester	230 s/c	323	2/c - 954	130
A II	Anchorage-Devil Canyon	345 s/c ^{<u>3</u>/}	155	2/c - 954	600
	Devil Canyon-Ester	230 s/c $\frac{3}{}$	189	1/c - 954	185
	Watana-Devil Canyon	230 s/c $\frac{3}{}$	27	1/c - 2156	488

 $\frac{1}{2}$ Case I Alternatives exclude the proposed Susitna Project; Case II Alternative A includes the Susitna Project. $\frac{2}{100\%}$ voltage support at both ends.

 $\frac{3}{1}$ Two single_circuit lines on the same right-of-way.

Note: s/c = single circuit; 1/c = single conductor; 2/c = two conductor bundle.

1 6


230KV TANGENT TOWER



1

 $\left(\right)$

 $\left[\right]$

 $\left[\right]$

i anti anti a

 $\left\{ \begin{array}{c} 1 \\ 1 \end{array} \right\}$

345KV TANGENT TOWER

CHAPTER 6 SYSTEM EXPANSION PLANS

CHAPTER 6 SYSTEM EXPANSION PLANS

One benefit of transmission interconnection between two independent power systems is the reduction in the installed generating capacity that is possible, while maintaining the same electric power supply (generation) reliability level for both the independent and interconnected power systems. To calculate this reduction in installed generating plant capacity (megawatts), generation expansion plans had to be developed for both the independent and the interconnected power systems.

This chapter describes the actual process used in the generation expansion planning for the independent power systems of the Anchorage and Fairbanks areas, and for an interconnected Anchorage - Fairbanks power system. Generation expansion planning is a rather complex process. A brief description of the somewhat simplified method used in this Economic Feasibility Study is described below.

6.1 GENERATION PLANNING CRITERIA

A. Generating Unit Data

Existing generating unit data were obtained from the Battelle (Ref. 1) and University of Alaska, August 1976 (Ref. 2) reports. These available data were reviewed and updated using new information obtained by IECO-RWRA engineers during interviews with the managers of the Railbelt utilities. The updated existing generation unit data is presented in Tables 6-1 and 6-2.

Preliminary information on near future (1979-1986) generation expansion planning, including probable generation capacity requirements, for the AML&P and CEA systems was obtained directly from the two utilities. More

detailed information on GVEA generation expansion plans was available in the review copy of the report <u>Power Supply Study - 1978</u> (Ref. 3) and the <u>Report on FMUS/GVEA</u> Net Study (Ref. 4).

B. Installed Reserve Capacity

At the present time, there is apparently no uniform policy as to the required installed generation reserve margins for Alaskan electric power utilities. By definition, the installed generation reserve capacity includes spinning reserve, "hot" and "cold" standby reserves, and generating units on maintenance and overhaul work. No effort is made in this study to separate the installed reserve capacity into spinning and other types of reserves. Utilities in Alaska currently keep spinning reserves to the very minimum, mainly because of the no-load fuel cost incurred by the spinning reserves, and because most generating units in Alaska's Railbelt are quick starting, combustion turbine-type units. This situation may change in the future when new larger, slow starting, thermal power plants are constructed, exceptions being hydro plant units which can be started rather rapidly.

To develop alternative generation expansion plans for this study, a criterion for installed reserve generation capacity had to be established. A 20% reserve margin or the largest single unit at the time of peak system load was decided on as the installed generation reserve criterion. In general, the 20% value is close to the installed reserve goals of most U.S.A. utilities. Recently, the Department of Energy's Economic Regulatory Administration reported the following for the 1978 winter peak load of the lower 48 states:

"According to the forecast, total available power resources for the lower 48 states will total nearly 500,000 MW. Peak demand is anticipated at 380,000 MW, for a reserve of nearly 120,000 MW or 31.5 percent. The lowest reserve - the 21.1 percent - will occur for the southeastern Electric Reliability Council, the DOE said, with the Mid-Atlantic Council experiencing the highest reserve margin at 45.1 percent" (Ref. 5).

C. Unit Retirement

Except for the Knik Arm Power Plant (CEA), no other generating units were reported for retirement by the Railbelt utilities during the 1980-1992 period. Later, to include the effect of the proposed Susitna Hydroelectric Project and to obtain a better economic analysis, this study period was extended through 1997. An assumption was made that the generating units available from 1980-1992 will also be available from 1993 through 1997. Many of them, however, will serve as system standby reserve units.

D. Generation Expansion Planning

To program the economic feasibility study and to establish transmission line interconnection benefits, generation expansion plans for the 1980-1997 period were developed for:

- Independent Anchorage area system.
- Independent Fairbanks area system.
- Interconnected Anchorage-Fairbanks system (intertie for reserve sharing only).
- Interconnected Anchorage-Fairbanks system (intertie for reserve sharing and power transfer).
- Interconnected Anchorage-Fairbanks system (with Susitna Hydroelectric Project).

Basically, generation planning includes three aspects: forecasting future loads (previously described in Chapter 3); developing generation reserve and reliability criteria (discussed later in this chapter); and determining when, how much, and what type of generation capacity is needed (which is discussed below).

Generation timing and capacity were determined by the most probable load forecasts for the Anchorage, Fairbanks, and combined Anchorage-Fairbanks areas, as described in Chapter 3.

Unit sizes for the alternative system expansion plans were determined by the ability of the power system to withstand the loss of a generating unit (or units) and still maintain reasonable system generation reliability. In determining unit sizes, due consideration was given to the valuable generation expansion planning data for the 1979-1986 period which was obtained by IECO-RWRA engineers from the Railbelt area utilities.

IECO-RWRA engineers determined the type of generation mix for the expansion plans based on:

- Preliminary planning information obtained through interviews with Railbelt utilities.
- Information available in the Battelle Report and Alaska Power Administration's January 1979 report draft (Ref. 6).
- The judgment of IECO-RWRA power system planners.

Most of the planned generation additions are baseload-type thermal steam power plants burning coal, gas, or oil as fuel. They are mixed with a few additional peaking-type combustion turbine generating units using natural gas or oil as fuel. It is assumed that in the later years of this study many existing combustion turbine generating units, presently used as baseload or intermediate units, will become peaking or standby units.

6.2 MULTI-AREA RELIABILITY STUDY

A. Purpose

The PTI Multi-Area Reliability (MAREL) Computer Program is used for alternative generation expansion planning, mainly for its ability to maintain a nearly constant level of generation supply reliability in all cases. This approach provides a nearly equal reliability level as far as generation ability to meet the load is concerned. The MAREL program

gives reliability equivalence to both individual area and interconnected system generation planning alternatives. The MAREL program manual (Ref. 7) introduces this program with the following:

"The PTI Multi-Area Reliability Program MAREL determines the reliability of multi-area power systems. It has been written in FORTRAN IV for use on a PRIME 400 time-sharing computer. Reliability indices computed by the program include system loss of load probability (LOLP), LOLP values for the individual areas, probability of various failure conditions and probability that each transmission (intertie) link is limiting in the transfer of generation reserves from one area to another."

MAREL program results helped determine the effectiveness of a transmission line intertie between the Anchorage and Fairbanks areas, and established the amount of generating capacity needed to give the individual areas approximately the same LOLP as for the interconnected system. MAREL study results are also applicable to the alternative which includes the Upper Susitna Project. In this instance the study became a three area reliability study with the Susitna area having only net generation and no load.

B. Reliability Index

To perform individual and interconnected system reliability studies (MAREL), it was necessary to select a reference system generation reliability index. As described above, the MAREL program uses LOLP calculation techniques for each study case. For each load condition the program user adjusts input data, specifically generator unit sizes, generator types, location of generating plants, and intertie capacities, to obtain generation expansion plans of near equal reliability for various alternatives. The LOLP method is very much the adapted method used by U.S.A. utilities during the last 30 years. According to the IEEE/PES Working Group on

Performance Records for Optimizing System Design, Power System Engineering Committee (Ref. 8):

"This (LOLP reliability) index is defined as the long run average number of days in a period of time that load exceeds the available installed capacity. The index may be expressed in any time units for the period under consideration and, in general, can be considered as the expected number of days that the system experiences a generating capacity deficiency in the period. This index is commonly, but mistakenly, termed the "loss of load probability, (LOLP)". A year is generally used as the period of consideration. In this case, the LOLP index is the long-run number of days/year that the hourly integrated daily peak load exceeds the available installed capacity."

There is no standard value of LOLP which is used throughout the electric power industry. However, one day in ten years is a very much accepted value by the lower 48 utilities. Since to the authors' knowledge, LOLP index has not previously been used in Alaska, it was decided to use one day in ten years as LOLP index in this study. The use of this LOLP index may imply larger generation reserve margins than are presently used in Alaska, but an equal or even lower LOLP index is justifiable for Alaska for at least the following reasons:

- In very cold climatic zones the loss of electric power may be more critical than in more temperate climates.
- There is very little information on existing generation and transmission outage rates in Alaska. Therefore, there is more uncertainty about the study input data.
- At present, most of the power systems in Alaska are independently operated. In case of emergency, utilities cannot rely on help from neighboring utilities or power pools as can most of utilities

in the lower 48. Therefore, a lower LOLP reliability index is justifiable.

 Higher planned generation reserves may be needed to provide protection against possible unplanned delays in construction of new larger thermal units.

C. Program Methodology

A general description of the MAREL computer program methodology is contained in Appendix C. The particular program application to this study is "Planning of interconnections to achieve regional integration and more widespread sharing of generation reserves" (Ref. 7). Briefly, the program models each area as a one-bus system to which all generators and loads are connected. Transmission interties between areas are modeled as having limited power transfer capabilities and specified line outage rates. The method assumes that each area takes care of its own internal transmission needs.

D. Load Model

Annual load models were developed for the Anchorage and Fairbanks areas. Daily peak load data for 1975 were obtained from AML&P, CEA, FMUS, and GVEA. The Railbelt utility representatives agreed that 1975 was a typical year with normal weather conditions. The 1975 load models were converted into per unit system for the MAREL program. The computer program multiplied this 1975 load model (input) by the respective study year peak loads to obtain annual load models for each year of the study. Forecasted annual peak loads and the per unit annual load models for the Anchorage and Fairbanks areas are shown in Tables 6-3 and 6-4. Annual demand curves indicating biweekly non-coincident peaks are shown on Figure 6-1. Figure 6-1 also indicates that there is very little diversity between the loads of the Anchorage and Fairbanks areas.

E. Generating Unit Data

Information on existing generating unit data, as indicated in Tables 6-1 and 6-2, was used in the study. Unit base ratings were rounded off to the nearest megawatt in the study. Sizes for new generating units used in the expansion plans are indicated on Figures 6-2, 6-3, 6-4, and 6-5.

Generating unit outage rates, which are required for calculating LOLP indexes, were obtained from the most recent Edison Electric Institute (EEI) report on equipment availability (Ref. 9). The rates for combustion turbines were obtained from the actual operating experience of CEA and GVEA at the Beluga and Zehnder Power Plants. The EEI publication defines the forced outage rate as:

Forced Outage Rate = $FOH/(SH + FOH) \times 100$

Where FOH represents forced outage hours and SH represents service hours. Generating unit outage rates used in the MAREL study are indicated below:

Unit Designation	Forced Outage Rate (%)
Combustion Turbine*	5.5
Hydroelectric Plant	1.6
Thermal Steam Plant (small units)	5.9
Thermal Steam Plant (100-200 MW)	5.7
Thermal Steam Plant (300 MW)	7.9

* The Forced Outage Rate for combustion turbines was based on the following information:

 CEA experience at Beluga during 1977-1978 period, six units base loaded. Unit availability87% of the timeScheduled maintenance8% of the timeForced outage5% of the time

Therefore, the calculated Forced Outage Rate equals 5.4%.

 In 1975 GVEA experience at Zehnder Station, Units No. 1 and 2 provides calculated Forced Outage Rates of 4.2% and 4%, respectively; however, these units were basically standby units.

F. Generating Unit Maintenance

The MAREL program automatically schedules generating unit maintenance within the specified restrictions. For the purpose of this study, it was assumed that no unit maintenance will be scheduled during the November-March winter season.

G. Intertie Data

The MAREL program models the transmission intertie by limiting intertie transfer capabilities and considering intertie outage rates. No load loss sharing method was used. This means that one area will share its generating reserves only up to the limit of intertie transfer capability or available reserves in the other area, whichever is limiting. The forced outage rates (on a per year basis) used in the study for transmission and line terminal equipment are indicated below:

Line Voltage (kV)	Forced Outage Rate (per unit/100 miles)
230	0.00113
345	0.00225

Note:

The following outage rate was used for both 230-kV and 345-kV line terminals: 36 hours/10 years.

6.3 SYSTEM EXPANSION PLANS

A. Planning Study Period

Based on generation planning criteria and the results of the MAREL reliability study (previously described in this chapter), alternative generation expansion plans were developed. The 1984-1997 period was selected for the alternative expansion plans for the following reasons:

- 1984 is the earliest year when the interconnected system can be operational.
- The 1992-1997 period includes the Upper Susitna Hydroelectric Project, based on the optimistic assumption that Watana Unit No. 1 will be on-line in January 1992.
- The study period is long enough for the present worth economic analysis method, and includes most of the costs and benefits obtainable by the introduction of an intertie in 1984.

To close the gap between the existing generation systems and the first study year (1984) of the intertie economic feasibility study, generation expansion plans for the independent Anchorage and Fairbanks areas for 1980 through 1983 were developed. Information on planned generation additions supplied by the generating utilities in the Railbelt area was used for this purpose.

B. Independent System Expansion Plans

Generation expansion plans for the independent Anchorage and Fairbanks systems were also needed to calculate economic benefits of the interconnection. The planned generation additions consist of thermal base load and peaking units. They do not include the Upper Susitna Project (Watana and Devil Canyon Hydro Plants), which are only included in the interconnected system expansion plans. The independent Anchorage and Fairbanks generation expansion plans are indicated on Figure 6-2.

C. Interconnected System Expansion Plans

Two cases of system interconnection were studied - Case I, direct interconnection between Anchorage and Fairbanks (Ester), and Case II, interconnection between Watana-Devil Canyon with Anchorage and Fairbanks systems. Under Case I four alternatives were developed as follows:

- <u>Case IA</u> includes a single-circuit 230-kV transmission line having 130-MW power transfer capability allocated for reserve sharing only. This plan is shown on Figures 6-3 and 6-6.
- Case IB includes one single-circuit 230-kV transmission line (1984-1991) and two single-circuit 230-kV transmission lines (1992-1997) having the following generation reserve sharing capabilities: 100 MW (1984-1987), 130 MW (1989-1991) and 190 MW (1992-1997). In addition, this alternative has a firm power transfer capability of 30 MW (1984-1987) and 70 MW (1992-1997). This plan is shown on Figures 6-4 and 6-6.
- Case IC includes one single-circuit 345-kV transmission line having a 130-MW power transfer capability allocated for generation reserve sharing and a 250-MW capacity available for firm power transfer. This case was developed for comparative cost information purposes only without generation expansion plans (MAREL study) and is presented on Figure 6-7.
- <u>Case ID</u> is the same as Case IA, except with intermediate switching stations at Palmer and Healy. This plan is shown on Figures 6-3 and 6-8.

Under Case II, only one solution was studied: two single-circuit 230-kV transmission lines from Watana to Devil Canyon; two single-circuit 230-kV lines from Devil Canyon to Ester (Fairbanks); and two single-circuit 345-kV lines from Devil Canyon to Anchorage.

D. Reliability Indexes

The results of the MAREL study show loss of load probability (LOLP) indexes for independent system expansion plans and plans for an interconnected system (with and without the Upper Susitna Project), and are indicated in Tables 6-7, 6-8, and 6-9. As previously discussed in Subsection 6.2B, the LOLP index of one day in ten years (0.1 day/year) or lower was maintained throughout the study.

6.4 **REFERENCES**

- Battelle Pacific Northwest Laboratories, <u>Alaskan Electric Power</u>, <u>An Analysis of Future Requirements and Supply Alternatives for the</u> Railbelt Region, Vol. I, March 1978.
- University of Alaska, Institute for Social and Economic Research, Electric Power in Alaska, 1976 - 1995, August 1976.
- 3. Stanley Consultants, <u>Power Supply Study 1978 for Golden Valley</u> Electric Association, Inc.
- Alaska Resource Sciences Corporation, <u>Report FMUS/GVEA Net Study</u>, Vol. 1, May 1978.
- Electric Light and Power, <u>Capacity Can Meet Winter Peaks DOE</u>, November 1978.
- Alaska Power Administration, <u>Upper Susitna River Project</u>, <u>POWER</u> MARKET ANALYSES, Draft, January 1979.

- 7. Power Technologies, Inc. <u>PTI Multi-Area Reliability Program (MAREL)</u>, Computer Program Manual, September 1978.
- "Reliability Indices for Use in Bulk Power Supply Adequacy Evaluation", <u>IEEE Transactions on Power Apparatus and Systems</u>, Vol. PAS-97, No. 4, July/August 1978.
- 9. Edison Electric Institute, <u>Report on Equipment Availability for the</u> Ten-Year Period 1967-1976, December 1977.

1

[

Î

 \square

EXISTING GENERATION SOURCES ANCHORAGE - COOK INLET AREA

	Unit	Year of		Unit F Base	Rating Peak	Dependable Capacity	
Name/Location	Reference	Installation	Туре	<u>(kW)</u>	(kW)	(kW)	Remarks
ANCHORAGE MUNICIE	PAL LIGHT AND P	OWER (AML&P)					
Anchorage Anchorage Anchorage Anchorage Anchorage	Unit 1 Unit 2 Unit 3 Unit 4	1968 1972	Diesel SCGT SCGT SCGT SCGT	2,200 15,130 15,130 18,650 31,700	18,000 18,000 21,000 35,000		Black start unit
Anchorage	Unit 5	1975	SCGT	36,800	40,000	<u></u>	Combined cycle
CHUGACH ELECTRIC Beluga Beluga Beluga Beluga Beluga Bernice Lake Bernice Lake Bernice Lake International International International Cooper Lake Knit Arm	ASSOCIATION (C Unit 1 Unit 2 Unit 3 Unit 4 Unit 5 Unit 6 Unit 7 Unit 1 Unit 2 Unit 1 Unit 2 Unit 3 Unit 1 Unit 2 Unit 3 Unit 1 Unit 2 Unit 3 Unit 1 Unit 2 Several	1978 1978 1978	SCGT SCGT SCGT SCGT SCGT SCGT SCGT SCGT	15,150 15,150 53,500 67,810 67,810 67,810 8,200 19,600 24,000 14,530 14,530 18,600 7,500 7,500 14,500	18,700 18,700 67,000 10,000 67,000 72,900 16,500 20,500 16,500 21,500 9,600 9,600 17,700	16,500	To be retired in 1985
MATANUSKA ELECTR	IC ASSOCIATION	(MEA)					
Talkeetna			Diesel	600			Standby
HOMER ELECTRIC A	SSOCIATION (HEA	<u>)</u>					
English Bay Homer-Kenai Homer Port Graham Seldovia			Diesel Diesel SCGT Diesel Diesel	100 300 7,000 200 1,648		1,500	Leased to CEA Leased from GVEA (1977-1979)
SEWARD ELECTRIC	SYSTEM (SES)						
Seward	Unit 1 Unit 2 Unit 3		Diesel Diesel Diesel	1,500 1,500 2,500	1,500 3,000 -	} 5,500	Standby
ALASKA POWER ADM	INISTRATION (AF	PA)					•
Eklutna	Unit 1		Hydro	30,000	35,000	30,000	

 $\left[\right]$

.

1

 $\left[\right]$

i i

EXISTING GENERATION SOURCES FAIRBANKS - TANANA VALLEY AREA

	Unit	Voor		Unit H	lating	Dependable	
Name/Location	Reference	Installation	Туре	(kW)	(kW)	(kW)	Remarks
FAIRBANKS MUNIC	CIPAL UTILIT	LES SYSTEM (FMUS	<u>)</u>				
Fairbanks Fairbanks Fairbanks Fairbanks Fairbanks Fairbanks Fairbanks Fairbanks Fairbanks	Chena 1 Chena 2 Chena 3 Chena 4 Chena 5 Chena 6 Diesel 1 Diesel 2 Diesel 3	1954 1952 1952 1963 1970 1976 1967 1968 1968	ST ST ST SCGT SCGT Diesel Diesel Diesel	5,000 2,000 1,500 20,000 5,350 23,500 2,665 2,665 2,665	7,000		
GOLDEN VALLEY	ELECTRIC ASS	DCIATION (GVEA)					
Zehnder Sub. Zehnder Sub. Zehnder Sub. Zehnder Sub. Zehnder Sub. Healy Healy Northpole Northpole U. of Alaska Delta	Unit 1 Unit 2 Unit 3 Unit 4 Units 1-7 Unit-1 Unit 1 Unit 2 Units 7&8	1971 1972 1975 1975 1970 1967 1976 1977	SCGT SCGT SCGT Diesel ST Diesel SCGT Diesel Diesel	17,553 17,553 2,500 64,800 64,800	20,000 20,000 70,000 70,000	17,400 17,400 3,500 3,500 12,900 26,200 5,100 500	Peaking Service Leased to HEA (1977-1979) Mobile Unit

LOAD MODEL DATA ANCHORAGE AREA

ANNUAL PEAK LOAD IN MW (1983-1996)

789. 877. 977. 1080. 1196. 1313. 1441. 1581. 1724. 1881. 2041. 2215. 2402. 2591.

INTERVAL PEAK LOADS IN P.U. OF ANNUAL PEAK LOAD (26 INTERVALS / YEAR)

DAILY PEAK LOADS IN P.U. OF INTERVAL PEAK LOAD (260 WEEK DAYS / YEAR)

| 1.0000 .9769 | .9731 .953 | 8,9500 | .9462 | .8962 | .8731 | .8577 | ,8423 |
|--------------|------------|----------|-------|-------|--------|-------|-------|
| 1.0000 .9808 | .9663 .966 | 3.9615 | .9615 | .9519 | .9519 | .9423 | .9375 |
| 1.0000 .9913 | .9784 .982 | .9697 | .9654 | .9437 | .9307 | .9221 | .8918 |
| 1.0000 .9829 | .9487 .935 | 9 .9017 | .8889 | .8889 | .8846 | .8333 | .8034 |
| 1.0000 .9512 | .9317 .917 | 1 .9171 | .9073 | .9073 | .9024 | .9024 | .8976 |
| 1.0000 .9848 | .9798 .974 | 7 .9646 | .9495 | .9444 | .9343 | .9293 | .9141 |
| 1.0000 .9686 | .9634 .952 | 9 .9529 | .9476 | .9424 | .9372 | .9058 | .9058 |
| 1.0000 .9781 | .9727 .96 | 7 .9563 | .9563 | .9344 | .9344 | .9071 | .9071 |
| 1.0000 .9883 | .9883 .98 | 25 .9825 | .9708 | .9708 | .9649 | .9591 | .9415 |
| 1.0000 .9940 | .9820 .970 | 01 .9581 | .9461 | .9401 | .9341 | .9281 | .9162 |
| 1.0000 .9939 | .9877 .957 | 71 .9571 | 9509 | 9509 | 9448 | .9202 | .8589 |
| 1 0000 9938 | .9814 .96 | 9565 | .9379 | 9379 | 9379 | .9255 | .9255 |
| 1 0000 9810 | .9684 .96 | 20 9494 | 9494 | .9430 | .9367 | 9304 | 9177 |
| 1 0000 9804 | 9739 97 | 9 9673 | 9608 | .9542 | .9542 | .9477 | .8824 |
| 1 0000 9873 | 9745 95 | 54 9490 | 9490 | .9427 | 9427 | 9299 | 9299 |
| 1 00001 0000 | .9935 .98 | 71 9806 | 9742 | .9677 | .9613. | 9548 | 9484 |
| 1 0000 | 9814 961 | 9627 | 9565 | .9565 | 9441 | 9441 | .9379 |
| 1.0000 .9777 | .9609 .944 | 1 .9274 | .9106 | .8883 | .8715 | .8715 | .8045 |
| 0000 .9944 | .9944 .97 | 9722 | .9722 | 9611 | 9278 | 9222 | 9222 |
| 1 0000 .9948 | .9896 .980 | 6 . 9687 | 9583 | 9531 | .9375 | 9323 | 8802 |
| 1.0000 .9859 | .9484 .94 | 87 .9390 | 9296 | 9249 | .9202 | .9155 | 9014 |
| 1.0000 .9962 | .9658 .94 | 68 .9468 | 9087 | .7985 | .7757 | .7719 | 8555 |
| 1.00001.0000 | .9887 .96 | 52 .9549 | .9511 | .9474 | 9398 | .9361 | .9323 |
| 1.0000 .9754 | .8632 .859 | 6 .8421 | .8386 | .8386 | .8386 | .8386 | .8175 |
| 1.0000 .9840 | .9679 .95 | 9 9359 | .9327 | .9327 | .9135 | 8654 | 8045 |
| 1.0000 .9730 | .9730 .96 | 14 .9614 | 9575 | 9575 | .9537 | .9421 | .8340 |
| | | | | | | | |

 $\left\{ \begin{array}{c} & \\ & \\ & \\ & \\ & \end{array} \right\}$

4

LOAD MODEL DATA FAIRBANKS AREA

ANNUAL PEAK LOAD IN MW (1983-1996)

196. 212. 231. 249. 270. 291. 313. 338. 362. 390. 416. 446. 477. 511.

INTERVAL PEAK LOADS IN P.U. OF ANNUAL PEAK LOAD (26 INTERVALS / YEAR)

 $\substack{\textbf{0.87590.69900.73710.76040.57490.59710.56630.51110.43240.41150.38330.37470.3587}\\ \textbf{0.35380.38080.41770.42010.43730.46190.53190.57490.89190.93370.93491.00000.7690}$

DAILY PEAK LOADS IN P.U. OF INTERVAL PEAK LOAD (260 WEEK DAYS / YEAR)

1.00000.97480.94670.94670.94530.93130.89480.86540.84290.8177 1.00000.93670.92790.92790.90510.89980.88050.85940.82790.7891 1.00000.99330.96670.94830.94000.92330.90330.88000.86670.8267 1.00000.97580.96120.94510.86910.83200.82390.81100.79000/6769 1.00000.98500.98290.95940.95300.94660.91880.90810.90170.8825 1.00000.99790.99590.98770.97940.95880.93620.90530.89300.8827 1.00000.98480.95010.93710.91970.89370.88070.87200.86120.8091 1.00000.96870.96150.95190.93510.91590.88700.88220.87980.8558 1.00000.99150.99150.99150.97160.96870.93180.89200.88920*8693 1.00001.00000.96120.93130.92840.92840.92240.90750.90450.8955 1.00000.99040.99040.94550.92310.91990.91670.91350.87820.8558 1.00000.96720.95410.92790,92460.90490.89840.89510.8787098721 1.00000.96920.96920.95890.95890.94520.94520.93150.92120.9041 1.00000.98960.97220.96870.95830.94790.93400.92360.92010.8507 1.00000.96770.93870.93230.91290.90320.90320.90320.87100.8677 1.00000.87350.87060.86760.86460.85880.84710.84410.83820,8059 1.00000.94440.90640.90640.89470.82750.82750.82460.81870.8012 1.00000.99720.97750.96350.96350.94940.93820.93820.91010.8904 1.00000.99470,96810.93090.92820.90960.90690.90160.88830.8856 1.00000.98850.93300.91450.90990.89610.88910.88450.86370.8568 $1.00000.99150.98080.97650.94020.92950.92740.91880.91450.9017\\1.00000.96690.91180.89260.88840.79890.73970.64460.61020.6088$ 1.00000.97710.91050.90790.90790.89340.88950.88550.86320.8434 1.00000.97110.86330.83050.81870.79630.79240.74510.73320.7201 1.00000.99510.98160.97300.97170.95580.91650.88450.82430.6818 1.00000.99840.93930.92010.89940.88980.88500.84820.81310.7971

LOSS OF LOAD PROBABILITY INDEX $(LOLP)^{\frac{1}{2}}$ FOR STUDY CASES IA & $ID^{\frac{2}{2}}$

| | Anct | norage | Fairbanks | | | | | |
|---------------|--------------------------|-----------------------------|--------------------------|-----------------------------|--|--|--|--|
| Study
Year | Independent
Expansion | Interconnected
Expansion | Independent
Expansion | Interconnected
Expansion | | | | |
| 1984 | 0.0262 | 0.0063 | 0.8193 | 0.0066 | | | | |
| 1985 | 0.0123 | 0.0275 | 0.1446 | 0.0242 | | | | |
| 1986 | 0.0293 | 0.0178 | 0.2868 | 0.0268 | | | | |
| 1987 | 0.0288 | 0.0255 | 0.6766 | 0.0575 | | | | |
| 1988 | 0.0482 | 0.0799 | 0.1140 | 0.0300 | | | | |
| 1989 | 0.0330 | 0.0677 | 0.2318 | 0.0394 | | | | |
| 1990 | 0.0265 | 0.0680 | 0.0593 | 0.0670 | | | | |
| 1991 | 0.0193 | 0.0633 | 0.1550 | 0.0130 | | | | |
| 1992 | 0.0189 | 0.0286 | 0.0276 | 0.0275 | | | | |
| 1993 | 0.0546 | 0.0316 | 0.0586 | 0.0606 | | | | |
| 1994 | 0.0427 | 0.0321 | 0.1583 | 0.1365 | | | | |
| 1995 | 0.0326 | 0.0652 | 0.0373 | 0.0426 | | | | |
| 1996 | 0.0931 | 0.0586 | 0.0899 | 0.1021 | | | | |

 $\frac{1}{2}$ LOLP in days per year.

47. 1 1

 $\left(\right)$

1

 $\left[\right]$

J

) | |}_

4

 $\frac{2}{230}$ kV s/c, 130 MW reserve sharing only.

LOSS OF LOAD PROBABILITY INDEX (LOLP) $\frac{1}{FOR}$

CASE $IB^{2/}$

| | Anct | norage | Fair | rbanks |
|----------------------|--------------------------|-----------------------------|--------------------------|-----------------------------|
| Study
<u>Year</u> | Independent
Expansion | Interconnected
Expansion | Independent
Expansion | Interconnected
Expansion |
| 1984 | 0.0262 | 0.0077 | 0.8193 | 0.0018 |
| 1985 | 0.0123 | 0.0329 | 0.1446 | 0.0096 |
| 1986 | 0.0293 | 0.0220 | 0.2868 | 0.0152 |
| 1987 | 0.0288 | 0.0306 | 0.6766 | 0.0299 |
| 1988 | 0.0482 | 0.0799 | 0.1140 | 0.0300 |
| 1989 | 0.0330 | 0.0677 | 0.2318 | 0.0394 |
| 1990 | 0.0265 | 0.0680 | 0.0593 | 0.0670 |
| 1991 | 0.0193 | 0.0633 | 0.1550 | 0.0130 |
| 1992 | 0.0189 | 0.0359 | 0.0276 | 0.0143 |
| 1993 | 0.0546 | 0.0703 | 0.0586 | 0.0354 |
| 1994 | 0.0427 | 0.0550 | 0.1583 | 0.0654 |
| 1995 | 0.0326 | 0.0991 | 0.0373 | 0.0369 |
| 1996 | 0.0931 | 0.0838 | 0.0899 | 0.0506 |
| | | | | |

 $\underline{1}^{\prime}$ LOLP in days per year.

Ĵ.

Ì

)

 $\frac{2}{}$ 230-kV transmission system with reserve sharing and firm power transfer capability.

LOSS OF LOAD PROBABILITY INDEX $(LOLP)^{\frac{1}{2}}$ FOR CASE IIA²

| | Anct | norage | Fairbanks | | | | | |
|---------------|--------------------------|-------------------------------|--------------------------|-------------------------------|--|--|--|--|
| Study
Year | Independent
Expansion | Interconnected
Expansion3/ | Independent
Expansion | Interconnected
Expansion3/ | | | | |
| 1992 | 0.0189 | 0.0476 | 0.0276 | 0.0972 | | | | |
| 1993 | 0.0546 | 0.0418 | 0.0586 | 0.0299 | | | | |
| 1994 | 0.0427 | 0.0235 | 0.1583 | 0.0244 | | | | |
| 1995 | 0.0326 | 0.0070 | 0.0373 | 0.0089 | | | | |
| 1996 | 0.0931 | 0.0226 | 0.0899 | 0.0207 | | | | |

 $\frac{1}{1}$ LOLP in days per year.

Ţ

l

1

- 2/ Includes interconnections between Devil Canyon-Anchorage (345 kV), Devil Canyon-Watana (230 kV), and Devil Canyon-Ester (230 kV).
- $\frac{3}{}$ Interconnected expansion for three area system: Anchorage, Fairbanks, and Upper Susitna (generation only).



INDEPENDENT SYSTEM EXPANSION PLANS ANCHORAGE AND FAIRBANKS AREAS

- 22

σ

FIGURE 6-2



INTERCONNECTED SYSTEM EXPANSION PLAN ANCHORAGE - FAIRBANKS AREA WITHOUT SUSITNA PROJECT

6 - 23

FIGURE 6-3



σ

24

ANCHORAGE-FAIRBANKS AREA WITH FIRM POWER TRANSFER FIGURE (

П

E 6-4

TERCONNECTED SYSTEM EXPANSION PLAN ANCHORAGE - FAIRBANKS AREA WITH UPPER SUSITNA PROJECT

神

•_____

| 1979 | 1980 | 1981 | 1982 | 1983 | 1984 | 1985 | 1986 | 1987 | 1988 | 1989 | 1990 | 1991 | 1992 | 1993 | 1994 | 1995 | 1996 | 1997 | 19 |
|---|---------------------------------------|-------------------|-------------|---------------------------------------|--------------|---------------------------------------|--|---------------------|--------------|--|--------------|------------|--------------|---------------------------------------|---------------------------------------|--|--|---|----|
| ····· | ······ | -
-
- | | | | | | | | | | | | | | ··· · | · · · · · · · · · · · · · · · · · · · | | |
|) | · · · · · · · · · · · · · · · · · · · | | | | | | · · · · · · · · · · · · · · · · · · · | | | | | | <u></u> | | | -
-
-
-
-
-
- | | | - |
|) | | · | | | | | •••• | | | | | | | | · | · · · · · · · · · · · · · · · · · · · | | | |
| · · · · · · · · · · · · · · · · · · · | | •••• | - | | | | | | | | | | | | ·••
· · · | | | | • |
|) | | | | <u></u> | | | | | | | | ····· | | · | | · | ······································ | | |
|) <u> </u> | · · · · · · · · · · · · · · · · · · · | ··· · | | · · · · · · · · · · · · · · · · · · · | | | + | | | | | | | 1 | · · | | · · · · · · · · · · · · · · · · · · · | | |
| | • | | : <u>1</u> | | | | | | | | | | · · · · · · | | · · · · | · · · · | • • • | | • |
| | 1 | | | · · · · · · · · · · · · · · · · · · · | \sim | | | | | | | | | | | · · · | • · · · · · · · · | | |
|) | UPPER LI | MIT LOA | D FOREC | AST | $\mathbf{>}$ | | | | | +++ +++ | | | | | | ·
· · · · · · · · · · · · · · · · · · · | <u> </u> | | |
|) <u></u> | | | | | | | | | | | | | | | · · · · · · · · · · · · · · · · · · · | · • • • • • • • • • • • • • • • • • • • | ة | faar aan aa aa aa ah | ÷ |
| 1 | | •
• •
• • • | · · · · · · | | 1304 | 1472 | | | | | | | | : | | | . , | - | |
| ····
································· | | | | · · · · · · · · · · · · · | | <u> </u> | 1632 | | | | | | | •
{•- ••••••• | | · •••• | | | ł |
| · · · · · · · · · · · · · · · · · · · | | | | | | | | | | | | | 1 : - | UPP | ER SU | SITNA | PROJ | ECT | ŀ |
| | | | | · · · · · · · · · · · · · · · · · · · | | ANCH 9 - | 78 | 1832 | 1932 | 4 | | | | | · · · · | | | • | |
| • | | •• | | | <u> </u> | | :
:
: | | | \square | | | | · | | | | | |
| * **
 | | ···· ··· | | | | | ANCH IO +104 | | | 2132 | | | | | | · · · · · · · · · · · · · · · · · · · | · · · | · · · | |
|) <u></u>
 : | | | | | | | BELU9 +71 | | | | 2332 | λ | | | · · · · · · · · · · · · · · · · · · · | · · · · · · · · · · · · · · · · · · · | | | |
| | | ···· | | · · · · · · · · · · · · · · · · · · · | | -71 BELU | <u> </u> | COAL 1 +200 | COAL FI +100 | | | 25.52 | 4 | | | | MOST PI | ROBABLE | |
| · · · · · · · · · · · · · · · · · · · | | | | | | -69 NOR | 73 | | | COAL 2 +200 | | | |] | :
: : | \mathbf{X} | •••• | · . | |
|) | | | | | | · · · · · · · · · · · · · · · · · · · | | | -104 ANCH | | [[0]] 3 +20 | a | 2768 | K |] | | <u></u> | · · · · · · · · · · · · · · · · · · · | |
|) <u></u> | -69 NORT 3 | UNIT | DELETIC | IN . | | | | | | | | COAL 4 +20 | | 3004 | | . | | • • • | |
| | | | | | | | | | | | | | WATAN I +235 | | | | | | |
| | 1000 | LESS | LARGEST | UNIT | | | | | | | -69 NORT | 4 | | · · · · · · · · · · · · · · · · · · · | 3240 |] | <u> </u> | | |
| , | | INSTA | LLED CAP | ACITY | | | | | | | | | | WATAN 2 +236 | | 3411 | | | |
| | | IN MW | / | | | | ╸╂┵║╎┸╺╤╫┠┚┾┠╡
╍╬┿╏┽┾╦╿┩╏┠┸┆┸
╺┇┱╹ | | | ┿╋╦┽┶┝┶╎┾╿┿╿
╵╋┿┥╺┿┑┝╋╺┠╛
┥┫┿┥╡╴┊┝╋╺┠╛ | | | 1-200 COAL 5 | | WAIAN 3 7236 | " / | | | |
| | 1200 | INSTA | LLED CA | PACITY | | | | | | | | | -100 COAL F | 1 | | , | - 3753 | | - |
| | AHCH 5 +12 | UNIT A | ADDITIO | N | | | | | | | , | | | -78 PEAKAI
-104 ANCHII | | DVCAN 1 +171 | : / | | - |
| , <u> </u> | | | | | | | | | | | | | | | -300 GEN | <u> </u> | DVCAN 3 +171 | 2024 | |
| , | | | GEND |
 | | | | ┙┙┙┙┙┙
┙┙╸ | | | | | | | 4 | -300 GEN 2 | DU((AH 2 4)7) | DVCAN 4 +171 | / |
| | | | . | • • • • • • • • | | | الباغد المغنا البغا | ا يتصليه الله و و ا | 1444.111.1 | 1 | | i | | ; 1 | · 1 | -100 COALF3 | -78 PEAK A2 | | |

1

6 - 25

FIGURE 6-5



σ t 26



1

FIGURE 6-7

6 - 27

. -



FIGURE 6-8



6 - 29

FIGURE 6-9

CHAPTER 7 FACILITY COST ESTIMATES

CHAPTER 7 FACILITY COST ESTIMATES

7.1 TRANSMISSION LINE COSTS

The transmission line costs were obtained from past and current experience of the Consultants with the design and construction of transmission lines in Alaska. Cost data was escalated to 1979 levels and a factor of 1.46 (AVF = Average Value Factor) was applied to total costs to give an average value for construction in the area. The AVF includes a 10% addition for anticipated difficulty with the constraints associated with the selected line route.

A. Alaskan Experience

Facility cost estimates for alternative transmission intertie designs are based on an in-depth analysis of pertinent Alaskan transmission lines that have been built and are now in successful operation. Analyses were made based on actual experience to develop material and man-hour costs, together with specific installation requirements for structures, conductors, and footing assemblies. In addition, typical right-of-way clearance costs and other costs associated with the solicitation and obtention of right-of-way easements, permits, and environmental reviews were gathered to provide representative costs for estimating component items for the Anchorage-Fairbanks Intertie.

The first Alaskan transmission line capable of operating at voltages as high as 230 kV was the Beluga Line. It was constructed for Chugach Electric Association (CEA) in 1967 by City Electric, Inc. of Anchorage. This line traverses about 42.5 miles of undeveloped land, of which about 65% was muskeg swamp. No roads existed to connect the line right-of-way to any highway or railroad, requiring that access be by water (Cook Inlet -Susitna River), by air (helicopter), or by ORV (off-road vehicle). One major river crossing was required along the transmission line route.

The Beluga Line was constructed of aluminum lattice, X-shape, hinged-guyed towers and Drake (795 kcmil ACSR) conductor by the Contractor. Using one tower assembly yard at Anchorage, the Contractor made extensive use of helicopter delivery of men and materials with ORV equipment during winter weather to construct the line. This project was completed at a cost of about \$50,000 per mile, including right-of-way clearance.

The hinged-guyed, X-shaped tower proved successful and has since been used for the following lines described below.

1. <u>Knik Arm Transmission Line</u> - 230 kV (Aluminum Lattice Towers, 795 kcmil Drake ACSR Conductor), 1975. This line was built using Ownerfurnished material by force account and contract methods. The Owner (CEA) installed the piling and anchors, and contracted for the right-of-way clearing, tower erection, and wire stringing. Piling and anchors were installed using ORV equipment to carry the power tool for installing anchors and the Del Mag-5 diesel hammer and welding equipment for the piling work. City Electric, Inc. accomplished the tower erection and wire stringing using helicopter and ORV equipment.

| Summary of Actual Costs: | <u>\$/Mile</u> |
|--------------------------------|----------------|
| Construction Cost | 87,294 |
| Right-of-way Clearing Cost | 19,049 |
| Right-of-way Solicitation Cost | 7,706 |
| TOTAL (w/o Engineering) | 114,049 |

2. <u>Willow Transmission Line</u> - 115 kV (Tubular Steel Towers, 556.5 kcmil Dove ACSR Conductor), 1978. This line was built by contract using Owner-furnished material. Right-of-way clearing was accomplished by one contractor and line construction by another (Rogers Electric - an experienced Alaska contractor). This line contractor used a vibratory driver to install the 8" H-pile with great success. (This driver has since been used to drive 10" H-pile for another line. In one case, the tool drove a 14" H-pile for a sign support. The contractors are preparing

to drive more 14" piles for a new CEA line.) The introduction of the vibratory pole-driving technique, together with the application of the tubular steel, hinged-guyed, X-tower is expected to realize substantial cost savings on future transmission line projects.

| Summary of Actual Costs: | <u>\$/Mile</u> |
|--------------------------------|----------------|
| Construction Cost | 73,863 |
| Right-of-way Clearing Cost | 10,312 |
| Right-of-way Solicitation Cost | 4,909 |
| TOTAL (w/o Engineering) | 89,084 |

B. Material Costs

The estimated cost for the tower steel, as well as the physical characteristics were obtained from ITT Meyer Industries (Ref. 1). The cost of steel, therefore, has 1979 as the reference year. A 10 percent addition to the material cost was included to account for the 1.46 AVF explained above.

The cost of foundation steel was taken to be \$0.31 per 1b for WG Beam. This value is somewhat conservative, as the current market price is \$0.22 per 1b.

Prices for insulators and conductors have a reference year of 1977; thereafter, the price was escalated at 7 percent per year through 1979. The cost of right-of-way was based on actual average values paid by utilities in the same area as the proposed lines. Other factors used, that provide good indication of projected costs for the transmission line are:

- <u>Terrain Factor</u> This factor is used to correct the number of calculated towers per mile to actual towers per mile.
- <u>Line Angle Factor</u> This factor is used to increase the effective transversal load on the tower, and accounts for the 3⁰ design-angle for the towers.

 <u>Tower Weight Factor</u> - This factor is used to increase the total estimated tower weight, to account for heavy angle and dead-end towers.

C. Labor Costs

Labor costs were obtained from actual construction experience, obtained by the Consultants' construction records for transmission lines built in Alaska. This information included the cost of labor and a detailed breakdown of the man-hours required for every specific task included in the construction program. A multiplier of 2 was applied to the estimated cost of labor for this period, in order to obtain the 1.46 AVF indicated above.

D. Transportation Costs

An estimated unit cost of \$100 per ton was taken to represent the transportation and shipping costs from the Pacific Northwest to the line route staging depot, including loading and unloading (Ref. 2).

7.2 SUBSTATIONS COSTS

For this report, the facility costs for substations were obtained from the U.S. Department of Energy 1978 version of the previous FPC publication "Hydroelectric Power Evaluation" (Ref. 3). As the values included in the publication are list prices, with 1977 as reference year, they were adjusted to 1979 values by using the U.S. Bureau of Reclamation Index (Ref. 4). The cost of the substations includes the shunt compensation, required at both ends, for operation from no-load to full-load. No reactive power (VAR) compensation support from the source generators was considered in this study.
7.3 CONTROL AND COMMUNICATIONS SYSTEM COSTS

Control and communications sytems costs are included in the intertie cost estimates. The system is necessary to provide effective control of power system operations, and economic energy dispatch throughout the interconnected Anchorage-Fairbanks area. The cost estimates include a power line carrier type communications system, a digital supervisory control and data acquisition (SCADA) system, and automatic generation control equipment.

7.4 TRANSMISSION INTERTIE FACILITY COSTS

As previously discussed in Chapter 5, transmission line costs were calculated using TLCAP. Computer printout sheets indicating input data and the calculated results for all five intertie alternatives are shown in Appendix B. Costs for substation facilities and the control and communications system were added to the transmission line costs, thus obtaining the investment cost for the total intertie facilities. A cost summary for each of the five alternatives studied is presented in Table 7-1. Detailed cost estimates and supporting data are included in Appendix D.

7.5 COST OF TRANSMISSION LOSSES

The Transmission Line Optimization Program (TLCAP) for the selection of the optimum span-conductor combination, includes the cost of demand and energy losses for long transmission lines. The loss components are optimized by varying the voltages at the receiving and sending ends. The program assumes 100 percent volt support at both ends. Table 7-2 presents the present worth (1979) costs of calculated transmission line energy and demand losses.

7.6 BASIS FOR GENERATING PLANT FACILITY COSTS

Cost estimates were prepared for all new generating plants (five gasturbine units and five coal-fired steam plants), and associated substation and transmission facilities which will be affected by the transmission interconnection. The costs for the facilities are summarized in Table 7-3.

The most recent cost data and estimates available for both gas-turbine and coal-fired steam plants planned for the Railbelt area was used as a basis for the generating plant estimates. The three principal sources of cost data and information are included in the references at the end of this chapter. The Battelle study report (Ref. 2) provided background information and specific factors to determine applicable Alaskan construction cost location adjustement factors. The Stanley Consultants report to GVEA (Ref. 5) provided detailed cost estimates for both the 104-MW coal-fired plant at Healy and combustion turbines at the Northpole substation in Fairbanks. These estimates were then used to derive reference costs for other gas-turbine and coal-fired units of different capacity at other Railbelt sites. The nomogram developed by Arkansas Power & Light Company (Ref. 6) was used to determine the 100-MW reference cost estimate from reported costs relevant to the 104-MW coal-fired plant at Healy. The same nomogram was then used to determine plant costs for unit ratings of 200 and 300 MW, taking into consideration economies of scale. Subsequently, the Alaskan construction cost location adjustment factors were applied to derive site specific cost estimates.

Cost estimates for the associated transmission facilities were obtained from cost data developed during this study for the transmission intertie, the Stanley Consultants report (Ref. 5), and typical costs experienced in recent Alaskan transmission projects.

The cost estimates and supporting data are contained in Appendix D.

7.7 GENERATING PLANT FUEL COSTS

Benefits in addition to those resulting from generation reserve capacity sharing will result from the supply of firm power over the intertie. An analysis was made of the relative generation costs for both independent and interconnected system expansions to determine the comparative economic advantage of firm power interchange. The fuel cost component of operating expenses is the salient factor which affects the economic comparison of alternative system expansions. Therefore, a year-by-year analysis of alternative modes of generation was completed for each period during which firm power transfer over the intertie is possible, as follows:

| | | · | Tran | smission Interti | e Firm Pow | er Transfer |
|------|------|----------|----------|----------------------------------|----------------------|-----------------------------------|
| From | To | Duration | Capacity | <u>% Power Loss^{1/}</u> | Energy ^{2/} | <u>% Energy Loss^{1/}</u> |
| 1984 | 1987 | 4 yrs. | 30 MW | 6.9 | 145 GWh | 1.05 |
| 1992 | 1996 | 5 yrs. | 70 MW | 6.9 | 337 GWh | 1.05 |

 $\frac{1}{}$ Case IB.

; ...)

 $\frac{2}{}$ Annual Transmission Capacity Factor of 0.55 assumed for analysis.

Fuel costs were estimated utilizing the trend curves from the Battelle report for future natural gas and coal prices in the Railbelt area. The energy loss component of firm power transfer over the intertie was considered, in estimating the total cost of fuel required to generate sufficient energy in one area to displace a block of energy otherwise generated by a local plant in an independently supplied area.

A year-by-year analysis of the comparative cost of generation is given in Appendix D. Table 7-4 summarizes these costs. Although this analysis is germane to the confirmation of salient considerations regarding the economic feasibility of the intertie, this level of study of fuel costs is in no way a definitive substitution for a detailed year-by-year analysis of production costing for the multi-area interconnection.

7.8 MEA UNDERLYING SYSTEM COSTS

The construction of transmission intertie with the intermediate substation at Palmer (Case ID) provides an opportunity for Matanuska Electric Association (MEA) to purchase power at the intermediate substation at Palmer. Information in the System Planning Report (Ref. 8) indicates the following MEA system expansion investment cost for transmission lines and substation facilities with and without the intertie:

| Interconnected System | \$1,356,000 (1987) |
|-----------------------|--------------------|
| Independent System | \$6,646,000 (1987) |
| Independent System | \$2,004,000 (1992) |

The above costs are in 1979 dollars, values were escalated by 10% from 1978 to 1979 level. These values were used in an economic analysis to obtain additional benefits for Case ID.

7.9 CONSTRUCTION POWER COSTS FOR THE UPPER SUSITNA PROJECT

Completion of the transmission interconnection, prior to the development of the Watana and Devil Canyon sites of the Upper Susitna Project will enable the supply of electrical energy for construction power. A temporary wood-pole line to the sites will be supplied from a transmission tap along the intertie route, near the junction of the site access road with the main highway between Anchorage and Fairbanks. Generally, isolated diesel generation is used at such remote hydropower plant sites.

A comparison was made of the relative costs of isolated diesel generation and energy supply to the sites via the tap-line. Table 7-5 shows alternative cost streams through the construction period corresponding to the introduction of the Watana and Devil Canyon units to the interconnected Railbelt generation expansion, shown on Figure 6-5. The construction schedule, as outlined on page 94 of the Interim Feasibility Report (Ref. 7), was followed to establish the time frame for economic comparison of alternative modes of construction power supply. Results of the economic comparison indicate a clear advantage for utilizing the intertie as a source of construction power.

7.10 REFERENCES

- Letter from ITT Meyer Industries to R. W. Retherford Associates, Anchorage, Alaska, January 15, 1979.
- Battelle Pacific Northwest Laboratories, <u>Alaska Electric Power</u>: <u>An Analysis of Future Requirements and Supply Alternatives for the</u> <u>Railbelt Region</u>, March 1978.
- 3. DOE, Federal Energy Regulatory Commission, <u>Hydroelectric Power</u> Evaluation (Final Draft), August 1978.
- 4. U.S. Bureau of Reclamation, "BuRec Construction Costs", <u>Engineering</u> News Record, 22 March 1979.
- 5. Stanley Consultants, <u>Power Supply Study 1978</u>, Review Copy of Report to Golden Valley Electric Association, Inc.
- Power Engineering, "Nomogram calculates economy of scale in power plants", Volume 83, February 1979.
- 7. U.S. Army Corps of Engineers, <u>South-Central Railbelt Area, Alaska</u>, Upper Susitna River Basin Interim Feasibility Report, December 1975.
- 8. Robert W. Retherford Associates, <u>System Planning Report, Matanuska</u> <u>Electric Association</u>, Inc., January 1979.

COST SUMMARY FOR INTERTIE FACILITIES

Ê

i.

(

(

| | | Tot | al Cost a | t 1979 Le | vels (\$10 | 00) |
|----|---|---|---|--|---|---|
| | | <u>Case IA</u> | <u>Case IB</u> | <u>Case IC</u> | <u>Case ID</u> | <u>Case II</u> |
| 1. | Transmission Line: | | | | | |
| | Eng'g. & Constr. Supv.
Right-of-Way
Foundations
Towers
Hardware
Insulators
Conductor | 3,012
8,837
8,445
21,615
477
503
10,761 | 3,012
8,837
8,445
21,615
477
503
10,761 | 4,043
9,080
12,160
33,719
477
755
16,708 | 3,012
8,837
8,445
21,615
477
503
10,761 | 8,079
20,973
22,966
64,088
1,096
1,396
32,886 |
| | Subtotal | 53,650 | 53,650 | 76,942 | 53,650 | 151,484 |
| 2. | <u>Substations</u> :
Eng'g. & Constr. Supv.
Land
Transformers
Circuit Breakers
Station Equipment
Structures & Accessories
Subtotal | 1,352
57
1,703
1,093
1,223
3,628
9,056 | 1,352
57
1,703
1,093
1,223
3,628
9,056 | 1,855
46
3,291
1,323
1,933
3,978
12,426 | 2,816
81
1,703
1,953
1,345
4,026
11,924 | 6,902
185
11,917
6,410
4,375
<u>16,411</u>
46,200 |
| 3. | <u>Control and Communications:</u> | | | | | |
| | Eng'g. & Constr. Supv.
Equipment | 125
<u>2,375</u> | 125
2,375 | 125
2,375 | 165
<u>3,135</u> | 200
3,600 |
| | Subtotal | 2,500 | 2,500 | 2,500 | 3,300 | 3,800 |
| | Total Baseline 1979 Costs | <u>65,206</u> | 65,206 | 91,868 | <u>68,874</u> | 201,484 |

PRESENT WORTH OF INTERTIE LINE LOSSES 1984-1996 STUDY PERIOD $\frac{1}{}$

| Case | <u>\$ x 1000 (1979)</u> |
|--------------------------|-------------------------|
| IA & ID (230 kV) | 10,530 |
| IB (230 kV) | 11,582 |
| IC (345 kV) | 7,341 |
| II A (230 & 345 kV) | |
| Anchorage - Devil Canyon | 28,027 |
| Devil Canyon - Ester | 14,816 > \$49,125 |
| Watana - Devil Canyon | 6,282 |

 $\underline{1}^{\prime}$ Cost of losses, energy, and demand, escalated at 7% per year.

COST SUMMARY FOR GENERATING FACILITIES (Costs at 1979 Levels $\frac{1}{}$)

| | | • | | <u>Installed</u> | Cost | <u> Total Cos</u> | t <u>4/</u> |
|---------------|----------------|--------------------|-----|------------------|--------------|----------------------|--------------|
| Unit Name | <u>Code 2/</u> | Type ^{3/} | MW | Thousand \$ | <u>\$/kW</u> | Thousand \$ | <u>\$/kW</u> |
| Northpole #3 | NORT 3 | SCGT | 69 | 24,385 | 353 | 27,934 | 405 |
| Beluga #9 | BELU 9 | SCGT | 71 | 33,548 | 473 | 42,498 | 598 |
| Northpole #4 | NORT 4 | SCGT | 69 | 24,385 | 353 | 25,185 | 365 |
| Anchorage | PEAK A2 | SCGT | 78 | 22,620 | 290 | 23,400 | 300 |
| Northpole #5 | NORT 5 | SCGT | 69 | 24,385 | 353 | 25,185 | 365 |
| Anchorage #11 | ANCH 11 | Coal | 104 | 99,084 | 953 | 105,636 | 1016 |
| Unit F2 | COAL F2 | Coal | 100 | 130,000 | 1300 | 151,980 | 1520 |
| Unit No. 5 | COAL 5 | Coal | 200 | 200,000 | 1000 | 212,245 | 1061 |
| Unit No. 6 | COAL 6 | Coal | 300 | 274,000 | 913 | 292,250 | 974 |
| Unit No. 2 | GEN 2 | Coal | 300 | 274,000 | 913 | 292,250 | 974 |
| | | | | | | | |

- $\underline{1}^{\prime}$ Investment costs adjusted to January 1979 levels, excluding IDC.
- $\frac{2}{}$ Code name used in MAREL study.
- $\frac{3/}{\text{COAL}}$ SCGT Simple cycle combustion turbine, includes NO removal equipment. COAL Steam turbine, coal-fired with FGD equipment.
- $\frac{4}{1}$ Total cost includes substation and transmission costs.

SUMMARY

0F

ALTERNATIVE GENERATING PLANT FUEL COSTS

1

| \$ 1000 | (Escalated) | |
|---------------------------------|--|---|
| Independent
System Operation | Interconnected System Operation | |
| - | - | |
| 8,468 | 7,648 | 30 MW |
| 9,324 | 8,498 | 145 GWh
Firm Power Transfer |
| 10,267 | 9,029 | |
| · · · | | , |
| 6,851 | 8,324 | |
| 7,212 | 8,654 | |
| 7,933 | 8,016 | 337 GWh
Firm Power Transfer |
| 8,654 | 8,745 | |
| 9,015 | 9,109 | |
| | <u>\$ 1000</u>
Independent
<u>System Operation</u>
-
8,468
9,324
10,267
6,851
7,212
7,933
8,654
9,015 | \$ 1000 (Escalated) Independent
System Operation Interconnected
System Operation - - 8,468 7,648 9,324 8,498 10,267 9,029 6,851 8,324 7,212 8,654 7,933 8,016 8,654 8,745 9,015 9,109 |

ALTERNATIVE COSTS FOR CONSTRUCTION POWER SUPPLY

TO

WATANA AND DEVIL CANYON HYDROPOWER SITES

DURING

CONSTRUCTION OF UPPER SUSITNA PROJECT

| | 1979 Baseline Costs - \$1000 | | |
|------|--|---------------------------------|--|
| Year | Isolated Diesel
<u>Generation at Site</u> | Tapline Supply
From Intertie | |
| 1985 | 2,835 | 267 | |
| 1986 | 695 | 483 | |
| 1987 | 697 | 481 | |
| 1988 | 696 | 478 | |
| 1989 | 3,055 | 752 | |
| 1990 | 1,324 | 902 | |
| 1991 | 187 | 734 | |
| 1992 | 623 | 430 | |
| 1993 | 623 | 419 | |
| 1994 | $-500^{1/2}$ | 304 | |

 $\frac{1}{}$ Negative sign indicates that resale value of generating plant exceeds cost of generation in final year.

FIGURE 7-1



CONSTRUCTION PLAN FOR UPPER SUSITNA PROJECT:

Ref. Interim Feasibility Report - P.94, US Army Corps of Engineers, 12 Dec. 1975

Construction Period for Selected Projects:

Watana Dam - 6 Years Devil Canyon Dam - 5 Years Total Period - 10 Years (1 Year Overlap)

SUGGESTED REVISED SCHEDULE:

Ref. Chapter 6, Figure 6-5

First Unit On-Line at Watana - Beginning Year 1992 Last Unit On-Line at Devil Canyon - End of Year 1996 Period of Overlap in Construction - 2 Years Due to Introduction of First Unit at Devil Canyon in 1994

CHAPTER 8 ECONOMIC FEASIBILITY ANALYSIS

CHAPTER 8 ECONOMIC FEASIBILITY ANALYSIS

An economic feasibility analysis was performed to determine which system expansion plan provides the best use of available resources for supplying electrical power to the Railbelt area. Alternative system expansion plans and facility cost estimates were developed in Chapters 6 and 7. In this chapter, the results of the economic feasibility analysis are presented.

8.1 METHODOLOGY

This economic analysis uses the conventional present-worth model. Annual capital disbursement tables, on a year-by-year basis, were prepared for independent and interconnected system expansion plans. To evaluate these plans on an equal basis all capital disbursements were discounted to the 1979 base year and then totalized for each plan to obtain a single 1979 present-worth value. This approach does not include additional capital disbursements after 1996. Such disbursements will be required later to replace retired facilities. However, the extension of the present-worth model over the whole life of the proposed intertie will not significantly affect the results of this feasibility study. The year 1996 was chosen as the final year of the study period to include the last unit of Upper Susitna Hydropower Project (Devil Canyon Unit No. 4).

Figures 6-2 thru 6-5 in Chapter 6 show that many facility costs for both independent and interconnected system expansion plans do not vary. Therefore, in this economic analysis facility costs for the new generating plants not affected by the introduction of the intertie are eliminated. Also excluded from the analysis are plant fixed operation and maintenance costs. The exclusion of these 0&M costs will somewhat favor the independent system expansion alternatives. Only capital costs are used to evaluate generation reserve capacity sharing benefits. This simplification is based on the assumption that an average operating cost of generation for reserve sharing is approximately the same in the Anchorage and Fairbanks areas. To account for generating plant operating costs with reasonable accuracy, a multi-area production cost study would be needed. The multi-area production cost model simulates an economic dispatching of generating units in the system and computes expected fuel and variable O&M costs based on the energy (MWh) output for each unit, taking into consideration intertie transfer limits. Since such a study is outside the scope of the present work, a somewhat simplified method was used in this feasibility study. It is recommended that a multi-area production cost study be performed at a later time.

8.2 SENSITIVITY ANALYSIS

A computer program was developed by IECO to analyze the sensitivity of different escalation and discount rates on the capital costs of various alternatives. This program, the Transmission Line Economics Analysis Program (TLEAP), provides the following outputs:

- Cost disbursement tables for alternative system expansion plans.
- Discounted cost ratio (independent/interconnected) tables for system expansion alternatives.
- Tables indicating independent minus interconnected system costs.
- Separate tables indicating the discounted value of base year (1979) costs for the independent and interconnected systems.

Computer printout sheets indicating input data and calculated results for all alternatives included in this economic feasibility analysis are found in Appendix E.

8.3 ECONOMIC ANALYSIS

į.

Tables included in this chapter and in Appendix E indicate economic analyses for a range of annual escalation rates of 4% to 12%, and a range of discount rates from 8% to 12%. In the analysis of the results below, a long-term average annual escalation rate of 7% and a 10% discount rate are used. The 10% discount rate is now required by the Office of Management and Budget for federal projects.

A. <u>Benefits due to Generation Reserve Capacity Sharing</u>

Two cases were investigated to determine intertie benefits due to generation reserve capacity sharing alone: the 230-kV single circuit intertie and 345-kV single circuit intertie between Anchorage and Fairbanks. In both cases 130 MW of power transfer capacity was allocated for generation reserve capacity sharing purposes (Cases IA and IC in Chapter 6). The economic analysis results indicate:

| 230 kV | <u>PW (1979 Costs x 1000)</u> | | |
|--------------------------|-------------------------------|--|--|
| Independent Systems | \$406,853 | | |
| Interconnected System | 388,355 | | |
| Benefit | 18,498 | | |
| Less cost of line losses | 10,530 | | |
| Net Benefit | \$ 7,968 | | |

The above results indicate that the 230-kV intertie is economically feasible based on generation reserve capacity sharing only.

| 345 kV | <u>PW (1979 Costs x \$1000)</u> | | | |
|--------------------------|---------------------------------|--|--|--|
| Independent Systems | \$406,853 | | | |
| Interconnected System | 412,338 | | | |
| Benefit | -5,485 | | | |
| Less cost of line losses | -7,341 | | | |
| Net Benefit | \$-12,826 | | | |

The above results indicate that the 345-kV intertie is not economically feasible based on 130 MW power transfer capacity. To analyze the 345-kV intertie with different (higher) power transfer capacities allocated to generation reserve capacity sharing would require development of additional expansion plans and new MAREL studies.

Sensitivity of the results to variations in escalation and discount rates are indicated in Tables 8-1 and 8-2. Computer printouts, indicating cost disbursements, discounted cost ratios, and discounted value tables, are included in Appendix E (Economic Analyses Nos. 1 and 7).

B. <u>Benefits due to Firm Power Transfer and Generation Reserve</u> Capacity Sharing

One case was investigated to determine combined 230-kV intertie benefits due to both firm power transfer and generation reserve capacity sharing (Case IB in Chapter 6). This study case has one 230-kV single circuit line during the 1984-1991 period and two single circuit 230-kV lines during the 1992-1996 period. The economic analysis results indicate:

| | <u>PW (1979 Costs x \$1000)</u> |
|--------------------------|---------------------------------|
| Independent Systems | \$707,534 |
| Interconnected System | 681,364 |
| Benefit | 26,171 |
| Less cost of line losses | 11,582 |
| Net Benefit | \$ 14,589 |

The above intertie benefits can be combined with additional benefits due to supply of construction power to the Upper Susitna Hydropower Project sites (see Section 7.9).

| | PW (1979 Costs x \$1000) |
|--|--------------------------|
| Independent Systems
Interconnected System | \$715,566
685,295 |
| Benefit | 30,271 |
| Less cost of line losses $^{1/2}$ | 12,740 |
| Net Benefit | \$ 17,531 |

The increase in net benefits due to supply of construction power to the Upper Susitna Hydropower Project sites is \$2,942,000 or approximately 20 percent.

Sensitivity of the results to variations in escalation and discount rates are indicated in Tables 8-3 and 8-4. Computer printouts, indicating cost disbursements, discounted cost ratios and discounted value tables, are included in Appendix E (Economic Analyses Nos. 2 and 8).

C. 230-kV Intertie with Intermediate Substations

Two cases were investigated to determine additional benefits due to supply of power to the MEA System at Palmer substation, and construction power to the Upper Susitna Hydropower Project (Case ID, Chapter 6). These cases include a 230-kV single circuit line between Anchorage and Fairbanks (Ester), with intermediate substations at Palmer and Healy. The economic analysis results indicate:

 $\frac{1}{Losses}$ were increased by 10% to account for construction power.

D. Intertie with Upper Susitna Hydropower Project

Only system reliability (MAREL) analyses and facility cost estimates were developed for this alternative system expansion plan (Case II, Chapter 6). The economic feasibility analysis was not performed for this alternative because:

- The methodology of this economic analysis is more appropriate for thermal generation systems. It is not applicable to large mixed hydro/thermal generation systems. A multiarea production cost study, involving extensive analyses of optimum hydro operations in conjunction with thermal plants, would be required to obtain accurate results.
- A draft copy of the Upper Susitna project report prepared by the Alaska Power Administration (Ref. 1) was received by the Consultants in the course of this study. It includes revisions to unit ratings for the Upper Susitna Project used in the MAREL analyses (as described in Chapter 6). The new total installed capacity is 1573 MW, versus the 1392 MW installaed capacity used in development of the expansion plans analyzed in this report.

A study should be performed to accommodate the above revisions to the Susitna power ratings and change to the production economics due to major hydro substitution for thermal energy. The study should examine in detail the economic feasibility of Susitna hydropower, due to the displacement of large increments of thermal power.

For reference, Figure 6-5 in Chapter 6 indicates the initial expansion plan developed for this study. This figure also indicates the thermal generating unit displacement by Upper Susitna Hydropower units. MAREL study results indicate the following intertie requirements for maintaining the study criteria of equal reliability system expansion with introduction of Uppwer Susitna power:

| Period | Requirement |
|-----------|-----------------------------------|
| 1992 | One 345-kV S/C line to Anchorage |
| | Une 230-KV S/C TTHE CO Partbanks |
| 1993 | One 345-kV S/C line to Anchorage |
| | Two 230-kV S/C lines to Fairbanks |
| 1994-1996 | Two 345-kV S/C lines to Anchorage |
| | Two 230-kV S/C lines to Fairbanks |

8.4 REFERENCES

 $\left\{ \begin{array}{c} \\ \end{array} \right\}$

 Alaska Power Administration, <u>Upper Susitna Project Power Market</u> <u>Report</u> (Draft), February 1979.

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIF ECONOMIC FEASIBILITY STUDY

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS (IN \$1000)

| | | | | ESC.
7% | ALATION RA
8% | 1ES
9% | 10% | 11% | 12% |
|---|--|--|--|---|--|--|---|--|---|
| DISCOUNT
RATE
8.00
8.25
8.50
8.75
9.00
9.25
9.50
9.75
10.00
10.25
10.50
10.75
11.00
11.25
11.50
11.75
12.00 | 4%
======
19,512
19,688
19,845
19,845
20,104
20,207
20,295
20,367
20,425
20,469
20,519
20,525
20,521
20,526
20,481
20,446 | 5%
======
18,560
18,825
19,066
19,286
19,483
19,661
19,819
19,959
20,087
20,087
20,087
20,259
20,352
20,413
20,460
20,494
20,515
20,525 | =====
17, 215
17, 584
17, 925
18, 240
18, 529
18, 794
19, 036
19, 256
19, 455
19, 634
19, 794
19, 794
19, 794
19, 794
20, 060
20, 168
20, 260
20, 337
20, 400 | =====
15,417
15,907
16,365
16,791
17,187
17,554
17,894
18,208
18,498
18,498
18,763
19,005
19,226
19,426
19,607
19,768
19,912
20,038 | ======
13,098
13,729
14,322
14,878
15,398
15,885
16,340
16,764
17,158
17,525
17,864
18,178
18,467
18,732
18,975
19,197
19,398 | ======
10,183
10,977
11,727
12,433
13,098
13,724
14,311
14,863
15,380
15,864
16,316
16,738
17,130
17,495
17,834
18,147
18,436 | <pre>======
6,590
7,572
8,502
9,381
10,213
10,998
11,740
12,439
13,098
13,718
14,301
14,848
15,362
15,842
15,842
16,712
16,712
17,103</pre> | 2,226
3,423
4,560
5,639
6,662
7,632
8,550
9,420
10,242
11,019
11,753
12,442
13,098
13,713
14,291
14,834
15,344 | -3,011
-1,567
-193
1,114
2,357
3,537
4,659
5,723
6,733
7,691
8,598
9,457
10,270
11,039
11,766
12,451
13,098 |

5 APRIL 79

ω

9

TABLE 8-1

5 APRIL 79

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONOMIC FEASIBILITY STUDY

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS (IN \$1000)

| | | | | | | TTC | | | |
|----------|--------|---------|--------|-----------|----------|----------|---------|---------|----------|
| DISCOUNT | 4% |
5% | 6% _ | ESC
7% | B% | 9% | 10% | 11% | 12% |
| RATE | ===== | ===== | ====== | ====== | ====== | ===== | 22222 | -27.391 | -33.665 |
| 8 00 | -3.562 | -5,375 | -7,604 | -10,311 | -13,564 | -17,438 | =22,010 | -27/371 | -31,950 |
| 0.00 | -7 187 | -4-899 | -7,016 | -9,594 | -12,698 | -16,400 | -20,781 | -23,932 | - 31,730 |
| 8.25 | -3,105 | -1.149 | -6.459 | -8,912 | -11,872 | -15,409 | -19,602 | -24,550 | -30,300 |
| 8.50 | -2,023 | -4/-47/ | -5.931 | -8.265 | -11,086 | -14,465 | -18,475 | -23,201 | -20,130 |
| 8.75 | -2,488 | -4,024 | -57751 | -7.649 | -10.338 | -13,564 | -17,399 | -21,925 | -21,252 |
| 9.00 | -2,1/1 | = 5,022 | | -7 065 | -9.627 | -12,705 | -16,372 | -20,705 | -25,792 |
| 9,25 | -1,873 | -3,243 | -4,950 | -1,005 | -8.0/19 | -11.887 | -15,392 | -19,539 | -24,414 |
| 9.50 | -1,594 | -2,885 | -4,507 | -0,510 | -0,704 | -11,108 | -14.456 | -18,426 | -23,097 |
| 9.75 | -1,331 | -2,548 | -4,082 | -5,984 | -0,500 | -10. 745 | -13.564 | -17,361 | -21,836 |
| 10.00 | -1,086 | -2,230 | -3,681 | -5,485 | -7,694 | =10,505 | | -16.345 | -20.631 |
| 10 25 | -856 | -1,932 | -3,302 | -5,012 | -7,112 | -9,000 | -12,713 | -15 375 | -19.479 |
| 10.50 | -641 | -1.651 | -2,944 | -4,564 | -6,560 | -8,986 | -11,902 | -13/3/3 | -18.377 |
| 10.30 | - 1/11 | -1.387 | -2,607 | -4,141 | -6,036 | -8,346 | -11,128 | -14,440 | -17 72/ |
| 10.75 | - 75/ | -1.140 | -2.289 | -3,740 | -5,539 | -7,737 | -10,392 | -15,564 | -11,324 |
| 11.00 | -204 | -1,140 | -1,989 | -3.361 | -5,068 | -7,159 | -9,690 | -12,720 | -16,510 |
| 11.25 | -80 | -909 | -1 708 | -3,003 | -4.621 | -6,610 | -9,022 | -11,916 | =15,358 |
| 11.50 | 80 | -695 | -1,700 | -2 665 | -4.198 | -6,088 | -8,386 | -11,149 | -14,440 |
| 11.75 | 229 | -491 | -1,445 | | -7708 | -5.592 | -7,781 | -10,417 | -13,564 |
| 13 00 | 367 | -302 | -1,195 | -2,54/ | - 3, 170 | | | | |

8 - 10

TABLE 8-2

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONOMIC FEASIBILITY STUDY

DIFFERENTIAL DISCOUNTED VALUE OF BASE YFAR (1979) COSTS INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS (IN \$1000)

| | FSCALATION RATES | | | | | | | | 127 |
|---|---|---|---|---|---|--|---|---|--|
| DIRCOUNT | // % | 5% | 6% | 7% | 8% | 9% | 10% | 114 | ====== |
| DISCOUNT
RATE
R.00
R.25
8.50
R.75
9.00
9.25
9.50
9.75
10.00
10.25
10.50
10.75
11.00
11.25
11.50 | 4%
=====
27,096
27,259
27,400
27,519
27,617
27,695
27,754
27,795
27,820
27,828
27,821
27,799
27,764
27,715
27,655
27,655
27,583 | 5%
=====
26,190
26,456
26,695
26,908
27,096
27,259
27,400
27,519
27,618
27,697
27,757
27,800
27,826
27,836
27,831
27,811 | 6%
=====
24,824
25,212
25,567
25,891
26,185
26,450
26,687
26,899
27,086
27,250
27,511
27,611
27,611
27,691
27,753
27,797 | 7%
=====
22, 926
23, 456
23, 948
24, 402
24, 820
25, 557
25, 557
25, 879
26, 171
26, 434
26, 671
26, 883
27, 070
27, 234
27, 376
27, 497 | 8%
=====
20,414
21,110
21,760
22,367
22,932
23,456
23,943
24,808
25,189
25,539
25,859
26,149
26,649
26,860
26,860 | 9%
======
17,198
18,086
18,921
19,705
20,440
21,127
21,770
22,370
22,929
23,448
23,930
24,376
24,788
25,167
25,515
25,833
26,123 | 102
======
13,177
14,288
15,337
16,325
17,257
18,133
18,957
19,731
20,457
21,136
21,772
22,366
22,919
23,434
23,911
24,354
24,763 | =====
8,242
9,608
10,902
12,127
13,285
14,379
15,412
16,387
17,306
18,171
18,984
19,749
20,466
21,138
21,767
22,355
22,903 | 2,268
3,927
5,503
6,998
8,417
9,761
11,035
12,241
13,382
14,460
15,479
16,440
17,347
18,201
19,005
19,760
20,470 |

5 APRIL 79

- 11

ω

5 APRIL 79

.

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONUMIC FEASIBILITY STUDY

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS (IN \$1000)

| | | | | FSC | ALATTON RA | TFS | | | ***** |
|----------|--------|--------|--------|---------|------------|----------|--------|--------|--------|
| DISCOUNT | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 112 | 12% |
| RATE | ====== | ===== | ===== | ====== | ===== | ====== | ===== | ===== | ====== |
| 8 00 | 30.913 | 30.276 | 29,194 | 27,595 | 25,399 | 22,515 | 18,844 | 14,275 | 8,685 |
| 8 25 | 31.014 | 30,476 | 29,511 | 28,050 | 26,015 | 23,319 | 19,865 | 15,546 | 10,243 |
| 8 50 | 31,094 | 30.649 | 29.796 | 28,467 | 26,586 | 24,070 | 20,824 | 16,746 | 11,720 |
| 0,50 | 71,153 | 30,798 | 30.051 | 28,848 | 27,115 | 24,771 | 21,725 | 17,878 | 13,117 |
| 0.15 | 71 102 | 30,922 | 30,278 | 29,195 | 27.604 | 25,425 | 22,571 | 18,945 | 14,440 |
| 9.00 | 71 212 | 21.02/ | 30,477 | 29.509 | 28,053 | 26,033 | 23,363 | 19,950 | 15,689 |
| 9.20 | 71 21/ | Z1 10/ | 30,650 | 29.793 | 28,466 | 26,597 | 24,104 | 20,895 | 16,870 |
| 9.50 | 31,214 | 74 14/ | 20 708 | 30.046 | 28,844 | 27.120 | 24.796 | 21,783 | 17,985 |
| 9.75 | 51,199 | 31,104 | 70 077 | 20 271 | 29,188 | 27.604 | 25.442 | 22,617 | 19,035 |
| 10.00 | 51,169 | 31,204 | 30,923 | 20 / 70 | 29,500 | 28,049 | 26.042 | 23,398 | 20,025 |
| 10.25 | 51,125 | 51,225 | 31,023 | 70 4/0 | 277 300 | 28, //58 | 26.601 | 24.130 | 20,957 |
| 10.50 | 31,063 | 51,229 | 51,106 | 30,042 | 70 077 | | 27,118 | 24.813 | 21.833 |
| 10.75 | 30,990 | 31,216 | 31,166 | 50,791 | 30,033 | | 27,110 | 25.451 | 22.655 |
| 11.00 | 30,903 | 31,188 | 31,208 | 30,916 | 50,250 | 29,174 | | 237931 | 22,033 |
| 11.25 | 30,805 | 31,144 | 31,231 | 31,019 | 30,455 | 29,483 | 20:031 | 20,043 | 231421 |
| 11.50 | 30,695 | 31,086 | 31,236 | 31,100 | 30,628 | 29,165 | 28,445 | 20,041 | 24/147 |
| 11.75 | 30,575 | 31,015 | 31,226 | .31,162 | 30,777 | 30,014 | 28,814 | 27,110 | 24,824 |
| 12.00 | 30,444 | 30,932 | 31,199 | 31,205 | 30,902 | 30,238 | 29,154 | 21,585 | 20,455 |

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONOMIC FEASIBILITY STUDY

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS (IN \$1000)

| | | | | ESC | ALATION RA | TES | ********* | | |
|----------|--------|--------|--------|--------|------------|--------|-----------|--------|--------|
| DISCOUNT | 4% | 5% | 6% | 7% - | 8% | 9% | 10% | 11% | 12% |
| RATE | ====== | ====== | ===== | 233222 | ===== | ====== | | 222322 | ===== |
| 8.00 | 21,225 | 20,637 | 19,694 | 18,339 | 16,509 | 14,133 | 11,132 | 7,418 | 2,896 |
| 8.25 | 21,319 | 20,810 | 19,960 | 18,715 | 17,014 | 14,787 | 11,958 | 8,443 | 4,149 |
| 8.50 | 21,397 | 20,962 | 20,202 | 19,062 | 17,483 | 15,399 | 12,736 | 9,412 | 5,337 |
| 8.75 | 21,458 | 21,095 | 20,420 | 19,381 | 17,920 | 15,973 | 13,469 | 10,328 | 6,464 |
| 9.00 | 21,503 | 21,209 | 20,616 | 19,673 | 18,324 | 16,509 | 14,157 | 11,193 | 7,531 |
| 9.25 | 21,534 | 21,305 | 20,790 | 19,939 | 18,699 | 17,009 | 14,804 | 12,008 | 8,541 |
| 9.50 | 21,551 | 21,385 | 20,943 | 20,180 | 19,044 | 17,475 | 15,410 | 12,777 | 9,496 |
| 9.75 | 21,554 | 21,448 | 21,078 | 20,399 | 19,361 | 17,908 | 15,978 | 13,501 | 10,400 |
| 10.00 | 21.545 | 21,496 | 21,193 | 20,595 | 19,652 | 18,310 | 16,509 | 14,181 | 11,253 |
| 10.25 | 21,525 | 21,529 | 21,291 | 20,770 | 19,918 | 18,682 | 17,005 | 14,821 | 12,058 |
| 10.50 | 21,493 | 21,548 | 21,372 | 20,924 | 20,159 | 19,025 | 17,467 | 15,421 | 12,817 |
| 10.75 | 21,450 | 21,555 | 21,438 | 21,060 | 20,378 | 19,342 | 17,897 | 15,983 | 13,532 |
| 11.00 | 21,398 | 21,549 | 21,488 | 21,177 | 20,574 | 19,632 | 18,296 | 16,509 | 14,205 |
| 11.25 | 21,336 | 21,531 | 21,523 | 21,277 | 20,750 | 19,897 | 18,666 | 17,001 | 14,837 |
| 11.50 | 21,265 | 21,502 | 21,545 | 21,360 | 20,905 | 20,138 | 19,007 | 17,459 | 15,431 |
| 11.75 | 21,185 | 21,462 | 21,554 | 21,427 | 21,042 | 20,357 | 19,322 | 17,886 | 15,988 |
| 12.00 | 21,098 | 21,413 | 21,551 | 21,479 | 21,161 | 20,554 | 19,611 | 18,282 | 16,509 |

5 APRIL 79

ALASKA POWER AUTHORITY ANCHURAGE - FAIRBANKS INTERTIE ECUNOMIC FEASIBILITY STUDY

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS (IN \$1000)

| | | | | ESC | ALATION RA | TES | | | |
|----------|---------|--------|---------|--------|------------|--------|--------|---------|--------|
| DISCOUNT | 42 | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| RATE | ====== | ===== | ===== | ====== | ===== | | 14 708 | 13.451 | 9.313 |
| 8 00 | 25.042 | 24,722 | 24,063 | 23,008 | 21,494 | 19,450 | 10,170 | 1/1 791 | 10.465 |
| 0.00 | 25,074 | 24.829 | 24,259 | 23,309 | 21,918 | 20,019 | 17,554 | 14,301 | 101405 |
| 0.20 | 257077 | 2/ 916 | 24.431 | 23,582 | 22,309 | 20,548 | 18,224 | 15,250 | 11,004 |
| 8.50 | 23,090 | 24/710 | 24 581 | 23.828 | 22.668 | 21,039 | 18,869 | 16,079 | 12,585 |
| 8,75 | 25,091 | 24,900 | 24, 301 | 20.048 | 22,996 | 21,494 | 19,472 | 16,853 | 13,554 |
| 900 | 25,078 | 25,036 | 24,109 | 24,040 | 24 206 | 21.915 | 20.034 | 17,579 | 14,469 |
| 9,25 | 25,051 | 25,070 | 24,817 | 24,243 | | 22,302 | 20.557 | 18,260 | 15,332 |
| 9.50 | 25,011 | 25,089 | 24,906 | 24,410 | 23,307 | | 21.043 | 18.897 | 16,143 |
| 9.75 | 24,958 | 25,092 | 24,976 | 24,566 | 23,812 | 221037 | 21/042 | 10,493 | 16.906 |
| 10 00 | 24.895 | 25,081 | 25,029 | 24,696 | 24,032 | 22,905 | 21,474 | 20 048 | 17.623 |
| 10.00 | 2/1-820 | 25.057 | 25,066 | 24,805 | 24,228 | 23,285 | 21,911 | 20,040 | 14 205 |
| 10.25 | 24,020 | 25,020 | 25.087 | 24,895 | 24,401 | 23,553 | 22,296 | 20,500 | 10,293 |
| 10.50 | 24,135 | | 25,093 | 24.968 | 24,552 | 23,797 | 22,649 | 21,047 | 18,924 |
| 10.75 | 24,041 | 24,911 | | 25.023 | 24.682 | 24,017 | 22,974 | 21,494 | 19,513 |
| 11.00 | 24,531 | 24,910 | 25,004 | | 2/1.793 | 24.213 | 23,270 | 21,907 | 20,063 |
| 11.25 | 24,425 | 24,839 | 25,065 | 25,001 | | 24.386 | 23,539 | 22,289 | 20,575 |
| 11.50 | 24,305 | 24,757 | 25,029 | 25,084 | 24,000 | 24,000 | 22,783 | 22.640 | 21,052 |
| 11.75 | 24,177 | 24,666 | 24,982 | 25,093 | 24,959 | 24,000 | | 22,962 | 21.494 |
| 12.00 | 24,042 | 24,500 | 24,925 | 25,087 | 25,015 | 24,009 | C4,002 | 201702 | |

5 APRIL 79

8 - 14

TABLE 8-6

CHAPTER 9 FINANCIAL PLANNING CONCEPTS

CHAPTER 9 FINANCIAL PLANNING CONCEPTS

The approach taken in this study towards the financial planning for the intertie facilities represents the preliminary conceptual structuring of the ultimate financial package needed to implement the Railbelt transmission system expansion on a progressive basis. This approach seeks to be demonstrative of the methodology employed, rather than an attempt to arrive at specific recommendations. The acceptance of debt allocations by participants to the Alaskan Intertie Agreement (AIA) will require individual financial positions to be evaluated, prior to negotiations on specific portions of the total debt for which a particular participant will ultimately agree to sign. Therefore, what follows is an initial exploration of possible financial arrangements, and will serve as a starting point for successive evaluations by each potential participant to the AIA.

9.1 SOURCES OF FUNDS

An initial appraisal of viable sources of funds has been made to determine the combination which will represent the most financially advantageous terms and also will reflect the projected allocation of financial responsibility that may be acceptable to each of the participants.

The following principal sources were examined:

- State of Alaska revenue bonds floated by APA.
- REA loans negotiated by APA and participants.
- CFC loans negotiated in conjunction with REA loans.
- FFB loans negotiated by APA and participants.
- Municipal bond issues by Anchorage and Fairbanks.

The conditions under which each of the above sources would be negotiable are dependent upon the ability to generate revenue to make repayment.

A. State of Alaska Revenue Bonds

Of these sources, the issue of State of Alaska bonds would require the most complex formula for revenue generation, to arrive at an acceptable agreement to ensure complete payback through time on a steady cash flow basis. It is thought that the issue of State bonds should be deferred from present consideration, until such time as a combined generation and transmission project is ready for funding. Within the confines of the Railbelt development, this would be appropriate when consideration is given to the financing of the first hydropower development of the Upper Susitna Project, together with its associated transmission facilities. Accordingly, although programmatic inclusion of APA bonds is retained in the Transmission Line Financial Analysis Program (TLFAP), for present analytical purposes, consideration has been given only to the remaining sources for analysis of initial financial plans for the intertie. The transmission intertie facilities represent what may be regarded as the first stage development of the ultimate transmission system that will be required for the Watana and Devil Canyon hydropower plants of the Upper Susitna Project. Only the financial sources discussed in the following sections were then considered for initial funding of the Anchorage-Fairbanks Interconnection.

B. <u>Rural Electrification Administration (REA)</u>

The principal participants, with the exception of the Anchorage and Fairbanks municipal systems, are all REA utilities of the Alaska District. Therefore, REA funding is assumed for the maximum amount of total project financial requirements. In accordance with REA stipulations, the loan ceiling is normally 70 percent of total project costs. Thus, a maximum of the full amount under the 70 percent ceiling was considered for the prime source of funds, at an interest rate of 5 percent over a repayment period of 35 years.

Although not considered at this first level of financial planning, REA also makes guaranteed loans, which normally are made for prevailing interest rates of the order of 8-1/2 percent.

OMB restrictions are expected to reflect through future REA commitments for project funding. Therefore, with the large capital outlay necessary for the intertie, it may be necessary to consider alternative sources of supplementary capital to structure a complementary loan package for the project. The Consultants have accordingly considered the CFC and FFB as part of financial contingency plans.

C. National Rural Utilities Cooperative Finance Corporation (CFC)

The CFC makes loans to REA utilities to supplement REA funds, with loans that are currently carrying an interest rate of 8.75 percent, with a repayment period of 35 years. To structure a loan package for the balance of project costs, CFC funds would be drawn on to the extent justifiable under the primary criteria of providing the most advantageous overall financial terms.

D. Federal Finance Bank (FFB)

The FFB also provides supplementary funding, complementary to CFC as a financial source, with loans that bear interest at a higher rate than that to be obtained from CFC. Currently, the interest rate for FFB loans is 9.375 percent for project funding, with a repayment period of 35 years.

E. Municipal Bonds

Anchorage and Fairbanks municipalities both have the authority to arrange financing for a portion of the project by the issuance of tax-exempt, general obligation bonds. For purposes of analysis, the interest rate was assumed to be 7.5 percent under prevailing market conditions, with a maturity period of 35 years. These terms are to be construed as conservative under present market conditions. In practice some measure of improvement can be anticipated depending upon prevailing economic and financial considerations at the time of entry to the bond market. For purposes of illustration, a final interest rate of 7.25 percent was assumed to simulate the progressive improvement of terms anticipated for this project.

Thirty percent of the total project costs are assumed to be funded by municipal bonds, which is deemed reasonably reflective of the participation of the municipal systems in the Alaskan Intertie Agreement. It also is the complementary portion of total project costs that would meet the ceiling of the maximum REA loan available to member utilities.

9.2 PROPORTIONAL ALLOCATIONS BETWEEN SOURCES

In the ultimate financial package for the transmission intertie, the final negotiated amounts for debt financing and bonding will be agreed to by APA and AIA participants. To arrive at the proportional allocation of total project costs between possible sources will require protracted effort on the part of APA and AIA participants, in the successive negotiations with REA and other federal funding agencies, together with the officials responsible for decisions relating to issuance of municipal bonds.

To assist with an evaluation of financial positions in relation to possible agreement on resolution of questions pertaining to proportional allocations between sources, the Consultants offer the following approach for initial consideration:

- REA funds would be used to the limit of the normal 70 percent ceiling, as a proportion of project costs. If due to budgetary restraints REA is not amenable to funding the full proportion, supplementary loans would be sought from a combination of CFC and FFB.
- The balance of funding, 30 percent of projects costs, would be obtained through a joint issue of general obligation bonds, by the municipalities of Anchorage and Fairbanks.

In preparing a financial plan to follow this approach the following analysis was completed using computer programs TLFAP and COMPARE.

- An initial run of TLFAP was made with the following allocations and assumptions for funding terms and conditions:
 - 70% funding by REA loan, at 5% interest rate.
 - 30% funding by general obligation municipal bonds, with equal division of obligation between Anchorage and Fairbanks. A conservative rate of 7.5% was assumed for this issue.
 - 35-year repayment period for both sources.
- 2. On the assumption that REA funds would have to be supplemented by loans arranged jointly with CFC and FFB, an analysis was made of a 20% portion of the total REA allocation, to illustrate the capability of minimizing total financial obligations through judicious combinations within the package. This was accomplished using program COMPARE, which derives the present value of future payments for up to three loan sources under varying loan terms. To simplify the procedure, a similar repayment period of 35 years was assumed with base case and sensitivity runs, as follows:
 - Equal division 10/10% between CFC and FFB, with interest rates of 8.75% and 9.375%, respectively.
 - Sensitivity runs of <u>+</u>5% for both CFC and FFB, in converse proportion, at the same interest rates.
- The best of the three test-cases, selected on the basis of least present value to borrower, was then substituted in TLFAP, with the following modifications to previous input of 1. above.
 - 50% allocation to REA funding @ 5% interest rate.
 - 20% source allocation; divided between CFC and FFB according to the results of the COMPARE analysis:
 - 15% of total by CFC loan at 8.75% interest rate
 5% of total by FFB loan at 9.375% interest rate

This combination results in the lowest present value of the three alternative divisions, presented on Sheets F-7, F-8 and F-9 of Appendix F.

 30 % source allocation to municipal bonds at an improved interest rate of 7.25%, to indicate possible positive offset to the higher composite rate resulting from the combination of loans from CFC and FFB.

The results of this analysis are contained in Appendix F.

9.3 ALLOCATED FINANCIAL RESPONSIBILITY FOR PARTICIPANTS

A. Basis for Assumption of Financial Obligation

Once the source allocations are determined, the next step involving discussions, evaluations, and negotiations between the participants is the determination of the allocated responsibility for debt assumption and subsequent service over the repayment period. The approach followed was to match percentage of total funds to the AIA participants on the basis of service jurisdictions, potential benefits from facilities, and a certain judgement in relation to the acceptability, or otherwise, of certain allocations to individual participants. A degree of tokenism was also judged to be appropriate at this initial stage, to allow for minimum funding participation by utilities without major generating plants.

This enables all utilities, that are directly affected by the interconnection to take a major or minor share of the responsibility for debt service of the total facility costs in support of the project.

The only utility which is not an immediate direct beneficiary of the intertie is CVEA. Although TLFAP contains a provision for later participation by this utility, it is not anticipated that CVEA will exercise this option prior to the connection of the Glennallen-Valdez system to the intertie, at or before completion of the first stage development of the Upper Susitna Project.

B. Allocation of Total Project Costs

Table 9-1 provides a division of total project costs on a percentage basis and a subsequent allocation between participants. This preliminary set of debt service allocations was used for the financial planning projections contained in Appendix F. These may be used by individual participants as a starting point for their own analysis and evaluation of the impact of their assumed obligation on their own financial operations.

The allocation of costs was aided by considering the logical division of the total facility into three sections:

| From | To | <u>Distance (Miles)</u> |
|-----------|---|--|
| Anchorage | Palmer | 40 |
| Palmer | Healy | 191 |
| Healy | Ester | 92 |
| | <u>From</u>
Anchorage
Palmer
Healy | <u>From</u> <u>To</u>
Anchorage Palmer
Palmer Healy
Healy Ester |

The costs included in Table 9-1 pertain to Case ID transmission facilities, single-circuit 230 kV transmission line with intermediate switching at Palmer and Healy. This also allows the realization of investment participation by MEA in the AIA to the extent indicated in Table 9-1. Although the benefits of the interconnection are more indirect for HEA, a small percentage participation in the intertie project is included for this utility.

C. Effect of Sinking Fund on Total Revenue Requirements

In evaluating the revenue requirements for each participant to the AIA, the cumulative effect of the municipal bond sinking fund on the allocated debt repayment should be noted. The total revenue required from each participant is indicated on pages F-8, F-9, and F-10 and F-19, F-20, and F-21 of Appendix F, and includes both debt service and sinking fund payments over the 35-year period, to full loan amortization and bond maturity.

9.4 FINANCIAL PLAN FOR STAGED DEVELOPMENT

The following is intended as one possible view of future plans for financing successive expansions and extensions of the initial interconnection of Railbelt utilities.

A. Interconnection Extension between Systems

The implementation of the Anchorage-Fairbanks Transmission Intertie will cause Railbelt utilities to examine their system expansions in relation to those of other utilities, to determine mutual benefits of additional transmission facilities to firm ties between adjacent systems. The cost of associated facilities could be financed on a comprehensive basis, possibly on more advantageous terms than if attempted by individual utilities or municipalities. The cost of such additions to utility systems could be met from a revolving fund administered by APA, on behalf of the participants.

One possibility for application of major funds for system extension would be the interconnection of the CVEA system to the Anchorage end of the intertie. The participation of CVEA in the AIA would then be desirable, with possibly a token allocation, prior to the determination of the timing and cost of the facilities to link the initial interconnection with the CVEA system at Glennallen. This could be implemented on a separate basis, or as part of an integrated plan for the transmission system associated with the development of Susitna hydropower.

B. Expansion of a Susitna Transmission System

The implementation of the Susitna Hydropower Project would require that a comprehensive financial plan be followed for funding the generation project and associated transmission facilities. The large increments of firm power possible from the Susitna development would require the expansion of the initial intertie, to receive the energy blocks for transmission to Anchorage and Fairbanks.

As part of the comprehensive financial plan, the funding of transmission line and substation facility expansion through time could be arranged on the basis of total incremental funding, with partition of costs and financial obligations between participants, on a similar basis to that used for this initial approach to first stage financing of the transmission system interconnection via the Railbelt.

9.5 REFERENCES

- 1. International Engineering Company, Inc. Financial Planning Model
- 2. Moody's Bond Record

'Tax Exempt Bond Yields by Ratings'
'Tax Exempts Vs. Governments and Corporates'

January 1979

TABLE 9 - 1

ALLOCATION OF TOTAL PROJECT COSTS BETWEEN PARTICIPANTS TO ALASKAN INTERTIE AGREEMENT A I A

SECTIONAL INTERCONNECTION DIVISIONS

| | Anchorage | | Palmer | | Healy | | Ester | | |
|--------------------------|-----------|-------------|------------------|-----------------|-----------------|-------------|------------|----------|--------|
| | . 1. | Section I | | Section II | | Section III | | | |
| · · · | | 40 M | | 191 M | I . | 92 M | | | |
| INTERTIE COMPONENTS | | | PROJECT COSTS | - 1979 \$1000 (| (%) | | | TOTAL FA | CILITY |
| Transmission Line | | 6644 (10) | | 31,726 (46) | | 15,282 (22) | | 53,652 | (78) |
| Substations: | | | | | | | | | |
| Anchorage | 3976 (6) | | | | | | | 3,976 | (6) |
| Palmer | | | 717 (1) 717 (1) | | | | | 1,434 | (2) |
| Healy | | | | | 717 (1) 717 (1) | | | 1,434 | (2) |
| Ester | | | | | · | | 5,080 (7%) | 5,080 | (7) |
| Control & Communications | | 1,450 (2) | | 400 (1) | | 1,450 (2) | | 3,300 | (5) |
| TOTAL | · . | 12,787 (19) | , | 33,560 (49) | | 22,529 (32) | | 68,876 | (100) |
| AIA PARTICIPANTS | | <u>H</u> | LLOCATIONS OF TO | TAL PROJECT COS | STS (%) | | | | |
| AM&LP | | (5) | | (10) | | | | | (15) |
| CEA | | (10) | | (20) | | | | | (30) |
| НЕА | | (1) | | | | | | | (1) |
| MEA | | (3) | | | | | | | (3) |
| CVEA | | | | (9) | | (27) | | | (36) |
| FMUS | | | | (10) | | (5) | | | (15) |

9 - 10

.

. -----

[
CHAPTER 10 INSTITUTIONAL CONSIDERATIONS

CHAPTER 10 INSTITUTIONAL CONSIDERATIONS

The Intertie Advisory Committee has proven itself most useful during this study. It has enabled initial discussions to be held between potential participants in the projected interconnection of Railbelt utilities via the Anchorage-Fairbanks Transmission Intertie. This committee represents a sure, first step towards the formation of a continuing, viable, cohesive entity, through which the intertie can be built and the resulting benefits realized by the continued expansion and operation of the interconnected utility systems in the Railbelt.

10.1 PRESENT INSTITUTIONS AND RAILBELT UTILITIES

The predominant pattern of ownership management and operating responsibility by public power organizations in Alaska is exemplified by the prospective participants to an Alaskan Intertie Agreement (AIA). In addition to REA and municipal utilities in the Railbelt, it is anticipated that both the Alaska Power Administration and the Alaska Power Authority would be parties to the AIA. The probable composition of institutions and participating utilities is anticipated to be:

Alaska Power Authority

Anchorage Municipal Light and Power

• Chugach Electric Association, Inc.

Homer Electric Association, Inc.

Matanuska Electric Association, Inc.

Golden Valley Electric Association, Inc.

Fairbanks Municipal Utility System

Alaska Power Administration

The above group of utilities may be joined by Copper Valley Electric Association, Inc. at a later date, to extend the interconnected facilities to the Glennallen-Valdez system.

A. Statutes and Limitations

The enabling legislation for the Alaska Power Authority (APA) is contained in HB 442 for the Legislature of the State of Alaska. It provides for the establishment of power projects and the authorization to proceed with developments that will serve "to supply power at the lowest reasonable cost to the state's municipal electric, rural electric, cooperative electric, and private electric utilities, and regional electric authorities, and thereby to the consumers of the state, as well as to supply existing or future industrial needs".

APA would mainly act on behalf of the municipal and rural electric utilities as a party to the AIA. Therefore, it is not presently anticipated that the authorized "powers to construct, acquire, finance, and incure debt" would be required for the Intertie Project. Rather APA could integrate and coordinate the efforts of the other participants to the AIA, to ensure that an expeditious approach is maintained during the course of the project.

APA is in an excellent position to coordinate regional programs with its state-wide involvement. For example, such coordination may assist in the process of securing an abridgement of the two county rule for the transmission intertie. Left unresolved, such existing statutes may otherwise constitute a roadblock to the realization of the benefits to be achieved by interconnection of systems of participating utilities over the large geographical area encompassed.

B. Jurisdiction and Service Territories

The Alaska Power Authority exercises jurisdiction over power projects in Alaska as a State entity. It parallels the Alaska Power Administration, which has federal jurisdiction in Alaska for the United States Department of Energy in Washington, D.C.

Both State and Federal entities have statewide responsibility in Alaska.

10 - 2

The service territories of the municipal and rural electric utilities are shown on the maps of Figures 4-1, 4-2, and 4-3 in Chapter 4. The confines of the Railbelt result in elongated geographical service areas. Such areas are particularly appropriate in relation to the transmission corridor for the intertie and enable the delineation of easements along the route to be made relative to existing transmission and distribution facilities in the area.

10.2 ALASKAN INTERCONNECTED UTILITIES

To provide an identity for the utility participants to the AIA, it is suggested that the name Alaskan Interconnected Utilities (AIU) be adopted by the existing Railbelt utilities to be included in the institutional and management plan for the implementation and operation of the intertie.

A. Present Arrangements and Future Requirements

To a certain extent, the operating utilities in the Anchorage and Fairbanks areas have already evolved mutual interests. These interests now need to be augmented, to satisfy future operating requirements.

Prior to interconnection, there would be a need to coordinate revised planning for system expansion, the scheduled construction of facilities, and the separate building programs of each utility. A Planning Subcommittee of the Intertie Advisory Committee, composed of technical staff from AIU, would be desirable in the near future if this program is implemented. This planning subcommittee could be empowered to resolve joint planning problems affecting participating members.

Later on, an Operating Subcommittee would be required to determine operating procedures and coordinate system planning policy, working towards centralized economic dispatch for the interconnected system. The need for improved communications facilities will also need to be addressed, together with the mode of overall system control and data acquisition for interconnected facilities.

10 - 3

B. Evolution of Institutional Framework

In any approach toward projecting institutional requirements for the establishment of the necessary framework to support the Anchorage-Fairbanks Transmission Intertie, it is essential to preserve a sense of perspective towards the future and allow for the possibility of integrating the presently conceived plans and concepts within a larger and more comprehensive institutional structure. This is particularly appropriate to the task of system interconnection, when successive expansions are necessary to accommodate the incremental additions associated with major generating plants.

In the case of the Railbelt, the possible implementation of the major hydropower developments of the Upper Susitna Project, would require that the institutional structure required for the transmission intertie be compatible with future institutional needs of the Susitna developments. Thus, whatever institutional changes would be brought about by a program of hydropower development of the Susitna should represent only a transition between organizational requirements keyed to transmission system expansion without the impact of the Susitna developments and with the addition of major hydropower sources, such as Watana and Devil Canyon.

The evolutionary approach to effecting this transition is preferable over an abrupt change of institutional structures and it is thought that with the acceptance of a pattern of multiple participation in the planning, financing, implementation, and operation of the Intertie, a suitable mode of proportionate involvement can also be considered for applicability to other transmission facilities required for the Susitna Project. This division of fiscal and managerial responsibility can also be extended into the operation of the system.

In this way a maximum of local utility participation can be achieved, with a financially beneficial allocation of total project costs between funding sources to arrive at a least financial cost package to multiple borrowers having pre-arranged sharing of debt-service obligations.

10 - 4

10.3 REFERENCES

- Battelle Pacific Northwest Laboratories, <u>Alaska Electric Power</u>: <u>An Analysis of Future Requirements and Supply Alternatives for</u> <u>the Railbelt Region</u>, March 1978.
- 2. University of Alaska, Institute for Social and Economic Research, <u>Electric Power in Alaska 1976-1995</u>, August 1976.
- 3. House Bill 442 in the Legislature of the State of Alaska, Finance Committee, Tenth Legislature - Second Session.

APPENDIX A NOTES ON FUTURE USE OF ENERGY IN ALASKA

APPENDIX A

NOTES ON FUTURE USE OF ENERGY IN ALASKA

Power requirements studies analyzing historical data and forecasting future trends have been regularly accomplished for the REA-financed electric utilities in Alaska since they began operation. These studies and their forecasts over the years provide an interesting perspective as to the changes in use of electricity and the change in numbers of users, but do not fully account for the forces that produce these changes.

It is observed that electrical uses increase as the dreary, manual routines of everyday life are displaced by the equivalent electrically-powered devices. This allows the human effort to be directed elsewhere or eliminated. Electric lighting, water pumping (many Alaska homes have their own water systems) and heating, clothes washing, refrigerator, freezer, vacuum cleaner, dishwasher, cooking aids, radio and TV (education and recreation), lawn mower, chain saw, etc., all direct electrical energy toward improving the quality of life and making human effort more productive.

The typical Alaskan family is becoming more productive as a unit through an increasing percentage of the family partners entering the community group of wage earners. Increasing income allows the family to seek out new means of improving the quality of living.

There are on the horizon a number of technological triumphs that will undoubtedly find uses in those communities where the families can assign some of their resources to enhancing their lives. The home computer with its implications of many more "robots" to come and the electric car are just two of such items nearing the scene.

These considerations certainly support the trends of electrical energy use that are being forecast and could well result in the forecasts being exceeded, if the rising standards of Alaskan life are maintained into the future.

The following paragraphs are a direct excerpt from a system planning report (see Ref. 7 in Section 3) completed in early 1979 for the Matanuska Electric Association, Inc. of Palmer, Alaska. This electric system is the oldest REA-financed system in Alaska and the statistics cited which relate the use of electrical energy to the average family earnings over a period of 35 years of actual history and a forecast of 15 to 25 years are interesting indeed.

***INTRODUCTION**

The accomplishment of long-range planning requires that data be estimated for future conditions and that technical answers for those conditions be evaluated in a prudent manner. Technical answers to a defined set of conditions can be readily developed using state-of-the-art methods. An occasional set of conditions prompts innovation when conventional methods appear limited; but, it is demonstrably clear that the <u>estimate of future</u> <u>conditions</u> is the single most significant factor affecting the ultimate value of a long-range plan.

It will be noted in the following System Planning Report a great effort was made to provide <u>accurate and detailed historical data</u>. A better understanding of the nature of electrical consumers and their actual performance amidst the set of observed environmental restraints (political and natural) is bound to be enhanced by such data. It is believed that forecasts of future conditions will also benefit in sufficient measure to make the effort a bargain.

A - 2

^{*} Excerpted from MEA System Planning Report, January 1979 - see Chapter 3, Ref. 7.

The understanding of a long-range plan in the context of the whole growth of a community or region and in terms more useful to the consumer of electricity and his representatives is believed extra difficult today because of environmental concerns, high inflation and other cost aberrations.

To provide some perspective that is intended to illuminate the broad impact and position of the MEA electric supply system on its service area a tabular listing of significant MEA statistics is included herewith on the following page, Table A-1.

This table contains the 35-year history of MEA and a 20-year forecast based on the data in the Long-Range Plan. The numbers listed may surprise the reader at first inspection but this simple listing of historic factual data and related future estimates serves to demonstrate the powerful influence of electricity on the quality of life and the productivity of the MEA service area.

A - 3

| Year | Ave. No.
Served
Average
kWh/Mo. | Ave. No.
<u>(w/o LP)</u>
Average
kWh/Mo. | Miles
of
Line
Dist. Trans. | Const.
Per
Mile
Dist. | Ave. Cost
Purch.
Power
\$/kWh | Average
Revenue
Total Sales
\$/kWh | Average
Revenue
(w/o LP)
\$/kWh | Average
Bill/Const.
(w/o LP)
\$/Mo. | Average
Family
Income
\$/Mo. | Portion
of
Income
Percent |
|--|--|---|-------------------------------------|--------------------------------|--|---|--|--|---------------------------------------|------------------------------------|
| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) |
| 1942 | <u>210</u>
142 | $\frac{188}{47}$ | <u>90</u>
0 | 2.3 | 0.020 | 0.0628 | 0.1074 | 5.07 | 175 | 2.9 |
| 1954 | <u>1401</u>
533 | <u>1393</u>
335 | $\frac{313}{0}$ | 4.5 | 0.0196 | 0.0450 | 0.0531 | 17.82 | 590 | 3.02 |
| 1966 | <u>3134</u>
951 | <u>3113</u>
694 | <u>708</u>
63 | 4.4 | 0.0114 | 0.0348 | 0.0366 | 25.40 | 885 | 3.9 |
| 1977 | 9434
1578 | <u>9352</u>
1318 | <u>1430</u>
97 | 6.6 | 0.0128 | 0.0359 | 0.0368 | 48.50 | 2248 | 2.4 |
| an a | | | | | See Foot | notes | | | | |
| Level I
('82-85') | <u>16693</u>
2100 | $\frac{16510}{1785}$ | <u>2212</u>
241 | 7.5 | 0.0187 | 0.0546 | 0.0559 | 99.78 | 3303 | 3.02 |
| Level II
('87-'92) | <u>30510</u>
2799 | <u>30060</u>
2488 | <u>2705</u>
269 | 11.3 | 0.0348 | 0.0692 | 0.0705 | 175.30 | 4853 | 3.60 |
| Level III
('92-'99) | <u>55744</u>
3714 | 54956 | $\frac{3041}{293}$ | 18.3 | 0.0488 | 0.0829 | 0.0837 | 292.45 | 7131 | 4.10 |

MEA STATISTICAL SUMMARY - PAST, PRESENT AND FORECAST

The basic historical data was taken from the REA From 7. Each column is explained as follows:

- (1) The year of operation MEA first energized its system on January 19, 1942. Level I, II, and III refer to the Load Levels of the December 1978 Long Range Plan. The years in parenthesis are estimated dates when these levels might be reached.
- (2) The total average number of consumers with LPs and their average monthly energy (kWh) use.
- (3) The average number of consumers (w/o LPs) and their average monthly energy (kWh) use.
- (4) Miles of line at year end.
- (5) Average number of consumers served per mile of distribution line Columns (2) divided by Column (4).
- (6) Cost of purchased power at Levels I, II and III these are estimates developed by RWR from miscellaneous sources. These forecast are believed to be consistent with other elements of the forecast.
- (7), (8), and (9) For levels I, II and III the figures resulted from a generalized forecast of costs using the investments indicated by the Long Range Plan escalated at 7% per year, the operating costs per consumer escalated @ 7% per year and the purchased power costs of Column (6). It was also assumed that there would be 10% losses of energy and that MEA margins would be 10% of Gross Revenue.
- (10) The estimated average family income is developed from old payroll records, the "Statistical Abstract of the U.S." (Public by Bureau of the Census) 1977, and "The Alaska Economy, Year-End Performance Report 1977" (Published by Alaska Department of Commerce and Economic Development). Future income estimates made by escalating 1977 numbers at 1.08 per year which is the approximate average growth rate of income for the last 35 years.
- (11) Column (9) divided by Column (10) multiplied by 100.

TABLE A-1

APPENDIX B TRANSMISSION LINE COST ANALYSIS PROGRAM (TLCAP)

APPENDIX B

TRANSMISSION LINE COST ANALYSIS PROGRAM (TLCAP)

B.1 GENERAL DESCRIPTION

The Transmission Line Cost Analysis Program (TLCAP) calculates the installation, operation, and maintenance costs of a transmission line using a detailed unit cost model. It also automatically determines the "optimum" span and conductor size combination. Applications include the following:

- Voltage Selection TLCAP examines the relative economics of various voltage levels.
- <u>Span and Conductor Optimization</u> Span and conductor are optimized simultaneously to provide a matrix of present worth costs.
 Sensitivity of present worth costs to assumed discount rate is also automatically included.
- <u>Tower Type Selection</u> TLCAP compares the cost impact of alternate tower types.

B.2 COMPUTER PROGRAM APPLICATIONS FOR OPTIMUM TRANSMISSION LINE COSTS

Choosing the most economical voltage level and other line parameters for any projected transmission line is a complex problem. It requires the simultaneous consideration of a multitude of interrelated factors, each of which will have a decided influence on line performance and the installed and operational costs of both the line and the overall system. The installed cost of a line increases rapidly with the voltage used. For typical single-circuit ac lines, the cost increase is approximately in direct proportion to the increase in voltage. On the other hand, the load carrying capacity of a line increases with the square of the voltage,

but this is partially offset by the increase in phase spacing and the resultant increase of line impedance.

Another factor affecting the load carrying capacity and line cost is the size of the conductor and the number of conductors per phase. Since the installed cost of the conductors may constitute as much as 28% of the total line cost, the selection of the conductor is an important decision in any line design.

For EHV lines, conductor size selection is first governed by two basic electrical requirements - the current carrying capacity and the corona performance in terms of corona loss radio interference (R.I.) and television interference (T.V.I.). As the line voltage increases, the corona performance becomes more and more the governing factor in selecting conductor size and bundle configuration.

If consideration is given to the electrical aspects alone, there is an optimum solution as to the size and number of conductors for each voltage level and load carrying requirement. However, the size of the conductor affects the loads on the structures supporting it, as well as the sag, tension, span length, and tower height and weight. All such factors influence the total cost and economics of the line. Hence, both the electrical and mechanical aspects must be considered together in order to arrive at a truly optimized overall line cost. Often a solution which is entirely satisfactory from the electrical viewpoint alone will be in conflict with the mechanical requirements. This is particularly true at locations where heavy ice loading is encountered. For example, a small conductor in a bundle of three may meet all the electrical requirements but may be entirely unsatisfactory mechanically due to excessive sag and overstress. This results in higher towers or shorter spans with more towers per unit length of line than would a larger conductor in a bundle of two. A large number of conductor and phase configurations must usually be tried before an optimum solution is found for a specific voltage level.

The voltage level for any given line should be chosen on the basis of its effect on the system to which it will be connected. This may require medium- or long-range estimation of load flow. For example, it may be more advantageous to build a single 750-kV line instead of two 400-kV lines. Each solution has its own impact on the system with respect to reliability, stability, switching over-voltages, transfer of power, and possibly the cost of future expansion. In other words, the line should be custom designed to meet present and future needs of the system within which it is to operate. It should also provide for the lowest overall cost in terms of investment and operation. Without proper attention to future needs, the "lowest initial cost solution" for a line between two given points may not necessarily be the most desirable or satisfactory one.

In addition to the variables mentioned above, there are numerous other line parameters that must be considered to properly evaluate and compare the various solutions. A few of the more important ones are:

- Conductor material, size, and stranding.
- Tower types, such as rigid or guyed, single or double-circuit, ac or dc, metal or wood.
- Foundation costs.
- Wind and ice load criteria, and their effect on tower cost through transverse, vertical, broken-wire, and/or construction loads.

Number and strength of insulators.

Insulator swing and air gap.

Applicable material and labor costs.

Investment charges, demand, and annual energy loss charges.

To accurately assess all the complexities and interrelationships, and to integrate them into a totally coordinated design that will produce a line of required performance at minimum cost, a carefully engineered computer program was developed by IECO. Program methodology of TLCAP is shown on Figure C-1. Briefly, program elements include:

TRANSMISSION LINE COST ANALYSIS PROGRAM (TLCAP)

METHODOLOGY



- <u>Conductor Selection</u> A large variety of conductor sizes and strandings are on file for automatic use by the program. Depending upon line voltage and load, the program determines the minimum power and energy losses for each conductor studied.
- Insulation Selection The program calculates the incremental cost differences caused by changes in the insulator length, which together with other studies of system performance indicates the best insulation for each voltage level. To ensure maximum transmission capacity, the minimum possible phase spacing is used with each type of tower, considering clearance to tower steel and insulator swing.
- Tower Selection and Span Optimization The installed cost of towers represents a large portion of the total line cost. Therefore, this item is given special and careful consideration in the calculations. The installed cost of a tower is usually a function of the weight of the steel used. A considerable difference in weight between different tower configurations can be experienced, even in cases where the loads are identical. If to this variable, the variations in loads due to conductor size, bundling, and climatic criteria are added, it becomes evident that correct tower weights can only be determined by an actual tower design in which all the variables are properly considered. Therefore, the optimization program is complemented with a tower design program. Appropriate foundation and insulation costs are added to each tower solution to obtain the total installed cost per tower location. This information is then used by the optimization program to determine the optimum span length (the span that results in the lowest tower cost per unit length of line) for each conductor configuration being considered.

In processing these criteria, including a present worth evaluation of annual energy loss and other time-related charges, the optimization pro-

gram arrives at a long-range minimum cost solution for each voltage level investigated. However, as previously mentioned, the final evaluation of the adequacy of a line should be based upon its present and future effect on the system as a whole. Therefore, the lowest cost solution for a select number of conductor configurations, with their specific electrical characteristics, should be tried in a few additional system study runs to obtain a proper basis for a final decision.

B.3 TLCAP SAMPLE OUTPUTS

Sample outputs of the TLCAP computer program are shown on the following pages. The output cases are listed below:

- Anchorage Fairbanks, 230 kV (Case IA).
- Anchorage Fairbanks, 230 kV (Case IB).
- Anchorage Fairbanks, 345 kV (Case IC).
- Anchorage Devil Canyon, 345 kV (Case II-1).
- Devil Canyon Ester, 230 kV (Case II-2A).
- Watana Devil Canyon, 230 kV (Case II-3A).

INTERNATIONAL ENGINEERING CO. INC SAN FRANCISCO CALIFORNIA

TRANSMISSION LINE COST ANALYSIS PROGRAM VERSION 1: 23 FEB 1979,

ANCHORAGE-FAIRBANKS INTERTIE CASE IA 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION DATE: 12 APR 79 TIME: 9:29:47

B-7

•

| × | * | × | × | * | × | ¥ | * | × | × | × | ¥ | ¥ | * | * | * | * | × |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| × | | | | | | | | | | | | | | | | | * |
| × | | | | I | N | Ρ | U | T | | Ð | A | Ţ | A | | | | * |
| * | | | | | | | | | | | | | | | | | * |
| * | * | × | * | × | * | * | * | * | * | × | * | * | * | × | * | × | * |

| SYSTEM FOONDMIC FACTORS | INPUT VALUE | REFERENCE YEAR FOR INPUT |
|--|--|--------------------------------------|
| | | |
| STARTING YEAR OF STUDY
ENDING YEAR OF STUDY
BASE YEAR FOR ESCALATION
MAXIMUM CIRCUIT LOADING
AVERAGE CIRCUIT LOADING
DEMAND COST FACTOR
ENERGY COST FACTOR
VAR COST FACTOR | 1979
1996
1977
136.8 MVA
41.0 MVA
73.0 \$/KW
13.0 MILLS/KWH
0.0 \$/KVAR | 1992
1992
1979
1979
1984 |
| CAPITAL COST/DISCOUNT RATE:
MINIMUM
MAXIMUM
NUMBER OF INTERVALS
O&M COST FACTOR
RIGHT OF WAY COST FACTOR
RIGHT OF WAY CLEARING COST
INTEREST DURING CONSTRUCTION
FNGINEFRING FEF | 7.0 PERCENT
10.0 PERCENT
1
1.5 % CAP.COST
715.0 \$/ACRE
1430.0 \$/ACRE
0.00 % INST.CST
11.00 % INST.CST | 1984
1984
1979
1979
1979 |

| * * * * | * * | ** | * * | ** | ¥ | * * | * | b ± |
|---------|-----|-----|-----|-----|---|-----|-----|------------|
| ¥ | | | | | | | | * |
| * | IN | ΡU | T | DA | T | A | | * |
| * | | | | | | | | * |
| *** | * * | * * | *.* | * * | × | * * | * 1 | * * |

| CONDUCTOR 1 | ΔΤΑ | GROUNDWI | RE DATA | SPAN DATA | | | | | |
|---|--|--|-------------------------------|--------------------------------|----------------------------------|--|--|--|--|
| NUMBER PER PHASE
CONDUCTOR SPACING
VULTAGE
VULTAGE VARIATION
LINE EREQUENCY | 1
0.0 IN
230 KV
10.00 PCT
60 CPS | NUMBER PER TOWER
Diameter
Weight | 0
0.00 IN
0.0000 LBS/FT | MINIMUM
Maximum
Interval | 1200. FT
1600. FT
100.0 FT | | | | |

B-8

FAIRWEATHER LOSSES

LINE LEAGTH

POWER FACTOR

| WEATHER DATA | | | | | | | | | |
|--------------|------------------|--------------|--|--|--|--|--|--|--|
| | | | | | | | | | |
| MAXIMUM | RAINFALL RATE | 1.18 IN/HR | | | | | | | |
| махтичн | RAINFALL DURATIO | N 1 HRS/YF | | | | | | | |
| AVERAGE | RAINFALL RATE | 0.03 IN/HR | | | | | | | |
| AVERAGE | RAINFALL DURATIO | N 636 HRS/YF | | | | | | | |
| MAXIMUN | SNOWFALL RAIE | 1.87 IN/HR | | | | | | | |
| MAXIMUM | SNOWFALL DUPATIO | N 1 HRS/YF | | | | | | | |
| AVERAGE | SNOWFALL RATE | 0.13 IN/HR | | | | | | | |
| AVERAGE | SNOWFALL DURATIO | N 264 HRS/YF | | | | | | | |
| RELATIVE | AIR DENSITY | 1.000 | | | | | | | |

0.00 KW/MI

323.00 MILES

0,95

| **** | ***** | ***** | * * * |
|---------|-------|-------|-------|
| * | | | * |
| * | INPUT | DATA | * |
| * | | | * |
| * * * * | ***** | ***** | * * * |

SAG/TENSION DESIGN FACTORS

| EVERYDAY STRESS TEMPERATURE | 40. DEGRE | ES F | ICE AND WIND TENSION (PCT UTS) | 50. PERCENT |
|-----------------------------------|------------|------|--------------------------------|-----------------|
| ICE AND WIND TEMPERATURE | 0. DEGRE | ES F | HIGH WIND TENSION (PCT UTS) | 50, PERCENT |
| HIGH WIND TEMPERATURE | 40. DEGRE | ES F | EXTREME ICE TENSION (PCT UTS) | 70. PERCENT |
| EXTREME ICE TEMPERATURE | 30. DEGRE | ES F | ICE THICKNESS WITH WIND | 0.50 INCHES |
| MAX DESIGN TEMP FOR GND CLEARANCE | 120, DEGRE | ES F | WIND PRESSURE WITH ICE | 4,00 LBS/SQ.FT. |
| EDS TENSION (PCT UTS) | 20, PERCE | NT | HIGH WIND | 9.0 LBS/SQ.FT. |
| NESC CONSTANT | 0.31 LBS/F | T | | |
| | | | EXTREME ICE | 0.50 INCHES |

TOWER DESIGN -----

| TOTAL NUMBER OF PHASES | 3 | DISTANCE BETWEEN PHASES: | |
|--------------------------------|-----------------|--------------------------|----------|
| PHASE SPACING | 20.0 FEET | D1 | 20.00 FT |
| CONDUCTOR CONFIGURATION FACTOR | 1.02 | 02 | 20.00 FT |
| GROUND CLEARANCE | 28.0 FEET | 03 | 40.00 FT |
| NO. OF INSULATORS PER TOWER | 48 | D4 | 0.00 FT |
| INSULATOR SAFETY FACTOR | 2,50 | D5 | 0.00 FT |
| STRING LENGTH | 6,5 FEET | D6 | 0.00 FT |
| I, VEE, OR COMBINATION | 3 | | |
| FOUNDATION TYPE | 4 | | |
| TERRAIN FACTOR | 1.06 PER UNIT | | |
| LINE ANGLE FACTOR | .0864 | | |
| TOWER GROUNDING | 0 | | |
| TRANSVERSE OVERLOAD FACTOR | 2,50 | | |
| VERTICAL OVERLOAD FACTOR | 1.50 | | |
| LONGITUDINAL LOAD | 1000. LBS | | |
| MISCELLANEOUS HARDWARE WEIGHT | 0.11 TONS/TOWER | | |
| TOWER WEIGHT FACTOR | 1.02 | | |

TOWER WEIGHT ESTIMATION ALGORITHM

1.1

TOWER TYPE 9: 230KV TOWER

TW = 0.00016*TH**2 = 3.09797*TH**0.3333 = 0.08943*FFFVDL = 0.27367*EFFTDL + 0.00510*TH*EFFTDL + 0.00160*TH*EFFVDL + 18.37912 KIPS

CONDUCTOR SUMMARY

| | | | | | | | | TEMP.CUEF. | |
|-----------|----------|-----------|----------------------|-------------------------|-----------------------|------------------------|------------------------|------------------------|--|
| ID NUMBER | NAME | SIZE(KCM) | STRANDING
(AL/ST) | UNIT WEIGHT
(LBS/FT) | OUT.DIAM,
(INCHES) | TOTAL AREA
(SQ.IN.) | MODULUS
(EF7E6 PSI) | ALPHA★E≖6
PER DEG F | |
| | | ******** | | | ******* | ******* | ********** | ********* | |
| 24 | GROSBEAK | 636.0 | 26/7 | 0.8750 | 0,9900 | 0.5809 | 11.00 | 10.3 | |
| 25 | EGRET | 636.0 | 30/19 | 0,9880 | 1.0190 | 0.6134 | 11.30 | 9.7 | |
| 26 | FLAMINGO | 666.0 | 24/7 | 0,8590 | 1.0000 | 0.5914 | 10,55 | 10.7 | |
| 27 | GANNET | 666.0 | 26/ 7 | 0.9180 | 1,0140 | 0.6087 | 11.00 | 10.3 | |
| 28 | STILT | 715.0 | 24/7 | 0,9210 | 1.0360 | 0.6348 | 10.55 | 10.7 | |
| 29 | STARLING | 715.0 | 26/ 7 | 0,9850 | 1.0510 | 0.6535 | 11.00 | 10.3 | |
| 30 | REDWING | 715.0 | 30/19 | 1.1110 | 1.0810 | 0.6901 | 11.30 | 9.7 | |
| - 31 | сиской | 795.0 | 24/ 7 | 1.0240 | 1.0920 | 0.7053 | 10,55 | 10.7 | |
| 32 | DRAKE | 795.0 | 26/ 7 | 1,0940 | 1.1080 | 0,7261 | 11.00 | 10.3 | |
| 33 | TERN | 795.0 | 45/ 7 | 0.8960 | 1,0630 | 0.6676 | 9.40 | 11.5 | |
| 34 | CONDOR | 795.0 | 54/ 7 | 1.0240 | 1.0930 | 0,7053 | 10.85 | 10.9 | |
| 35 | MALLARD | 795.0 | 30/19 | 1,2350 | 1,1400 | 0.7668 | 11.30 | 9.7 | |
| 36 | RUDDY | 900.0 | 45/ 7 | 1.0150 | 1.1310 | 0.7069 | 9,40 | 11.5 | |
| 37 | CANARY | 900.0 | 54/7 | 1,1590 | 1.1620 | 0.7985 | 10.85 | 10.9 | |
| 38 | RAIL | 954.0 | 45/ 7 | 1.0750 | 1.1650 | 0.8011 | 9,40 | 11.5 | |
| 39 | CARDINAL | 954.0 | 54/ 7 | 1.2290 | 1.1960 | 0.8464 | 10.85 | 10.9 | |

B-10

e

| * | | | | | \$ |
|---------|-----|-----|------|---------|----|
| * | INP | UT | DAT | A | 1 |
| * | | | | | \$ |
| * * * * | *** | *** | **** | * * * * | \$ |

CONDUCTOR SUMMARY

LO DEDICT

| | NAME | ULT.TENS.
STRENGTH(LBS) | GEOM.MEAN
RADIUS(FT) | PRICE(\$/LB) | THERM.LIMIT
(AMPERES) | AT 25 DEG C
(OHMS/MILE) | IND.REACT.
(OHMS/MILE) | CAP.REACT.
(MOHM-MILES) |
|---|---|--|--|--|---|--|--|--|
| ID NUMBER
24
25
26
27
28
29
30 | NAME
GROSHEAK
FGRET
FLAMINGO
GANNET
STILT
STARLING
REDWING
CUERDO | 25000.0
31500.0
23700.0
26200.0
25500.0
28100.0
34600.0 | 0.0335
0.0351
0.0355
0.0343
0.0347
0.0355
0.0372
0.0366 | PRICE(\$/LB)
0.628/1977
0.609/1977
0.640/1977
0.609/1977
0.608/1977
0.608/1977
0.612/1977
0.636/1977 | (AMPERES)
790.
870.
810.
820.
840.
850.
860.
900. | 0.1452
0.1447
0.1399
0.1373
0.1320
0.1294
0.1288
0.1214 | 0.4118
0.4060
0.4118
0.4092
0.4066
0.4050
0.3992
0.3992 | 2.6347
2.0136
2.6294
2.6347
2.6400
2.6453
2.5661
2.5502 |
| 31
32
33
34
35
36
37
38
39 | CUCKOU
DRAKE
TERN
CONDOR
MALLARD
RUDDY
CANARY
RAIL
CARDINAL | 31200.0
32900.0
28500.0
38400.0
25400.0
32300.0
26900.0
34200.0 | 0.0375
0.0352
0.0368
0.0392
0.0374
0.0392
0.0374
0.0392
0.0385
0.0404 | 0.622/1977
0.677/1977
0.635/1977
0.599/1977
0.676/1977
0.633/1977
0.671/1977
0.632/1977 | 910.
890.
900.
910.
935.
950.
970.
990. | 0.1172
0.1188
0.1172
0.1162
0.1082
0.1040
0.0998
0.0987 | 0.3992
0.4060
0.4007
0.3928
0.3928
0.3928
0.3928
0.3949
0.3902 | 2,5450
2,5766
2,5555
2,5186
2,5080
2,5027
2,5027
2,4816 |

B-11

* * INPUT DATA * *

| UNIT MATERIALS COSTS | INPUT | VALUE | REFERENCE YEAR FOR INPU |
|------------------------------------|---------|-----------|-------------------------|
| ***** | ***** | | ***** |
| PRICE OF TOWER MATERIAL | 0.957 | \$/LB | 1979 |
| PRICE OF CONCRETE | 0.00 | \$/CU.YD. | 1977 |
| PRICE OF GROUND WIRE | 0.000 | \$/LB | 1977 |
| INSTALLED COST OF GROUNDING SYSTEM | 0.00 | \$/TOWER | 1977 |
| TOWER SETUP | 1751. | \$ | 1979 |
| TOWER ASSEMBLY | 0,455 | \$/LB | 1979 |
| FOUNDATION SETUP | 0. | \$ | 1979 |
| FOUNDATION ASSEMBLY | 4140.00 | \$/TON | 1979 |
| FOUNDATION EXCAVATION | 0.00 | \$/CU.YD. | 1979 |
| PRICE OF MISCELLANEOUS HARDWARE | 290.00 | \$/TOWER | 1977 |

UNIT LABOR COSTS

| REFFRENCE YEAR LABOR COST | 24.00 \$/MANHOUR | 1979 |
|---------------------------|------------------|------|
| STRING GROUND WIRE | 0.0 S/MILE | 1977 |
| STRING LABOR MARKUP | 4.2 PER UNIT | |

UNIT TRANSPORTATION COSTS

| • • • • • • • • |
· . | | | • · · . | | |
|---------------------|---------|--------|----|---------|---|--|
| HARDWARE | 100.0 | \$/TON | | •.• | ÷ | |
| INSULATOR | 100.0 | \$/TON | OR | \$/M**3 | | |
| GROUND WİRE | 100.0 | \$/10N | | | | |
| CONDUCTOR | 100.0 | \$/TON | | | | |
| FOUNDATION STEEL | 100.0 | \$/TON | | | | |
| FOUNDATION CONCRETE | 100.0 | \$/YD | | | | |
| TOWER | 100.0 | \$/10N | | | | |
| | | | | | | |

B-12

•

| * * * | * * | * * 1 | * * | ** | * * * | t A 3 | (★ ★ : | * * 1 | 1 8 1 | *** | 1 1 | K # 1 | A A | * # | **1 | * * | 1 |
|-------|------------|--------------|-----|---------------------------|---------------------|---------------------------|-------------------------------|-----------------------------------|---|---|---|---|---|---|--|--|--|
| | | | | | | | | | | | | | | | | | \$ |
| A | υT | OM/ | A T | IC | CC | INC | JUC | TOF | 2 5 | SEL | EC | T I | 10 | Ν | | | 1 |
| | | ALL | - | លប | ANT | 'IT | IE: | SF | PEF | 1 5 | IIL | .E | | | | | * |
| | | | | | | | | | | | | ۰. | | | | | \$ |
| * * * | #`# | * * 1 | * * | ** | * * * | ** | ** | *** | *** | *** | * | * * * | * * | * * | ** | k * | # |
| | • * *
A | AUT | | AUTOMAT
AUTOMAT
ALL | AUTOMATIC
ALL QU | AUTOMATIC CC
All QUANT | AUTOMATIC CONC
ALL QUANTIT | AUTOMATIC CONDUC
ALL QUANTITIE | AUTOMATIC CONDUCTOR
ALL QUANTITIES F | AUTOMATIC CONDUCTOR S
ALL QUANTITIES PER | AUTOMATIC CONDUCTOR SEL
ALL QUANTITIES PER M | AUTOMATIC CONDUCTOR SELEC
ALL QUANTITIES PER MIL | AUTOMATIC CONDUCTOR SELECT
ALL QUANTITIES PER MILE | AUTOMATIC CONDUCTOR SELECTIO
ALL QUANTITIES PER MILE | AUTOMATIC CONDUCTOR SELECTION
ALL QUANTITIES PER MILE | AUTOMATIC CONDUCTOR SELECTION
ALL QUANTITIES PER MILE | AUTOMATIC CONDUCTOR SELECTION
ALL QUANTITIES PER MILE |

CAPITAL COST/DISCOUNT RATE OF 7.00 PERCENT

PRESENT WORTH

| COND | JCTOR | | | | INSTALLED COST | | | LINE LOSSES | ORM COST | LINE COSI |
|------|-------|----------|-----------|----------------|----------------|---------|----------|-------------|----------|-----------|
| NO. | KCM | SPAN(FT) | MATERIALS | TRANSPORTATION | INSTALLATION | ENG/IDC | SUBTOTAL | SUBTOTAL | SUBTOTAL | TOTAL |
| | | | ******** | | ********* | | | ****** | | |
| 34 | 954. | 1300. | 68147. | 3834. | 84796. | 9328, | 166104. | 32600. | 3284. | 201988. |
| 35 | 795. | 1300. | 64664 | 3721. | 82616. | 9088. | 160089. | 39120. | 3151. | 202359. |
| 35 | 795. | 1400. | 65375. | 3684 | 82031. | 9023. | 160113. | 39120. | 3161. | 202394. |
| 37 | 900. | 1300. | 67299. | 3772. | 84608. | 9307. | 164986. | 34543. | 3257. | 202784. |
| 39 | 954 | 1400 | 69552 | 3828. | 84673. | 9314. | 167367. | 32600. | 3322. | 203288. |
| 37 | 900 | 1400 | 68697. | 3766 | 84494. | 9294, | 166251. | 34543. | 3294. | 204088. |
| 35 | 795 | 1500. | 66879. | 3689. | 82176. | 9039. | 161784. | 39120. | 3206. | 204109. |
| 32 | 795 | 1300. | 65558 . | 3685. | 83893. | 9228. | 162364. | 39523. | 3195. | 205082. |
| 30 | 715. | 1300- | 63510- | 3615. | 82301. | 9053. | 158478. | 44166. | 3112. | 205756. |
| 30 | 715 | 1400 | 64204 | 3576 | 81729. | 8990. | 158498. | 44166. | 3122. | 205787. |
| 34 | 795. | 1300 | 65807 | 3659 | 84359 | 9279 | 163104. | 39599. | 3209. | 205913. |
| 32 | 795 | 1400- | 66784. | 3669 | 83683. | 9205. | 163342. | 39523. | 3226. | 206091. |
| 30 | 954 | 1500. | 71843 | 3870 | 85337. | 9387. | 170437. | 32600. | 3397. | 206433. |
| 38 | 954 | 1300. | 70136. | 3831. | 86787. | 9547. | 170300. | 32997. | 3371. | 206667. |
| 30 | 954 | 1200 | 70386. | 4033. | 87082. | 9579. | 171080. | 32600. | 3385. | 207065. |
| 37 | 900. | 1500 | 70983. | 5807. | 85172. | 9369 | 169331. | 34543. | 3369. | 207242. |
| 34 | 795 | 1400 | 67235. | 3653 | 84298. | 9273. | 164459. | 39599. | 3248. | 207306. |
| 35 | 795 | 1600 | 69124. | 3735 | 82979. | 9128. | 164966. | 39120. | 3282. | 207367. |
| 30 | 715 | 1500. | 65702. | 3580 | 81896. | 9009. | 160187. | 44166. | 3167. | 207520. |
| 35 | 795. | 1200. | 66889 | 3916. | 85020. | 9352 | 165176. | 39120. | 3254. | 207549. |
| 37 | 900 | 1200. | 69631 | 3977. | 86926 | 9562 | 170096. | 34543. | 3361. | 207999. |
| 29 | 715 | 1300 | 64091 | 3593 | 83683 | 9205. | 160573. | 44804. | 3150. | 208527. |
| 20 | 636 | 1200 | 58648- | 3345 | 82481. | 9073. | 153548. | 52193. | 2975. | 208715. |
| 22 | 795 | 1500. | 68883. | 3701 | 84257 | 9268. | 166109. | 39523. | 3295. | 208926. |
| 36 | 900. | 1300 | 69499 | 3780. | 86682. | 9535. | 169496. | 36096. | 3351. | 208942. |

·

B-13

| \$ | | | * |
|----|------------|------------|-----|
| * | COST OUTPU | T PER MILE | . * |
| * | PRESENT V | ALUE RATE | * |
| * | 7.00 P | ERCENT | * |
| * | - | • | * |

CONDUCTOR NUMBER = 39 954. KCMIL 1300. FT SPAN 87.7 FT TOWER

| INSTALLED COST
BREAKDOWN | QUANTITY | MATERIAL
COST(\$) | TONNAGE | TRANSPORTATION
COST(\$) | INSTALLATION
COST(\$) | TOTAL
COST(\$) |
|--|---|--|---------------------------------------|--|--|---|
| CONDUCIOR
GROUNDWIRE
INSULATORS
HARDWARE
TOWERS
FOUNDATIONS
RIGHT OF WAY | 15840. FT
0. FT
207. UNITS
4.3 UNITS
4.3 UNITS
13. ACRES | 14086,
0.
1313,
1429,
38870,
3327,
9120, | 9.73
0.00
1.14
0.47
20.31 | 973.
0.
244.
47.
2031.
538. | 18257.
0.
26019.
22280.
18241. | 33316.
0.
1557.
1477.
66921.
26145.
27361.
9328. |
| IDC/ENGINEERING | | 9328.
68147. | 31.65 | 3834. | 84796. | 166104. |

| | | PRESENT VALUE (\$) | | |
|-------------------|---------------|--------------------|---------------|--|
| LOSS ANALYSIS | DEMAND LOSSES | ENERGY LOSSES | TOTAL LOSSES | |
| RESISTANCE LOSSES | 24588.
0. | 7992. | 32580.
19. | |
| TOTALS | 24588. | 8011. | 32600. | |

INTERNATIONAL ENGINEERING CO. INC SAN FRANCISCO CALIFORNIA

TRANSMISSION LINE COST ANALYSIS PROGRAM VERSION 1: 23 FEB 1979,

ANCHORAGE-FAIRBANKS INTERTIE CASE IB 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION DATE: 12 APR 79 TIME: 9:37:07

| *** | ***** | ***** | * * |
|-----|-------|-------|-----|
| * | | | × |
| * | INPUT | DATA | * |
| * | | | Ϋ́, |

| SYSTEM ECONOMIC FACTORS | INPUT VALUE | REFERENCE YEAR FOR INPUT |
|------------------------------|----------------|--------------------------|
| | | |
| STARTING YEAR OF STUDY | 1979 | |
| ENDING YEAR OF STUDY | 1996 | |
| BASE YEAR FOR ESCALATION | 1977 | |
| MAXIMUM CIRCHII LOADING | 136.8 MVA | 1992 |
| AVERAGE CIRCUIT LOADING | 49.2 MVA | 1992 |
| DEMAND COST FACTOR | 73.0 \$/KW | 1979 |
| ENERGY COST FACTOR | 13.0 MILLS/KWH | 1 1979 |
| VAR COST FACTOR | 0.0 \$/KVAR | 1984 |
| CAPITAL COST/DISCOUNT RATE: | | |
| MINIM | 7.0 PERCENT | 1984 |
| ΜΔΥΤΜΙΜ | 10.0 PERCENT | 1984 |
| NUMBER OF INTERVALS | 1 | |
| DEM COST FACTOR | 1.5 % CAP.COS | ST 1979 |
| PICHT OF WAY COST FACIOR | 715.0 \$/ACRE | 1979 |
| PICHT DE WAY CLEARING COST | 1430.0 S/ACRE | 1979 |
| INTEDEST DUPTNE CONSTRUCTION | 0.00 % INST.CS | ST |
| FNGINFFRING FEE | 11.00 % INST.C | ST |

| CONDUCTOR D | ATA | GROUNDWIR | E DATA | SI | PAN DATA |
|---|--|--|-------------------------------|--------------------------------|----------------------------------|
| NUMBER PER PHASE
CONDUCTOR SPACING
VOLTAGE
VOLTAGE VARIATION
LINE FREQUENCY | 1
0.0 IN
230 KV
10.00 PCT
60 CPS | NUMBER PER TOWER
DIAMETER
WEIGHT | 0
0.00 IN
0.0000 LBS/FT | MINIMUM
MAXIMUM
INTERVAL | 1200. FT
1600. FT
100.0 FT |

| WEATHER DATA | | | | | | | |
|-------------------------------|----------------------------------|------------------------------|---------------------|---------------------------|--|--|--|
| MAXIMUM
MAXIMUM | RAINFALL | RATE | 1.18 | IN/HR
HRS/YR | | | |
| AVERAGE
AVERAGE
MAXIMUM | RAINFALL
RAINFALL
SNOWFALL | RATE
DURATION
RATE | 0.03
636
1.87 | HRS/YR
IN/HR | | | |
| MAXIMUM
AVERAGE | SNOWFALL
SNOWFALL | DURATION
RATE
DURATION | 1
0.13
264 | HRS/YR
IN/HR
HRS/YR | | | |
| RELATIV | E AIR DEN | SITY | 1.000 | | | | |

0.00 KW/MI

323.00 MILES

0,95

FAIRWEATHER LOSSES

LINE LENGTH

POWER FACTOR

1

| ., *** | ***** | ****** | * * * |
|--------|-------|--------|----------|
| * | | | # |
| * | INPUT | DATA | * |
| × | | | * |
| * * * | ***** | ****** | ** |

SAG/TENSION DESIGN FACTORS

| EVERYDAY STRESS TEMPERATURE
ICE AND WIND TEMPERATURE
HIGH WIND TEMPERATURE
EXTREME ICE TEMPERATURE
MAX DESIGN TEMP FOR GND CLEARANCE
EDS TENSION (PCT UTS)
NESC CONSTANT | 40. DEGREES F
0. DEGRFES F
40. DEGREES F
30. DEGREES F
120. DEGREES F
20. PERCENT
0.31 LBS/FT | ICE AND WIND TENSION (PCT UTS)
HIGH WIND TENSION (PCT UTS)
EXTREME ICE TENSION (PCT UTS)
ICE THICKNESS WITH WIND
WIND PRESSURE WITH ICE
HIGH WIND | 50. PERCENT
50. PERCENT
70. PERCENT
0.50 INCHES
4.00 LBS/S0.FT.
9.0 LBS/S0.FT. |
|--|---|--|---|
| | | EXTREME ICE | 0.50 INCHES |

D1

D2

03

D4

.D5

D6

TOWER DESIGN

3

1.02

TOTAL NUMBER OF PHASES PHASE SPACING CONDUCTOR CONFIGURATION FACTOR GROUND CLEARANCE NO. OF INSULATORS PER TOWER INSULATOR SAFETY FACTOR STRING LENGTH I, VEE, OR COMBINATION FOUNDATION TYPE IERRAIN FACTOR LINE ANGLE FACTOR TOWER GROUNDING TRANSVERSE OVERLOAD FACTOR VERTICAL OVERLOAD FACTOR LONGITUDINAL LOAD MISCELLANEOUS HARDWARE WEIGHT TOWER WEIGHT FACTOR •

| 20.0 | FEET |
|------|------------|
| 1.02 | |
| 28.0 | FEET |
| 48 | |
| 2,50 | |
| 6.5 | FEET |
| - 3 | |
| 4 | |
| 1.06 | PER UNIT |
| 0864 | |
| 0 | |
| 2,50 | |
| 1.50 | · · · |
| 000. | LBS |
| 0.11 | TONS/TOWER |

DISTANCE BETWEEN PHASES: 20.00 FT 20.00 FT 40.00 FT 0.00 FT 0.00 FT 0,00 FT

TOWER WEIGHT ESTIMATION ALGORITHM

TOWER TYPE 9: 230KV TOWER

TW = 0.00016*TH**2 = 3.09797*TH**0.3333 = 0.08943*EFFVDL = 0.27367*EFFTDL + 0.00510*TH*EFFTDL + 0.00160*TH*EFFVDL + 18.37912 KIPS

0.50 INCHES

*

* INPUT DATA *

CONDUCTOR SUMMARY

| ID NUMBER | NAME | SIZE(KCM) | STRANDING
(AL/ST) | UNIT WEIGHT
(LBS/FT) | OUT.DIAM.
(INCHES) | TOTAL AREA
(SQ.IN.) | MODULUS
(EF/E6 PSI) | TEMP.COEF.
ALPHA*E-6
PER DEG F |
|-----------|-------------|-----------|----------------------|-------------------------|-----------------------|------------------------|------------------------|--------------------------------------|
| | | | | | ******** | | | |
| 27 | CROSBEAK | 636 0 | 26/ 7 | 0.8750 | 0,9900 | 0.5809 | 11.00 | 10.3 |
| 24 | FGPET | 636-0 | 30/19 | 0.9880 | 1.0190 | 0.6134 | 11.30 | 9,7 |
| 25 | ELAMINGO | 666 0 | 24/7 | 0.8590 | 1.0000 | 0.5914 | 10.55 | 10.7 |
| 20 | CANNET | 666.0 | 26/ 7 | 0.9180 | 1.0140 | 0.6087 | 11.00 | 10.3 |
| 27 | CT11 T | 715 0 | 24/ 7 | 0.9210 | 1.0360 | 0.6348 | 10,55 | 10.7 |
| 20 | | 715 0 | 26/ 7 | 0.9850 | 1.0510 | 0.6535 | 11.00 | 10.3 |
| 29 | DEDUTING | 715.0 | 30/19 | 1 1110 | 1.0810 | 0.6901 | 11.30 | 9.7 |
| 50 | CUCKOO | 795 0 | 24/7 | 1.0240 | 1.0920 | 0.7053 | 10.55 | 10.7 |
| 21 | | 795.0 | 26/ 7 | 1.0940 | 1.1080 | 0.7261 | 11.00 | 10.3 |
| 52 | | 795.0 | 15/7 | 0.8960 | 1.0630 | 0.6676 | 9,40 | 11.5 |
| 5.5 | 1ERN CONDOD | 795.0 | 5// 7 | 1.0240 | 1.0930 | 0.7053 | 10.85 | 10,9 |
| 54 | LUNDOR | | 20/10 | 1 2350 | 1.1400 | 0.7668 | . 11,30 | 9.,7 |
| 35 | MALLARD | 793.0 | 30717 | 1 0150 | 1.1310 | 0.7069 | 9,40 | 11.5 |
| 36 | RUDDY | 900.0 | 437 7 | 1 1500 | 1,1620 | 0.7985 | 10.85 | 10.9 |
| 37 | LANARY | 900.0 | 347 1 | 1 0750 | 1 1650 | 0.8011 | 9.40 | 11,5 |
| 38 | RAIL | 454.0 | 45/ / | 1 2200 | 1 1960 | 0.8464 | 10.85 | 10,9 |
| 39 | CARDINAL | 954.0 | 54/ / | 1.6290 | 1.1.100 | V 0 0 0 0 1 | | |

B-18

X.

CONDUCTOR SUMMARY

| ID NUMBER | NAME | ULT.TENS.
STRENGTH(LBS) | GEOM.MEAN
RADIUS(FT) | PRICE(\$7LB) | THERM,LIMIT
(AMPERES) | AC RESIST.
AT 25 DEG C
(OHMS/MILE) | IND.REACT.
(OHMS/MILE) | CAP.REACT.
(MOHM-MILES) |
|-----------|------------|----------------------------|-------------------------|--------------|--------------------------|--|---------------------------|----------------------------|
| | | | | ********* | | ******* | ********* | |
| 24 | GROSBEAK - | 25000.0 | 0.0335 | 0-628/1977 | 790. | 0.1452 | 0.4118 | 2.6347 |
| 25 | EGRET | 31500.0 | 0.0351 | 0.609/1977 | 870. | 0.1447 | 0.4060 | 2.6136 |
| 26 | FLAMINGO | 23700.0 | 0.0335 | 0.640/1977 | 810. | 0.1399 | 0.4118 | 2.6294 |
| 27 | GANNET | 26200.0 | 0.0343 | 0.609/1977 | 820. | 0.1373 | 0.4092 | 2.6347 |
| 28 | STILT | 25500,0 | 0.0347 | 0.627/1977 | 840. | 0.1320 | 0.4066 | 2.6400 |
| 29 | STARLING | 28100.0 | 0.0355 | 0.608/1977 | 850. | 0.1294 | 0.4050 | 2.6453 |
| 30 | REDWING | 34600.0 | 0.0372 | 0.612/1977 | 860. | 0.1288 | 0.3992 | 2.5661 |
| 31 | CUCKOO | 27100.0 | 0.0366 | 0.636/1977 | 900. | 0.1214 | 0.3992 | 2.5502 |
| 32 | DRAKE | 31200.0 | 0.0375 | 0.622/1977 | 910. | 0.1172 | 0.3992 | 2.5450 |
| 33 | TERN | 22900.0 | 0.0352 | 0.677/1977 | 890. | 0.1188 | 0.4060 | 2.5766 |
| 34 | CUNDOR | 28500.0 | 0.0368 | 0.635/1977 | 900. | 0.1172 | 0.4002 | 2,5555 |
| - 35 | MALLARD | 38400.0 | 0.0392 | 0.599/1977 | 910. | 0.1162 | 0.3928 | 2.5186 |
| 36 | RUDDY | 25400.0 | 0.0374 | 0.676/1977 | 935. | 0.1082 | 0.3928 | 2,5080 |
| 37 | CANARY | 32300.0 | 0.0392 | 0.633/1977 | 950. | 0.1040 | 0.3928 | 2.5027 |
| 38 | RAIL | 26900.0 | 0.0385 | 0.671/1977 | 970. | 0.0998 | 0.3949 | 2,5027 |
| 39 | CARDINAL | 34200.0 | 0.0404 | 0,632/1977 | 990. | 0.0987 | 0.3902 | 2,4816 |

B-19

| * * * * | **** | * * * | * * * | *** | ά χ |
|---------|------|-------|-------|-------|------------|
| * | | | | | * |
| * | INPU | T E |) A T | A | * |
| * | | | | | * |
| * * * * | **** | * * * | *** | * * * | * * |

200

. The second

 \mathbf{C}_{i}^{i}

| INIT MATERIALS COSTS | INPUT | VALUE | REFERENCE YEAR FOR INPUT. |
|------------------------------------|---------|-----------|---------------------------|
| | ***** | | ****** |
| PRICE OF TUWER MATERIAL | 0,957 | \$/LB | 1979 |
| PRICE OF CONCRETE | 0.00 | \$/CU.YD. | 1977 |
| PRICE OF GROUND WIRE | 0.000 | \$/LB | 1977 |
| INSTALLED COST OF GROUNDING SYSTEM | 0.00 | \$/TOWER | 1977 |
| TOWER SETUP | 1751. | \$ | 1979 |
| TOWER ASSEMBLY | 0,455 | \$/LB | 1979 |
| FOUNDATION SETUP | 0. | \$ | 1979 |
| FOUNDATION ASSEMBLY | 4140.00 | \$/TON | 1979 |
| FOUNDATION EXCAVATION | 0.00 | \$/CU,YD. | 1979 |
| PRICE OF MISCELLANEOUS HARDWARE | 290.00 | SVTOWER | 1977 |
| | | | |

UNIT LABOR COSTS

- . ---

.

| REFERENCE YEAR LABOR COST | 24.00 \$/MANHOUR | . • | 1979 |
|---------------------------|------------------|-----|------|
| STRING GROUND WIRE | 0.0 SIMILE | | 1977 |
| STRING LABOR MARKUP | 4.2 PER UNIT | | |

UNIT TRANSPORTATION COSTS

| TOWER | 100.0 \$/TÓN |
|---------------------|-------------------------|
| FOUNDATION CONCRETE | 100.0 \$/YD |
| FOUNDATION STEEL | 100.0 \$/TON |
| CONDUCTOR | 100.0 \$/TON |
| GROUND WIRE | 100.0 \$/TON |
| INSULATOR | 100.0 \$/TON OR \$/M**3 |
| HARDWARE | 100.0 \$/TON |
| | |

. - .

| * * * * | * * * | * * | * | * * | * | * | * ' | k 7 | * | * | *: | * 1 | * * | * | * : | * 1 | k d | * | × | * | × | * 1 | ł | * | * | * | × | × |
|---------|-------|-----|---|-----|---|---|-----|-----|---|---|----|-----|-----|---|-----|------------|-----|---|---|---|---|-----|-----|---|---|---|---|---|
| * | | | | | | | | | | | | | | | | | | · | | | | | | | | | | × |
| * . | AL | JT | 0 | MA | T | ľ | Ċ | C | 0 | N | DI | J | T | 0 | R | ţ | SE | L | Ε | С | Ţ | 10 |)N | Ľ | | | ÷ | * |
| * | | | A | LL | | Q | U/ | ٩N | T | 1 | T | IE | S | | P | EF | 2 | M | I | L | Ε | | | | | | | × |
| * | | | | | | | | | | | | | | • | | | | | | | | | | | | | | × |
| * * * * | * | * * | * | * * | * | × | * 1 | t é | * | × | *: | k 3 | ** | × | * | k 1 | * * | * | * | * | * | ×, | * * | * | * | * | * | * |

CAPITAL COST/DISCOUNT RATE OF 7.00 PERCENT

PRESENT WORTH

| CONDU | JCTOR | | | | INSTALLED COST | × | | LINE LOSSES | O&M COST | LINE COST |
|-------|-------|----------|-----------|----------------|----------------|---------|----------|-------------|----------|-----------|
| ND. | KCM | SPAN(FT) | MATERIALS | TRANSPORTATION | INSTALLATION | ENG/IDC | SUBTOTAL | SUBTOTAL | SUBTUTAL | TOTAL |
| | | | | ******** | | | ****** | | | |
| 39 | 954. | 1300. | 68147. | 3834. | 84796. | 9328. | 166104. | 35856. | 3284. | 205244. |
| 37 | 900. | 1300. | 67299. | 3772. | 84608. | 9307. | 164986. | 37993. | 3257. | 206235, |
| 35 | 795 | 1300. | 64664. | 3721. | 82616. | 9088. | 160089. | 43028. | 3151. | 206267. |
| 35 | 795. | 1400 | 65375. | 3684. | 82031. | 9023. | 160113. | 43028. | 3161. | 206302. |
| 39 | 954. | 1400. | 69552. | 3828. | 84673. | 9314 | 167367. | 35856. | 3322. | 206545. |
| 37 | 900. | 1400. | 68697. | 3766. | 84494. | 9294. | 166251. | 37993. | 3294. | 207538. |
| 35 | 795. | 1500. | 66879. | 3689. | 82176. | 9039 | 161784. | 43028. | 3206. | 208017. |
| 32 | 795. | 1300. | 65558. | 3685, | 83893. | 9228. | 162364. | 43468. | 3195. | 209027. |
| . 39 | 954. | 1500. | 71843. | 3870 | 85337. | 9387. | 170437. | 35856. | 3397. | 209689. |
| 34 | 795. | 1300. | 65807. | 3659. | 84359. | 9279. | 163104. | 43545. | 3209. | 209858. |
| 38 | 954 | 1300. | 70136. | 3831. | 86787. | 9547. | 170300. | 36293. | 3371. | 209963. |
| 32 | 795. | 1400. | 66784. | 3669 | 83683. | 9205, | 163342. | 4346B. | 3250. | 210036. |
| 30 | 715. | 1300. | 63510. | 3615. | 82301. | 9053. | 158478. | 48561. | 3112. | 210151. |
| 30 | 715. | 1400. | 64204 . | 3576 | 81729. | 8990. | 158498 | 48561. | 3122. | 210182. |
| 39 | 954 | 1200 | 70386. | 4033. | 87082. | 9579 | 171080. | 35856 | 3385. | 210321. |
| 37 | 900. | 1500. | 70983. | 3807. | 85172. | 9369. | 169331. | 37993. | 3369. | 210693. |
| - 34 | 795. | 1400. | 67235. | 3653. | 84298. | 9273, | 164459. | 43545. | 3248. | 211251. |
| 35 | 795. | 1600. | 69124. | 3735. | 82979. | 9128. | 164966. | 43028. | 3282. | 211275. |
| 37 | 900. | 1200. | 69631. | 3977. | 86926. | 9562. | 170096. | 37993. | 3361. | 211450. |
| 35 | 195 | 1200. | 66889. | 3916. | 85020. | 9352. | 165176. | 43028. | 3254. | 211457. |
| 30 | 715. | 1500 | 65702. | 3580 | 81896. | 9009. | 160187. | 48561. | 3167. | 211915. |
| 36 | 900. | 1300. | 69499. | 3780. | 86682. | 9535. | 169496. | 39701. | 3351. | 212547. |
| -38 | 954. | 1400. | 72348 | 3861 | 87234. | 9590. | 173039. | 36293. | 3440: | 212771. |
| 32 | 795. | 1500. | 68883 | 3701. | 84257. | 9268, | 166109. | 43468. | 3295. | 212871. |
| 20 | 715 | 1300 | 64091 | 3593 | 83683 | 9205. | 160573- | 49222 | 3150. | 212944 |

B-21

1

83683.

.

B-22

| ŧ | | | | | | * |
|---|------|------|-----|------|------|---|
| * | COST | OUTF | υT | PER | MILE | * |
| * | PRE | SENT | VAL | UE I | RATE | * |
| * | | 7.00 | PER | CEN | T | * |

CONDUCTOR NUMBER = 39 954. KCMIL 1300. FT SPAN 87.7 FT TOWER

| INSTALLED COST
BREAKDOWN | QUANTIT | Y | MATERIAL
COSI(\$) | TONNAGE | TRANSPORTATION
COST(\$) | INSTALLATION
COST(\$) | TOTAL
COST(\$) |
|--|---|--|---|---------------------------------------|--|--|---|
| CONDUCTOR
GROUNDWIRE
INSULATORS
HARDWARE
IOWERS
FOURDATIONS
RIGHT OF WAY | 15840.
0.
207.
4.3
4.3
13. | FT
FT
UNITS
UNITS
UNITS
ACRES | 14086.
U.
1313.
1429.
38870.
3327.
9120.
9328. | 9.73
0.00
1.14
0.47
20.31 | 973.
0.
244.
47.
2031.
538. | 18257.
0.
26019.
22280.
18241. | 33316.
0.
1557.
1477.
66921.
26145.
27361.
9328. |
| IDIALS | | | 68147. | 31.65 | 3834. | 84796. | 166104. |

PRESENT VALUE (\$)

| , | | | |
|------------------------------------|---------------|---------------|---------------|
| LOSS ANALYSIS | DEMAND LUSSES | ENERGY LOSSES | TOTAL LOSSES |
| RESISTANCE LOSSES
CORONA LOSSES | 24588.
0. | 11249.
19. | 35837.
19. |
| T() TALS | 24588. | 11268. | 35856. |

INTERNATIONAL ENGINEERING CO. INC SAN FRANCISCO CALIFORNIA

TRANSMISSION LINE COST ANALYSIS PROGRAM VERSION 1: 23 FEB 1979,

ANCHORAGE-FAIRBANKS INTERTIE CASE I-C 345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION DATE: 12 APR 79 TIME: 10:10:52

۰.

-

| * * * | * | * | * * | * * | : # | × | * * | * | * | * | * | × |
|----------|---|-----|-----|-----|-----|---|-----|---|---|---|---|---|
| * | | | | | | | | | | | | # |
| ¢ | | I | NP | UI | | D | A T | A | | | | × |
| k | | | | | | | | | | | | × |
| * * * | * | * : | * * | ** | * | × | * * | * | * | * | × | * |

| SYSTEM ECONOMIC FACTORS | INPUT VA | LUE | REFERENCE YEAR FOR INPUT | | |
|------------------------------|----------|------------|--------------------------|---|--|
| | | | | | |
| STARTING YEAR OF STUDY | 1979 | | | | |
| ENDING YEAR OF STUDY | 1996 | | | | |
| BASE YEAR FOR ESCALATION | 1977 | | | | |
| MAXIMUM CIRCUIT LOADING | 168,4 | MVA | 1992 | | |
| AVERAGE CIRCUIT LOADING | 58,9 | AVM | 1992 | | |
| DEMAND COST FACTOR | 73.0 | S/KW | 1979 | | |
| ENERGY COST FACTOR | 13.0 | MILLS/KWH | 1979 | | |
| VAR COST FACTOR | 0.0 | 5/KVAR | 1984 | | |
| CAPITAL COST/DISCOUNT RATE: | | | | | |
| MINIMUM | 7.0 | PERCENT | 1984 | | |
| MAXIMUM | 10.0 | PERCENT | 1984 | | |
| NUMBER OF INTERVALS | 1 | | | | |
| O&M COST FACTOR | 1.5 | % CAP.COST | 1979 | | |
| RIGHT OF WAY COST FACTOR | 715.0 | \$/ACRE | 1979 | | |
| RIGHT OF WAY CLEARING COST | 1430.0 | S/ACRE | 1979 | | |
| INTEREST DURING CONSTRUCTION | 0.00 | % INST.CST | | - | |
| ENGINEERING FEE | 11.00 | % INST.CST | | | |

· . .

| * * * * | ***** | ****** | * * |
|---------|-------|--------|-----|
| * | | | * |
| × | INPUT | DATA | * |
| * | | | * |
| **** | ***** | ****** | * * |

| CONDUCTOP | | GROUNDWI | RE DATA | SPAN DATA | | |
|--|---|--|-------------------------------|--------------------------------|----------------------------------|--|
| NUMBER PER PHASE
CONDUCTOR SPACING
VOLTAGE
VOLTAGE VARIATION
LINE FREQUENCY
FAIRWEATHER LOSSES
LINE LENGIH
POWER FACTOR | 2
18.0 IN
345 KV
10.00 PCT
60 CPS
1.70 KW/MI
323.00 MILFS
0.95 | NUMBER PER TOWER
DIAMETER
WEIGHT | 0
0.00 IN
0.0000 LBS/FT | MINIMUM
Maximum
Interval | 1000. FT
1600. FT
100.0 FT | |

WEATHER DATA

B-24

.

| MAXIMUM | RAINFALL | RATE | 1.18 | IN/HR | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| MAXIMUM | RAINFALL | DURATION | 1 | HRSZYR |
| AVERAGE | RAINFALL | RATE | 0.03 | IN/HR |
| AVERAGE | RAINFALL | DURATION | 636 | HRS/YR |
| MAXIMUM | SNOAFALL | RATE | 1.87 | IN/HR |
| MAXIMUM | SNOWFALL | DURATION | 1 | HRSZYR |
| AVERAGE | SHOWFALL | RATE | 0.13 | IN/HR |
| AVERAGE | SNOWF ALL | DURATION | 264 | HRSZYR |
| RELATIVE | AIR DENS | SITY | 1,000 | |
| | | | - | |
| * | * | * | * | * | * | * | ŧ | * | ÷ | * | * | × | * | × | * | × | * |
|---|---|---|---|---|---|---|---|---|---|-------|---|---|---|---|---|---|---|
| * | | ÷ | | | | | | | | 1.5.1 | | | | | • | | * |
| * | | | | I | N | Ρ | υ | T | | D | A | T | A | | | | * |
| × | | | | | | | | | | | | | | | | | * |
| * | * | * | * | * | × | * | * | × | * | * | * | * | * | * | ¢ | × | * |

SAG/TENSION DESIGN FACTORS

| EVERYDAY STRESS TEMPERATURE | 40, DEGREES F | ICE AND WIND TENSION (PCT UTS) | 50. PERCENT |
|-----------------------------------|----------------|--------------------------------|----------------|
| ICE AND WIND TEMPERATURE | 0, DEGREES F | HIGH WIND TENSION (PCT UTS) | 50, PERCENT |
| HIGH WIND TEMPERATURE | 40. DEGREES F | EXTREME ICE TENSION (PCT UTS) | 70. PERCENT |
| EXTREME ICE TEMPERATURE | 30, DEGREES F | ICE THICKNESS WITH WIND | 0.50 INCHES |
| MAX DESIGN TEMP FOR GND CLEARANCE | 120. DEGREES F | WIND PRESSURE WITH ICE | 4.00 L85/50.FT |
| EDS TENSION (PCT UTS) | 20. PERCENT | HIGH WIND | 9.0 LBS/SQ.FT |
| NESC CONSTANT | 0.31 LBS/FT | | - |
| | | EXTREME ICE | 0.50 INCHES |

TOWER DESIGN

| TOTAL NUMBER OF PHASES | 3 | | DISTANCE BETWEEN PHASES: | | |
|--------------------------------|-------|------------|--------------------------|--------|-----|
| PHASE SPACING | 27.0 | FEET | D1 | 27.00 | F 1 |
| CONDUCTOR CONFIGURATION FACTOR | 1.02 | | 50 | 27.00 | FI |
| GROUND CLEARANCE | 32.0 | FEET | D3 | 54.00 | FT |
| NO. OF INSULATORS PER TOWER | 72 | | D4 | 0.00 | FT |
| INSULATOR SAFFTY FACTOR | 2,50 | | D5 | . 0.00 | FI |
| STRING LENGTH | 9.5 | FEET | D6 | 0.00 | FT |
| I, VEF, OR COMBINATION | 3 | | | | |
| FOUNDATION TYPE | 4, | | | | |
| TERRAIN FACTOR | 1.06 | PER UNIT | | | |
| LINE ANGLE FACTOR | .0864 | | | | |
| TOWER GROUNDING | 0 | | | | |
| TRANSVERSE OVFRLOAD FACTOR | 2.50 | | | | |
| VERTICAL OVERLOAD FACTOR | 1,50 | | | | |
| LONGITUDINAL LOAD | 1000. | LBS | | | |
| MISCELLANEOUS HARDWARE WEIGHT | 0.11 | TONS/TOWER | | | |
| TOWER WEIGHT FACTOR | 1.02 | | | | |

IDWER WEIGHT ESTIMATION ALGORITHM

TOWER TYPE 10: 345KV TOWER

TW = 0.00043*TH**2 - 0.992111*TH**0.6000 - 0.10371*FFFVDL -0.27365*EFFTDL + 0.00503*TH*EFFTDL + 0.00181*TH*FFFVDL + 20.77701 KIPS

****** ** × * INPUT DATA * × × × ** *******

.

CONDUCTOR SUMMARY *****

.

| I
 |) NIMBER | NAME | SI7E(KCM) | STRANDING
(AL/ST) | UNIT WEIGHT
(LBS/FT) | OUT.DIAM.
(INCHES) | TOTAL AREA
(SQ.IN.) | MODULUS
(EF/E6 PSI) | TEMP.COEF.
ALPHA*E=6
PER DEG F |
|---------|----------|----------|-----------|----------------------|-------------------------|-----------------------|------------------------|------------------------|--------------------------------------|
| | 29 | STARLING | 715.0 | 261 7 | 0,9850 | 1.0510 | 0.6535 | 11.00 | 10.3 |
| | 30 | REDWING | 715.0 | 30/19 | 1.1110 | 1.0810 | 0.6901 | 11.30 | 9.7 |
| đ | 31 | сискоо | 795.0 | 24/ 7 | 1.0240 | 1,0920 | 0.7053 | 10.55 | 10.7 |
| | 32 | DRAKE | 795.0 | 26/ 7 | 1.0940 | 1.1080 | 0.7261 | 11.00 | 10.3 |
| 2 | 33 | TERN | 795.0 | 45/ 7 | 0.8960 | 1.0630 | 0.6676 | 9.40 | 11.5 |
| | 34 | CONDOR | 795.0 | 54/ 7 | 1.0240 | 1.0930 | 0,7053 | 10.85 | 10,9 |
| | 35 | MALLARD | 795.0 | 30/19 | 1,2350 | 1.1400 | 0.7668 | 11.30 | 9,7 |
| | 36 | PUDDY | 900.0 | 45/ 7 | 1.0150 | 1.1310 | 0.7069 | 9.40 | 11.5 |
| | 37 | CANARY | 900.0 | 54/ 7 | 1.1590 | 1,1620 | 0.7985 | 10.85 | 10,9 |
| | 38 | PATL | 954.0 | 45/ 7 | 1.0750 | 1.1650 | 0.8011 | 9.40 | 11.5 |
| | 39 | CARDINAL | 954.0 | 54/ 7 | 1.2290 | 1.1960 | 0.8464 | 10.85 | 10.9 |
| | 40 | ORTULAN | 1033.0 | 45/ 7 | 1.1650 | 1,2130 | 0,8678 | 9.40 | 11.5 |
| | | | | | | | | | |

E

÷.

CONDUCTOR SUMMARY

| ID NUMBER | NAME | ULT.TFNS.
STRENGTH(LBS) | GEOM.MEAN
RADIUS(FT) | PRICE(\$/LB) | THERM.LIMIT
(AMPERES) | AC RESIST.
AT 25 DEG C
(OHMS/MILE) | IND.REACT.
(OHMS/MILE) | CAP.REACT.
(MOHM-MILES) |
|-----------|----------|----------------------------|-------------------------|--------------|--------------------------|--|---------------------------|----------------------------|
| 29 | STARLING | 28100.0 | 0.0355 | 0.608/1977 | 850. | 0.1294 | 0.4050 | 2.6453 |
| 30 | REDWING | 34600.0 | 0.0372 | 0.612/1977 | 860. | 0.1288 | 0.3992 | 2,5661 |
| 31 | CUCKOO | 27100.0 | 0.0366 | 0,636/1977 | 900. | 0,1214 | 0.3992 | 2,5502 |
| 32 | DRAKE | 31200.0 | 0.0375 | 0,622/1977 | 910. | 0.1172 | 0.3992 | 2.5450 |
| 33 | TERN | 22900.0 | 0.0352 | 0.677/1977 | 890. | 0,1188 | 0.4060 | 2.5766 |
| 34 | CUNDOR | 28500.0 | 0.0368 | 0.635/1977 | 900. | 0,1172 | 0.4002 | 2.5555 |
| 35 | MALLARD | 38400.0 | 0.0392 | 0,599/1977 | 910. | 0,1162 | 0.3928 | 2,5186 |
| 36 | RUDDY | 25400.0 | 0.0374 | 0.676/1977 | 935. | 0,1082 | 0.3928 | 2,5080 |
| 37 | CANARY | 32300.0 | 0.0392 | 0,633/1977 | 950. | 0,1040 | 0.3928 | 2,5027 |
| 38 | RAIL | 26900.0 | 0.0385 | 0.671/1977 | 970. | 0.0998 | 0.3949 | 2,5027 |
| 39 | CARDINAL | 34200.0 | 0.0404 | 0.632/1977 | 990 | 0.0987 | 0.3902 | 2.4816 |
| 40 | ORTOLAN | 28900.0 | 0.0401 | 0.670/1977 | 1020. | 0.0924 | 0,3902 | 2,4658 |

B-27

- 1. L.

...

| UNIT MATERIALS COSTS | INPUT | VALUE | REFERENCE YEAR FOR INPUT |
|------------------------------------|---------|-----------|---|
| | | | *************************************** |
| PRICE OF TUWER MATERIAL | 0,957 | \$/LB | 1979 |
| PRICE OF CONCRETE | 0.00 | \$/CU,YD. | 1977 |
| PRICE OF GROUND WIRE | 0.000 | \$/LB | 1977 |
| INSTALLED COST OF GROUNDING SYSTEM | 0.00 | \$/TOWER | 1977 |
| TOWER SETUP | 1751. | \$ | 1979 |
| TOWER ASSEMBLY | 0.455 | \$/LB | 1979 |
| FOUNDATION SETUP | 0. | \$ | 1979 |
| FOUNDATION ASSEMBLY | 4140.00 | \$/TON | 1979 |
| FOUNDATION EXCAVATION | 0.00 | \$/CU.YD. | 1979 |
| PRICE OF MISCELLANEOUS HARDWARE | 290.00 | \$/TOWER | 1977 |

UNIT LABOR COSTS

| REFERENCE YFAR LABOR COST | 24.00 \$/MANHOUR | 1979 |
|---------------------------|------------------|------|
| STRING GROUND WIRE | 0.0 \$/MILE | 1977 |
| STRING LABOR MARKUP | 4.2 PER UNIT | |

UNIT TRANSPORTATION COSTS

| TOWER | 100.0 \$/TON |
|---------------------|-------------------------|
| FOUNDATION CONCRETE | 100.0 \$/YD |
| FOUNDATION STEEL | 100.0 \$/TON |
| CONDUCTOR | 100.0 \$/TON |
| GROUND WIRE | 100.0 \$/TON |
| INSULATOR | 100.0 \$/TON OR \$/M**3 |
| HARDWARE | 100.0 \$/TON |

B-28

• ·

-

| * * * * | * * * | ** | **: | * * * | * * * | ** | * * * | * * * | *** | * * * * | ****** |
|---------|-------|-----|-----|-------|-------|-----|-------|-------|-------|---------|--------|
| × | | | | | | | | | | | ł. |
| * | ΑU | τo | MA | TIC | CC |)ND | UC I | OR | SEL | ECTI | ON # |
| × | | A | LL | QU | ANT | IT | IES | PE | R M | ILE | |
| * | | | | | | | | | | | |
| * * * * | *** | * * | **: | * * * | * * * | ** | *** | * * * | * * * | **** | ****** |

CAPITAL COST/DISCOUNT RATE OF 7.00 PERCENT

LINE LOSSES O&M COST INSTALLED COST ------_____ _____ SUBTOTAL SUBTOTAL SUBTOTAL MATERIALS TRANSPORTATION INSTALLATION ENG/IDC SPAN(F1) _____ _____ -----_____ -----------------715. 1300. 238214. 22728. 4821. 105622. 6261. 113812. 12519. 795. 1300. 108253. 6486. 114488. 12594. 241821. 19629. 4908. 238902. 22728. 4854. 715. 1400. 6256. 12419. 107324. 112903. 4944. 795. 1400. 6487. 113599. 12496-242620. 19629. 110039. 715. 1200. 105232. 6340. 115902. 12749. 240223. 22728. 4843. 4929. 795. 1200. 12823. 243753. 19629. 107799. 6561. 116571. 23923. 4857. /15. 1300. 12715. 240461. 105955. 6203. 115588. 715. 1500. 113036. 12434. 242026. 22728. 4939. 110237. 6320. 23923. 4852. /15. 1200. 104868. 6250. 117221. 12894. 241233. 6399. 12774. 244556. 20589. 4960. 795. 1300. 109255. 116128. 245825. 19629. 5031. 795. 1500. 113021. 6554. 113739. 12511. 4955. 6443. 12954. 245282. 20589. /95. 1200. 108121. 117764.

12836.

12673.

12998.

12731.

129.08.

13071.

13133.

13205.

12813.

13233.

12953.

13115.

.13111.

245246.

242600.

245522.

246703.

249645.

249892.

245378.

248805.

247910.

245285.

252127.

252308.

248254.

B-29

CONDUCTOR

KCM.

795. 1300.

715. 1400.

795. 1200.

795. 1400.

900. 1300.

900. 1200.

715. 1100.

795. 1100.

795. 1400.

715. 1100.

954. 1300.

954. 1200.

795. 1200.

109378.

108480.

107991.

111805.

112812.

111385.

106343.

106831.

115550.

105362.

114706.

113228.

109517.

6341.

6237.

6373.

6435.

6583.

6612.

6506.

6723.

6390.

6388.

6714.

6740.

6440.

116691.

115211.

118160.

115732.

117342.

119395.

120046.

116486.

120302.

117754.

119225.

119187.

118824.

NO.

30

35

30

35

30

35

29

30

29

32

35

35

34

29

34

32

37

37

30

35

34

29

39

39

31

PRESENT WORTH

4972.

4922.

4956.

5026.

5082.

5065.

4931.

5014.

5049.

4916.

5143.

5125.

5016.

21069. 23923.

21069.

20589.

17916.

17916.

22728.

19629.

21069.

23923.

16883.

16883.

21550.

LINE COST

TOTAL

265762.

266357.

266483.

267192.

267793.

268310.

269240.

269692.

270008.

270105.

270485.

270825.

271286.

271445.

271546,

272318.

272642,

272872.

273036.

273448.

274027.

274124.

274153.

274315.

274820.

| * | | * |
|---|----------------------|---|
| * | COST OUTPUT PER MILE | * |
| × | PRESENT VALUE RATE | * |
| * | 7.00 PERCENT | * |
| * | | * |

CONDUCTOR NUMBER = 30 715. KCMIL 1300. FT SPAN 90.1 FT TOWER

| INSTALLED COST
BREAKDOWN | QUANTITY | MATERIAL
CUST(\$) | TONNAGE | TRANSPORTATION
COST(\$) | INSTALLATION
COST(\$) | TOTAL
COST(\$) |
|--|---|---|--|--|--|---|
| CONDUCTOR
GROUNDWIRE
INSULATORS
HARDWARE
TOWERS
FOUNDATIONS
RIGHT OF WAY | 31680. FT
0. FT
310. UNITS
4.3 UNITS
4.3 UNITS
13. ACRES | 24661,
0,
1970,
1429,
63399,
4791,
9371,
12519 | 17.60
0.00
1.70
0.47
33.12 | 1760
0.
366.
47.
3312.
775. | 25306.
0.
37681.
32083.
18742. | 51727.
0.
2336.
1477.
104393.
37648.
28114.
12519. |
| IDC/ENGINEERING | | 105622. | 52.90 | 6261. | 113812. | 238214. |

PRESENT VALUE (\$)

| OSS ANALYSIS | DEMAND LOSSES | ENERGY LOSSES | TOTAL LOSSES |
|-------------------|----------------|----------------|-----------------|
| RESISIANCE LOSSES | 9670,
2088, | 3735.
7235. | 13405.
9323. |
| TOTALS | 11758. | 10970. | 22728. |

B-30

INTERNATIONAL ENGINEERING CO. INC San Francisco California

TRANSMISSION LINE CUST ANALYSIS PROGRAM VERSION 1: 23 FEB 1979,

ANCHDRAGE-DEVIL CANYON CASE II-1 345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION DATE: 12 APR 79 TIME: 10:25:33

5 B ...

| × | | | * |
|---|-------|------|---|
| × | INPUT | DATA | * |
| * | | | * |

SYSTEM ECONOMIC FACTORS INPUT VALUE REFERENCE YEAR FOR INPUT ______ ------STARTING YEAR OF STUDY 1979 ENDING YEAR OF STUDY 1996 BASE YEAR FOR ESCALATION 1977 MAXIMUM CIRCUIT LOADING 631.6 MVA 1992 AVERAGE CIRCUIT LOADING 347.4 MVA 1992 DEMAND COST FACTOR 73.0 S/KW 1979 ENERGY COST, FACTOR 13.0 MILLS/KWH 1979 VAR COST FACTOR 0.0 5/KVAR 1984 CAPITAL COST/DISCOUNT RATE: MINIMUM 7.0 PERCENT 1984 MAXIMUM 10.0 PERCENT 1984 NUMBER OF INTERVALS 1 **O&M COST FACTOR** 1979 1.5 % CAP.COST RIGHT OF WAY COST FACTOR 715.0 \$/ACRE 1979 RIGHT OF WAY CLEARING COST 1430.0 \$/ACRE 1979 - INTEREST DURING CONSTRUCTION 0.00 % INST.CST ENGINEERING FEE 11.00 % INST.CST

| * | | | | | # |
|----------|-------|-----|------|------|----------|
| * | INP | UT | DAT | A | * |
| A | | | | | * |
| * * * * | * * * | *** | **** | **** | * |

| CONDUCTOR DATA | | GROUNDWIF | RE DATA | SPAN DATA | | |
|---|---|--|-------------------------------|---------------------------------------|----------------------------------|--|
| NUMBER PER PHASE
CONDUCTOR SPACING
VOLTAGE
VOLTAGE VARIATION
LINE FREQUENCY
FAIRWEATHER LOSSES | 2
18.0 IN
- 345 KV
10.00 PCT
60 CPS
1.70 KW/MI | NUMBER PER TOWER
DIAMETER
WEIGHT | 0
0.00 IN
0.0000 LBS/FT | MINIMUM
<u>Maximum</u>
Interval | 1000. FT
1600. FT
100.0 FT | |

WEATHER DATA MAXIMUM RAINFALL RATE 1.18 IN/HR MAXIMUM RAINFALL DURATION 1 HRS/YR AVERAGE RAINFALL RATE 0.03 IN/HR AVERAGE RAINFALL DURATION 636 HRS/YR MAXIMUM SNOWFALL RATE 1.87 IN/HR MAXIMUM SNOWFALL DURATION 1 HRS/YR AVERAGE SNOWFALL RATE 0.13 IN/HR AVERAGE SNOWFALL DURATION 264 HRS/YR RELATIVE AIR DENSITY 1.000

155.00 MILES

0,95

LINE LENGTH

POWER FACTOR

| * * * * | ***** | ****** | * * |
|----------|-------|--------|-----|
| * | | | * |
| # | INPUT | DATA | * |
| × | | | * |
| **** | | | |

SAG/TENSION DESIGN FACTORS

| EVERYDAY STRESS TEMPERATURE | 40. DEGREES F | ICE AND WIND TENSION (PCT UTS) | 50. PERCENT |
|-----------------------------------|----------------|--------------------------------|-----------------|
| ICE AND WIND TEMPERATURE | 0. DEGREES F | HIGH WIND TENSION (PCT UTS) | 50. PERCENT |
| HIGH WIND TEMPERATURE | 40. DEGRFES F | EXTREME ICE TENSION (PCT UTS) | 70. PERCENT |
| EXTREME ICE TEMPERATURE | 30, DEGREES F | ICE THICKNESS WITH WIND | 0.50 INCHES |
| MAX DESIGN TEMP FOR GND CLEARANCE | 120. DEGREES F | WIND PRESSURE WITH ICE | 4.00 LBS/S0.FT. |
| EDS TENSION (PCT UTS) | 20. PERCENT | HIGH WIND | 9.0 LBS/SQ.FT. |
| NESC CUNSTANT | 0.31 LBS/FT | | |
| | | EXTREME ICE | 0.50 INCHES |

TOWER DESIGN

1000. LBS

.0864

TOTAL NUMBER OF PHASES PHASE SPACING CONDUCTOR CONFIGURATION FACTOR GROUND CLEARANCE NO. OF INSULATORS PER TOWER INSULATOR SAFETY FACTOR STRING LENGTH I, VEE, OR COMBINATION FOUNDATION TYPE TERRAIN FACTOR LINE ANGLE FACTOR TOWER GROUNDING TRANSVERSE OVERLOAD FACTOR VERTICAL OVERLOAD FACTOR LONGITUDINAL LOAD MISCELLANEOUS HARDWARE WEIGHT TOWER WEIGHT FACTOR

| 3 | | DISTANCE | BETWEEN | PHASES: | |
|------|------------|--------------|---------|---------|---|
| 27.0 | FEET | | D1 | | |
| 1.02 | | | D2 | | |
| 32.0 | FEET | | D3 | | - |
| 72 | | | D4 | | |
| 2.50 | | | D5 | | |
| 9,5 | FEET | | D'6 | · . | |
| 3 | | • | | | |
| 4 | | | | | |
| 1.06 | PER UNIT | | | | |
| 0864 | | | | | |
| 0 | | | | | |
| 2.50 | | | | | |
| 1.50 | | *· • | | | |
| 000. | LBS | · | | | |
| 0.11 | TONS/TOWER | 5 - 1 | | | |
| 1.02 | | | 1 | | |

27.00 FT

27.00 FT

54.00 FT

0.00 FT

0.00 FT

0.00 FT

TOWER WEIGHT ESTIMATION ALGORITHM

. .

TOWER TYPE 10: 345KV TOWER

TW = 0.00043+TH++2 - 0.992111+TH++0.6000 - 0.10371+EFFVDL -0.27365*EFFTDL + 0.00503*TH*EFFTDL + 0.00181*TH*EFFVDL + 20.77701 KIPS

. . .

and in the same build

CONDUCTOR SUMMARY

| 11 | NUMBER | NAME | SIZE(KCM) | STRANDING
(AL/ST) | UN I T-WEIGHT
(LBS/FT) | OUT.DIAM.
(INCHES) | TOTAL AREA
(SQ.IN.) | MODULÚS
(EF/E6 PSI) | TEMP.COEF.
ALPHA*E-6
PER DEG F |
|----|--------|----------|-----------|----------------------|--------------------------------------|-----------------------|------------------------|------------------------|--------------------------------------|
| | 29 | STARLING | 715.0 | 26/ 7 | 0.9850 | 1.0510 | 0,6535 | 11.00 | 10.3 |
| | 30 | REDWING | 715.0 | 30/19 | 1.1110 | 1,0810 | 0.6901 | 11.30 | 9.7 |
| _ | 31 | CUCKOO | 795.0 | 24/7 | 1.0240 | 1.0920 | 0,7053 | 10,55 | 10.7 |
| 5 | 32 | DRAKE | 795.0 | 26/ 7 | 1,0940 | 1.1080 | 0.7261 | 11.00 | 10.3 |
| N | 33 | TERN | 795.0 | 45/ 7 | 0,8960 | 1,0630 | 0.6676 | 9,40 | 11.5 |
| | 34 | CONDOR | 795.0 | 54/ 7 | 1.0240 | 1.0930 | 0.7053 | 10.85 | 10,9 |
| | 35 | MALLARD | 795.0 | 30/19 | 1,2350 | 1.1400 | 0.7668 | 11.30 | 9.7 |
| | 36 | RUDDY | 900.0 | 45/ 7 | 1.0150 | 1.1310 | 0.7069 | 9.40 | 11.5 |
| | 37 | CANARY | 900.0 | 54/ 7 | 1,1590 | 1.1620 | 0,7985 | 10.85 | 10.9 |
| | 38 | RAIL | 954.0 | 45/ 7 | 1,0750 | 1,1650 | 0.8011 | 9.40 | 11.5 |
| | 39 | CARDINAL | 954.0 | 54/ 7 | 1,2290 | 1.1960 | 0.8464 | 10.85 | 10,9 |
| | 40 | ORTOLAN | 1033.0 | 45/ 7 | 1,1650 | 1,2130 | 0,8678 | 9.40 | 11.5 |

CONDUCTOR SUMMARY

| | | • | | | | AC RESIST. | | |
|-----------|----------|----------------------------|-------------------------|--------------|--------------------------|----------------------------|---------------------------|----------------------------|
| ID NUMBER | NAME | ULT.TENS.
STRENGTH(LBS) | GEOM.MEAN
RADIUS(FT) | PRICE(\$/LB) | THERM.LIMIT
(AMPERES) | AT 25 DEG C
(OHMS/MILE) | IND.REACT.
(OHMS7MILF) | CAP.REACT.
(MOHM-MILES) |
| *** | | | | ********** | | | | |
| 29 | STARLING | 28100.0 | 0.0355 | 0.608/1977 | 850. | 0.1294 | 0.4050 | 2,6453 |
| 30 | REDWING | 34600.0 | 0.0372 | 0.612/1977 | 860. | 0.1288 | 0,3992 | 2.5661 |
| 31 | CUCKDO | 27100.0 | 0.0366 | 0.636/1977 | 900. | 0.1214 | 0.3992 | 2.5502 |
| 32 | DRAKE | 31200.0 | 0.0375 | 0.622/1977 | 910. | 0.1172 | 0.3992 | 2.5450 |
| 33 | TERN | 22900.0 | 0.0352 | 0.677/1977 | 890. | 0,1188 | 0.4060 | 2,5766 |
| 34 | CUNDOR | 28500.0 | 0.0368 | 0.635/1977 | 900. | 0.1172 | 0.4002 | 2,5555 |
| 35 | MALLARD | 38400.0 | 0.0392 | 0.599/1977 | 910. | 0.1162 | 0.3928 | 2.5186 |
| 36 | RUDDY | 25400.0 | 0.0374 | 0.676/1977 | 935. | 0,1082 | 0.3928 | 2.5080 |
| 37 | CANARY | 32300.0 | 0.0392 | 0.633/1977 | 950. | 0.1040 | 0.3928 | 2,5027 |
| 35 | RAIL | 26900.0 | 0.0385 | 0.671/1977 | 970. | 0.0998 | 0.3949 | 2,5027 |
| 39 | CARDINAL | 34200.0 | 0.0404 | 0,632/1977 | 990. | 0,0987 | 0.3902 | 2.4816 |
| 4 () | ORTOLAN | 28900.0 | 0.0401 | 0.670/1977 | 1020. | 0.0924 | 0.3902 | 2.4658 |

-

in

مين بالمدمونية

المسترجيها

| UNIT MATERIALS COSTS | INPUT VALUE | REFERENCE YEAR FOR INPUT |
|------------------------------------|-----------------|--------------------------|
| ***** | ******** | |
| PRICE OF TOWER MATERIAL | 0.957 \$/LB | 1979 |
| PRICE OF CONCRETE | 0.00 \$/CU.YD. | 1977 |
| PRICE OF GROUND WIRE | 0.000 \$/LB | 1977 |
| INSTALLED COST OF GROUNDING SYSTEM | 0,00 \$/TOWER | 1977 |
| TOWER SETUP | 1751 | 1979 |
| TOWER ASSEMBLY | 0.455 \$/LB | 1979 |
| FOUNDATION SETUP | 0. \$ | 1979 |
| FOUNDATION ASSEMBLY | 4140.00 \$/TON | 1979 |
| FOUNDATION EXCAVATION | 0.00 \$/CU.YD. | 1979 |
| PRICE OF MISCELLANEOUS HARDWARE | 290,00 \$/TOWER | 1977 |

UNIT LABOR COSTS

. .

| REFERENCE YEAR LABOR COST | 24.00 \$/MANHOUR | 1979 |
|---------------------------|------------------|------|
| STRING GROUND WIRE | 0.0 S/MILE | 1977 |
| STRING LABOR MARKUP | 4.2 PER UNIT | |

UNIT TRANSPORTATION COSTS

| TOWER | 100.0 \$/TON |
|---------------------|-------------------------|
| FOUNDATION CONCRETE | 100.0 \$/YD |
| FOUNDATION STEEL | 100.0 \$/TON |
| CONDUCTOR | 100.0 \$/TON |
| GROUND WIRE | 100.0 \$/TON |
| INSULATOR | 100,0 \$/TON OR \$/M**3 |
| HARDWARE | 100.0 \$/TON |

1

.

1.1

********************* AUTOMATIC CONDUCTOR SELECTION * × ALL QUANTITIES PER MILE * × *********

CAPITAL COST/DISCOUNT RATE OF 7.00 PERCENT **********

PRESENT WORTH

| CONDUCTOR | | INSTALLED COST | | | | | LINE LOSSES | U&M COST | LINE COST | |
|-----------|-------|----------------|-----------|----------------|--------------|--|-------------|-----------------|-----------|---------|
| NO. | KCM | SPAN(FT) | MATERIALS | TRANSPORTATION | INSTALLATION | ENG/IDC | SUBTOTAL | SÜBTOTAL | SUBTOTAL | TOTAL |
| | | | | | | ****** | | | | ***** |
| 39 | 954. | 1300. | 114706. | 6714. | 117754. | 12953, | 252127. | 90411. | 5143. | 347681. |
| 39 | 954. | 1200. | 113228. | 6740. | - 119225; | 13115. | 252308. | 90411. | 5125. | 347843. |
| 40 | 1033. | 1200. | 117782. | 6840. | 121885. | 13407. | 259913. | 84621. | 5295. | 349829. |
| 37 | 900. | 1300 | 112812. | 6583, | 117342. | 12908, | 249645. | 95660. | 5082. | 350386. |
| 39 | 954. | 1400 | 117620. | 6769. | 117532. | 12928. | 254849. | 90411. | 5222. | 350482. |
| 37 | 900. | 1200. | 111385. | 6612. | 118824. | 13071. | 249892. | 95660. | 5065. | 350616. |
| 39 | 954. | 1100 | 113373. | 6859. | 122168. | 13438. | 255838. | 90411. | 5176. | 351425. |
| 40 | 1033. | 1100. | 116899. | 6910. | 124193. | 13661. | 261664. | 84621. | 5307. | 351591. |
| 40 | 1033. | 1300. | 120420. | · 6869 . | 121120. | 13323. | 261732. | 84621. | 5358, | 351711. |
| 37 | 900. | 1400 | 115679 | 6635. | 117111. | 12882. | 252308. | 95660. | 5159. | 353120. |
| 38 | 954- | 1200. | 114994 | 6662. | 121202. | 13332. | 256189. | 91853. | 5204. | 353246. |
| 35 | 795. | 1300. | 108253. | 6486. | 114488. | 12594. | 241821. | 107119. | 4908. | 353847. |
| 57 | 900. | 1100 | 111580. | 6734 | 121780. | 13396. | 253490. | 95660. | 5118. | 354268. |
| 35 | 795. | 1400. | 110039. | 6487. | 113599. | 12496. | 242620. | 107119. | 4944. | 354683. |
| 38 | 954. | 1300. | 117510. | 6684. | 120390. | 13243. | 257827. | 91853. | 5262. | 354942. |
| 38 | 954. | 1100 | 114231. | 6738 | 123557. | 13591. | 258117. | 91853. | 5220. | 355190. |
| 35 | 795. | 1200. | 107799. | 6561. | 116571. | 12823. | 243753. | 107119. | 4929. | 355800. |
| 39 | 954 | 1500. | 121880. | 6899. | 118425. | 13027. | 260230. | 90411. | 5357. | 355998. |
| 40 | 1033. | 1400 | 124683 | 6989 | 121712 | 13388. | 266772. | 84621. | 5488. | 356881. |
| 45 | 795. | 1500. | 113021. | 6554 | 113739. | 12511. | 245825. | 107119. | 5031. | 357975. |
| 32 | 795. | 1300. | 109255 | 6399 | 116128. | 12774 | 244556. | 108934. | 4960. | 358450. |
| | 900. | 1500. | 119895 | 6762 | 117998 | 12980. | 257634. | 95660. | 5293. | 358587. |
| 22 | 795 | 1200 | 108121 | 6443 | 117764 | 12954 | 245282 | 108934. | 4955. | 359170. |
| 36 | 900 | 1200 | 113498. | 6552 | 120883 | 13297 | 254229 | 100106. | 5156. | 359491. |
| 34 | 795. | 1300 | 109378 | 6341. | 116691. | 12836. | 245246. | 109437. | 4972. | 359654. |
| ۶ų | | -
- | 10/3/04 | | | ************************************** | | • • • • • • • • | ··· • • • | |

.

B-37

1

CONDUCTOR NUMBER = 39 954. KCMIL 1300. FT SPAN 94.7 FT TOWER

| INSTALLED COST
Breakdown | QUANTIT | Y | MATERIAL
CUST(\$) | TONNAGE | TRANSPORTATION
COST(5) | INSTALLATION
COST(3) | TOTAL
Cust(\$) |
|---|---------|-------|----------------------|---------|---------------------------|-------------------------|-------------------|
| \$\$\$ \$\$\$ \$\$\$ \$\$\$ \$\$\$ \$\$\$ \$\$\$ \$\$\$ \$\$\$ \$\$ | | - | | | ***** | | |
| CONDUCTOR | 31680. | FT | 28172. | 19.47 | 1947. | 25870 | 55989 |
| GROUNDWIRE | 0. | FT | 0. | 0.00 | 0. | 0 - | 0 |
| INSULATORS | 310. | UNITS | 1970. | 1.70 | 366 | | 2776 |
| HARDA ARF | | | 1429. | 0.47 | 47. | | 1477. |
| TOWERS | 4.3 | UNITS | 68496. | 35.79 | 3579. | 40104 | 112179. |
| FOUNDATIONS | 4.3 | UNITS | 4791. | • | 775. | 32083. | 37648 |
| RIGHT OF WAY | 14. | ACRES | 9848. | | • | 19697 | 29545 |
| IDC/ENGINEERING | | | 12953. | | | • • • • • | 12953 |
| | | | ***** | | | | |
| TOTALS | | | 114706. | 57.43 | 6714. | 117754. | 252127. |

| | PRESENT VALUE (\$) | | | | | |
|------------------------------------|--------------------|-----------------|-----------------|--|--|--|
| LOSS ANALYSIS | DEMAND LOSSES | ENERGY LOSSES | TOTAL LOSSES | | | |
| RESISTANCE LOSSES
CORONA LUSSES | 44314,
2088, | 39493.
4517. | 83807.
6604. | | | |
| TOTALS | 46401, | 44010. | 90411. | | | |

internationalista Autoria

·

INTERNATIONAL ENGINEERING CO. INC SAN FRANCISCO CALIFORNIA

TRANSMISSION LINE COST ANALYSIS PROGRAM VERSION 1: 23 FEB 1979,

DEVIL CANYON-ESTER 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION DATE: 12 APR 79 TIME: 9:45:19

| SYSTEM ECONOMIC FACTORS | INPUT VALUE | REFERENCE YEAR FOR INPUT |
|---|--|--------------------------|
| * | 97 Q Q Q Q Q Q Q Q Q Q Q Q Q Q Q Q Q Q Q | |
| STARTING YEAR OF STUDY | 1979 | |
| ENDING YFAR OF STUDY | 1996 | |
| BASE YEAR FOR ESCALATION | 1977 | |
| MAXIMUM CIRCUIT LOADING | 194.7 MVA | 1992 |
| AVERAGE CIRCUIT LOADING | 107.1 MVA | 1992 |
| DEMAND COST FACTOR | 73.0 \$/KW | 1979 |
| ENERGY COST FACTOR | 13.0 MILLS/ | KWH 1979 |
| VAR COST FACTOR | 0.0 \$/KVAR | 1984 |
| CAPITAL COST/DISCOUNT RATE: | • | |
| MINIMUM | 7.0 PERCEN | T 1984 |
| MAXIMUM | 10.0 PERCEN | T 1984 |
| NUMBER OF INTERVALS | 1 | |
| ORM COST FACTOR | 1.5 % CAP.I | COST 1979 |
| RIGHT OF WAY COST FACTOR | 715.0 \$/ACRE | 1979 |
| RIGHT OF WAY CLEARING COST | 1430.0 \$/ACRE | 1979 |
| INTEREST DURING CONSTRUCTION | 0.00 % INST | .CST |
| ENGINEERING FEE | 11.00 % INST | CST |

DEVIL CANYON-ESTER CASE II-2A 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION DATE: 12 APR 79 TIME: 9:45:19

| * * * * | * * * * | * * * | **: | * * * | *** |
|---------|---------|-------|-----|-------|-----|
| * | | | | | , |
| * | INPL | JT | DA | ΤA | 1 |
| * | | | | | |
| **** | * * * * | *** | ** | * * * | *** |

| | CONDUCTOR DATA | | GROUNDWI | RE DATA | SPA | N DATA |
|------|--|---|--|-------------------------------|--------------------------------|----------------------------------|
| D_70 | NUMBER PER PHASE
CONDUCTOR SPACING
VOLTAGE
VOLTAGE VARIATION
LINE FREQUENCY
FAIRWEATHER LOSSES
LINE LENGTH
PUWER FACTOR
WEATHER DATA | 1
0.0 IN
230 KV
10.00 PCT
60 CPS
0.00 KW/MI
189.00 MILES
0.95 | NUMBER PER TOWER
DIAMETER
WEIGHT | 0
0.00 IN
0.0000 LBS/FT | MINIMUM
MAXIMUM
INTERVAL | 1200. FT
1600. FT
100.G FT |
| | MAXIMUM RAINFALL RATE
MAXIMUM RAINFALL DURATION
AVERAGE RAINFALL DURATION
MAXIMUM SNOWFALL RATE
MAXIMUM SNOWFALL RATE
MAXIMUM SNOWFALL DURATION
AVERAGE SNOWFALL RATE
AVERAGE SNOWFALL DURATION
RELATIVE AIR DENSITY | 1.18 IN/HR
1 HRS/YR
0.03 IN/HR
636 HRS/YR
1.87 IN/HR
1 HRS/YR
0.13 IN/HR
264 HRS/YR
1.000 | | | | |

CASE II-2A DEVIL CANYON-ESTER 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION DATE: 12 APR 79 TIME: 9:45:19

| **** | * * * * * * | ****** | * * |
|------|-------------|--------|-----|
| * | | | * |
| * | INPUT | DATA | * |
| * | | | * |
| **** | ***** | ****** | ¥ × |

SAG/TENSION DESIGN FACTORS

PHASE SPACING

GROUND CLEARANCE

| EVERYDAY STRESS TEMPERATURE
ICE AND WIND TEMPERATURE
HIGH WIND TEMPERATURE
EXTREME ICE TEMPERATURE
MAX DESIGN TEMP FOR GND CLEARANCE
EDS TENSION (PCT UTS) | 40. DEGREES F
0. DEGREES F
40. DEGREES F
30. DEGREES F
120. DEGREES F
20. PERCENT
0. 31 LBS/FI | ICE AND WIND TENSION (PCT UTS)
HIGH WIND TENSION (PCT UTS)
EXTREME ICE TENSION (PCT UTS)
ICE THICKNESS WITH WIND
WIND PRESSURE WITH ICF
HIGH WIND | 50. PERCENT
50. PERCENT
70. PERCENT
0.50 INCHES
4.00 LBS/SQ.FT.
9.0 LBS/SQ.FT. |
|---|--|--|---|
| HESC CONSTANT | | FXTREME ICE | 0.50 INCHES |



3

4

0

1000. LBS

.0864

2,50

1.50

1,02

1.06 PER UNIT

0.11 TONS/TOWER

DISTANCE BETWEEN PHASES: 20.00 FT D1 20.00 FT 02 40.00 FT D3 0.00 FT D4 0,00 FT D5 0.00 FT D6

STRING LENGTH I, VEE, OR COMBINATION FOUNDATION TYPE TERRAIN FACTOR LINE ANGLE FACTOR TOWER GROUNDING TRANSVERSE OVERLOAD FACTOR VERTICAL OVERLUAD FACTOR LONGITUDINAL LOAD MISCELLANEOUS HARDWARE WEIGHT TOWER WEIGHT FACTOR

TOWER WEIGHT ESTIMATION ALGORITHM

TOWER TYPE 9: 230KV TOWER

TW = 0.00016*TH**2 - 3.09797*TH**0.3333 - 0.08943*EFFVDL -0.27367*EFFTDL + 0.00510*TH*EFFTDL + 0.00160*TH*EFFVDL + 18.37912 KIPS

DEVIL CANYON-ESTER 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION DATE: 12 APR 79 TIME: 9:45:19

· · · · ·

| * * * * | **** | ***** | * * * * |
|----------------|-----------|-------|---------|
| * | | | * |
| * | INPUT | DATA | * |
| * [`] | | | * |
| **** | * * * * * | **** | * * * * |

CONDUCTOR SUMMARY

| ID-NUMBER | NAME | SIZE (KCM) | STRANDING
(AL/ST) | UNIT WEIGHT
(LBS/FT) | OUT.DIAM.
(INCHES) | TOTAL AREA
(SQ.IN.) | MODULUS
(EF/E6 PSI) | TEMP.COEF.
ALPHA*E=6
PER DEG F |
|---------------------------------------|----------|------------|----------------------|-------------------------|-----------------------|------------------------|------------------------|--------------------------------------|
| | | | | | | | | ******** |
| 24 | GROSBEAK | 636.0 | 26/ 7 | 0.8750 | 0 9900 | 0 5800 | 11 00 | 10 7 |
| 25 | EGRET | 636.0 | 30/19 | 0.9880 | 1 0190 | 0.617/ | 11.00 | 10.3 |
| 26 | FLAMINGO | 666.0 | 24/ 7 | 0.8590 | 1 0000 | 0.50134 | 11.50 | 9.1 |
| 27 | GANNET | 666.0 | 26/ 7 | 0 9180 | 1 01//0 | 0 4097 | 10,00 | 10.7 |
| 28 | STILT | 715.0 | 24/7 | 0 0210 | 1 0740 | 0.0007 | 11.00 | 10.5 |
| 2.9 | STARLING | 715 0 | 26/7 | 0 0950 | 1.0500 | 0.0340 | 10,55 | 10.7 |
| 31) | REDWING | 715 0 | 30/10 | 1 1110 | | 0.000 | 11,00 | 10.5 |
| 31 | СИСКОЛ | 795 0 | 30717 | | 1.0810 | 0.6901 | 11,30 | 9.7 |
| 7,2 | DDAKE | 793.0 | 24/ / | 1.0240 | 1,0920 | 0.7053 | 10,55 | 10.7 |
| 77 | TEDU | 795.0 | 26/ 1 | 1.0940 | 1.1080 | 0.7261 | 11.00 | 10.3 |
| 3 3 | 1 E R M | .795.0 | 45/ 7 | 0,8960 | 1.0630 | 0.6676 | 9,40 | .11.5 |
| 54 | CUNDOR | 795.0 | 54/ 7 | 1.0240 | 1.0930 | 0.7053 | 10.85 | 10.9 |
| 35 | MALLARD | 795.0 | 30/19 | 1.2350 | 1.1400 | 0.7668 | 11.30 | 97 |
| 36 | RUDDY | 900.0 | 45/ 7 | 1,0150 | 1.1310 | 0 7069 | 9 // 0 | 11 5 |
| 37 | CANARY | 900.0 | 54/7 | 1 1590 | 1 1620 | 0.7007 | 7,40 | 11.5 |
| 35 | RATI | 95/1 0 | 15/7 | 1 0750 | 1.1020 | 0.7905 | 10.85 | 10.9 |
| 3.0 | CAPDINAL | | 437 7 | 1.0700 | 1.1050 | 0.8011 | 9.40 | 11.5 |
| , , , , , , , , , , , , , , , , , , , | CARDINAL | 954.0 | 54/ / | 1.2290 | 1.1960 | 0.8464 | 10.85 | 10.9 |

· · · · · · · ·

DEVIL CANYON-ESTER CASE II-2A 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION DATE: 12 APR 79 TIME: 9:45:19

. .

B-43

......

CONDUCTOR SUMMARY

| ID NUMBER | NAME | ULT.TENS.
STRENGTH(LBS) | GEOM,MEAN
RADIUS(FT) | PRICE(\$/LB) | THERM.LIMIT
(AMPERES) | AC RESIST.
AT 25 DEG C
(OHMS/MILE) | IND.REACT.
(OHMS/MILE) | CAP.REACT.
(MOHM-MILES) |
|------------|----------|----------------------------|-------------------------|--------------|--------------------------|--|---------------------------|----------------------------|
| | | | ******** | **** | | ********** | | ********** |
| 24 | GROSBEAK | 25000.0 | 0.0335 | 0.628/1977 | 790. | 0.1452 | 0.4118 | 2.6347 |
| 25 | EGRET | 31500.0 | 0.0351 | 0.609/1977 | 870. | 0.1447 | 0.4060 | 2.6136 |
| 5 2 | FLAMINGO | 23700.0 | 0.0335 | 0.640/1977 | 810. | 0.1399 | 0.4118 | 2.6294 |
| 27 | GANNET | 56500.0 | 0,0343 | 0.609/1977 | 820, | 0.1373 | 0.4092 | 2.6347 |
| 5 8 | SILLT | 25500.0 | 0.0347 | 0.627/1977 | 840. | 0.1320 | 0.4066 | 2.6400 |
| 5,9 | SIARLING | 28100.0 | 0,0355 | 0.608/1977 | 850. | 0,1294 | 0.4050 | 2.6453 |
| 30 | REDWING | 34600.0 | 0.0372 | 0,612/1977 | 860. | 0.1288 | 0.3992 | 2.5661 |
| 31 | CUCKOO | 27100.0 | 0.0366 | 0.636/1977 | 900. | 0.1214 | 0.3992 | 2.5502 |
| 32 | DRAKE | 31200.0 | 0.0375 | 0,622/1977 | 910. | 0,1172 | 0.3992 | 2,5450 |
| 35 | TERN | 55800.0 | 0,0352 | 0.677/1977 | 890. | 0.1188 | 0.4060 | 2.5766 |
| 34 | CONDOR | 28500.0 | 0.0368 | 0.635/1977 | 900. | 0.1172 | 0.4002 | 2,5555 |
| 35 | MALLARD | 38400.0 | 0.0392 | 0,599/1977 | 910. | 0.1162 | 0.3928 | 2.5186 |
| 35 | RUDDY | 25400.0 | 0.0374 | 0,676/1977 | 935. | 0,1082 | 0.3928 | 2.5080 |
| 37 | CANARY | 32300.0 | 0.0392 | 0.633/1977 | 950. | 0.1040 | 0.3928 | 2.5027 |
| 38 | PAIL | 26900.0 | 0.0385 | 0.671/1977 | 970. | 0.0998 | 0.3949 | 2.5027 |
| 39 | CARDINAL | 34200.0 | 0.0404 | 0.632/1977 | 990. | 0,0987 | 0.3902 | 2,4816 |

DEVIL CANYON-ESTER CASE II-24 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION DATE: 12 APR 79 TIME: 9:45:19

*

.

| | * INPUT DATA * | | | | | | |
|-------------------------------|--------------------|--------------------------|--|--|--|--|--|
| ********** | | | | | | | |
| UNIT MATERIALS COSTS | INPUT VALUE | REFERENCE YEAR FOR INPUT | | | | | |
| | | | | | | | |
| PRICE OF TOWER MATERIAL | 0.957 \$/LB | 1979 | | | | | |
| PRICE OF CONCRETE | 0.00 \$/CU.YD. | 1977 | | | | | |
| PRICE OF GROUND WIRE | 0.000 \$/LB | 1977 | | | | | |
| INSTALLED COST OF GROUNDING S | YSTEM 0.00 S/TOWER | 1977 | | | | | |
| TOWER SETUP | 1751. \$ | 1979 | | | | | |
| TOWER ASSEMBLY | 0.455 \$/LB | 1979 | | | | | |
| FOUNDATION SETUP | 0.5 | 1979 | | | | | |
| FOUNDATION ASSEMBLY | 4140.00 \$/TON | 1979 | | | | | |
| FOUNDATION EXCAVATION | 0.00 \$/CU.YD. | 1979 | | | | | |
| PRICE OF MISCELLANEOUS HARDWA | RE 290.00 \$/TOWER | 1977 | | | | | |

.

****** * UNIT LAHOR COSTS -----

| REFERENCE YEAR LABOR COST | 24.00 \$/MANHOUR | 1979 |
|---------------------------|------------------|------|
| STRING GROUND WIRE | 0.0 \$/MILE | 1977 |
| STRING LABOR MARKUP | 4.2 PER UNIT | |

UNIT TRANSPORTATION COSTS

| TOWFR | 100.0 S/TON |
|---------------------|-------------------------|
| FOUNDATION CONCRETE | 100.0 \$/YD |
| FOUNDATION STEEL | 100.0 \$/TON |
| CONDUCTOR | 100.0 \$/TON |
| GROUND WIRE | 100.0 \$/TON |
| INSULATOR | 100.0 \$/TON DR \$/M**3 |
| HARDWARE | 100.0 \$/TON |
| | |

B-44

.

DEVIL CANYON-ESTER 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION DATE: 12 APR 79 TIME: 9:45:19

•

3.

B-45

| ******************************* | *** |
|---|-----|
| * | * |
| * AUTOMATIC CONDUCTOR SELECTION | × |
| ALL QUANTITIES PER MILE | * |
| * | * |
| ******* | *** |

PRESENT WORTH

CAPITAL COST/DISCOUNT RATE OF 7.00 PERCENT

| CUND | IC TOR | | | : | INSTALLED COST | | | LINE LOSSES | O&M COST | LINE COST |
|------|-------------|----------|-----------|--------------------|-----------------|---------|----------|-------------|----------|-----------|
| NÜ. | K C M | SPAN(FT) | MATERIALS | TRANSPORTATION | INSTALLATION | ENG/IDC | SUBTOTAL | SUBTOTAL | SUBTOTAL | FOTAL |
| | | | | | | • | | | | |
| 39 | 954. | 1300. | 68147. | 3834. | 84796. | 9328. | 166104. | 36988. | 3284. | 206376. |
| 37 | 90 . | 1300. | 67299. | 3772. | 84608. | 9307. | 164986. | 39195. | 3257. | 207436. |
| 35 | 795. | 1300. | 64664. | 3721. | 82616. | 9088. | 160089. | 44359. | 3151. | 207598. |
| 35 | 795. | 1400. | 65375. | 3684. | 82031. | 9023. | 160113. | 44359. | 3161. | 207633. |
| 39 | 954. | 1400. | 69552. | 3828. | 84673. | 9314. | 167367. | 36988. | 3355. | 207676. |
| 37 | 900. | 1400. | 68697. | 3766. | 84494. | 9294. | 166251. | 39195. | 3294. | 208739. |
| 35 | 795 | 1500. | 66879. | 3689. | 82176. | 9039. | 161784. | 44359. | 3206. | 209348. |
| 32 | 795. | 1300 | 65558. | 3685. | 83893. | 9228. | 162364. | 44830. | 3195. | 210389. |
| 39 | 954 | 1500. | 71843. | 3870 | 85337. | 9387. | 170437. | 36988. | 3397. | 210821. |
| 38 | 954 | 1300. | 70136 | 3831. | 86787. | 9547. | 170300. | 37456. | 3371. | 211126. |
| 34 | 195 | 1500. | 65807. | 3659 | 84359 | 9279. | 163104. | 44915. | 3209. | 211228. |
| 32 | 795 | 1400 | 66784 | 3669. | 83683. | 9205. | 163342. | 44830. | 3226. | 211398. |
| 39 | 954 | 1200. | 70386. | 4033. | 87082- | 9579. | 171080. | 36988. | 3385. | 211453. |
| 30 | 715 | 1300 | 63510. | 3615 | 82301. | 9053. | 158478. | 50049. | 3112. | 211639, |
| 30 | 715 | 1400 | 64204 | 3576. | 81729 | 8990 | 158498 | 50049 | 3122. | 211669. |
| 37 | 900 | 1500 | 70983 | 3807 | 85172 | 9369 | 169331. | 39195 | 3369. | 211894. |
| 35 | 795 | 1.500. | 69124 | 3735 | 82979 | 9128 | 164966 | 44359 | 3282. | 212607. |
| 30 | 735 | 1//00 | 67235 | 3653 | 84298 | 9273 | 164459 | 44915 | 3248. | 212621. |
| 27 | 000 | 1200 | 69671 | 3075 | 86926 | 9562 | 170096 | 39195 | 3361. | 212651. |
| 75 | 705 | 1200. | 64880 | 3016 | 85020 | 9352 | 165176. | 44359 | 3254 | 212788. |
| 20 | 715 | 1200. | 46703 | 2590 | 81804 | 0000 | 160187 | 50049 | 3167. | 213402. |
| 50 | 110. | 1000 | 60400 | 2,000 + | 01070¢
04403 | 0575 | 140/04 | //0968 | 3351 | 213814 |
| 30 | 900. | 1300. | 09499. | 3700. | 00002 # | 7333. | 177070 | 77/54 | 3001. | 213934 |
| 38 | 954. | 1400. | 12348. | 3501. | 01634 | - 07Ce | 144100 | 1/1970 | 1205 | 214277 |
| 52 | 795. | - 1500. | 68883. | 5701. | 84257. | 9268. | 100109- | 44020. | 2673. | 21/202 |
| 38 | 954. | 1500. | 71305. | 3980. | 88398. | 9124. | 1/540/. | 51420. | 2421+ | C14673+ |

the second s

DEVIL CANYON-ESTER CASE II-2A 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION DATE: 12 APR 79 TIME: 9:45:19

ø

(II)

| R (| | |
|------------|----------------------|---|
| * | COST OUTPUT PER MILE | ; |
| * | PRESENT VALUE RATE | 1 |
| * | 7.00 PERCENT | , |
| * . | | ; |
| | | |

CONDUCTOR NUMBER = 39 954, KCMIL 1300, FT SPAN 87.7 FT TOWER

| INSTALLED COST
HREAKDOWN | QUANTITY | | MATERIAL
COST(\$) | TONNAGE | TRANSPORTATION
COST(\$) | INSTALLATION
COST(\$) | TOTAL
COST(\$) |
|-----------------------------|----------------|-------|------------------------|---------------|----------------------------|--------------------------|-------------------|
| CONDUCTOR | 15840. F | T | 14086. | 9.73 | 973. | 18257. | 33316. |
| INSULATORS | 0, F
207, U | INITS | 1313. | 0.00 | 244. | 0. | 1557. |
| HARDWARE | 4.3 U | INITS | 1429.
38870. | 0_47
20_31 | 47.
2031. | 26019. | 1477.
66921. |
| FOUNDATIONS
RIGHT OF WAY | 4,3 U | INITS | 3327 .
9120. | | 538. | 22280. | 26145.
27361. |
| IDC/ENGINEERING | | | 9328 | | | | 9328. |
| TOTALS | | | 68147. | 31.65 | 3834. | 84796. | 166104. |

| | PRESENT VALUE (\$) | | | | | | |
|------------------------------------|--------------------|---------------|-----------------------|--|--|--|--|
| LOSS ANALYSIS | DEMAND LOSSES | ENERGY LOSSES | TOTAL LOSSES | | | | |
| RESISTANCE LOSSES
Corona Losses | 19547.
0. | 17422.
19. | 36969 .
19. | | | | |
| TOTALS | 19547. | 17441. | 36988, | | | | |

1

INTERNATIONAL ENGINFERING CO. INC SAN FRANCISCO CALIFORNIA

TRANSMISSION LINE COST ANALYSIS PROGRAM VERSION 1: 23 FEB 1979,

WATANA-DEVIL CANYON CASE II-3A 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION DATE: 12 APR 79 TIME: 9:02:43

| **: | * * | * | * | × | * | × | * | * | * | * | * | × | * | × | * |
|-----|-----|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| × | | | | | | | | | | | | | | | * |
| * | | I | N | Ρ | U | T | | D | A | T | Ą | | | | ŧ |
| * | | | | | | | | | | | | | | | * |
| ** | * * | * | × | × | * | * | * | * | * | × | * | * | ¥ | A | * |

INPUT VALUE

SYSTEM ECONOMIC FACTORS

STARTING YEAR OF STUDY ENDING YEAR OF STUDY BASE YEAR FUR ESCALATION MAXIMUM CIRCUIT LUADING AVERAGE CIRCUIT LUADING DEMAND COST FACTOR ENERGY COST FACTOR VAR CUST FACTOR CAPITAL COST/DISCOUNT RATE: MINIMUM MAXIMUM NUMBER OF INTERVALS O&M COST FACTOR RIGHT OF WAY COST FACTOR RIGHT OF WAY CLEARING COST

INTEREST DURING CONSTRUCTION

ENGINEERING FEE

_____ -------1979 1996 1977 514.0 MVA 1992 282.7 MVA 1992 73.0 \$/KW 1979 13.0 MILLS/KWH 1979 0.0 \$/KVAR 1984 7.0 PERCENT 1984 10.0 PERCENT 1984 1 1979 1.5 % CAP.COST 1979 715.0 \$/ACRE 1430.0 \$/ACRE 1979 0.00 % INST.CST 11.00 % INST.CST

REFERENCE YEAR FOR INPUT

WATANA-DEVIL CANYON 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION DATE: 12 APR 79 TIME: 9:02:43

| **** | **** | *** | * |
|------|-------|--------|----------|
| * | | | * |
| * | INPUT | DATA | * |
| * | | | × |
| **** | **** | ****** | * * |

1200. FT 1600. FT 100.0 FT

| CONDUCTOR DATA | A | GROUNDWIK | SPAN DATA | | |
|--|---|--|-------------------------------|--------------------------------|--|
| NUMBER PER PHASE
CONDUCTOR SPACING
VOLTAGE
VOLTAGE VARIATION
LINE FREQUENCY
FAIRWEATHER LOSSES
LINE LENGTH
POWER FACTOR | 1
0.0 IN
230 KV
10.00 PCT
60 CPS
0.00 KW/MI
27.00 MILES
0.95 | NUMBER PER TOWER
DIAMETER
WEIGHT | 0
0.00 IN
0.0000 LBS/FT | MINIMUM
Maximum
Interval | |
| WEATHER DATA | | | | | |
| MAXIMUM RAINFALL RATE
MAXIMUM RAINFALL DURATION
AVERAGE RAINFALL RATE
AVERAGE RAINFALL DURATION
MAXIMUM SHOWFALL RATE
MAXIMUM SNOWFALL DURATION
AVERAGE SNOWFALL RATE
AVERAGE SNOWFALL DURATION
RELATIVE AIR DENSITY | 1.18 IN/HR
1 HRS/YR
0.03 IN/HR
636 HRS/YR
1.87 IN/HR
1 HRS/YR
0.13 IN/HR
264 HRS/YR
1.000 | | | | |

B-48

| * * * | * * * * | *** | *** | * * * * | : * |
|-------|---------|-----|-----|---------|-----|
| * | | | | | * |
| × | INF | דטי | DAT | A | × |
| × | | | | | * |
| * * * | **** | *** | *** | **** | * |

SAG/TENSION DESIGN FACTORS

| EVERYDAY STRESS TEMPERATURE | 40. DEGREES F | ICE AND WIND TENSION (PCT UTS) | 50. PERCENT |
|-----------------------------------|----------------|--------------------------------|-----------------|
| ICE AND WIND TEMPERATURE | 0. DEGREES F | HIGH WIND TENSION (PCT UTS) | 50. PERCENT |
| HIGH WIND TEMPERATURE | 40. DEGREES F | EXTREME ICE TENSION (PCT UTS) | 70. PERCENT |
| EXTREME ICE TEMPERATURE | 30. DEGREES F | ICE THICKNESS WITH WIND | 0.50 INCHES |
| MAX DESIGN TEMP FOR GND CLEARANCE | 120. DEGREES F | WIND PRESSURE WITH ICE | 4.00 LBS/SQ.FT. |
| EDS TENSION (PCT UTS) | 20. PERCENT | HIGH WIND | 9.0 LBS/SQ.FT. |
| NESC CONSTANT | 0,31 LBS/FT | EXTREME ICE | 0.50 INCHES |

. .

TOWER DESIGN

| TOTAL NUMBER OF DUARES | z . | DISTANCE BETWEEN PHASES: | |
|--------------------------------|-----------------|--------------------------|----------|
| TUTAL NUMBER OF PHASES | 30 0 EEET | DI | 20.00 FT |
| PHASE SPACING | EV.V FECT | | 30 00 57 |
| CONDUCTOR CONFIGURATION FACTOR | 1.02 | 02 | 20.00 FT |
| GROUND CLEARANCE | 28.0 FEET | D3 | 40.00 FT |
| NO. OF INSULATORS PER TOWER | 48 | D4 | 0.00 FT |
| INSULATOR SAFFTY FACTOR | 2.50 | 05 | 0.00 FT |
| STRING LENGTH | 6.5 FEET | D6 | 0,00 FT |
| I, VEE, OR COMBINATION | 3 | | |
| FOUNDATION TYPE | 4 | | |
| TERRAIN FACTOR . | 1,06 PER UNIT | | |
| LINE ANGLE FACTOR | .0864 | | |
| TOWER GROUNDING | 0 | | |
| TRANSVERSE OVERLOAD FACTOR | 2,50 | | |
| VERTICAL OVERLOAD FACTOR | 1.50 | | |
| LONGITUDINAL LOAD | 1000, LBS | | |
| MISCELLANEOUS HARDWARE WEIGHT | 0.11 TONS/TOWER | | |
| TOWER WEIGHT FACTOR | 1.02 | | |

TOWER WEIGHT ESTIMATION ALGORITHM

TOWER TYPE 9: 230KV TOWER

```
.,
TW = 0.00016*TH**2 - 3.09797*TH**0.3333 - 0.08943*EFFVDL -
0.27367*EFFTDL + 0.00510*TH*EFFTDL + 0.00160*TH*FFFVDL +
18.37912 KIPS
```

B-49

CONDUCTOR SUMMARY

TEMP.COFF. STRANDING UNIT WEIGHT OUT.DIAM. TOTAL AREA MODULUS ALPHA*E=6 ID NUMBER NAME SIZF(KCM) (AL/ST)(LRS/FT) (INCHES) (SQ.IN.) (EF/E6 PSI) PER DEG F --------------_____ -----_____ ------______ 52 NUTHATCH 1510.0 45/ 7 1.7020 1.4660 1.2680 9.40 11.5 53 PARROT 1510.0 54/19 1,9420 1,5060 1,3366 10.30 10.8 51 LAPWING 1590.0 45/ 7 1,7920 1,5020 1.3350 9.40 11.5 55 FALCON 1590.0 54/19 2.0440 1.4076 1.5450 10.30 10.8 50 CHUKAR 1780.0 84/19 2.0740 1.6020 1.5120 9.05 11.3 57 HLUEBIRD 2156.0 84/19 2,5120 1,7620 1.8280 9.05 11.3 53 KIWI 2167.0 72/7 2,3040 1,7370 1.7760 9,25 12.0

WATANA-DEVIL CANYON 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION DATE: 12 APR 79 TIME: 9:02:43

.

CONDUCTOR SUMMARY

.

| ID NUMBER | ' NAME | ULT.TENS.
STRENGTH(LBS) | GEOM.MEAN
RADIUS(FT) | PRICE(\$/LB) | THERM.LIMIT
(AMPERES) | AC RESIST.
AT 25 DEG C
(OHMS/MILE) | IND.REACT.
(OHMS/MILE) | CAP.REACT.
(MOHM-MILES) |
|-----------|----------|----------------------------|-------------------------|--------------|--------------------------|--|---------------------------|----------------------------|
| 52 | NUTHATCH | 41600.0 | 0.0485 | 0.664/1977 | 1300. | 0.0649 | 0.3670 | 2,3126 |
| 53 | PARROT | 53200.0 | 0.0508 | 0.630/1977 | 1320. | 0.0602 | 0.3622 | 2.2862 |
| 54 | LAPWING | 43800.0 | 0.0497 | 0.660/1977 | 1340. | 0.0623 | 0.3638 | 2.2915 |
| 55 | FALCON | 56000.0 | 0.0521 | 0.636/1977 | 1360. | 0.0612 | 0.3580 | 2.2704 |
| 56 | CHUKAR | 53600.0 | 0.0534 | 0.675/1977 | 1440. | 0.0560 | 0.3548 | 2.2387 |
| 57 | BLUEBIRD | 63400.0 | 0,0588 | 0.673/1977 | 1610. | 0.0475 | 0.3443 | 2.1648 |
| 58 | KIWI | 50900.0 | 0.0570 | 0.699/1977 | 1600. | 0.0480 | 0.3480 | 2,1806 |

| * * * * | * * * | * * * | *** | **** | * |
|---------|-------|-------|-----|------|---|
| * | | | | | ¥ |
| * | INP | UT | DAT | A | × |
| * | | | | | * |
| * * * * | * * * | * * * | *** | **** | * |

| UNIT MATERIALS COSTS | INPUT | VALUF | REFERENCE YEAR FOR INPUT |
|------------------------------------|---------|-----------|--------------------------|
| **=********* | ***** | ***** | *** |
| PRICE OF TOWER MATERIAL | 0.957 | \$/LB | 1979 |
| PRICE OF CONCRETE | 0.00 | \$/CU.YD. | 1977 |
| PRICE OF GROUND WIRE | 0.000 | \$/LB | 1977 |
| INSTALLED COST OF GROUNDING SYSTEM | 0.00 | \$/TOWER | 1977 |
| TOWER SETUP | 1751. | \$ | 1979 |
| TOWER ASSEMBLY | 0,455 | \$/LB | 1979 |
| FOUNDATION SETUP | Ο, | \$ | 1979 |
| FOUNDATION ASSEMBLY | 4140.00 | \$/TON | 1979 |
| FOUNDATION EXCAVATION | 0.00 | \$/CU,YD, | 1979 |
| PRICE OF MISCFLLANEOUS HARDWARE | 290.00 | \$/TOWER | 1977 |

UNIT LABOR COSTS

| - | - | - | - | - | - | _ | _ | - | - | - | - | - | - | _ | _ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | |

•

| REFEPENCE YEAR LABOR COST | 24.00 \$7MANHOUR | 1979 |
|---------------------------|------------------|------|
| STRING GROUND WIRE | 0.0 S/MILE | 1977 |
| STRING LABOR MARKUP | 4.2 PER UNIT | |

UNIT TRANSPORTATION COSTS

| TOWER | 100,0 \$/TON |
|---------------------|-------------------------|
| FOUNDATION CONCRETE | 100.0 \$/YD |
| FOUNDATION STEEL | 100.0 S/TON |
| CONDUCTOR | 100,0 \$/TON |
| GROUND WIRE | 100.0 \$/TON |
| INSULATOR | 100.0 \$/TON OR \$/M**3 |
| HARDWARE | 100.0 S/TON |

| * * * * | * | * : | * | * | × | × | * | * | × | * | × | * | × | * | * | Ŕ | * | × | * | × | * | * | * | × | × | * | * | * | × | × | * | × | × | * |
|--------------|-----|-----|------------|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|-----|-----|---|---|---|---|---|---|---|---|---|---|---|---|
| A | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | × |
| # | AL | J. | T (| 0 | М | A | T | I | С | | С | 0 | N | D | U | C | T | 0 | R | | SI | E١ | Ľ | E | С | T | I | 0 | N | | | | | * |
| * | | | ٠, | A | L | L | | Ŋ | U | A | Ν | T | I | T | I | E | S | | P | E | R | 1 | М | I | L | Ε | | | | | | | | × |
| ¥ | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | * |
| * * * * | * : | k i | k : | × | * | * | × | × | A | Ŕ | Ŕ | * | * | × | * | × | * | × | ¥ | × | * : | * : | × | × | A | * | * | * | * | × | * | * | * | * |

÷.

CAPITAL COST/DISCOUNT RATE OF 7.00 PERCENT

PRESENT WORTH

| COND | UCTOR | | | | INSTALLED COST | | | LINF LOSSES | U&M COST | LINE COST |
|------|-------|----------|-----------|----------------|----------------|---------|----------|-------------|----------|-----------|
| NU. | KLM | SPAN(FT) | MATERIALS | TRANSPORTATION | INSTALLATION | ENG/IDC | SUBTOTAL | SUBTOTAL | SURTOTAL | TOTAL |
| | | | | | | | | | | |
| 57 | 2156. | 1300. | 89569. | 5105. | 90521. | 9957. | 195153. | 116334. | 3992. | 315478. |
| 57 | 2156. | 1200. | 90137. | 5217. | 92027. | 10123. | 197504. | 116334. | 4033. | 317870. |
| 57 | 2156. | 1400. | 92123. | 5160. | 90934. | 10003. | 198219. | 116334. | 4071. | 318623. |
| 58 | 2167. | 1300. | 92415. | 5125. | 93237. | 10256. | 201033. | | -4114. | 322730. |
| 58 | 2167. | 1500. | 92234. | 5204. | 94210. | 10363. | 202012. | 117583. | 4125. | 323720. |
| 57 | 2156. | 1500. | 95709. | 5268. | 92163. | 10138. | 203339. | 116334. | 4194. | 323866. |
| 56 | 1780. | 1300. | 82764. | 4678. | 88729. | 9760. | 185931. | 137630. | 3767. | 327327. |
| 58 | 2167. | 1400. | 95989. | 5226. | 94328. | 10376. | 205919. | 117583. | 4233. | 327734, |
| 56 | 1780. | 1400. | 84951. | 4714. | 88966. | 9786. | 188417. | 137630. | 3833. | 329879. |
| 56 | 1780. | 1200. | 83451. | 4796. | 90292 | 9932. | 188471. | 137630. | 3812. | 329912. |
| 53 | 1510. | 1300. | 77500. | 4479. | 87032. | 9573. | 178584. | 148218. | 3590. | 330391. |
| 57 | 2156. | 1600. | 100185. | 5423. | 94144. | 10356. | 210108. | 116334. | 4350. | 330792. |
| 53 | 1510. | 1400. | 79192. | 4490. | 86974. | 9567. | 180224. | 148218. | 3637. | 332078. |
| 56 | 1780. | 1500. | 88068. | 4799. | 90008. | 9901. | 192776. | 137630. | 3937. | 334342. |
| 53 | 1510. | 1200. | 79083. | 4642. | 89077. | 9798 | 182601. | 148218. | 3669. | 334486. |
| 55 | 1590. | 1300. | 79058 | 4570. | 87330. | 9606. | 180565, | 150744. | 3640. | 334949. |
| 58 | 2167. | 1500. | 100672. | 5386. | 96330. | 10596. | 212984. | 117583. | 4397. | 334964, |
| 53 | 1510. | 1500. | 81760. | 4550. | 87688. | 9646. | 183644. | 148218. | 3721 | 335582. |
| 55 | 1590. | 1400. | 80792. | 4584. | 87283. | 9601. | 182260. | 150744. | 3688. | 336692. |
| 52 | 1510. | 1200. | 72903. | 4188. | 87159. | 9587, | 173837. | 160117. | 3459. | 337413. |
| 55 | 1590. | 1200. | 80560. | 4729. | 89344. | 9828 | 184460 | 150744. | 3716. | 338920. |
| 55 | 1590. | 1500. | 83400. | 4646. | 88008. | 9681. | 185734. | 150744. | 3773. | 340251. |
| 56 | 1780. | 1600. | 92071. | 4932. | 91788. | 10097. | 198888. | 137630. | 4079 | 340596. |
| 54 | 1590. | 1300. | 79970. | 4495. | 89119. | 9803. | 183387. | 153527. | 3692. | 340605. |
| 53 | 1510. | 1600. | 85158. | 4653. | 89108. | 9802. | 188721. | 148218. | 3840. | 340778. |

B-53

:

CONDUCTOR NUMBER = 57 2156. KCMIL 1300. FT SPAN 87.4 FT TOWER

| INSTALLED COST
BREAKDOWN | QUANTIT | Y - | MATERIAL
COST(\$) | TONNAGE | TRANSPORTATION
COST(\$) | INSTALLATION
COST(\$) | TOTAL
Cost(\$) |
|-----------------------------|---------|-------|----------------------|---------|----------------------------|--------------------------|-------------------|
| | 150/10 | E T | 70/50 | 10.00 | 1000 | 21770 | 5 |
| CONDUCTOR | 12040. | | 50059. | 19.90 | 1990. | 21/30. | 54378. |
| CKHUNDWIKE | 0. | F 1 | 0. | 0.00 | 0. | 0. | Ο. |
| INSULATORS | 207. | UNITS | 1313. | 1.14 | 244. | | 1557. |
| HARDWARE | | | 1429. | 0.47 | 47. | | 1477. |
| TOWERS | 4.3 | UNITS | 43756. | 22.86 | 2286. | 28342. | 74384 |
| FOUNDATIONS | 4.3 | UNITS | 3327. | | 538. | 22280. | 26145. |
| RIGHT OF WAY | 13. | ACRES | 9085 | | | 18170. | 27255. |
| IDC/ENGINFFRING | | | 9957. | | | | 9957. |
| | | | | | | | |
| TOTALS | | | 89569. | 44.37 | 5105. | 90521. | 195153. |

PRESENT VALUE (\$)

| LOSS ANALYSIS | DFMAND LOSSES | ENERGY LOSSES | TOTAL LOSSES |
|-------------------|-------------------|---------------|--------------|
| | | | |
| RESISTANCE LOSSES | 61516. | 54818. | 116334. |
| CORONA L'OSSES | 0. | 0. | 0. |
| | Q = 2 = 2 = 2 ≤ 4 | | |
| TOTALS | 61516. | 54818. | 116334. |

B-54

APPENDIX C MULTI-AREA RELIABILITY PROGRAM (MAREL)

APPENDIX C

| Power
Technologies
Inc | MULTI AREA
RELIABILITY PROGRAM (MAREL) | BULLETIN
PTI/103
Page 1 of 3 |
|------------------------------|---|------------------------------------|
| P.O. BOX 1058 | SCHENECTADY, NEW YORK 12301 | 5 8 3 7 4 - 2 2 0 |

SUMMARY

The Multi-Area Reliability Program (MAREL) computes the Loss of Load Probability (LOLP) reliability index for electric generating systems of several areas interconnected by a transmission network without any restrictions on the network topology. The program permits the study of large power pools and reliability councils as well as individual utilities imbedded in an extensive interconnection. The program is intended to be used in the design and analysis of generation systems and the interconnection capability requirements needed to share reserves among the interconnected areas. The program may be used for as many as six or seven interconnected areas modeled directly. A greater number may be accommodated by developing equivalent systems. The output includes area and total system LOLP indices as well as data or the probable causes of failures and their locations in the network. The program structure is flexible so that load and capacity models may be as detailed as required and at the same time, the complex evaluation of the individual area reliability levels may be performed with efficiency.

PROGRAM ELEMENTS AND MODELS The structure of MAREL is shown in block form on Figure 1. Input data may be provided for each case or partially supplied by saved case files. The program structure is set up to analyze one year at a time under the control of the user. This facilitates the development of system expansions interactively or with a series of runs on a batch basis without the risk of the possibility of using excessive computer time.



FIGURE 1

STRUCTURE OF MULTI AREA RELIABILITY PROGRAM

PTI/103

- Loads are modeled by area with distributions of peak loads for each 'season' of the year. A season may be of whatever length is appropriate for the study, weeks, months, or longer intervals.
- Capacity Models are developed for each area for each season of the year and are available capacity-probability density tables.
- Maintenance Outages are simulated either by adding the capacity on outage to the appropriate area and season load model or by modification of the proper capacity-probability table. Maintenance may be prescheduled and input or done automatically within MAREL by an algorithm designed to level available area generation reserves over the year.
- Transmission Interconnections are modeled by the use of a linear flow network which models the limitations on individual tie line transfer capabilities considering their forced outage rates (if desired) without restrictions on the network configuration or topology.
- Program Controls are set by the user to establish the fineness with which the loads and capcities are represented and to set tolerance levels on the LOLP computations to save unnecessary computer effort and cost.
- Program Output may include area load and capacity models as well as maintenance schedules, three sets of both seasonal and annual area and system LOLP indices, the probabilities of various failure modes. That is, the program automatically calculates area LOLP values as though the area were isolated and then two separate LOLP values with the actual interconnection. These two LOLP indices represent the extremes of possible operating policies concerning the sharing of generation reserves, sharing only available reserves, and (2) sharing (1)load losses up to the transfer limitations imposed by the network. Failure mode probabilities show the prob-abilities and locations of failures caused by generation shortages or transmission limitations as well as combinations and indicate the probabilities that each individual tie may be limiting. These data are useful in developing reliable system designs.
- System Size is not restricted except by limits on acceptable computational effort and cost. Past PTI system studies have included two interconnected reliability councils represented by nine or ten areas and incorporating approximately 500 units for a total of 100,000 mw of generation.
- Generation reliability level analysis which includes the effects of the interconnected system for the expansion planning of individual utilities and power pools.
- Planning of interconnections to achieve regional integration and more widespread sharing of generation reserves.
- Evaluation of the reliability benefits of strengthening ties vis-a-vis additions to generation reserves.

PROGRAM APPLICATIONS

C - 2

- Assistance in locating weak portions of a system in order to locate new bulk power facilities for maximum reliability improvement.
- Analysis of the reliability benefits of new jointly-owned plants located remotely or within one system's territory.
- Evaluation of the ability of individual utilities to reliably survive the postponement of new plant additions in their own and interconnected systems.

MAREL is available for use at PTI for studies by individual utilities or groups of systems. It may also be leased for installation on a client's computer. The lease entitles the user to:

- Complete set of source code for all modules including all MAREL activities and subroutines.
- Engineering and program reference manuals.
- Installation on a suitable PRIME 400 computer at the client's site and a training seminar.

Installation on other computers is feasible but will only be done on the basis of charging for the time and expense required.

Since PTI is a consulting engineering organization and uses MAREL in studies for clients, the program is continually being enhanced and updated.

While updates are not included in the MAREL lease price, PTI will offer all significant MAREL improvements to lessees at add-on prices.

PTI can assist MAREL users in the development of system equivalents where their use is attractive to the user.

Contact: C.K. Pang, Senior Engineer

or A.J. Wood, Principal Engineer Power Technologies, Inc. P.O. Box 1058 Schenectady, N.Y. 12301

Tel. (518) 374-1220 Telex 145498 POWER TECH SCH

1/78

FOR FURTHER

INFORMATION

AVAILABILITY AND SUPPORT

PTI/103

MULTI-AREA RELIABILITY PROGRAM (MAREL)

SAMPLE OUTPUT SHEETS FOR TWO-AREA RELIABILITY STUDY - YEAR 1989

Note: The following other output sheets (35 cases) are on file with Alaska Power Authority under a separate cover:

- Independent System Expansion Plans (years 1984 through 1996)
- Interconnected System Expansion Plans (years 1984 through 1996)
- Interconnected System Expansion, Three-Area Realiability Study with Susitna (years 1992 through 1996)
- Interconnected System Expansion Plans, with Firm Power Transfer (years 1984 through 1987 and 1992 through 1996)

C - 4

IECREL *TIE89

01/18/79 11:01

PRT018

| | | · · | | | | | | ф. |
|----------------|--------------------------|-------|-------|-----|----|-------|-------------|---------|
| | | | | | | | | |
| | | | | | | | | |
| 272727 | 1.11.11.11.11.11.1 | WWW | WWW | WWW | WW | W | | * |
| 10 10 10
TJ | 11 11 11 11 11 11
1.? | w W | W W | W | | W | | |
| 11
7.7 | 11
17.7 | 10 IV | W W | W | | W | | |
| 11
T.1 | WINNER | Ŵ | WWWW | WWW | W | W | | |
| 11
127 | 37 | W | WW | W | | W | | 4*
* |
| 1J | 10 | W W | W W | W | | W W | | ** |
| 101313 | NAVANW | WWW | W W | WWW | WW | WWWWW | | *** |
| | 11 12 17 11 11 | | | | | | | *** |
| | | | | | | | | * |
| | * | | | | | | | · * |
| | WWWW | WWW | WWWWW | WW | W | WWW | | * |
| WWW | W | W | W | W | W | W W | | * |
| WWW | W | W | W | W | W | W W | | * |
| WW WW | W | W | WWWW | WW | W | WWWW | | * |
| MWW | W | W | W | W | W | W | | * |
| WWW | W | W | W | W | W | W | · · · · · · | * |
| | W | WWW | WWWWW | WW | W | WWW | | * |
| | | | | | | | | * |
| | | | | | | | | * |
| | | | | | | | | |
---- MULTI-AREA RELIABILITY PROGRAM - MAREL --------- VERSION : NOVEMBER 15, 1978 ----

STUDY CASE:

...

| | ······································ | *** |
|-------|--|-----|
| ***** | *************************************** | ** |
| ** | TRANSMISSION INTERTIF ECONOMIC FEASIBILITY | ** |
| ** | ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC CLEAR | ** |
| ** | $\mathbf{T}_{\text{A}} = \mathbf{T}_{\text{A}} + \mathbf{T}_{\text{A}} = \mathbf{T}_{\text{A}} + \mathbf{T}_{\text{A}} = \mathbf{T}_{\text{A}} + $ | ** |
| ** | 2-AREA RELIABILITY STUDY - HEAR 1909 - INTERCOMPLETE | ** |
| ** | ······································ | *** |
| ***** | *************************************** | |

YEAR OF STUDY=1989PROBABILITY THRESHOLD=0.10E-07FAILURE PROB. THRESHOLD=0.20E-08

PROB. RATIO FOR LOAD LEV.=0.0100ROUNDING MW STEP SIZE=MAX. NO. OF AREAS WITH NEGATIVE
MARCIN TO BE EXAMINED=2MAX. OF CAPACITY STEPS=50

----- SYSTEM DATA -----

| NO. | OF | AREAS | OR BU | JSES | 8 | 2 | |
|-----|----|--------|-------|------------|----|---|--|
| NO. | OF | AREAS | WITH | GENERATION | 8 | 2 | |
| NO. | OF | AREAS | WITH | LOADS | 8, | 2 | |
| NO. | OF | LINES | WITH | OUTACES | = | 1 | |
| NO. | OF | FIRM 1 | LINES | | = | Ø | |

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY 2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

----- DATA FOR LINES WITH OUTAGES -------- AVAILABLE CAPACITY PROBABILITY ----

LINE NO. 1, LINK NO. 3 TIE FROM AREA 1 ANCHOR -TO- AREA 2 FAIRBA

| LEVEL | CAP(FOR) | CAP(REV) | PROBABILITY |
|-------|----------|----------|-------------|
| 1 | 0 | 0 | 0.004000 |
| 2 | 130 | 130 | 0.996000 |

----- TIME USED IN CPUS : INCREMENT = 2, ELAPSED = 2

GENERATOR UNIT DATA FOR ANCHORAGE-FAIRBANKS STUDY TWO AREA SYSTEM JANUARY 15 1979

SUMMARY ON CAPACITY, PEAK LOAD AND MAINTENANCE : AREA ANCHOR

| SEASON | | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | |
|----------------------|-----------------|-------------|-------|--------|--------|--------|--------|--------|-------|-------|--|
| INSTALLE
CAPACITY | CD
7 (MW) | 1747 | 1747 | 1747 | 1747 | 1747 | 1747 | 1747 | 1747 | 1747 | |
| PEAK LOA | AD (MW) | 1200 | 882 | 789 | 752 | 729 | 725 | 826 | 886 | 1441 | |
| INSTALLE | D RESERVES : | | | | | | | | | | |
| | MW | 547 | 865 | 958 | 995 | 1018 | 1022 | 921 | 861 | 306 | |
| | PERCENT | 45.58 | 98.07 | 121.42 | 132.31 | 139.64 | 140.97 | 111.50 | 97.18 | 21.24 | |
| CAPACITY
MAINTENA | 'ON
NCE (MW) | 0 | 135 | 227 | 256 | 286 | 287 | 188 | 122 | 0 | |
| RESERVES | AFTER MAINT | ENANCE : | | | | | | | | | |
| | MW | 54 7 | 730 | 731 | 739 | 732 | 735 | 733 | 739 | 306 | |
| | PERCENT | 45.58 | 82.77 | 92.65 | 98.27 | 100.41 | 101.38 | 88.74 | 83.41 | 21.24 | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |

UNIT RETIREMENTS AND INSTALLATIONS :

| NO. | UNIT | CAP(MN) | F.O.R. | RET/INST | SEASON | DATE |
|-----|--------|---------|--------|-------------------------------------|--------|--------|
| | | | | الله الله مواجود بنيه الله الما يور | | |
| 1 | COAL 2 | 200 | 0.057 | INST | 1 | 1/1989 |

C – 9

| UNIT | RETIREME | INTS AND I | NSTALLAT | TONS : | | |
|------|----------|------------|----------|----------|--------|------|
| | | | | | | - |
| MO. | INIT | CAP(MW) | F.O.R. | RET/INST | SEASON | DATE |
| | | | | | | |

| | MW | 111 | 203 | 250 | 266 | 273 | 255 | 249 | 219 | 72 |
|--------------------------|---------------|---------|--------|--------|--------|--------|--------|--------|--------|-------|
| | PERCENT | 40.51 | 117.51 | 185.19 | 223.53 | 243.75 | 196.15 | 183.09 | 131.93 | 23.00 |
| CAPACITY (
MAINTENAN) | ON
CE (MW) | 0 | 14 | 55 | 72 | 100 | 65 | 54 | 25 | 0 |
| RESERVES | AFTER MAINT | TENANCE | 8 | | | | | | | |
| | MW | 111 | 194 | 195 | 194 | 173 | 190 | 195 | 194 | 72 |
| | PERCENT | 40.51 | 109.60 | 144.44 | 163.03 | 154.46 | 146.15 | 143.38 | 116.87 | 23.00 |

INSTALLED RESERVES :

| SEASON | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 |
|----------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| INSTALLED
CAPACITY (MW) | 385 | 385 | 385 | 385 | 385 | 385 | 385 | 385 | 385 |
| PEAK LOAD (MW) | 274 | 177 | 135 | 119 | 112 | 130 | 136 | 166 | 313 |

SUMMARY ON CAPACITY, PEAK LOAD AND MAINTENANCE : AREA FAIRBAL



POWER TELLICION POWER TRUCKAR

MAINTENANCE FOR SEASONS : 1 9

 $\left| \begin{array}{c} 7 \\ 1 \end{array} \right|$

| | | | | |

 $\left[\right]$

 $\left\{ \right\}$

 $\left(\right)$

d j

GENERATOR UNIT DATA FOR ANCHORAGE-FAIRBANKS STUDY TWO AREA SYSTEM JANUARY 15 1979

SUMMARY ON CAPACITY, PEAK LOAD AND MAINTENANCE : AREA FAIRBAS

| SEASON | | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 |
|-----------------------|----------------|----------|--------|--------|--------|--------|--------|-------------|--------|----------|
| INSTALLEI
CAPACITY | D
(MW) | 385 | 385 | 385 | 385 | 385 | 385 | 38 5 | 385 | 385 |
| PEAK LOAI | D (MW) | 274 | 177 | 135 | 119 | 112 | 130 | 136 | 166 | 313 |
| INSTALLEI | D RESERVES : | | | | | | | | | |
| | MW | 111 | 208 | 250 | 266 | 273 | 255 | 249 | 219 | 72 |
| | PERCENT | 40.51 | 117.51 | 185.19 | 223.53 | 243.75 | 196.15 | 183.09 | 131.93 | 23.00 |
| CAPACITY
MAINTENAI | ON
ICE (MW) | Ø | 14 | 55 | 72 | 100 | 65 | 54 | 25 | 0 |
| RESERVES | AFTER MAINT | ENANCE : | 5 | | | | | | | • |
| | MW | - 111 | 194 | 195 | 194 | 173 | 190 | 195 | 194 | 72 |
| | PERCENT | 40.51 | 109.60 | 144.44 | 163.03 | 154.46 | 146.15 | 143.38 | 116.87 | 23.00 |
| | | | | | | | | | | |

. . .

UNIT RETIREMENTS AND INSTALLATIONS :

| no. | UNIT | CAP(MV) | F.O.R. | RET/INST | SEASON | DATE |
|-----|------|---------|--------|----------|----------------|------|
| | | | | | manian an anal | |

C - 10

التوسيسانية

1211

.

C - 11

CENERATOR UNIT DATA FOR ANCHORAGE-FAIRBANKS STUDY TWO AREA SYSTEM JANUARY 15 1979 -

SUMMARY ON CAPACITY AND PEAK LOAD BY AREA

| AREA | ANCHOR | FAIRBA |
|---|--------|--------|
| PEAK LOAD SEASON | 9 | 9 |
| INSTALLED CAPACITY (MW)
AT ANNUAL PEAK | 1747 | 385 |
| ANNUAL PEAK
LOAD (MW) | 1441 | 313 |
| INSTALLED
RESERVES (MW) | 306 | 72 |
| RESERVES IN PERCENT OF
ANNUAL PEAK LOAD | 21.24 | 23.00 |
| AREA WEIGHTED AVERAGE
UNIT FOR (PERCENT) | 5.46 | 7.42 |
| AREA ANNUAL AVERAGE
MAINTENANCE(PERCENT) | 9.55 | 11.11 |

 \mathbf{O}

- 12

CENERATOR UNIT DATA FOR ANCHORAGE-FAIRBANKS STUDY TWO AREA SYSTEM JANUARY 15 1979

-----SUMMARY BY AREAS-----

| | AREA | NO.OF UNITS | CAP.(MW) |
|---|--------|-------------|----------|
| | | | |
| 1 | ANCHOR | 36 | 1747 |
| 2 | FAIRBA | 24 | 385 |

SEASONAL RESERVES IN PERCENT OF PEAK LOADS AFTER MAINTENANCE OF UNITS FOR THE TOTAL SYSTEM

| • | SEASON | RESERVES | ORDER | SEASON | RESERVES |
|---|--------|----------|-------|--------|----------|
| | | | | | |
| | 1 | 44.6404 | 1 | 9 | 21.5507 |
| | 2 | 87.2521 | 2 | 1 | 44.6404 |
| | 3 | 100.2164 | 3 | 2 | 87.2521 |
| | 4 | 107.1182 | 4 | 8 | 88.6882 |
| | 5 | 107.6100 | 5 | 7 | 96.4657 |
| | б. | 108.1871 | 6 | 3 | 100.2164 |
| | 7 | 96.4657 | . 7 | . 4 | 107.1182 |
| | 8 | 88.6882 | 8 | 5 | 107.6100 |
| | 9 | 21.5507 | 9 | 6 | 108.1871 |
| | | | | | |

CENERATOR UNIT DATA FOR ANCHORAGE-FAIRBANKS STUDY TWO AREA SYSTEM JANUARY 15 1979

MAINTENANCE SUMMARY BY MW AND PERCENT OF TOTAL AREA CAPACITY :

| SEASON | AREA | ANCHOR | AREA | FAIRBA |
|--------|------|--------|------|--------|
| | | | | |
| 1 | 0 | 0.00 | 0 | 0.00 |
| 2 | 135 | 7.73 | 14 | 3.64 |
| 3 | 227 | 12.99 | 55 | 14.29 |
| 4 | 256 | 14.65 | 72 | 18.70 |
| 5 | 286 | 16.37 | 100 | 25.97 |
| 6 | 287 | 16.43 | 65 | 16.88 |
| 7 | 188 | 10.76 | 54 | 14.03 |
| 8 | 122 | 6.98 | 25 | 6.49 |
| 9 | 0 | 0.00 | Ø | 0.00 |

| AREA EFOR | | 5.4550 | 7.4169 |
|-------------|---|--------|--------|
| SYSTEM EFOR | 8 | 5.8093 | |

EFOR : WEIGHTED EFFECTIVE FORCED OUTAGE RATE IN PERCENT.

*** END OF PROCRAM MNTCE ***

----- TIME USED IN CPUS : INCREMENT = 2, ELAPSED = 4

---- TIME USED IN CPUS : INCREMENT = 0, ELAPSED = 4

*** AREA 1 ANCHOR HAS NO UNITS ON *** *** MAINTENANCE FOR SEASONS : 1 9 ***

*** AREA 2 FAIRBA HAS NO UNITS ON ***

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY 2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

dimension of

--- LOSS OF LOAD PROBABILITY AT VARIOUS AREAS ----

| AT | AREA | PROBABILITY
ISOLATED | PROBABILITY
WITH LLS | PROBABILITY
WITHOUT LLS |
|----|--------|-------------------------|-------------------------|----------------------------|
| 1 | ANCHOR | 0.149268E+00 | 0.798471E-01 | 0.676829E-01 |
| 2 | FAIRBA | 0.190494E+01 | 0.909675E-01 | 0.394379E-01 |
| | SYSTEM | | 0.915377E-01 | 0.915377E-01 |

NOTE : LLS = LOAD LOSS SHARING

***** ALL PROBABILITIES ARE IN DAYS/PERIOD *****

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY 2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

--- PROBABILITY OF MINIMAL CUTS ----

| CUT | PROBABILITY | C | UT MEMBERS(LINKS) |
|-----|--------------|----------|-------------------|
| 1 | 0.792771E-01 | 1 | 2 |
| 2 | 9.570032E-03 | 1 | 3 |
| 3 | 0.116904E-01 | 2 | 3 |

***** ALL PROBABILITIES ARE IN DAYS/PERIOD *****

C - 17

ANCHORACE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY 2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

--- MINIMAL CUTS AND DEFICIENT NODES(AREAS) ---

| CUT | PROBABILITY | NODES(AREAS) IN DEFICIENT REGION |
|-----|--------------|----------------------------------|
| 1 | 0.792771E-01 | 1 ANCHOR 2 FAIRBA |
| 2 | 0.570032E-03 | 1 ANCHOR |
| 3 | 0.116904E-01 | 2 FAIRBA |

***** ALL PROBABILITIES ARE IN DAYS/PERIOD *****

ANCHORACE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY 2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

--- PROBABILITY THAT EACH LINE IS LIMITING ---

| LINE LINK | DES | CRIPTION | TOTAL | FORWARD | REVERSE |
|-----------|----------|-------------|--------------|--------------|--------------|
| | AREA | TO AREA | PROBABILITY | DIRECTION | DIRECTION |
| 1 3 | 1 ANCHOR | TO 2 FAIRBA | 0.122604E-01 | 0.116904E-01 | 0.570032E-03 |

***** ALL PROBABILITIES ARE IN DAYS/PERIOD *****

0

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY 2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

ISOLATED SITUATION - SUMMARY :

AREA LOLP IN DAYS/PERIOD BY SEASONS.

| | AREA | AREA |
|--------|--------|--------|
| SEASON | ANCHOR | FAIRBA |
| | | |
| 1 | 0.0021 | 0.3096 |
| 2 | 0.0000 | 0.0071 |
| 3 | 0.0000 | 0.0000 |
| 4 | 0.0000 | 0.0000 |
| 5 | 0.0000 | 0.0000 |
| 6 | 0.0000 | 0.0000 |
| 7 | 0.0000 | 0.0000 |
| 8 | 0.0000 | 0.0000 |
| 9 | 0.1472 | 1.5882 |
| YEAR | 0.1493 | 1.9049 |

ANCHORACE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY 2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

ISOLATED SITUATION - SUMMARY :

EXPECTED MW-DAYS LOSS BY SEASONS.

| SEASON | AREA
ANCHOR | AREA
FAIRBA |
|--------|----------------|----------------|
| 1 | 0.09 | 7.45 |
| 2 | 0.00 | 0.14 |
| 3 | 0.00 | 0.00 |
| 4 | 0.00 | 0.00 |
| 5 | 0.00 | 0.00 |
| 6 | 0.00 | 0.00 |
| 7 | 0.00 | 0.00 |
| 8 | 0.00 | 0.00 |
| 9 | 8.87 | 44.23 |
| YEAR | 8.9548 | 51.8097 |

ANCHORACE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY 2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

ISOLATED SITUATION - SUMMARY :

EXPECTED MW DEFICIENCY BY SEASON.

| SEASON | AREA
ANCHOR | AREA
FAIRBA |
|--------|----------------|----------------|
| 1 | 42.38 | 24.04 |
| 2 | 13.57 | 19.22 |
| 3 | 0.00 | 0.00 |
| 4 | 0.00 | 0.00 |
| 5 | 0.00 | 0.00 |
| 6 | 0.00 | 0.00 |
| 7 | 0.00 | 0.00 |
| 8 | 0.00 | 0.00 |
| 9 | 60.24 | 27.85 |

INDICES FOR THE YEAR :

| MW-DAYS | 8.95 | 51.81 |
|-----------|-------|-------|
| LOLP-DAYS | 0.15 | 1.90 |
| ECMWD | 59.99 | 27.20 |

ANCHORACE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY 2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

INTERCONNECTED WITH LOAD LOSS SHARING :

AREA LOLP IN DAYS/PERIOD BY SEASONS.

| SEASON | AREA
ANCHOR | AREA
FAIRBA |
|--------|----------------|----------------|
| 1 | 0.0004 | 0.0020 |
| 2 | 0.0000 | 0.0000 |
| 3 | 0.0000 | 0.0000 |
| 4 | 0.0000 | 0.0000 |
| 5 | 0.0000 | 0.0000 |
| 6 | 0.0009 | 0.0000 |
| 7 | 0.0000 | 0.0000 |
| 8 | 0.0000 | 0.0000 |
| 9 | 0.0794 | 0.0890 |
| YEAR | 0.0798 | 0.0910 |

.

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY 2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

INTERCONNECTED WITH NO LOAD LOSS SHARING :

AREA LOLP IN DAYS/PERIOD BY SEASONS.

| | AREA | AREA |
|------------|--------|--------|
| SEASON | ANCEOR | FAIRBA |
| | | |
| | | |
| 1 | 0.0003 | 0.0017 |
| • | 0 0000 | 0 0000 |
| | 0.0000 | 0.0000 |
| 3 | 0.0000 | 0.0000 |
| U U | 0.0000 | 0.0000 |
| 4 | 0.0000 | 0.0000 |
| | | |
| 5 | 0.0000 | 0.0000 |
| 6 | 0 0000 | A AAAA |
| U U | 0.0000 | 0.0000 |
| 7 | 0.0000 | 0.0000 |
| | | |
| 8 ` | 0.0000 | 0.0000 |
| ~ | | |
| 9 | 0.0673 | 0.0378 |
| | | |
| YEAR | 0.0677 | 0.0394 |
| | | |

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY 2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/13/1979

--- SYSTEM RESULT SUMMARY IN PER UNIT ---

| PROBABILITY O | F SUCCESS EVENTS | 52' | 0.999648E+00 |
|---------------|-------------------------|----------|--------------|
| PROBABILITY O | F FAILURE EVENTS | . = | 0.352068E-03 |
| PROBABILITY O | F NEGLECTED UNSPECIFIED | EVENTS = | 0.270125E-08 |
| SUM OF THE AB | OVE 3 PROBABILITIES | 57 | 0.100000E+01 |

PROBABILITY OF UNCLASSIFIED FAILURE EVENTS = 0.620649E-09

DEFINITION OF EVENTS :

SUCCESS : ALL LOADS SATISFIED.

FAILURE : ONE OR MORE AREA LOADS NOT SATISFIED.

UNSPECIFIED : NOT IDENTIFIED AS EITHER SUCCESS OR FAILURE.

UNCLASSED FAILURE : CAUSE OF FAILURE NOT ESTABLISHED. CAUSE OF FAILURE IS INDICATED BY MINIMAL CUTS.

TOTAL ELAPSED TIME IN CPUS = 20

***** END OF PROGRAM MAREL *****

0

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY

- .

PAGE 0001

| ANCI | IOHAGE | - FAII | IIBANKS | TRAN | SMISSI | ON INTI | SRITE I | LCONOM. | IC FEAS | SIBILITY | |
|--------------|-------------|--------|-----------------------|-----------|---------|----------------|--------------|------------------|-----------------|-------------|-------|
| 2 -AI | REA RE | LIVRIF | ITY ST | JDY — | YEAR 19 | 996 : J | INTERCO | DNNECTI | sD = 1/ | 15/1979 | |
| 2 | .1 | Ø | 0.(|) () | Ø | Ø | 0 | Ø | | | |
| 0 | 0 | 0 | 0 1 | 10 | Ø | Ø | Ø | 0 | | | |
| 0 | 0 | 0 | 0 (|) 0 | | • | | | | • | |
| 1 | 1 | 1 | 4 | | | | | | | | |
| 1996 | | | | | | | | | | | |
| 0.11 | E-07 | 0.2E-0 | 07 0. | 5E-05 | | | | | | | |
| 0.01 (|).10 | | | | | | | | | | |
| 2 | 1 | 50 | | | | | | | | | |
| 2 | 1 | 0 | 2 2 | 2 | | | | | | | |
| ANCHORI | FAIRBA | | | | | | | | | | |
| | 1 | 2 | 2 [.] | | | | | | | | |
| 1 | Ō | 0 0 | .004004 |) | | | | | | | |
| 2 | 130 | 130 0 | .996000 |) | | | | | | | |
| LOAT | DATA | IN PE | R UNIT | INTER | VAL DUI | RATION | CURVE | | | | |
| TWO | AREA | SYSTEM | | JAN | UARY 1 | 5 1979 | | | | | |
| 1 | 1 | 1 | | | •••••• | | | | | | |
| 2 | 10 | 26 | 9 14 | 1983 | | | | | | | |
| 1 (| | 60 | ó î | | | | • | | | | |
| * 1 1 | 1 1 1 | | 3 4 4 | 5 5 6 | 677 | 8 8 9 | a a a | 99 | | | |
| 0 0 0 | 0 0 0 | 0 0 0 | 0 0 0 | 6 6 6 | 0 0 0 | 666 | 666 | áá | | | |
| 1 4 | | 20 | 000 | 3 | 000 | | 000 | 00 | | | |
| 700 | Ω 77 | 077 | 1020 | 1106 | 1313 | 1441 | 1581 | 1724. | 1881. | | |
| 9041 | 2215 | 2402 | 2501 | 1170. | 1010. | X-7-5 L • | 10011 | | 10011 | | |
| 6041. | 6667 | 7404 | 7500 | 6571 | 6346 | 6122 | 5865 | .54B1 | 5353 | 5224 5160 | .5064 |
| . 0000 | -0001 | 4060 | 5160 | 5737 | 5769 | 6154 | .6827 | 8429 | .8526 | .91351.0000 | .8301 |
| 1 0000 | 0760 | 0721 | 0729 | 0500 | 0462 | 1010-2 | 8731 | 9577 | 8423 | ****** | 10001 |
| 1 0000 | 0202 | 0663 | 9663 | 0615 | 0615 | 0510 | 0510 | 94.23 | 0375 | | |
| 1.0000 | - 9630 | 0794 | 0227 | 0607 | 0654 | 0437 | 0307 | 0221 | 2019 | | |
| 1 0000 | 0820 | 64.97 | 0350 | 9017 | 8889 | 6888 | . 2001 | .8333 | 8934 | | |
| 1.0000 | 0512 | 0317 | 9171 | 0171 | 9073 | 9673 | 0004 | 9824 | .8976 | | |
| 1.0000 | 0.942 | 0709 | 0747 | 0646 | 9405 | 9444 | 0343 | 6203 | 0141 | | |
| 1,0000 | 06.06 | 0634 | 0520 | 0520 | 0476 | 0494 | 0372 | 0058 | 0059 | | |
| 1.0000 | .9000 | 0727 | 0617 | 0563 | 0562 | 0744 | 9324 | 0071 | 9071 | | |
| 1.0000 | .7701 | . 7121 | . 2011 | 0.000 | 0700 | 0702 | 0640 | 0501 | 0415 | | |
| 1.0000 | 0040 | . 2003 | 0701 | 0501 | 0461 | 0201 | 0741 | 0.901 | 0162 | | |
| 1.0000 | .9950 | .9620 | 0571 | 0571 | 0500 | 0500 | 0249 | 0202 | 8580 | | |
| 1.0000 | . 7707 | 0.014 | . 9071 | 0565 | 6776 | 0270 | 0770 | 0255 | 0255 | | |
| 1.0000 | .9900 | 0604 | .9009 | 0.404 | 0404 | 0490 | 0067 | 0200 | 0177 | | |
| 1.0000 | 19010 | 0720 | .9020 | 0677 | 0600 | 0540 | 0549 | 0477 | 19111
1994 | | |
| 1.0000 | 19001 | 0745 | 0554 | 0400 | 0400 | 0497 | 0497 | 0.020 | 0200 | | |
| 1.0000 | . 9069 | .7690 | 0071 | 0.0000 | +75220 | 0677 | 0612 | 0540 | 04.54 | | |
| 1.00001 | 0,000 | .9903 | . 7011 | 0697 | 0565 | 0565 | 0// 11 | 0441 | 0770 | | |
| 1.0000 | .9900 | .9014 | 0141 | . 9046 | 0.106 | 0000 | 6715 | 0715 | 06:25 | | |
| 1.0000 | | | . 7421 | 0700 | 0700 | AC 11 | 00110 | - 0000 | - 6929 | | |
| 1.0000 | .9944 | . 7744 | 0000 | .9143 | .7(22 | .9011 | . 74(0 | 0000 | 0000 | | |
| 1.0000 | -9948 | .9290 | .9870 | .9007 | 19000 | . 9001 | .7070 | 19020 | 0002 | | |
| 1.0000 | .9839 | .9564 | .9406 | . 2020 | 0007 | -7297
7005 | | - 77700
77710 | 07014 | | |
| 1.0000 | .9962 | .9008 | .9400 | .9400 | .9000 | 0.474 | 0.000 | 0041 | 0000 | | |
| 1.00000 | 1.0000 | .9887 | .9002 | .9049 | 19011 | ·7414
0004 | 0004 | . 9001 | .7020 | | |
| 1.0000 | .9704 | .0032 | .0090 | .0421 | .0330 | .0007 | 0100 | • 0360
0654 | 0110 | | |
| 1.0000 | .9840 | .9679 | .9019 | .9339 | .9327 | - 9321
0575 | .9139 | .0401 | .0040
• 07/A | | |
| 1.0000 | .9730 | .9730 | .9014 | .9014 | *2019 | 19010 | 12031 | 19421 | 10040 | | |
| 2 F/ | AIRBA | 20 | 0.0 | J
0740 | 00.4 | 010 | 000 | 070 | 004 | | |
| 106 | 212. | 231. | 249. | 270. | 291. | 313. | 338. | 00 | 370. | | |

C - 25

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY

~

C - 26⁻

PAGE 0002

.

| 416. | 446. | 477. | 511. | | | | - | · · | | | | |
|----------|---------------|-----------------|------------|----------|---------|--------|----------|--------|--------|--------|----------|-----|
| 0.07590 | .69900. | .73710 | .76040. | .57490. | 59710. | 56630 | 51110. | 43240. | 41150. | 38330. | 37470.3 | 587 |
| 0.35329 | .38389 | 41770 | .42010. | 43730 | 46190. | 53190. | 57490. | 89190. | 93370. | 93491. | 00000.70 | 690 |
| 1.00000 | .97420 | .94670 | .94670. | .94530. | 93130. | 89489. | .86540. | 84290. | 8177 | | | |
| 1.000000 | .93670 | 92790 | .92790. | 90510. | 82280. | 88950. | .85940. | 82790. | 7891 | | | |
| 1.06000 | 99320 | 96670 | -94830 | 94000 | 92330 | 90330 | 22200 | 86670 | 8267 | | | |
| 1 00000 | 07520 | C6120 | 94510 | 26910 | 83200 | 22396 | £1100 | 79000 | 6769 | | | |
| 1.00000 | 02500 | 08200 | 05940 | 95360 | 94660 | 91888 | 90810 | 96176 | 8825 | | | |
| 1.00000 | 00700 | 00500 | 02770 | 07040 | 05220 | 02620 | 00530 | 80200 | 8827 | | | |
| 1.00.000 | 00400 | 05010 | 00710 | 01070 | 000000 | 00020 | 97200 | 96190 | 2001 | | | |
| 1.00000 | .90500 | .93010 | . 90110. | 00510 | 09310. | 00700 | 000000 | 07000 | 0551 | | | |
| 1.00000 | .90870 | .90130 | .90190. | 93510 | 91890 | 00100 | 00220. | 01202. | 0000 | | | |
| 1.00000 | .99150 | .99100 | .99100. | .97160. | .96870. | 93189. | .89200. | 10920. | 8073 | | | |
| 1.00001 | .00000 | .96120 | .93130. | 92540. | .92840. | 92240. | .90750. | 90400. | 8935 | | | |
| 1.00000 | .99040 | .99040 | .94350. | .92310. | .91990. | 91670 | .91350. | 87820. | 8558 | | | |
| 1.00000 | .96723 | .95410 | .92790. | .92460. | 90490. | 82840. | . 89510. | 87870. | 8721 | | | |
| 1.00000 | .96920 | .96920 | .95890. | .95890. | .94520. | 94520 | .93150. | 92120. | 9041 | | | |
| 1.00000 | .98960 | .97220 | .96270. | , 95820. | 94790. | 93400 | .92360. | 92010. | 8507 | | | |
| 1.000000 | .96770 | .93870 | .93230. | .91290. | .90320. | 90320 | .90320. | 87100. | 8677 | | | |
| 1.00000 | .87350 | .07060 | .86760. | .86460. | 85889. | 84710 | .84410. | 83820. | 8959 | | | |
| 1.00000 | .94440 | .90640 | .90640. | . 89470. | 82750. | 22750 | .82460. | 81870. | 8912 | | | |
| 1.00000 | .99720 | .97750 | .96350. | 96250. | 94940. | 98820 | 93320. | 91010. | 8904 | | | |
| 1.00000 | .99470 | .96810 | .93090. | 92820. | 90960. | 90690. | .90160. | 86530. | 8856 | | | |
| 1.00000 | .93330. | .93300 | .91450. | 90990. | 89610. | 88910 | 88450. | 86370. | 8568 | | | |
| 1.00000 | .99150 | .98929. | .97650. | 94020. | 92950. | 92749. | 91289. | 91450. | 9017 | | | |
| 1.00000 | .96690 | .91120 | .89260. | 88840. | 79890. | 73970 | 64460. | 61020. | 6028 | | | |
| 1.00000 | .97710 | 91050 | .90790. | 90790. | 89340. | 88950. | 82559. | 86320. | 8434 | | | |
| 1.00000 | .97110 | .26330 | .83050. | 81870 | 79630. | 79240 | 74510. | 73320. | 7201 | | | |
| 1.00000 | .99510 | .98160 | .97300. | 97170. | 95589. | 91650 | 88450. | 82430. | 6818 | | | |
| 1.00000 | .99840 | 93920 | 92010 | 89940 | 88980. | 88500. | 84820. | 61310. | 7971 | | | |
| CENE | RATER 1 | UNIT D | ATA FOI | ANCHO | DRACE-I | AIRBAI | IKS STU | JDY | | | | |
| TUO | AREA S | YSTEM | | | | ANUARY | 7 15 19 | 79 | | | | |
| 1 | 1 | 1 | | | | | | | | | | |
| 12 | ī | 1.0E-1 | 2 . | | | | | | | | | |
| ATT | CHOR | 44 | 12 | | | | | | | | | |
| 1.0 | | | | | | | | | | | | |
| 1 AN | CU 1 | 15 0.0 | 055 | | | | | | | | | |
| 2 11 | | 15 0.0 | 055 | | | | | | | | | |
| 3 11 | | 19 0.0 | 055 | | | | | | | | | |
| 4 AU | | 32 0.0 | 055 | | | | | | | | | |
| 5 10 | | 37 0.0 | 055 | | | | | | | | | |
| 6 AU | | 12 0.0 | 055 | | | | | | | | | |
| 7 AR | | 78 0.0 | 055 | | | | | | | | | |
| n At! | | 21 0.0 | 055 | | | | | | | | | |
| O ATH | CILB | 73 0 0 | 055 | | | | | | | | | |
| 10 12 | | 15 0 0 | 055 | | | | | | | | | |
| 11 27 | | 15 0 0 | 355 | | | | | | | | | |
| 12 D. | | 54 0 0 | 055 | | | | | | | | | |
| 12 12 | | | 722 | | | | | | | | | |
| 14 27 | | 54 0 0 | 055 | | | | | | | | | |
| 15 00 | | 69 0 0 | 055 | | | | | | | | | |
| 16 07 | 1000
11177 | 60 0 0 | 055 | | | | | | | | | |
| 17 17 | | 60 0 0 | 000 | | | | | | | | | |
| 10 200 | LU U | ου ν.v
α Α 4 | 000 | | | | | | | | | |
| 10 05 | ius I
DM O | - 0 V - V | 000 | | | | | | | | | |
| 19 152 | 101 4
DT 0 | 20 0.0 | 000 | | | | | | | | | |
| ուն հետ | ini o | - 47 V. | UUU | | | | 1 | | | | | |

PAGE 0003

| 21 INTL 1
22 INTL 2
23 INTL 3
24 COOP 1
25 COOP 2
26 KNIT A
27 INTL 4
23 INTL 5
29 INTL 6
30 INTL 7
31 HOMER
32 EKLUTN
33 BELU 9
34 ANCH 1
35 ANCH 1
37 ANCH 1
38 COAL 2
39 COAL 3
40 COAL 4
41 COAL 5
42 PEAKA1
43 CEN 1
43 CEN 1
43 CEN 1
43 CEN 1
44 COAP 2
45 PEAKA2
-99 | 14
14
19
8
15
71
71
71
71
71
71
71
71
71
70
200
200
200
200
200
200
200
200
200 | 0.055
0.055
0.055
0.055
0.0555
0.0555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.05555
0.005555
0.005555
0.005555
0.005555
0.005555
0.005555
0.005555
0.005555
0.005555
0.005555
0.005555
0.005555
0.005555
0.0055555
0.0055555
0.0055555
0.0055555
0.0055555
0.00555555
0.0055555555 | R. NNNNNNNNNNNNNNNNNNNNNNNNNNNNNNNNNNNN | 1/1986
1/1985
1/1985
1/1987
1/1993
1/1999
1/1991
1/1992
1/1993
1/1994
1/1995 |
|--|--|---|---|--|
| 1 | | | | |
| -99 | ~ ~ | | | |
| FAIIBA | 26 | 12 | | |
| 1 CHEN 1
2 CHEN 2
3 CHEN 3
4 CHEN 4
5 CHEN 5
6 CHEN 6
7 DIES 1
8 DIES 1
9 DIES 3
10 ZEHN 1
11 ZEHN 2
12 ZEHN 3
13 ZEHN 4
14 ZEHND2
16 ZEHND3
17 ZEHND4
18 ZEHND5
19 HEAL 1
20 HEAL D | 5 2 2 0 5 4 3 3 2 17 1 7 4 4 3 3 3 2 2 6 3 | 0.059
0.059
0.05950
0.055500000000000000000000000000000000 | | · · · |

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY

PAGE 0004

| 21 | NORT 1 | 65 | 0.055 | | |
|-----|--------|-----|-------|---|--------|
| .22 | NORT 2 | 65 | 0.055 | | |
| 23 | UALASK | 5 | 0.295 | | |
| 25 | COALF1 | 100 | 0.057 | N | 1/1988 |
| 27 | COALF2 | 100 | 0.057 | N | 1/1992 |
| 28 | COALF3 | 100 | 0.057 | Ν | 1/1995 |
| -99 | | | | | |
| -99 | | | | | |
| 1 | | | | | |
| 9 | | | | | |
| -99 | | | | | |

C - 28

APPENDIX D DATA AND COST ESTIMATES FOR TRANSMISSION INTERTIE AND GENERATING PLANTS

APPENDIX D

DATA AND COST ESTIMATES FOR

TRANSMISSION INTERTIE AND GENERATING PLANTS

D.1 DATA AND COST ESTIMATES FOR TRANSMISSION INTERTIE

A. Cost Summary and Disbursements for Intertie Facilities

| | | Tot | al Cost a | t 1979 Le | vels - \$1 | 000 |
|----|---|---|---|--|---|---|
| | | Case IA | Case IB | Case IC | <u>Case ID</u> | <u>Case II</u> |
| 1. | Transmission Line: | | | | | |
| | Eng'g. & Constr. Supv.
Right-of-Way
Foundations
Towers
Hardware
Insulators
Conductor | 3,012
8,837
8,445
21,615
477
503
10,761 | 3,012
8,837
8,445
21,615
477
503
10,761 | 4,043
9,080
12,160
33,719
477
755
16,708 | 3,012
8,837
8,445
21,615
477
503
10,761 | 8,079
20,973
22,966
64,088
1,096
1,396
32,886 |
| | Subtotal | 53,650 | 53,650 | 76,942 | 53,650 | 151,484 |
| 2. | Substations: | | | | | |
| | Eng'g. & Constr. Supv.
Land
Transformers
Circuit Breakers
Station Equipment
Structures & Accessories
Subtotal | 1,352
57
1,703
1,093
1,223
3,628
9,056 | 1,352
57
1,703
1,093
1,223
<u>3,628</u>
9,056 | 1,855
46
3,291
1,323
1,933
<u>3,978</u>
12,426 | 2,816
81
1,703
1,953
1,345
4,026
11,924 | 6,902
185
11,917
6,410
4,375
<u>16,411</u>
46,200 |
| 3. | <u>Control and Communications</u> :
Eng'g. & Constr. Supv.
Equipment | 125
2,375 | 125
2,375 | 125
<u>2,375</u> | 165
3,135 | 200
3,600 |
| | Subtotal | 2,500 | 2,500 | 2,500 | 3,300 | 3,800 |
| | Total Baseline 1979 Costs | 65,206 | 65,206 | <u>91,868</u> | <u>68,874</u> | 201,484 |

Capital disbursements for each of the above cases are given on following computation sheets, these being identical to those later used for financial planning purposes with selected alternative.

D - 1

CAPITAL INVESTMENT DISBURSMENTS FOR TRANSMISSION INTERTIE CASES IA & IB

| | 1981-1 | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TOTAL |
|-----------------------------|--------|--------|--------|--------|--------|--------|-------|
| 1. THANSMISSION LINE | | | | | | | |
| ENGINEERING AND CONSTRUCTI | UN | | | | | | |
| SUPERVISION | 452 | 753 | 0 | 392 | 693 | 723 | 3012 |
| RIGHT OF WAY | Ó | 2209 | 6659 | 0 | Ŭ | Ű | 8837 |
| FOUNDATIONS | 0 | . 0 | 0 | 5580 | 6165 | 0 | 8445 |
| TOWERS | 0 | O | 0 | 0 | 9727 | 11888 | 21615 |
| HARDHARE | 0 | 0 | 0 | 0 | 72 | 405 | 477 |
| INSULATORS | 0 | 0 | 0 | 0 | 75 | 428 | 503 |
| CONDUCTOR | . 0 | 0 | 0 | 0 | 1614 | 9147 | 10761 |
| SUB-TUTAL | 452 | 2962 | 6628 | 2672 | 18346 | 22591 | 53650 |
| 2. SUBSTATIONS | | | | | | | |
| ENGINEERING & CONSTRUCTION | • | | | | | | |
| SUPERVISION | 270 | 270 | 270 | 270 | 135 | 135 | 1352 |
| LAND | 57 | 0 | 0 | υ | 0 | 0 | 57 |
| TRANSFORMERS | • 0 | 0 | 341 | 596 | 596 | 170 | 1703 |
| CIRCUIT BREAKERS | Û | 0 | 219 | 383 | 383 | 109 | 1093 |
| STATION EQUIPMENT | 0 | . 0 | 245 | 428 | 428 | 122 | 1223 |
| STRUCTURES & ACCESSURIES | 0 | 0 | 126 | 1451 | 1451 | 0 | 3628 |
| SUB-TOTAL | 327 | 270 | 1800 | 3128 | 2493 | 537 | 9056 |
| 3. CONTROL AND COMMUNICATIO | INS | | | | | | |
| ENGINEERING AND INSTALLATI | ON | | | | | | |
| SUPERVISION | 0 | 0 | 0 | 0 | 54 | 71 | 125 |
| EQUIPMENT | 0 | 0 | 0 | 0 | 950 | 1425 | 2375 |
| SUB-TOTAL | 0 | 0 | 0 | 0 | 1004 | 1496 | 2500 |
| TUTAL | 779 | 3233 | 8428 | 5800 | 22342 | 24624 | 65206 |
| TUTAL FOR YEAR | O | 4012 | 0 | 14228 | Ú | 46967 | 65206 |

CAPITAL INVESTMENT DISBURSMENTS FOR TRANSMISSION INTERTIE CASE IC

| | 1981-1 | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TOTAL |
|-----------------------------|--------|--------|--------|--------|--------|--------|-------|
| 1. TRANSMISSION LINE | | | | | | | |
| ENGINEERING AND CONSTRUCTI | ON | | | | | | |
| SUPERVISION | 606 | 1011 | 0 | 526 | 930 | 970 | 4043 |
| RIGHT OF WAY | 0 | 2270 | 6810 | 0 | 0 | 0 | 9080 |
| FOUNDATIONS | 0 | 0 | 0 | 3283 | 8877 | 0 | 12160 |
| TOWERS | 0 | 0 | 0 | 0 | 15174 | 18545 | 33719 |
| HARDWARE | 0 | 0 | Û | 0 | 72 | 405 | 477 |
| INSULATORS | 0 | 0 | 0 | 0 | 113 | 642 | 755 |
| CONDUCTOR | 0 | 0 | 0 | . 0 | 2506 | 14202 | 16708 |
| SUB-TOTAL | 606 | 3281 | 6810 | 3809 | 27671 | 34765 | 76942 |
| 2. SUBSTATIONS | | | | | | | |
| ENGINEERING & CONSTRUCTION | ł | | | | | | |
| SUPERVISION | 371 | 371 | 371 | 371 | 186 | 186 | 1855 |
| LAND | 46 | 0 | 0 | 0 | 0 | 0 | 46 |
| TRANSFORMERS | 0 | 0 | 658 | 1152 | 1152 | 329 | 3291 |
| CIRCUIT BREAKERS | 0 | 0 | 265 | 463 | 463 | 132 | 1323 |
| STATION EQUIPMENT | 0 | 0 | 387 | 677 | 677 | 193 | 1933 |
| STRUCTURES & ACCESSORIES | 0. | 0 | 796 | 1591 | 1591 | 0 | 3978 |
| SUB-TOTAL | 417 | 371 | 2476 | 4254 | 4068 | 840 | 12426 |
| 3. CONTROL AND COMMUNICATIO | INS | | | | | | |
| ENGINEERING AND INSTALLATI | ION . | | | | | | |
| SUPERVISION | 0 | 0 | 0 | 0 | 54 | 71 | 125 |
| EQUIPMENT | 0 | 0 | 0 | 0 | 950 | 1425 | 2375 |
| SUB-TOTAL | 0 | 0 | 0 | 0 | 1004 | 1496 | 2500 |
| TOTAL | 1023 | 3652 | 9286 | 8062 | 32743 | 37101 | 91868 |
| TOTAL FOR YEAR | 0 | 4675 | 0 | 17348 | 0 | 69844 | 91868 |

CAPITAL INVESTMENT DISBURSMENTS FOR TRANSMISSION INTERTIE CASE ID

| | | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TOTAL |
|------------------------------|------|--------|--------|--------|--------|--------|-------|
| 1. TRANSMISSION LINE | | | | | | | |
| ENGINEERING AND CONSTRUCTIO | N | | | | | | |
| SUPERVISION | 452 | 753 | 0 | 392 | 693 | 723 | 3012 |
| RIGHT OF WAY | 0 | 5508 | 662B | 0 | 0 | 0 | 8837 |
| FOUNDATIONS | 0 | 0 | 0 | 2280 | 6165 | 0 | 8445 |
| 10H# NS | 0 | 0 | 0 | n | 9727 | 11888 | 21615 |
| HARDWARE | 0 | 0 | 0 | 0 | - 72 | 405 | 477 |
| INSULATORS | 0 | 0 | 0 | 0 | 75 | 428 | 503 |
| CONDUCTOR | 0 | 0 | 0 | 0 | 1614 | 9147 | 10761 |
| SUB-TOTAL | 452 | 2962 | 6628 | 2672 | 18346 | 22591 | 53650 |
| 2. SUBSTATIONS | | | | | | | |
| ENGINEERING & CONSTRUCTION | | | | | | | |
| SUPERVISION | 563 | 563 | 563 | 563 | 282 | 282 | 2816 |
| LAND | 81 | 0 | 0 | 0 | 0 | 0 | 81 |
| TRANSFORMERS | 0 | 0 | 341 | 596 | 596 | 170 | 1703 |
| CIRCUIT BREAKERS | 0 | 0 | 391 | 684 | 684 | 195 | 1953 |
| STATION EQUIPMENT | 0 | 0 | 569 | 471 | 471 | 135 | 1345 |
| STRUCTURES & ACCESSORIES | 0 | 0 | 805 | 1610 | 1610 | 0 | 4026 |
| SUB-TOTAL | 644 | 563 | 2369 | 3924 | 3642 | 782 | 11924 |
| 3. CONTROL AND COMMUNICATION | S | | | | | | |
| ENGINEERING AND INSTALLATIO | N | | | | | | |
| SUPERVISION | 0 | 0 | 0 | 0 | 71 | 94 | 165 |
| EQUIPMENT | 0 | 0 | 0 | 0 | 1254 | 1881 | 3135 |
| SUB-TOTAL | 0 | 0 | 0 | 0 | 1325 | 1975 | 3300 |
| TOTAL | 1096 | 3525 | 8996 | 6596 | 23313 | 25348 | 68874 |
| TOTAL FOR YEAR | 0 | 4621 | 0 | 15592 | 0 | 48661 | 68874 |

CAPITAL INVESTMENT DISBURSEMENTS FOR TRANSMISSION INTERTIE CASE II

| | 1981-1 | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TOTAL |
|-----------------------------|--------|--------|--------|--------|--------|--------|--------|
| 1. TRANSMISSION LINE | | | | | | | |
| ENGINEERING AND CONSTRUCTI | ON | | | | | | |
| SUPERVISION | 1212 | 2020 | 0 | 1050 | 1858 | 1939 | 8079 |
| RIGHT OF WAY | 0 | 5243 | 15730 | 0 | 0 | 0 | 20973 |
| FOUNDATIONS | 0 | 0 | 0 | 6201 | 16765 | 0 | 22966 |
| TOWERS | 0 | 0 | 0 | 0 | 28840 | 35248 | 64088 |
| HARDWARE | 0 | 0 | 0 | 0 | 164 | 932 | 1096 |
| INSULATORS | 0 | 0 | 0 | 0 | 209 | 1187 | 1396 |
| CUNDUCTOR | 0 | 0 | 0 | 0 | 4933 | 27953 | 32886 |
| SUB-TOTAL | 1212 | 7263 | 15730 | 7251 | 52770 | 67259 | 151484 |
| 2. SUBSTATIONS | | | | | | | |
| ENGINEERING & CONSTRUCTION | J | | | | | | |
| SUPERVISION | 1380 | 1380 | 1380 | 1380 | 690 | 690 | 6905 |
| LAND | 185 | 0 | · · 0 | 0 | 0 | 0 | 185 |
| TRANSFORMERS | 0 | 0 | 2383 | 4171 | 4171 | 1192 | 11917 |
| CIRCUIT BREAKERS | 0 | 0 | 1282 | 2244 | 2244 | 641 | 6410 |
| STATION EQUIPMENT | 0 | . 0 | 875 | 1531 | 1531 | 438 | 4375 |
| STRUCTURES & ACCESSORIES | 0 | 0 | 3282 | 6564 | 6564 | 0 | 16411 |
| SUB-TOTAL | 1565 | 1380 | 9203 | 15890 | 15200 | 2960 | 46200 |
| 3. CONTROL AND COMMUNICATIO | INS | | | | | | |
| ENGINEERING AND INSTALLAT | ION | | | | | | |
| SUPERVISION | 0 | 0 | 0 | 0 | 86 | 114 | 500 |
| EQUIPMENT | • 0 | 0 | n
 | 0 | 1440 | 2160 | 3600 |
| SUB-TOTAL | 0 | 0 | 0 | 0 | 1526 | 2274 | 3800 |
| TOTAL | 2777 | 8643 | 24933 | 23142 | 69496 | 72493 | 201484 |
| TOTAL FOR YEAR | 0 | 11421 | 0 | 48074 | 0 | 141989 | 201484 |

D - 3

B. <u>Case IA & IB</u>, Anchorage-Fairbanks Intertie, 230 kV s/c Transmission System, 323 Miles

1. Cost Summary

76474**5**

| T/L Cost @ \$166,104 per mile | \$53,652,000 |
|-----------------------------------|--------------|
| Anchorage Substation | 3,976,000 |
| Ester Substation | 5,080,000 |
| Control and Communications System | 2,500,000 |
| TOTAL | \$65,208,000 |

2. Anchorage Substation Costs

| 1 | 138-kV Circuit Breaker
Structures and Accessories | \$ | 86,000
108,000 |
|---|---|-----|---------------------|
| 1 | 138-kV Air Disconnect Switch
Structures and Accessories | | 11,000
38,000 |
| 4 | 13.8-kV, 12-MVAR Shunt Reactor Bank
Structures and Accessories | | 420,000
315,000 |
| 4 | 13.8-kV Circuit Breaker
Structures and Accessories | | 154,000
119,000 |
| 4 | 13.8-kV Air Disconnect Switch
Structures and Accessories | | 31,000
64,000 |
| 4 | 1Ø - 48 MVA, 138/230-kV Autotransformer
Structures and Accessories | 1 | ,020,000
538,000 |
| 2 | 230-kV Circuit Breakers
Structures and Accessories | | 338,000
407,000 |
| 4 | 230-kV Air Disconnect Switch
Structures and Accessories | | 70,000
234,000 |
| | Land 2 acres | | 23,000 |
| | TOTAL | \$3 | ,976,000 |

3. Ester Substation Costs

en: min

-

38-15-7-C

| 1 | 138-kV Circuit Breaker
Structures and Accessories | \$ | 86,000
108,000 |
|---|--|-----|--------------------|
| 1 | 138-kV Air Disconnect Switch
Structures and Accessories | | 11,000
38,000 |
| 3 | 13.8-kV, 12-MVAR Shunt Capacitor Bank
Structures and Accessories | | 265,000
198,000 |
| 3 | 13.8-kV Circuit Breaker
Structures and Accessories | | 116,000
89,000 |
| 4 | 1Ø, 46 MVA, 138/230-kV Autotransformer
Structures and Accessories | | 984,000
516,000 |
| 3 | 230-kV Circuit Breaker
Structures and Accessories | | 507,000
613,000 |
| 9 | 230-kV Air Disconnect Switch
Structures and Accessories | | 157,000
528,000 |
| 3 | 230-kV, 16-MVAR Reactor
Structures and Accessories | | 474,000
356,000 |
| | Land 3 acres | | 34,000 |
| | TOTAL | \$5 | 5,080,000 |

C. <u>Case IC</u>, Anchorage-Fairbanks Intertie, 345 kV s/c Transmission System, 323 miles

1. Cost Summary

| T/L Cost @ \$238,214 per mile | \$76,943,000 |
|-----------------------------------|--------------|
| Anchorage Substation | 6,195,000 |
| Ester Substation | 6,231,000 |
| Control and Communications System | 2,500,000 |
| TOTAL | \$91,868,000 |

2. Anchorage Substation Costs

3.

-

| 1 | 138-kV Circuit Breaker
Structures and Accessories | \$ 86,000
108,000 |
|-----|---|-------------------------|
| 1 | 138-kV Air Disconnect Switch
Structures and Accessories | 11,000
38,000 |
| 1 | 13.8-kV 16-MVAR Shunt Reactor Bank
Structures and Accessories | 112,000
84,000 |
| 1 | 13.8-kV Circuit Breaker
Structures and Accessories | 39,000
30,000 |
| 1 | 13.8-kV Air Disconnect Switch
Structures and Accessories | 8,000
16,000 |
| 4 | 10 - 48-MVA, 138/345-kV Autotransformer
Structures and Accessories | 1,936,000
725,000 |
| 2 | 345-kV Circuit Breaker
Structures and Accessories | 653,000
340,000 |
| 5 | 345-kV Air Disconnect Switch
Structures and Accessories | 114,000
330,000 |
| 4 | 1Ø - 33-1/3-MVAR, 345-kV Shunt Reactor
Structures and Accessories | 882,000
660,000 |
| | Land 2 acres | 23,000 |
| | TOTAL | \$6,195,000 |
| Est | ter Substation Cost | |
| 1 | 138-kV Circuit Breaker
Structures and Accessories | \$86,000
108,000 |
| 1 | 138-kV Air Disconnect Switch
Structures and Accessories | 11,000
38,000 |
| 1 | 13.8-kV, 15-MVAR Shunt Capacitor
Structures and Accessories | 132,000
100,000 |
| 1 | 13.8-kV Circuit Breaker
Structures and Accessories | 39,000
30,000 |
| 1 | 13.8-kV Air Disconnect Switch
Structures and Accessories | 8,000
16,000 |

3. Ester Substation Cost (Continued)

| 4 | 1Ø - 48 MVA, 138/345-kV Autotransformer
Structures and Accessories | \$1,936,000
725,000 |
|---|---|------------------------|
| 2 | 345-kV Circuit Breaker
Structures and Accessories | 653,000
340,000 |
| 5 | 345-kV Air Disconnect Switch
Structures and Accessories | 114,000
330,000 |
| 4 | 1Ø - 33-1/3-MVAR, 345-kV Shunt Reactor
Structures and Accessories | 882,000
660,000 |
| | Land 2 acres | 23,000 |
| | TOTAL | \$6,231,000 |

D. <u>Case ID, Anchorage-Fairbanks Intertie, 230 kV s/c Transmission</u> System, 323 miles

1. Cost Summary

LARGE

| T/L Cost @ \$166,104 per mile | \$53,652,000 |
|-----------------------------------|--------------|
| Anchorage Substation | 3,976,000 |
| Palmer Substation | 1,434,000 |
| Healy Substation | 1,434,000 |
| Ester Substation | 5,080,000 |
| Control and Communications System | 3,300,000 |
| TOTAL | \$68,876,000 |

2. Anchorage-Palmer, 230 kV s/c Transmission System, 40 miles

| T/L Cost @ \$166,104 per mile | \$ 6,644,000 |
|-----------------------------------|--------------|
| Anchorage Substation | 3,976,000 |
| Palmer Substation | 717,000 |
| Control and Communications System | 1,450,000 |
| TOTAL | \$12,787,000 |

3. Palmer-Healy, 230 kV s/c Transmission System, 190.5 miles

| T/L Cost @ \$166,104 per mile | \$31,726,000 |
|-----------------------------------|--------------|
| Palmer Substation | 717,000 |
| Healy Substation | 717,000 |
| Control and Communications System | 400,000 |
| TOTAL | \$33,560,000 |

4. Healy-Ester, 230 kV s/c Transmission System, 92 miles

| T/L Cost @ \$166,104 per mile | \$15,282,000 |
|-----------------------------------|--------------|
| Healy Substation | 717,000 |
| Ester Substation | 5,080,000 |
| Control and Communications System | 1,450,000 |
| TOTAL | \$22,529,000 |

5. Anchorage Substation Costs

| 1 | 138-kV Circuit Breaker
Structures and Accessories | \$
86,000
108,000 |
|---|---|-------------------------|
| 1 | 138-kV Air Disconnect Switch
Structures and Accessories | 11,000
38,000 |
| 4 | 13.8-kV, 12-MVAR Shunt Reactor Bank
Structures and Accessories | 420,000
315,000 |
| 4 | 13.8-kV Circuit Breaker
Structures and Accessories | 154,000
119,000 |
| 4 | 13.8-kV Air Disconnect Switch
Structures and Accessories | 31,000
64,000 |
| 4 | 1Ø - 48-MVA, 138/230-kV Autotransformer
Structures and Accessories | 1,020,000
538,000 |
| 2 | 230-kV Circuit Breakers
Structures and Accessories | 338,000
407,000 |
| 4 | 230-kV Air Disconnect Switch
Structures and Accessories | 70,000
234,000 |
| | Land 2 acres |
23,000 |
| | TOTAL | \$
3,976,000 |
| | D - 8 | |

| 6. | Palm | er Substation - (One Line Bay) | | |
|----|------|---|----|--------------------|
| | 1.5 | 230-kV Circuit Breaker
Structures and Accessories | \$ | 253,000
305,000 |
| | 2 | 230-kv Air Disconnect Switch
Structures and Accessories | | 36,000
117,000 |
| | | Land | | 6,000 |
| | | TOTAL | \$ | 717,000 |
| 7. | Heal | y Substation - (One Line Bay) | | |
| | 1.5 | 230-kV Circuit Breaker
Structures and Accessories | | 253,000
305,000 |
| | 2 | 230-kV Air Disconnect Switch
Structures and Accessories | | 36,000
117,000 |
| | | Land | · | 6,000 |
| | | TOTAL | \$ | 717,000 |
| 8. | Este | er Substation Costs | | |
| | 1 | 138-kV Circuit Breaker
Sturctures and Accessories | \$ | 86,000
108,000 |
| | 1 | 138-kV Air Disconnect Switch
Structures and Accessories | | 11,000
38,000 |
| | 3 | 13.8-kV, 12-MVAR Shunt Capacitor Bank
Structures and Accessories | | 265,000
198,000 |
| | 3 | 13.8-kV Circuit Breaker
Structures and Accessories | | 116,000
89,000 |
| | 4 | 1Ø - 46-MVA, 138/230-kV Autotransformer
Structures and Accessories | | 984,000
516,000 |
| | 3 | 230-kV Circuit Breaker
Structures and Accessories | | 507,000
613,000 |

10

D - 9

8. Ester Substation Costs (Continued)

| 9 | 230-kV Air Disconnect Switch
Structures and Accessories | \$ | 157,000
528,000 |
|---|--|-----|--------------------|
| 3 | 230-kV, 16-MVAR Reactor
Structures and Accessories | | 474,000
356,000 |
| | Land 3 acres | | 34,000 |
| | TOTAL | \$5 | ,080,000 |

E. <u>Case II, Anchorage - Upper Susitna - Fairbanks Intertie</u> <u>345 kV 2-s/c Anchorage-Devil Canyon 155 miles</u> <u>230 kV 2-s/c Devil Canyon-Ester</u> <u>189 miles</u> <u>230 kV 2-s/c Watana-Devil Canyon</u> <u>27 miles</u>

1. Cost Summary

| Anchorage - Devil Canyon T/L @ \$504,254 per mile* | \$ 78,159,000 |
|--|---------------|
| Devil Canyon - Ester T/L @ \$332,208 per mile* | 62,787,000 |
| Watana - Devil Canyon T/L @ \$390,306 per mile* | 10,538,000 |
| Anchorage Substation | 23,160,000 |
| Devil Canyon Substation | 10,109,000 |
| Ester Substation | 11,339,000 |
| Watana Substation | 1,596,000 |
| Control and Communications System | 3,800,000 |
| TOTAL | \$201,488,000 |

* Includes two single-circuit lines.

2. Anchorage Substation Cost

3.

TOTAL

| 2 | 138-kV Circuit Breaker
Structures and Accessories | \$ | 172,000
216,000 |
|-----|--|-----|------------------------|
| 2 | 138-kV Air Disconnect Switch
Structures and Accessories | | 23,000
76,000 |
| 7 | 1Ø - 210.5-MVA, 138/345-kV Autotransformer
Structures and Accessories | | 8,516,000
3,404,000 |
| 9 | 345-kV Circuit Breaker
Structures and Accessories | | 2,938,000
1,528,000 |
| 18 | 345-kV Air Disconnect Switch
Structures and Accessories | | 408,000
1,191,000 |
| 2 | 345-kV, 200-MVAR Shunt Capacitor
Structures and Accessories | | 2,647,000
1,984,000 |
| | Land 5 acres | | 57,000 |
| | TOTAL | \$2 | 3,160,000 |
| Dev | il Canyon Substation Cost | | |
| 3 | 345-kV Circuit Breaker
Structures and Accessories | \$ | 981,000
509,000 |
| 6 | 345-kV Air Disconnect Switch
Structures and Accessories | | 138,000
399,000 |
| 7 | 1Ø - 90.3-MVA, 230/345-kV Autotransformer
Structures and Accessories | | 3,418,000
1,466,000 |
| 6 | 230-kV Circuit Breaker | | 1,015,000 |
| | Structures and Accessories | | 1,224,000 |

Land 4 acres \$10,109,000

46,000
4. Ester Substation Cost

5.

00**11**/19.

1.110/2.20

(Marked

| 2 | 138-kV Circuit Breaker
Structures and Accessories | \$ | 172,000
216,000 |
|-----|---|-----|------------------------|
| 2 | 138-kV Air Disconnect Switch
Structures and Accessories | | 23,000
76,000 |
| 7 | 1Ø - 65-MVA, 138/345-kV Autotransformer
Structures and Accessories | | 2,086,000
1,253,000 |
| 6 | 13.8-kV Air Disconnects
Structures and Accessories | | 46,000
96,000 |
| 6 | 13.8-kV Circuit Breaker
Structures and Accessories | | 232,000
181,000 |
| 6 | 13.8-kV, 6-MVAR Capacitor
Structures and Accessories | | 264,000
200,000 |
| 9 | 230-kV Circuit Breaker
Structures and Accessories | | 1,523,000
1,838,000 |
| 18 | 230-kV Air Disconnect Switch
Structures and Accessories | | 314,000
1,055,000 |
| 2 | 230-kV, 80-MVAR Capacitor
Structures and Accessories | | 968,000
727,000 |
| | Land 6 acres | | 69,000 |
| | TOTAL | \$1 | 1,339,000 |
| Wat | ana Substation Cost | | |
| 3 | 230-kV Circuit Breakers
Structures and Accessories | \$ | 508,000
613,000 |
| 6 | 230-kV Disconnect Switch
Structures and Accessories | | 106,000
352,000 |
| | Land | | 17,000 |
| | TOTAL | \$ | 1,596,000 |

D.2 DATA AND COST ESTIMATES FOR GENERATING PLANTS

- B. Cost Estimates and Disbursements for Generating Plants
 - Note: Only specific units affected by interconnection of Anchorage and Fairbanks systems are considered:
 - 1. Northpole #3 (NORT 3) 69 MW SCGT in Fairbanks Area.

This unit is necessary for independent system expansion. Will not be required if interconnection assured.

Rating - 68.6 MW (net) Combustion Turbine Fuel - Distillate from North Pole Refinery Ref. Table B-1, Appendix B of Stanley Consultants Review Report For 1983 Installation:

| Unit Cost = | \$31,482,000 | | |
|---------------------------|--------------|----|----------|
| NO _X Cost | 1,387,000 | | |
| Subtotal | \$32,869,000 | or | \$476/kW |
| Assoc. Iransm. <u>1</u> / | 4,783,000 | | |
| TOTAL | \$37,652,000 | or | \$546/kW |

See Also: P. 45 of GVEA Power Supply Study - 1978 by Stanley Consultants & P. 28 - Table 10 Escalation Rates.

| | | GNP Deflators | |
|-----------|---------------|---------------------------|-----------|
| Period | Labor (1.20%) | Material (<i>1</i> .80%) | Composite |
| 1983-1980 | 1.085 | 1.07 | 1.075 |
| 1980-1979 | 1.095 | 1.08 | 1.085 |

Summary of Costs:

| Facility | 1979 Baseline (| Costs |
|--|------------------------------|-----------------------------|
| Gas-Turbine Unit
Assoc. Transm. | \$24,385,000 or
3,549,000 | \$353/kW |
| Total Capital Investment | \$27,934,000 or | \$405/kW |
| <u>Disbursements</u> - \$1000
<u>Pre-Operational Period</u> | <u>1st Year</u> (1983) | <u>2nd Year</u> (1984) |
| Gas-Turbine Unit
Assoc. Transm. | 7,315 (30%)
355 (10%) | 17,070 (70%)
3,194 (90%) |
| Total Facilities | \$7,670 | \$20,264 |

 $\frac{1}{2}$ Relocation of facilities and expansion of existing Northpole substation.

2. Beluga #9 (BELU 9) 71 MW RCGT in Anchorage Area.

This unit will be postponed for one year by interconnection, from beginning year 1985 to 1986.

This unit will draw on Beluga gas reserves for fuel supply. Design of unit is assumed to be simple-cycle, similar to existing units on Chugach System - Ref. Beluga Units 1, 2, 4, 6, & 7.

Estimated Cost of Unit:

From Reference Cost Estimate for NORT 3 at Fairbanks Cost at Bus-bar of 69 MW unit = \$353/kWBy comparison for 71 MW unit = \$350/kWNow applying Alaskan construction cost location factors from Battelle Report, Table 6.3, P. 6.12 Applicable factor from Fairbanks to Beluga = $\frac{1.62}{1.2}$ = 1.35 Estimated Cost = \$473/kW or \$33,548,000

Disbursements:

| Pre-Operational Period | <u>1st Year</u> | <u>2nd Year</u> |
|--------------------------|-----------------|-----------------|
| Independent Expansion | 1983 | 1984 |
| Interconnected Expansion | 1984 | 1985 |
| Proportion of Total | 30% | 70% |
| Investment - \$1000 | 10,064 | 23,484 |

Associated Transmission Facilities:

Transmission Line (allow 50 miles) @ \$126,000/mile

Total Cost of Line Facilities = \$6,300,000

Substation Additions at Beluga and Knik Arm = \$2,650,000

Total Transmission Line and Substation Facilities = \$8,950,000

Disbursements:

| | 1979 Base | ine Costs |
|--|-----------|-----------|
| Pre-Operational Period | 1st Year | 2nd Year |
| Independent Expansion | 1983 | 1984 |
| Interconnected Expansion | 1984 | 1985 |
| Proportion of Total | 10% | 90% |
| Investment - \$1000
Transm. & Substations | 895 | 8,055 |
| Total Facilities | | |

\$42,490,000

Northpole #4 (NORT 4) 69 MW SCGT in Fairbanks Area.
 This unit is necessary for independent system expansion.
 Will not be required with an interconnected system.

Scheduled In-Service Beginning Year 1990

Unlike NORT 3, no transmission additions will be required, with completion of relocation and expansion of the substation. Considering only cost of unit with assoc. transf. and swgr. For 1979 Baseline Cost Levels:

Total Capital Investment = \$25,185,000 or \$365/kW

Disbursements:

| Pre-Operational Period | <u>lst Year</u> (1988) | <u>2nd Year</u> (1989) |
|--------------------------|------------------------|------------------------|
| GT unit, transf. & swgr. | 7,555 (30%) | 17,630 (70%) |

Anchorage Peaking Unit #2 (PEAK A2) 78 MW SCGT

This unit is required for both independent and interconnected systems but in-service date is advanced one year with intertie.

Basing cost of addition on Northpole Unit 4 installation i.e. SCGT unit with associated transformer and switching. Estimated cost based on rating, with allowance for scale.

For 1979 Baseline Cost Levels:

69 MW GT Unit Total Cost = \$25,185,000 or \$365/kW 78 MW GT Unit Total Cost = \$28,080,000 or \$360/kW

Now applying Alaskan construction cost location adjustment factor from Battelle Report Table 6.3 P. 6.12

Applicable factor from Fairbanks to Anchorage = 1/1.2 = 0.83

Total Capital Investment = \$23,400,000 or \$300/kW Disbursements:

| Year | Independent | Interconnected | <u>% Total</u> | Cost -
\$1000_ |
|------|-------------|----------------|----------------|-------------------|
| 1 | 1994 | 1993 | 30 | 7,020 |
| 2 | 1995 | 1994 | 70 | 16,380 |

5. Northpole #5 (NORT 5) 69 SCGT in Fairbanks Area.

This unit is necessary for independent system expansion. Will not be required with an interconnected system.

Scheduled In-Service Beginning Year 1997

The addition of this unit completes the expansion for the independent systems of the Railbelt Area, the time frame is such that for interconnected expansion, with the staged increments of hydro capacity from the Susitna development, the last unit at Devil Canyon would be on-line beginning year 1997.

Similar to NORT 4, no transmission additions are assumed to be required, such that power would be delivered from the expanded Northpole Substation to the existing system.

Considering only cost of unit, with associated transf. and swgr.

For 1979 Baseline Cost Levels:

Total Capital Investment = \$25,185,000 or \$365/kW

Disbursements:

| | (\$1 | 000) |
|--------------------------|-----------------|------------------------|
| Pre-Operational Period: | lst Year (1995) | <u>2nd Year (1996)</u> |
| GT unit, transf. & swgr. | 7,555 (30%) | 17,630 (70%) |

6. Anchorage #11 (ANCH 11) 104 MW Coal-Fired Steam-Electric Plant.

This unit will be required for independent system expansion but will be postponed, with interconnection, from in-service 1988 to 1993.

Cost estimate for this plant is based on Healy Unit 2 estimate prepared by Stanley Consultants, with applicable Alaskan construction cost location adjustment factor.

From Stanley Consultants Report to GVEA, Appendix A, P. A-1.

For 1984 Installation Date (1978 Cost Levels):

Healy Unit 2 Plant (Without FGD):

| Plant and Equipment
Contingency | \$102,924,000
3,088,000 | or | \$ 990/kW |
|---|-----------------------------|----|-----------|
| Total Construction Cost
Eng'g., Legal & Overhead | \$107,012,000
14,982,000 | or | \$1029/kW |
| TOTAL | \$121,994,000 | or | \$1173/kW |
| Escalating @ 10% to 1979 Cost Level | | | \$1290/kW |
| Total Baseline 1979 Cost
without FGD = | \$134,160,000 | | |

Now Including Cost of Desulphurization:

| Plant and Equipment
Contingency | \$111,174,000
3,335,000 | or | \$1069/kW |
|---|------------------------------------|----|-----------|
| Total Construction Cost
Eng'g., Legal & Overhead | \$114,509,000
<u>16,031,000</u> | or | \$1101/kW |
| TOTAL | \$130,540,000 | or | \$1255/kW |
| Escalating @ 10% to 1979 Cost Level | | | \$1380/kW |
| Total Baseline 1979 Cost
with FGD = | \$143,520,000 | | |

Associated Transmission Facilities:

Assuming relatively short transmission line with substation facilities required, for connection to existing AML&P transmission system in Anchorage area.

Cost Estimate for Transmission Line:

Transmission Line (allow 30 miles) @ \$126,000/mile Total Cost of Line Facilities = \$3,780,000 Cost Estimate for Substation Facilities:

| Equipment
Contingency | \$2,700,000
203,000 |
|---|------------------------|
| Total Construction Cost
Eng'g., Legal & Overhead | \$2,903,000
 |
| TOTAL | \$3,280,000 |
| Escalating @ 10% to 1979 Cost Level | |
| Total 1979 Baseline Cost | \$3,608,000 |

Summary of Costs:

| | WO/FGD | W/FGD |
|---------------------------|---------------|---------------|
| Coal-Fired Plant (104 MW) | \$134,160,000 | \$143,520,000 |
| Transmission Line | 3,780,000 | 3,780,000 |
| Substation Facilities | 3,608,000 | 3,608,000 |
| TOTAL | \$141,548,000 | \$150,908,000 |

Now applying Alaskan construction cost location adjustment factor from Table 6.3 P. 6.12 of Battelle Study Report:

| Apply | ing | this | factor, | Total | Costs | = | \$99, | 084, | 000 | <u>\$105</u> | ,636 | 5,000 |
|-------|-----|------|---------|-------|-------|---|-------|------|-----|--------------|------|-------|
| | | | | | or | = | \$953 | /k₩ | | \$101 | 5/k1 | N |

Disbursements - \$1000

1987

6.

Coal-Fired Plant (ANCH 11) 1979 Baseline Costs W/FGD % Total WO/FGD Pre-Operational Year: Interconnected Independent 2 2,009 1,878 1982 1987 1. 8 7,513 8,037 1988 2. 1983 28,174 30,139 1989 30 1984 3. 37,172 34,747 37 4. 1985 1990 20,093 20 18,783 5. 1986 1991 3 2,817 3,014 1987 1992 6. Associated Transmission Facilities 1,034 20 1,034 1991 5. 1986

4,138

80

4,138

D - 18

1992

7. Coal-Fired Unit F2 (COAL F2) 100 MW in Fairbanks Area.

This unit will be required for both the independent and interconnected system expansions, with generation reserve sharing only. However, with both reserve sharing and firm power transfer, it is replaced, together with COAL 5, by a 300 MW unit (COAL 6).

This unit will be very similar to ANCH 11, which in turn was based on the Healy Unit 2 Plant, as reported by Stanley Consultants. The unit costs will be increased proportionately, to allow for the change of unit size from 104 MW to 100 MW. This has been economically scaled using the nomograph (Figures D-1 and D-2) in this appendix.

For Generating Plant COAL F2:

| <u> Plant Cost Estimates</u> : | <u>1979 Baseline</u> | Cost | Levels |
|--------------------------------|----------------------|------|-----------|
| Without FGD | \$120,000,000 | or | \$1200/kW |
| With FGD | \$130,000,000 | or | \$1300/kW |

Associated Transmission Facilities:

Assuming a plant site location at or near Healy, the transmission line and substation requirements are similar to those required for Healy Unit 2. Reference Stanley Consultants Review Report to GVEA, Appendix A, P. A-1:

Transmission Facility Costs:

| | 1979 Cost Levels
(1.1 x 1978 Costs) | | | |
|--------------------------|--|--------------------------|--|--|
| | Transmission
Line | Substation
Facilities | | |
| Equipment and Material | \$15,510,000 | \$3,348,000 | | |
| Contingency | 465,000 | 100,000 | | |
| Construction Cost | \$15,975,000 | \$3,448,000 | | |
| Eng'g., Legal & Overhead | 2,455,000 | 102,000 | | |
| TOTAL | \$18,430,000 | \$3,550,000 | | |

| <u>Disbursements</u> - | \$1000 | | | |
|------------------------|---------------------|----------------|---------|--------|
| Coal-Fired Unit | (COAL F2): | | | |
| | | 1979 B | aseline | Costs |
| Pre-Operational | Year: | <u>% Total</u> | WO/FGD | W/FGD |
| 1. | 1986 | 2 | 2,400 | 2,600 |
| 2. | 1987 | 8 | 9,600 | 10,400 |
| 3. | 1988 | 30 | 36,000 | 39,000 |
| 4. | 1989 | 37 | 44,400 | 48,100 |
| 5. | 1990 | 20 | 24,000 | 26,000 |
| 6. | 1991 | 3 | 3,600 | 3,900 |
| Associated Tran | smission Facilities | : | | |
| 5. | 1990 | 20 | 4,400 | 4,400 |
| 6 | 1001 | 80 | 17 580 | 17 580 |

8. Coal-Fired Unit 5 (COAL 5) 200 MW in Anchorage Area.

This unit will be required for both the independent and interconnected system expansions, with generation reserve sharing only. However, with both reserve sharing and firm power transfer, it is replaced, together with COAL F2, by a 300-MW unit (COAL 6).

The cost estimate for this generating plant was obtained by scaling costs from a base reference of 100 MW to 200 MW, using the nomograph (Figures D-1 and D-2) contained in this Appendix. Then Alaskan construction cost location adjustment factors were used to determine the cost relevant to the Beluga site in the Anchorage Area.

From Healy to Beluga - Location Factor = 2.75/2.42 = 1.14

For Generating Plant COAL 5

Plant Cost Estimates:

-

| | 1979 E | 1979 Baseline Cost Levels (\$1000) | | | | |
|-------------|--------------|------------------------------------|--------------|-----------|--|--|
| | Healy S | Site | Beluga | Site | | |
| Without FGD | \$165,000 or | \$825/kW | \$188,000 or | \$ 940/kW | | |
| With FGD | \$175,000 or | \$875∕k₩ | \$200,000 or | \$1000/kW | | |

Associated Transmission Facilities:

Assuming a section of transmission line and substation facilities, for connection to existing transmission system in Anchorage area.

| Transmission Line (allow 50 miles) @ | \$174,000/mile |
|--------------------------------------|----------------|
| Total Cost of Line Facilities = | \$ 8,700,000 |
| Substation Terminal at Knik Arm = | 3,545,000 |
| Total Transmission Facilities | \$12,245,000 |

Disbursements - \$1000

Coal-Fired Unit (COAL 5)

| | | 13/3 R | aseline (| JOSTS |
|------------------|---------------------|---------|-----------|---------|
| Pre-Operational | Year: | % Total | WO/FGD | W/FGD |
| | | | | |
| 1. | 1986 | 2 | 3,760 | 4,000 |
| 2. | 1987 | 8 | 15,040 | 16,000 |
| 3. | 1988 | 30 | 56,400 | 60,000 |
| 4. | 1989 | 37 | 69,560 | 74,000 |
| 5. | 1990 | 20 | 37,600 | 40,000 |
| 6. | 1991 | 3 | 5,640 | 6,000 |
| Associated Trans | mission Facilities: | | | • · · · |
| 5. | 1990 | 20 | 2,450 | 2,450 |
| 6. | 1991 | 80 | 9,795 | 9,795 |

9. Coal-Fired Unit 6 (COAL 6) 300 MW in Anchorage Area.

This unit will not be required either for independent or interconnected system expansion for generation reserve sharing only. However, with reserve capacity sharing and firm power transfer, it will replace both COAL F2 and COAL 5.

The cost estimate for this plant has been derived from the cost for the reference 100 MW plant, using the nomograph (Figures D-1 and D-2) contained in this Appendix. This enabled consideration of economies of scale obtained when the unit capacity is changed from 100 to 300 MW and the differential costs associated with the two sites, according to the Alaskan construction cost location adjustment factor, similar to that developed for COAL 5. Plant Cost Estimates:

| | Healy S | ite | <u> </u> | | |
|-------------|--------------|----------|--------------|----------|--|
| Without FGD | \$200,000 or | \$667/kW | \$228,000 or | \$760/kW | |
| With FGD | \$240,000 or | \$800/kW | \$274,000 or | \$913/kW | |

Associated Transmission Facilities:

Assuming a section of transmission line and substation facilities, for connection to existing transmission system in Anchorage area.

| Transmission Line (allow 50 miles) @ | \$240,000/mile |
|--------------------------------------|----------------|
| Total Cost of Line Facilities = | \$12,000,000 |
| Substation Terminal at Knik Arm = | 6,250,000 |
| Total Transmission Facilities | \$18,250,000 |

Disbursements - \$1000

Coal-Fired Unit (COAL 6)

| | | 1979 B | aseline | Costs |
|-----------------|---------------------|---------|---------|---------|
| Pre-Operational | Year: | % Total | WO/FGD | W/FGD |
| 1. | 1986 | 2 | 4,560 | 5,480 |
| 2. | 1987 | 8 | 18,240 | 21,920 |
| 3. | 1988 | 30 | 68,400 | 82,200 |
| 4. | 1989 | 37 | 84,360 | 101,380 |
| 5. | 1990 | 20 | 45,600 | 54,800 |
| 6. | 1991 | 3 | 6,840 | 8,220 |
| Associated Tran | smission Facilities | | | |
| 5. | 1990 | 20 | 3,650 | 3,650 |
| 6. | 1991 | 80 | 14,600 | 14,600 |

 <u>Coal-Fired Unit 2 (GEN 2) 300 MW at New Site in Anchorage Area</u>. This unit is required for both independent and interconnected systems but in-service date postponed one year with intertie.

For Generating Plant COAL 6:

It is assumed that site will be near to previous plant location at Beluga, in sufficient proximity to assume cost basis to be identical, with difference only in the time frame for construction.

Cost estimate for plant and associated transmission facilities are then identical to that for COAL 6.

Disbursements - \$1000

Coal-Fired Unit (GEN 2)

| | 1979 Baseline Costs | | | | | | |
|-----|---------------------|--------------------|------------|--------|---------|--|--|
| Pre | -Operational | <u>Year</u> : | % Total | WO/FGD | W/FGD | | |
| | Independent | Interconnected | | | | | |
| 1. | 1989 | 1990 | 2 | 4,560 | 5,480 | | |
| 2. | 1990 | 1991 | 8 | 18,240 | 21,920 | | |
| 3. | 1991 | 1992 | 30 | 68,400 | 82,200 | | |
| 4. | 1992 | 1993 | 37 | 84,360 | 101,380 | | |
| 5. | 1993 | 1994 | 20 | 45,600 | 54,800 | | |
| 6. | 1994 | 1995 | 3 | 6,840 | 8,220 | | |
| Ass | ociated Trans | mission Facilities | <u>.</u> : | | | | |
| 5. | 1993 | 1994 | 20 | 3,650 | 3,650 | | |
| 6. | 1994 | 1995 | 80 | 14,600 | 14,600 | | |

D.3 DATA AND COST ESTIMATES FOR SUPPLY OF CONSTRUCTION POWER TO UPPER SUSITNA PROJECT SITES

The requirements of the combined Railbelt area generation expansion, with inclusion of both Watana and Devil Canyon power from the Susitna development, schedules Unit 1 from Devil Canyon in January 1995, only 3 years after the first unit goes on line at Watana Damsite. Assuming as a first construction schedule that of the U.S. Army Corps of Engineers, the construction periods are 6 and 5 years, respectively, for Watana earthfill cam and the concrete arch dam at Devil Canyon. Thus, with the generation staging of the plan for interconnection, the total construction period would be 11 years, with pre-operational construction periods of 6 years for Watana and 5 years for Devil Canyon. There would be concurrent construction during 2 years.

Prior to the first unit on-line at Watana, construction power would be required for 6 years at Watana and 2 years at Devil Canyon. It is assumed, for purposes of analysis, that separate provision would need to be made for the full construction power needs at both sites. From estimates by the Consultants:

Connected Load

| Watana | a |
|--------|--------|
| Devil | Canyon |

4000 kW (estimated at 3750 kW) 3400 kW (estimated at 3350 kW)

Operational Assumptions for Both Sites:

6 months/yr intensive operation @ 0.65 LF @ 0.30 LF 6 months/yr light loading

Corresponding to construction planning assumptions of U.S. Corps of Engineers.

Figure 7-1 of Chapter 7 shows the recommended sites at Watana and Devil Canyon for the Susitna development and the routing of the tap line to the sites from the transmission tap station, located on the main transmission corridor for the Anchorage-Fairbanks Intertie. The tap line can later be used also for a subtransmission circuit for distribution in the area, following the completion of the construction program.

A. <u>Alternative 1 - Cost of Construction Power by Diesel Generation</u> (This will constitute benefits for B/C analysis)

Basic Assumptions:

- Diesel units purchased for Watana will be used for a period of 6 years and then sold at depreciated value.
- Diesel units purchased for Devil Canyon will be used for a period of 5 years and then sold at depreciated value.
- 3. No provision will be made at Devil Canyon for tapping 230-kV line from Watana once energized, due to prior purchase of diesel units for construction power.
- 4. Diesel units will be installed in multiples of 675 kW net/unit.
 6 units at Watana 4050 kW net capacity
 5 units at Devil Canyon 3375 kW net capacity

From previous construction power estimates for diesel unit installations:

1979 Cost = \$700/kW

Installation for Watana construction power units would be made in 1985, ready for service in January 1986.

Escalating @7% through 1985 - Cost Level = \$1050/kW.

Installation for Devil Canyon construction power units would be made in 1989, ready for service in January 1990.

Escalating @ 7% through 1989 - Cost Level = \$1377/kW.

Cost of Diesel Installations:

Watana = \$1050 x 4050 = \$4,252,500 Devil Canyon = \$1377 x 3355 = \$4,647,375

This capital investment would be disbursed in 1985 and 1989, respectively, for Watana and Devil Canyon.

Cost of Diesel Operation During Construction

Basic Assumption: Maximum Coincident Demand = Connected Load

This, incidentally, introduces a measure of maximum loading which tends to compensate for an initial lower estimate of construction power requirements by a factor equivalent to projected diversity.

Average Energy Usage Per Year:

Watana $3750 (0.65 + 0.30) \frac{8760}{2}$ kWh = 15,603,750 kWh Say 15.60 GWh/yr for 6 yrs. Devil Canyon $3350 (0.65 + 0.30) \frac{8760}{2}$ kWh = 13,939,350 kWh Say 13.94 GWh/yr for 5 yrs.

Operating Characteristics of Diesel Units:

| Fuel Ra | te Assumed | - | 13 kWh/gal | (diesel fuel) |
|---------|-----------------------|-----|------------|---------------|
| Base Pr | ice for Diesel Fuel | - | 41.2 ∉/gal | (1977 actual) |
| Plus 5% | Allowance for Lube Oi | 1 - | 43.3 ¢/gal | |

To be escalated @ 11% to 1980 and 7% thereafter.

0&M for diesel units estimated at 5% of total cost of incremental generation.

| lear | <u>Watana Dam</u> | Year | Devil Canyon |
|---------------|-------------------|------|--------------|
| 1 9 86 | \$1,118,500 | | |
| 1987 | 1,198,100 | | |
| 1 9 88 | 1,280,800 | | |
| 1989 | 1,371,200 | | |
| 1990 | 1,468,000 | 1990 | \$1,311,800 |
| 1991 | 1,569,400 | 1991 | 1,402,400 |
| | | 1992 | 1,501,300 |
| | | 1993 | 1,607,300 |
| | | 1994 | 1,708,800 |

DIESEL GENERATION OPERATING COSTS

| Year | Diesel Fuel
¢/gal | Including Lube Oil
mills/kWh | 0&M
<u>(mills/kWh)</u> | Total Operating Cost
(mills/kWh) |
|------|----------------------|---------------------------------|---------------------------|-------------------------------------|
| 1977 | 43.3 | 33.3 | 1.7 | 35.0 |
| 1978 | 48.1 | 37.0 | 1.9 | 38.9 |
| 1979 | 53.3 | 41.0 | 2.1 | 43.1 |
| 1980 | 59.2 | 45.5 | 2.3 | 47.8 |
| 1981 | 63,3 | 48.7 | 2.4 | 51.1 |
| 1982 | 67.8 | 52.2 | 2.6 | 54.8 |
| 1983 | 72.5 | 55.8 | 2.8 | 58.6 |
| 1984 | 77.6 | 59.7 | 3.0 | 62.7 |
| 1985 | 83.0 | 63.8 | 3.2 | 67.0 |
| 1986 | 88.8 | 68.3 | 3.4 | 71.7 |
| 1987 | 95.1 | 73.2 | 3.6 | 76.8 |
| 1988 | 101.7 | 78.2 | 3.9 | 82.1 |
| 1989 | 108.8 | 83.7 | 4.2 | 87.9 |
| 1990 | 116.5 | 89.6 | 4.5 | 94.1 |
| 1991 | 124.6 | 95.8 | 4.8 | 100.6 |
| 1992 | 133.3 | 102.5 | 5.2 | 107.7 |
| 1993 | 142.7 | 109.8 | 5.5 | 115.3 |
| 1994 | 152.6 | 117.4 | 5.9 | 123.3 |

Depreciated Value of Diesel Units:

Basic Assumption of 15-Year Service Life. Assume Straight-Line Depreciation

1. Watana Installation

Installed Cost (new) = \$4,252,500 (1985)
Depreciation/Year = 283,500
Depreciated Value (1991) 6-Year Period = \$2,551,500

2. Devil Canyon Installation

Installed Cost (new) = \$4,647,375 (1989)
Depreciation/Year = 309,825
Depreciated Value (1994) 5-Year Period = \$3,098,250

Discounted Value of Benefits (Diesel Generation Alternative)

Base Year 1979 (Discounted @ 7%)

| Year | PWF' | Construction
Cost (\$) | Operating
<u>Cost (\$)</u> | Total Cost
(\$) | Present Value
(\$) |
|------|---------|---------------------------|-------------------------------|--------------------|-----------------------|
| 1979 | 1.00000 | | | | |
| 1985 | 0.66634 | 4,252,500 | | 4,252,500 | 2,833,611 |
| 1986 | 0.62274 | | 1,118,500 | 1,118,500 | 696,535 |
| 1987 | 0.58200 | | 1,198,100 | 1,198,100 | 697,294 |
| 1988 | 0.54393 | | 1,280,800 | 1,280,800 | 6 96,6 66 |
| 1989 | 0.50834 | 4,647,375 | 1,371,200 | 6,018,575 | 3,059,482 |
| 1990 | 0.47509 | | 2,779,800 | 2,779,800 | 1,320,655 |
| 1991 | 0.44401 | -2,551,500 | 2,971,800 | 420,300 | 186,617 |
| 1992 | 0.41496 | | 1,501,300 | 1,501,300 | 622,979 |
| 1993 | 0.38781 | | 1,607,300 | 1,607,300 | 623,327 |
| 1994 | 0.36244 | -3,098,250 | 1,718,800 | -1,379,450 | -499,968 |
| | | | | TOTAL PW' | 10,237,198 |

(- sign denotes assumed resale value)

B. <u>Alternative 2 - Cost of Construction Power by Temporary Tapline</u> (This will represent costs for B/C analysis)

Basic Assumptions:

- 1. Same loading conditions and time frame as per Alternative 1.
- 2. Sequence of temporary construction as per previous assumptions.
- Reuse of substation equipment possible after construction program completed but no salvage value on line material. (Note: Possible reuse as distribution line to recreational areas.) Assume resale value of substation equipment to be depreciated value based on 25-year life of facilities.
- Cost of power based on wholesale rates in Railbelt area.
 From previous estimates for line and substation facilities:

Construction Costs:

69-kV subtransmission line - \$3,200,000 (1985 level) Susitna tap station + Watana substation facilities Baseline cost level = \$26.50/kVA (1979) Escalating @ 7% to 1985 (6 yrs) Construction Cost = \$40/kVA (1985) Total Construction Cost = \$400,000

69/4.16 kW, 5 MVA, Substation at Devil Canyon (1979 levels) Transformer - \$45,000 fob factory (Virginia) Allowing 5% for shipping and handling, etc. At jobsite cost = \$47,250 Fused Disc. Sw. = 2,750 Structure, Conc, pad, etc. = <u>5,000</u> TOTAL \$55,000

Construction Costs:

| Equipment | 60% | \$55,000 | | | |
|-----------|-----|----------|----|-------------------|--|
| Labor | 30% | 28,000 | | | |
| Design | 10% | 9,000 | | | |
| TOTAL | | \$92,000 | or | \$18.4/kVA (1979) | |

Substation would be installed in 1989.

Escalated at 7% from 1979 levels.

1989 Construction Cost = \$36.2/kVA Total Construction Cost = \$181,000

O&M For Temporary Construction Power Line Maintenance

69 kV Wood Pole line - Approximately 40 miles long (11 + 29 M)

| • | Year | <u>\$/M</u> | Total O&M
<u>Costs (\$)</u> |
|---------------------------------------|------|-------------|--------------------------------|
| ſ | 1986 | 330 | 13,200 |
| | 1987 | 345 | 13,800 |
| | 1988 | 360 | 14,400 |
| 40 M lotal | 1989 | 380 | 15,200 |
| | 1990 | 400 | 16,000 |
| l | 1991 | 420 | 16,800 |
| | - | | 10.000 |
| · · · · · · · · · · · · · · · · · · · | 1992 | 440 | 12,800 |
| 29 M Total ≺ | 1993 | 460 | 13,300 |
| Ĺ | 1994 | 485 | 14,000 |
| | | | |

Note: That due to overlap in construction schedules for Watana and Devil Canyon the capacity of the Susitna tap station will need to be doubled by addition of second 5 MVA transfer. This will be moved to spares inventory after 2 years.

Cost of Construction Power Supplied over Temporary Line Facility

Based on information from RWRA 2/1/79

Wholesale rates for Railbelt area, with combination of Susitna Hydropower and large coal-fired plant feeding interconnection.

| Year | Rate of Change | Wholesale Rate
(mills/kWh) | <u>Cost of Ener</u>
<u>Bus-Bar</u> | gy (mills/kWh)
Substation |
|--------------|----------------|-------------------------------|---------------------------------------|------------------------------|
| 1979 | | 17 | Note: <u>19</u> | 77 Cost Levels |
| 1980 | > 10% | 18 | | |
| 1981 | | 20 | | |
| 1982 | | 22 | | |
| 1983 | | 24 | | |
| 1'984 | > 8% | 26 | | |
| 1985 | | 28 | | |
| 1986 | | 30 | 27.3 | 30.2 |
| 1987 | | 32 | | |
| 1988 | | 34 | | |
| 1989 | | 37 | | |
| 199 0 | > 7% | 39 | 31.0 | 33.5 |
| 1991 | | 42 | | |
| 1992 | | 45 | | |
| 1993 | | 47 | | |
| 1994 | > 5% | 50 | • | |
| 1.995 | | | 33.2 | 36.6 |
| 2000 | | | 36.2 | 39.1 |

Conversion of Total Energy Rate to 2-Part Tariff

Assumption: 100 MW Power Transfer at 0.6 LF is 525.6 GWh/yr.

| Year | Bulk Rate
(mills/kWh) | Total Revenue
for Bulk Rate
(\$1000) | 50/50 Revenue From:
<u>Demand Energy</u>
<u>(\$1000) (\$1000)</u> | Equivalen
Demand Rate
(\$/kWh) | t Tariff
Energy Rate
(mills/kWh) |
|----------------|--------------------------|--|---|--------------------------------------|--|
| 1979 | 17 | 8,935.2 | 4,467.6 | 74.5 | 8.5 |
| 1980 | 18 | 9,460.8 | 4,730.4 | 78.8 | 9.0 |
| 1981 | 20 | 10,512.0 | 5,256.0 | 87.6 | 10.0 |
| 1982 | 22 | 11,563.2 | 5,781.6 | 96.4 | 11.0 |
| 1983 | 24 | 12,614.4 | 6,307.2 | 105.1 | 12.0 |
| 1984 | 26 | 13,665.6 | 6,832.8 | 113.9 | 13.0 |
| 1985 | 28 | 14,716.8 | 7,358.4 | 122.6 | 14.0 |
| 1986 | 30 | 15,768.0 | 7,884.0 | 131.4 | 15.0 |
| 1987 | 32 | 16,819.2 | 8,409.6 | 140.2 | 16.0 |
| 1988 | 34 | 17,870.4 | 8,935.2 | 148.9 | 17.0 |
| 1989 | 37 | 19,447.2 | 9,723.6 | 162.1 | 18.5 |
| 1.990 | 39 | 20,498.4 | 10,249.2 | 170.8 | 19.5 |
| . 991 | 42 | 22,075.2 | 11,037.6 | 184.0 | 21.0 |
| 992 | 45 | 23,652.0 | 11,826.0 | 197.1 | 22.5 |
| :L 99 3 | 47 | 24,703.2 | 12,351.6 | 205.9 | 23.5 |
| 1994 | 50 | 26,280.0 | 13,140.0 | 219.0 | 25.0 |

Allow 5% adder for line and substation losses - assume the resulting rates are applicable to price construction power.

Cost Estimate for Construction Power

Assuming same loading as for diesel generation alternative.

| | Demand Rate | Energy Rate | Constru | ction Power | Costs |
|------|-------------|-------------|-------------|-------------|-------------------|
| Year | (\$/kW) | (mills/kWh) | Demand (\$) | Energy (\$) | <u>Total (\$)</u> |
| 1986 | 138.0 | 15.8 | 517,500 | 246,480 | 763,980 |
| 1987 | 147.2 | 16.8 | 552,000 | 262,080 | 814,080 |
| 1988 | 156.3 | 17.9 | 586,125 | 279,240 | 865,365 |
| 1989 | 170.2 | 19.4 | 638,250 | 302,640 | 940,890 |
| 1990 | 179.3 | 20.5 | 672,375 | 319,800 | 992,175 |
| 1991 | 193.2 | 22.1 | 724,500 | 344,760 | 1,069,260 |

1. Watana Damsite (3750 kW, 15.6 GWh/yr)

2. Devil Canyon Damsite (3350 kW, 13.94 GWh/yr)

| | Demand Rate | Energy Rate | Constru | ction Power | Costs |
|------|-------------|-------------|-------------|-------------|------------|
| Year | (\$/kW) | (mills/kWh) | Demand (\$) | Energy (\$) | Total (\$) |
| 1990 | 179.3 | 20.5 | 600,655 | 285,770 | 886,425 |
| 1991 | 193.2 | 22.1 | 647,220 | 308,074 | 955,294 |
| 1992 | 207.0 | 23.6 | 693,450 | 328,984 | 1,022,434 |
| 1993 | 216.2 | 24.7 | 724,270 | 344,318 | 1,068,588 |
| 1994 | 230.0 | 26.3 | 770,500 | 366,622 | 1,137,122 |

Depreciated Value of Substation Facilities

Basic Assumption of 25-Year Service Life

Assume Straight Line Depreciation

1. Watana Substation

| Installed Cost (new) | = | \$ 27.6/kVA (1985) | |
|----------------------|---|--------------------|-----------------|
| | = | \$138,000 | •
• |
| Depreciation/Year | = | \$ 5,520 | |
| Depreciated Value | = | \$104,880 (1991) | (6-year period) |

| 2. | Devil Canyon Substation | | | | | |
|----|-------------------------|---|----------------|--------|---------|---------|
| | Installed Cost (new) | = | \$
36.2/kVA | (1989) | | |
| | | = | \$
181,000 | | | |
| | Depreciation/Year | = | \$
7,240 | | | |
| | Depreciated Value | = | \$
144,800 | (1994) | (5-year | period) |

3. Susitna Tap Station/Watana Bus Tap

| Installed Cost (new) | = | \$
262,000 (1985 |) | |
|----------------------|---|---------------------|---|-----------------|
| Depreciation/Year | = | \$
10,480 | | |
| Depreciated Value | = | \$
167,680 (1994 |) | (7-year period) |

To transfer 5 MVA facility from Susitna Tap to Watana. Cost of removal and transfer = \$30,000 (1991) Cost of second 5 MVA step-down facility at Susitna tap. In 1989 for Supplementary power to Devil Canyon = \$343,400 Depreciated value after 2 years = \$315,900

<u>Discounted Value of Costs</u> (Sub-Transmission Tapline Alternative) Base Year 1979 (Discounted @ 7%)

| Year | PWF' | Construction
Cost (\$) | 0&M (\$) | Cost of Power
(\$) | Total Cost
(\$) | Present Value
(\$) |
|------|---------|---------------------------|----------|-----------------------|--------------------|-----------------------|
| 1979 | 1.00000 | | | | | |
| 1985 | 0.66634 | 400,000 | | | 400,000 | 266,536 |
| 1986 | 0.62274 | | 13,200 | 763,980 | 777,180 | 483,981 |
| 1987 | 0.58200 | | 13,800 | 814,080 | 827,880 | 481,826 |
| 1988 | 0.54393 | | 14,400 | 865,365 | 879,765 | 478,531 |
| 1989 | 0.50834 | 524,400 | 15,200 | 940,890 | 1,480,490 | 752,592 |
| 1990 | 0.47509 | | 16,000 | 1,878,600 | 1,894,600 | 900,106 |
| 1991 | 0.44401 | -390,780* | 16,800 | 2,024,554 | 1,650,574 | 732,871 |
| 1992 | 0.41496 | | 12,800 | 1,022,434 | 1,035,234 | 429,581 |
| 1993 | 0.38781 | | 13,300 | 1,068,588 | 1,081,888 | 419,567 |
| 1994 | 0.36244 | -312,480 | 14,000 | 1,137,122 | 838,642 | |
| | | | | | TOTAL PW' | 5,249,548 |

* Including one-time cost of transfer of tap facilities and resale value of 5-MVA substation.

B/C Ratio for Construction Power Supply by Tapline.

 $B/C \text{ Ratio} = \frac{\text{Discounted Cost of Diesel Generation Alternative}}{\text{Discounted Cost of Tapline Alternative}}$ $= \frac{10,237,198}{5,249,548}$ $= \underline{1.95}$

DERIVATION

0F

INPUT COST DATA FOR ECONOMIC ANALYSIS

TO OBTAIN

BASELINE COSTS ASSOCIATED WITH THE TWO CONSTRUCTION POWER ALTERNATIVES

| | | Alternative I | | Alternati | ive II |
|------|-------------|---------------|-----------|-----------|----------|
| | | Diesel Ger | neration | Tapline | Supply |
| Year | 7% Deflator | Escalated | Deflated | Escalated | Deflated |
| 1979 | 1.00 | | | | |
| 1980 | 1.07 | | | | |
| 1981 | 1.14 | | | | |
| 1982 | 1.23 | | | | |
| 1983 | 1.31 | | | | |
| 1984 | 1.40 | | | | |
| 1985 | 1.50 | 4,252,500 | 2,835,000 | 400,000 | 266,670 |
| 1986 | 1.61 | 1,118,500 | 694,720 | 777,180 | 482,720 |
| 1987 | 1.72 | 1,198,100 | 696,570 | 827,880 | 481,330 |
| 1988 | 1.84 | 1,280,800 | 696,090 | 879,765 | 478,130 |
| 1989 | 1.97 | 6,018,575 | 3,055,110 | 1,480,490 | 751,520 |
| 1990 | 2.10 | 2,779,800 | 1,323,710 | 1,894,600 | 902,190 |
| 1991 | 2.25 | 420,300 | 186,800 | 1,650,574 | 733,590 |
| 1992 | 2.41 | 1,501,300 | 622,950 | 1,035,234 | 429,560 |
| 1993 | 2.58 | 1,607,300 | 622,980 | 1,081,888 | 419,340 |
| 1994 | 2.76 | -1,379,450 | -499,800 | 838,642 | 303,860 |

SUMMARY

BASELINE COSTS (1979)

ASSOCIATED WITH TWO CONSTRUCTION POWER ALTERNATIVES

| | \$1000 | \$1000 (1979) | | | | | |
|------|---------------|------------------|--|--|--|--|--|
| | (Independent) | (Interconnected) | | | | | |
| | Diesel | Tapline | | | | | |
| Year | Generation | Supply | | | | | |
| 1985 | 2,835 | 267 | | | | | |
| 1986 | 695 | 483 | | | | | |
| 1987 | 697 | 481 | | | | | |
| 1988 | 696 | 478 | | | | | |
| 1989 | 3,055 | 752 | | | | | |
| 1990 | 1,324 | 902 | | | | | |
| 1991 | 187 | 734 | | | | | |
| 1992 | 623 | 430 | | | | | |
| 1993 | 623 | 419 | | | | | |
| 1994 | $-500^{1}/$ | 304 | | | | | |

 $\frac{1}{}$ Negative sign indicates net resale value predominates over costs.

D.4 ALTERNATIVE GENERATING PLANT FUEL COSTS

The year-by-year analysis of comparative fuel costs follows:

- A. First Period (1984-87) Firm Power Transfer of 30 MW, 145 GWh
 - Year Interconnected System Expansion Independent System Expansion
 - 1984 The number and type of generating plants is identical to that for each system operating independently.

Each independent system would be supplied by operational units on basis of economic dispatch to meet individual area needs.

The determination of relative economic advantage to either system, of a firm power transfer, would require a detailed analysis, necessitating production costing of economically dispatched units for the Anchorage and Fairbanks systems. It is a reasonable measure to delete the comparison of marginal advantages accruing for this year of operation.

1985 ANCH 9 - 78 MW SCGT is added to AML&P system, obviating the need for both NORT 3 and BELU 9. Two units are required in Anchorage area, ANCH 9 -78 MW SCGT and BELU 9 -71 MW RCGT, together with NORT 3 - 69 MW SCGT unit at the Northpole Station in Fairbanks.

As a first approximation, the relative generation cost advantage may be determined by estimating the respective fuel costs associated with the generation of 145 GWh of energy by either ANCH 9 or NORT 3, taking into consideration different primary fuel costs and thermal efficiencies. The unit ratings are sufficiently close to justify this analytical approach, on the basic assumption that equivalent energy would be generated during the year by the two units. An adjustment would then be made to allow for the differential cost of supplying line losses in the transmission intertie, which would amount to 1.5 GWh/yr.

Comparative Fuel Costs:

ANCH 9 - 78 MW SCGT

From Battelle Report (see Figure D-3) See Figure D-1 Trend Curve for HR8444 New Gas with 8% inflation and escalation 1985 Fuel Cost = \$3.60/MBTUNet Heat Rate = 14,500 BTU/kWh Annual Cost of Fuel (ACF) to generate 145 GWh: ACF @ 0.21 PCF^{2/} = $$3.60 \times 145 \times 14,500$ = \$7,569,000 NORT 3 - 69 MW SCGT

From Stanley Consultants Report P. 21 1978 Fuel Cost = \$1.98/MBTUEscalating @ 10% per year^{1/}: 1985 Fuel Cost = \$3.86/MBTUFor distillate from North Pole refinery From Table 6, P. 22: Net Heat Rate = 15,130 BTU/kWh Annual Cost of Fuel (ACF) to generate 145 GWh: ACF @ 0.24 PCF^{2/} = $$3.86 \times 145 \times 15,130$ = \$8,468,000

The total cost comparison is in favor of ANCH 9 generation to supply Fairbanks. Total cost of generation, including loss component = \$7,648,000.

1986

BELU 9 - 71 MW SCGT is addedANCH 10 - 104 MW coal-firedto CEA system, the inter-plant is added to AML&Pconnection having served tosystem for both independentdelay the in-service of theand interconnected systemcombustion turbine by one year.expansions. KNIK A - 15 MWIt is assumed that this unitthermal power plant (CEA) is alsowill be operated for supply toretired from both expansions.

The relative economic advantage is attributable to the fuel cost differential between distillate for NORT 3 generation and Beluga gas for generation by either ANCH 9 or BELU 9. Selecting ANCH 9 as in the previous analysis for 1985:

 $\frac{1}{7}$ 7% inflation + 3% escalation. $\frac{2}{7}$ PCF = Plant Capacity Factor.

year of operation.

Comparative Fuel Costs:

ANCH 9 - 79 MW SCGT

1986 Fuel Cost = \$4.00/MBTU Net Heat Rate = 14,500 BTU/kWh Annual Cost of Fuel (ACF) to generate 145 GWh: ACF @ 0.21 PCF = \$8,410,000

NORT 3 - 69 MW SCGT

1986 Fuel Cost = \$4.25/MBTU Net Heat Rate = 15,130 BTU/kWh Annual Cost of Fuel (ACF) to generate 145 GWh: ACF @ 0.24 PCF = \$9,324,000

The cost comparison is once again in favor of ANCH 9 generation to supply the equivalent amount of energy over intertie, as would otherwise be generated locally in Fairbanks.

Total cost of ANCH 9 generation, including transmission loss = \$8,498,000.

1987 This is the first year of operation of COAL 1 - 200 MW coal-fired plant on the Anchorage system. As this would be the first year of operation for the first major coal-fired plant in the Railbelt, for either independent or interconnected expansions, it would be thus common to the two alternatives. The relative cost advantages would then again be determined by consideration of the relative generation cost for ANCH 9 and NORT 3.

Comparative Fuel Costs:

ANCH 9 - 79 MW SCGTNORT 3 - 69 MW SCGT1987 Fuel Cost = \$4.25/MBTU1987 Fuel Cost = \$4.68/MBTUNet Heat Rate = 14,500 BTU/kWhNet Heat Rate = 15,130 BTU/kWhAnnual Cost of Fuel (ACF)Annual Cost of Fuel (ACF)to generate 145 GWh:to generate 145 GWh:ACF @ 0.21 PCF = \$8,936,000ACF @ 0.21 PCF = \$10,267,000

Total cost of ANCH 9 generation, including transmission loss = \$9,029,000.

B. Second Period (1992-96) - Firm Power Transfer of 70 MW, 337 GWh

Year Interconnected System Expansion

1992 Interconnected operation obviates the need for COAL 5 - 200 MW unit in Anchorage area and COAL F2 - 100 MW unit in Fairbanks area. Comparable generation is maintained by COAL 6 -300 MW unit in Anchorage area. Independent System Expansion

COAL 5 would have to be added to Anchorage system and COAL F2 to Fairbanks.

Comparative economic advantage is determined by relative magnitude of fuel costs, for either COAL 6 or COAL F2, to generate same energy.

Comparative Fuel Costs:

| • | COAL 6 - 300 MW | <u>COAL F2 - 100 MW</u> |
|---------------------------------------|-----------------|-------------------------|
| From Battelle Report (see Figure D-4) | | |
| Fuel Cost in 1992 | \$2.60/MBTU | \$1.90/MBTU |
| Net Heat Rate | 9,500 BTU/kWh | 10,700 BTU∕kWh |
| ACF to generate 337 GWh | \$8,324,000 | \$6,851,000 |

The comparative advantage in this case moves to the use of Healy coal. However, as with interconnection, the unit COAL F2 will be eliminated in favor of the economies of scale associated with the COAL 6 unit. Without production costing, it is not possible to determine the overall economic advantage of introducing COAL 6, so for present analysis it is assumed that no economic energy transfer is possible. However, as a first approximation, the fuel costs for this year will be entered into economic analysis to consider the effect of the differential. 1993 ANCH 11 - 104 MW coal-fired unit added to AML&P system in this year for interconnected expansion, after an interval of five years following the inservice date for same unit with independent expansion. PEAK A1 -78 MW combustion turbine also inservice from beginning of year. PEAK A1 - 78 MW combustion turbine in-service from beginning of year, for independent expansion of Anchorage system.

Of interest in this year is a comparison between the cost of energy generation for ANCH 11 and COAL F2 using the same source of fuel, Healy coal. Thus, the relative advantage of either generating at the existing plant site at Healy or in the vicinity of Anchorage may be examined for similar capacity units having the same thermal efficiency, to determine the economies of energy transfer by intertie.

Comparative Fuel Costs:

| | • | ANCH 11 | • | COAL F2 |
|----------------------------|---|--------------------------|---|---------------------------|
| Cost of Healy coal in 1993 | | \$2.4/MBTU ^{1/} | | \$2.00/MBTU ^{2/} |
| Net Heat Rate | | 10,700 BTU/kWh | | 10,700 BTU/kWh |
| ACF to generate 337 GWh | | \$8,654,000 | | \$7,212,000 |

Once again the comparative advantage lies with the generation of energy at the Healy site. However, with interconnection the need for COAL F2 disappears in favor of the economies of scale attendant on COAL 6. It may be noted that the cost differential in favor of Healy disappears if the COAL F2 site would be moved away from Healy for environmental reasons to say Nenana. In this case, the cost of generation would be approximately the same whether coal were transported either to Anchorage or Nenana, as the transmission loss, associated with ANCH 11 (104 MW) generation and transfer over the intertie, would be compensated for by the slightly higher heat rate to be expected with the 100 MW unit of COAL F2.

 $\frac{1}{2}$ Delivered to Anchorage plant site.

 $\frac{2}{2}$ Delivered to Healy plant site.

1994 As GEN 1 - 300 MW coal-fired generating plant added for both independent and interconnected system expansions, the previous combination of ANCH 11 and COAL F2 can again be examined to determine the differential cost of fuel.

Comparative Fuel Costs:

| • |) | ANCH 11 • | COAL F2 |
|--|---|----------------|----------------|
| Cost of Healy coal in 1994
(Minemouth Generation, FOB Tipple) | | \$2.5/MBTU | \$2.2/MBTU |
| Net Heat Rate | | 10,700 BTU/kWh | 10,700 BTU/kWh |
| ACF to generate 337 GWh | | \$9,015,000 | \$7,933,000 |

It may be noted that due to divergence of fuel cost trends after 1993, for coal delivered to either Anchorage or Nenana, rather than minemouth, the economic advantage moves progressively towards generation at an Anchorage location, with transfer of the equivalent energy over the intertie. However, in 1994, it is possible to transmit energy generated economically at Healy to Anchorage over the intertie.

Total cost of COAL F2 generation, including transmission loss = \$8,016,000.

1995 GEN 2 - 300 MW coal-fired plant COAL F3 - 100 MW coal-fired is introduced to the Anchorage plant is introduced to the area with independent system Fairbanks area and PEAK A2 expansion but the 78 MW com-78 MW combustion turbine is bustion turbine PEAK A2 is not added to the AML&P system. required in addition to the Interconnection results in the large coal-fired plant. COAL F3 postponement by one year of is added to the system in the the 300 MW GEN 2 in the Fairbanks area. Anchorage area.

> As COAL F3 is common to both the independent and interconnected system expansions, it is of interest whether the gas-fired PEAK A2 in Anchorage could economically displace the equivalent energy generated by the coal-fired unit COAL F3 in the Fairbanks area.

Comparative Fuel Costs:

| • | PEAK A2 | ۲ | COAL F3 |
|---|----------------|---|----------------|
| Cost of New Gas in 1995
(HR 8444 - 8% infl. + esc.) | \$7.70/MBTU | | |
| Cost of Healy Coal in 1995
(Minemouth Plant, FOB Tipple) | | | \$2.40/MBTU |
| Net Heat Rate | 14,500 BTU/kWh | | 10,700 BTU/kWh |
| ACF to generate 337 GWh | \$37,626,000 | | \$8,654,000 |

There is a definite economic advantage to coal generation at Healy and energy transfer over the intertie to displace gas-fired generation in Anchorage.

Total cost of COAL F3 generation, including transmission loss = \$8,745,000.

1996 GEN 2 - 300 MW coal-fired plant is introduced to the Anchorage area, the interconnection serving to postpone its in-service date by one year. PEAK A2 - 78 MW combustion turbine is introduced to the AML&P system in Anchorage.

In this final year of analysis, it is of interest to compare the relative economic advantages of coal-fired generation at either the Fairbanks (Healy) or Anchorage (Beluga) sites.

Comparative Fuel Costs:

| | • | <u>GEN 2</u> | • | COAL F3 |
|-----------------------------|---|---------------|---|----------------|
| Cost of Beluga Coal in 1996 | | \$3.3/MBTU | | |
| Cost of Healy Coal in 1996 | | | | 2.5/MBTU |
| Net Heat Rate | | 9,500 BTU/kWh | | 10,700 BTU/kWh |
| ACF to generate 337 GWh | | \$10,565,000 | | \$9,015,000 |

Once again it is more economical to generate in the Fairbanks area and transfer energy south over the intertie to Anchorage.

Total cost of COAL F3 generation, including transmission loss = \$9,109,000.

Nomogram calculates economy of scale in power plants

By JAMES MCALISTER, Arkansas Power & Light Co.

Historically, the per unit cost of larger power plants has been less than that of smaller plants. The proportionality was examined in some detail in the article "Economy of Scale in Power Plants" in the August 1977 issue of POWER ENGI-NEERING Magazine, p. 51.

The basic equation is: $(C_1/C_2) = (MW_1/MW_2)^p$ Where:

 $\begin{array}{lll} C_1 & = \mbox{ cost of plant 1} \\ C_2 & \mbox{ cost of plant 2} \\ MW_1 & \mbox{ capability of plant 1} \\ MW_2 & \mbox{ capability of plant 2} \\ P & = \mbox{ proportionality factor} \end{array}$

For many years, this proportionality factor averaged about 0.6, which led to the so-called "Six-tenths Power, -Law." However, as explained in the article referred to above, extended project schedules and inflation cause the factor to increase

This nomogram solves the equation and permits a cost comparison of plants of different sizes. It assumes, of course, that they are essentially identical in construction technique, design and time frame, and that the only significant difference is in size. *Example:* A 200-MW plant can be built for \$200 million. Find the cost of a similar 1000-MW plant.

Solution: (1) Connect unit ratings of 200 MW and 1000 MW on the MW_1 and MW_2 scales, and mark intersection with Reference Line X. (2) Align this point with assumed scaling factor P = 0.6 and extend to cut Reference Line Y. (3) Connect this point with 0.2 on C₁ scale and extend to C₂ scale. Read answer as \$0.53 billion. END

To obtain an extra copy of this article, circle 206 on Reader Service Card



POWER ENGINEERING/FEBRUARY 1979









ESTIMATES OF FUTURE NATURAL GAS PRICES (Source: Battelle Final Report 'Alaskan Electric Power', March 1978/Figure 6-6)




APPENDIX E

TRANSMISSION LINE ECONOMIC ANALYSIS PROGRAM (TLEAP)

APPENDIX E TRANSMISSION LINE ECONOMIC ANALYSIS PROGRAM (TLEAP)

The following pages contain TLEAP computer printout sheets for economic analyses 1, 2, 3, 5, 7, and 8.

ECON, ANAL.NO 1

1

tine a

ALASKA POWER AUTHORITY ANCHURAGE - FAIRBANKS INTERTIE Economic flastbility study

Ì

[]

1

\$

1

¥.

FUEL COMPONENT OF OPERATING COSTS CAPITAL DISBURSEMENTS IN \$1000 FUR IN \$1000 FOR ALTERNATIVE SYSTEM EXPANSIONS ALTERNATIVE SYSTEM EXPANSIONS INDEPENDENT INTERCONNECTED INDEPENDENT INTERCONNECTED COSTS - \$79 COSTS - \$79 FSCALATED \$ FSCALATED \$ 1979 1980 1981 4,011 1982 2,009 14,228 1983 26,666 46,967 81,942 10,959 1984 31,539 37,172 1985 21,127 1986 7,152 2,009 1987 1988 7,555 8,037 1989 23,110 30.139 1990 21,920 42,652 82,200 43,047 1991 101,380 89,352 1992 1993 58,450 108,400 29,840 74,830 1994 22,820 1995 23,935 17,630 1996 SUSITNA CONSTRUCTION POWER COSTS ADDITIONAL DISBURSEMENTS TN \$1000 FOR IN \$1000 FOR ALTERNATIVE MODES OF SUPPLY UNDERLYING TRANSMISSION SYSTEM DIESEL GENERATION INTERTIE TAPLINE INDEPENDENT INTERCONNECTED LOSTS - \$79 COSTS - \$79 COSTS - .\$79 COSTS - \$79 1979 1980 1981 1982 1983 1984 1995 1986 1987 1988 1989 1990 1991 1995 1993 1494 1995 1990

н 1 2

1

Ì

Ì.

5 APRIL 79

1

ECON, ANAL, NO 1

ř

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONOMIC FEASTBILITY STUDY

DISCOUNTED COST RAITOS FOR RANGE OF BASE YEAR (1979) COSTS ESCALATED OVER EXPANSION PERIOD - 1979 TO 1996

| | FSCALATION RATES | | | | | | | | | | |
|----------|------------------|--------|--------|--------|-------|-------|-------|-------|-------|--|--|
| DISCOUNT | 47 | 5% | 67 | 72 | 82 | 9% | 107 | 112 | 152 | | |
| RATE | ====== | ====== | ====== | ****** | | | | | | | |
| A.00 | 1.056 | 1.048 | 1.040 | 1.032 | 1.025 | 1.017 | 1.010 | 1.003 | .996 | | |
| A.25 | 1.058 | 1.050 | 1.042 | 1.034 | 1.027 | 1.019 | 1.012 | 1.005 | 998 | | |
| A.50 | 1.060 | 1.052 | 1.044 | 1.036 | 1.029 | 1.021 | 1.014 | 1.007 | 1.000 | | |
| A.75 | 1.002 | 1.054 | 1.046 | 1.038 | 1.030 | 1.023 | 1.016 | 1.008 | 1.001 | | |
| 9.00 | 1.064 | 1.056 | 1.048 | 1.040 | 1.032 | 1.025 | 1.017 | 1.010 | 1.003 | | |
| 9.25 | 1.066 | 1.058 | 1.050 | 1.042 | 1.034 | 1.027 | 1.019 | 1.012 | 1.005 | | |
| 9.50 | 1.068 | 1.060 | 1.052 | 1.044 | 1.036 | 1.028 | 1.021 | 1.014 | 1.007 | | |
| 9.75 | 1.069 | 1.061 | 1.054 | 1.046 | 1.038 | 1.050 | 1.023 | 1.016 | 1.009 | | |
| 10.00 | 1.071 | 1.063 | 1.055 | 1.048 | 1.040 | 1.032 | 1.025 | 1.017 | 1.010 | | |
| 10.25 | 1.073 | 1.065 | 1.057 | 1.050 | 1.042 | 1.034 | 1.027 | 1.019 | 1.012 | | |
| 10.50 | 1.075 | 1.067 | 1.059 | 1.051 | 1.044 | 1.036 | 1.028 | 1.021 | 1.014 | | |
| 10.75 | 1.077 | 1.069 | 1.061 | 1.053 | 1.046 | 1.038 | 1.030 | 1.023 | 1,016 | | |
| 11.00 | 1.079 | 1.071 | 1.063 | 1.055 | 1.047 | 1.040 | 1.032 | 1.025 | 1.018 | | |
| 11,25 | 1.081 | 1.073 | 1,065 | 1.057 | 1.049 | 1.042 | 1.034 | 1.027 | 1.019 | | |
| 11.50 | 1.082 | 1.075 | 1.067 | 1.059 | 1.051 | 1.043 | 1.036 | 1.028 | 1.021 | | |
| 11.75 | 1.084 | 1.076 | 1.069 | 1.061 | 1.053 | 1.045 | 1.038 | 1.030 | 1.023 | | |
| 12.00 | 1.086 | 1.078 | 1.070 | 1.063 | 1,055 | 1.047 | 1.040 | 1.032 | 1.025 | | |

DISCOUNTED VALUE OF DISBURSEMENTS FOR INDEPENDENT EXPANSION CUST RATIOS = DISCOUNTED VALUE OF DISBURSEMENTS FOR INTERCONNECTED EXPANSION

Ē I. ω

T

ECON, ANAL, NO 1

1 in state

ALASKA POWER AUTHORITY ANCHOPAGE - FAIRBANKS INTERTIE ECONUMIC FEASIBILITY STUDY

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS (IN \$1000)

| DISCOUNT | /1 Y | 59 | 67 | 77 | 87 | 97 | 107 | 117 | 122 |
|-----------|-----------------|--------|--------|--------|--------|--------|--------|--------|----------|
| 013(0/14) | 44 |]~ | | | | | | | |
| 8415 | | | | | | | | | |
| P.00 | 10,517 | 18,560 | 17,215 | 15,417 | 13,098 | 10,185 | 0,590 | 1,720 | - 5, 911 |
| A.25 | 19,688 | 18,825 | 17,584 | 15,907 | 13,729 | 10,977 | 7,572 | 3,423 | -1,567 |
| A.50 | 19,845 | 19,066 | 17,925 | 16,365 | 14,322 | 11,727 | 8,502 | 4,560 | -193 |
| P.75 | 10,963 | 19,286 | 18,240 | 16,791 | 14,87B | 12,433 | 9,381 | 5,639 | 1,114 |
| 9.00 | 20,104 | 19,483 | 18,529 | 17,187 | 15,39B | 13,09A | 10,213 | 6,662 | 2,357 |
| 9.25 | 20,207 | 19,661 | 18,794 | 17,554 | 15,885 | 13,724 | 10,998 | 7,632 | 3,537 |
| 9.50 | 20,295 | 19,819 | 19,036 | 17,894 | 16,340 | 14,311 | 11,740 | 8,550 | 4,659 |
| 9,75 | 20,367 | 19,959 | 19,256 | 18,208 | 16,764 | 14,863 | 12,439 | 9,420 | 5,723 |
| 10.00 | 20,425 | 20,082 | 19,455 | 18,49A | 17,158 | 15,380 | 13,098 | 10,242 | 6,733 |
| 10,25 | 20,469 | 20,188 | 19,634 | 18,763 | 17,525 | 15,864 | 13,718 | 11,019 | 7,691 |
| 19.50 | 20,500 | 20,278 | 19,794 | 19,005 | 17,864 | 16,316 | 14,301 | 11,753 | 8,598 |
| 10.75 | 20,519 | 20,352 | 19,936 | 19,226 | 18,178 | 16,738 | 14,848 | 12,445 | 9,457 |
| 11.00 | 20,525 | 20,413 | 20,060 | 19,426 | 18,467 | 17,130 | 15,362 | 13,098 | 10,270 |
| 11.75 | 20,521 | 20,460 | 20,168 | 19,607 | 18,732 | 17,495 | 15,842 | 13,713 | 11,039 |
| 11.50 | 20,505 | 20,494 | 50,260 | 19,768 | 18,975 | 17,934 | 16,292 | 14,291 | 11,766 |
| 11.75 | 20,481 | 20,515 | 20,357 | 19,912 | 19,197 | 18,147 | 16,712 | 14,834 | 12,451 |
| 12.00 | 20,446 | 20,525 | 20,400 | 20,038 | 19,39A | 18,436 | 17,103 | 15,344 | 13,098 |

н г 4 5 APPIL 79

ECON, ANAL. NO 1

ALASKA POWER AUTHORITY ANCHUPAGE - FAIRBANKS INTERTIE ECONOMIC FEASIBILITY STUDY

DISCOUNTED VALUE OF BASE YEAR (1979) INDEPENDENT SYSTEM COSTS IN \$1000

| | ESCALATION RATES | | | | | | | | | | | |
|----------|------------------|---------|---------|----------|---------|---------|---------|----------|---------|--|--|--|
| DISCOUNT | 42 | 5% | 6% | 72 | 8% | 9% | 102 | 112 | 12% | | | |
| RATE | | ******* | ******* | | | ******* | | 2232222 | ****** | | | |
| A 00 | 367,521 | 404,713 | 445,907 | 491,53A | 542,088 | 598,088 | 660,126 | 728,848 | 804,970 | | | |
| P. 25 | 359,139 | 345,342 | 435,430 | 479,824 | 528,991 | 583,447 | 643,759 | 710,556 | 784,529 | | | |
| 8.50 | 350,998 | 386,242 | 425,254 | 408,454 | 516,283 | 509,243 | 627,885 | 642,81A | 764,711 | | | |
| 8.75 | 343,089 | 377.404 | 415,382 | 457,417 | 503,949 | 555,461 | 612,487 | 675,615 | 745,495 | | | |
| 0,00 | 335.403 | 368,819 | 405.791 | 446.703 | 491,979 | 542,088 | 547,548 | 658,929 | 726,861 | | | |
| 9,25 | 327.936 | 360,480 | 396,476 | 1136,299 | 480,358 | 529,110 | 583,054 | 647,744 | 708,789 | | | |
| 9.50 | 320.678 | 352,377 | 387.429 | 426,196 | 469,077 | 516,512 | 568,98B | 627,041 | 691,260 | | | |
| 9.75 | 313.624 | 344.503 | 318.630 | 416,384 | 458,123 | 504,284 | 555,33A | 611, A04 | 674,255 | | | |
| 10.00 | 306.766 | 336.850 | 370.099 | 406,853 | 447,486 | 492,412 | 542,088 | 597,01A | 657,757 | | | |
| 10.25 | 300.09A | 329,412 | 361.801 | 397,594 | 437,154 | 480,884 | 529,226 | 582.66A | 641,74A | | | |
| 10.50 | 243.615 | 322.182 | 353,736 | 388,598 | 427,119 | 469,689 | 516.738 | 568,739 | 626,213 | | | |
| 10.75 | 207.309 | 315,152 | 345,89A | 379,856 | 417,370 | 458,817 | 504.613 | 555,217 | 611,134 | | | |
| 11.00 | 281.177 | 308.316 | 338.278 | 371.361 | 407.898 | 448,256 | 492.837 | 542,088 | 596,498 | | | |
| 11.25 | 275,211 | 301.609 | 350.869 | 363,104 | 39A.694 | 437,796 | 481.401 | 529,340 | 582,289 | | | |
| 11.50 | 269.407 | 295.203 | 323.606 | 355.077 | 389.749 | 428.028 | 470,292 | 516,960 | 568,490 | | | |
| 11.75 | 203.759 | 288,914 | 316,601 | 347.273 | 381.055 | 418.341 | 459,499 | 504,936 | 555,098 | | | |
| 12.00 | 258,263 | 282,795 | 309,847 | 339,686 | 372,604 | 408,928 | 449,014 | 493,256 | 542,088 | | | |

DISCOUNTED VALUE OF BASE YEAR (1979)INTERCONNECTED SYSTEM COSTS IN \$1000

| DISCOUNT | 47 | 5% | 6% | 7 % | 87 | 9% | 102 | 112 | 15% | | |
|----------|----------|----------|----------|---------|---------|---------|---------|---------|---------|--|--|
| RATE | ====== | 3223,222 | ******* | ======= | | ====== | | | ******* | | |
| A.00 | 348,009 | 386,153 | 428,691 | 476,121 | 528,990 | 587,905 | 653,536 | 726,623 | 807,981 | | |
| A.25 | 339,451 | 376,517 | 417,845 | 463,917 | 515,262 | 572,469 | 636,187 | 707,133 | 786,095 | | |
| P.50 | 331,153 | 367,176 | 407,333 | 452,090 | 501,961 | 557,516 | 619,383 | 688,257 | 764,903 | | |
| P.75 | 323,105 | 358,119 | 397,142 | 440,627 | 489,072 | 543,028 | 603,105 | 669,976 | 744,381 | | |
| 2,00 | 315,300 | 349,336 | 387,262 | 429,516 | 476,580 | 528,990 | 587,335 | 652,267 | 724,505 | | |
| 9.25 | 307.729 | 340.819 | 377,683 | 418,745 | 464,473 | 515,386 | 572,055 | 635,112 | 705,252 | | |
| 9.50 | 300.383 | 332,557 | 36A, 393 | 408,302 | 452,737 | 502,201 | 557,248 | 618,490 | 686,601 | | |
| 9.75 | 293,257 | 324,543 | 359,383 | 348,1/5 | 441,359 | 189,021 | 542,898 | 602,384 | 668,532 | | |
| 10.00 | 286.341 | 316.768 | 350,645 | 388,355 | 430,327 | 477,032 | 528,990 | 586,776 | 651,024 | | |
| 10.25 | 279.629 | 309,225 | 342,167 | 378,831 | 419,630 | 465,020 | 515,508 | 571,649 | 634,057 | | |
| 10.50 | 273.115 | 301,904 | 333,942 | 369,592 | 409,255 | 453,374 | 502,437 | 556,986 | 617,614 | | |
| 10.75 | 206.791 | 294.799 | 325,962 | 360,650 | 399,192 | 442,079 | 189,764 | 542,771 | 601,677 | | |
| 11.00 | 260.651 | 287.903 | 318,217 | 351,934 | 389,432 | 431,125 | 477,476 | 528,990 | 586,228 | | |
| 11.25 | 254,690 | 281.209 | 310,701 | 343,497 | 379,902 | 420,500 | 465,558 | 515,627 | 571,250 | | |
| 11.50 | 248,901 | 214.710 | 303,405 | 335,309 | 370,774 | 410,194 | 454,000 | 502,669 | 556,728 | | |
| 11.75 | 243,278 | 26A, 399 | 296, 323 | 327,362 | 361,859 | 400,194 | 442,788 | 490,102 | 542,646 | | |
| 12.00 | 237, A17 | 262,271 | 289,447 | 319,647 | 353,206 | 390,492 | 431,911 | 477,912 | 528,990 | | |

г 1 5

ALASKA POWER AUTHORITY ANCHOPAGE - FAIRBANKS INTERTIE ECONOMIC FEASIBILITY STUDY

| | CAPITAL D
IN S | SISBURSEMENTS | FUEL COMPONENT O
IN \$10 | F OPFRATING COSTS
00 FOR |
|------|-----------------------------|--------------------------------|-----------------------------------|----------------------------------|
| | ALTERNATIVE S | SYSTEM EXPANSIONS | ALTERNATIVE SYS | TEM EXPANSIONS |
| | INDEPENDENT
COSTS - \$79 | INTERCONNECTED
COSTS - \$79 | INDEPENDENT
ESCALATED \$ | INTERCONNECTED
ESCALATED \$ |
| 1979 | | | | |
| 1980 | | | | |
| 19A1 | | 4,011 | | |
| 1982 | 2,009 | 14,228 | | |
| 1983 | 26,666 | 46,967 | | |
| 1984 | 81,942 | 10,959 | | |
| 1985 | 37,172 | 31,539 | 8,468 | 7,648 |
| 1986 | 21,127 | 5,480 | 9,324 | 8,498 |
| 1987 | 33,552 | 23,929 | 10,267 | 9,029 |
| 1988 | 100,555 | 90,237 | | |
| 1989 | 145,210 | 135,530 | | |
| 1990 | 94,760 | 115,330 | | |
| 1991 | 119,475 | 112,834 | | |
| 1992 | 101,380 | 89,352 | 6,851 | 8,324 |
| 1993 | 58,450 | 108,400 | 7,212 | 8,654 |
| 1994 | 29,840 | 74,830 | 7,933 | 8,016 |
| 1995 | 23,935 | 22,820 | 8,654 | 8,745 |
| 1995 | 17,630 | | 9,015 | 4,104 |
| | ADUTTIONAL
IN S | DISBURSEMENTS | SUSITNA CONSTRUC
TN 510 | TION POWER COSTS
00 For |
| | UNDERLYING TR | ANSMISSION SYSIFM | ALTERNATIVE M | ODES OF SUPPLY |
| | INDEPENDENT
COSTS - \$79 | INTERCONNECTED
COSTS - \$79 | DIFSEL GENERATION
COSTS - \$79 | INTERTIE TAPLINE
COSTS - \$79 |
| 1979 | | | | |
| 1980 | | | | |
| 1981 | | | | |
| 1982 | | | | |
| 1983 | | | | |
| 1984 | | | | |
| 1985 | | | | |
| 1986 | | | | |
| 1987 | | | | |
| 1988 | | | | |
| 1989 | | | | |
| 1990 | | | | |
| 1991 | | | | |
| 1492 | | | | |
| 1993 | | | | |
| 1994 | | | | |
| 1995 | | | | |
| 1996 | | | | |

1 6

5 APRIL 79

ر ب

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONOMIC FEASTBILITY STUDY

5 APPIL 79

DISCOUNTED COST RATIOS FOR RANGE OF BASE YEAR (1979) COSTS ESCALATED OVER EXPANSION PERIOD - 1979 TO 1996

| | ESCALATION RATES | | | | | | | | | | |
|----------|------------------|--------|-------|--------|--------|-------|--------|-------|--------|--|--|
| DISCOUNT | 47 | 5% | 6% | 7% | 8% | 92 | 102 | 112 | 122 | | |
| RATE | ****** | ****** | | ****** | ====== | | ****** | ***** | ====== | | |
| 8.00 | 1.044 | 1.038 | 1.033 | 1.028 | 1.022 | 1.017 | 1.012 | 1.007 | 1.002 | | |
| A.25 | 1.045 | 1.040 | 1.034 | 1.029 | 1.024 | 1.018 | 1.013 | 1.008 | 1.003 | | |
| P.50 | 1.046 | 1.041 | 1.036 | 1.030 | 1.025 | 1.020 | 1.015 | 1,009 | 1.004 | | |
| 9.75 | 1.04A | 1.042 | 1.037 | 1.032 | 1.026 | 1.021 | 1.016 | 1.011 | 1.006 | | |
| 0,00 | 1.049 | 1.044 | 1.03A | 1.033 | 1.028 | 1.022 | 1.017 | 1.012 | 1.007 | | |
| 0.25 | 1.050 | 1.045 | 1.040 | 1.034 | 1.029 | 1.024 | 1.018 | 1.013 | 1.00A | | |
| 9,50 | 1.052 | 1.046 | 1.041 | 1.036 | 1.030 | 1.025 | 1.020 | 1.015 | 1.010 | | |
| 9.75 | 1.053 | 1.048 | 1.042 | 1.037 | 1.032 | 1.026 | 1.021 | 1.016 | 1.011 | | |
| 10.00 | 1.054 | 1.049 | 1.044 | 1,038 | 1.033 | 1.028 | 1.022 | 1.017 | 1.012 | | |
| 10.25 | 1.056 | 1.050 | 1.045 | 1.040 | 1.034 | 1,029 | 1.024 | 1.019 | 1.013 | | |
| 10.50 | 1.057 | 1.052 | 1.046 | 1.041 | 1.036 | 1.030 | 1.025 | 1.020 | 1.015 | | |
| 10.75 | 1.05A | 1.053 | 1.048 | 1.042 | 1.037 | 1.032 | 1.026 | 1.021 | 1.016 | | |
| 11.00 | 1.060 | 1.054 | 1.049 | 1.044 | 1.038 | 1.033 | 1.028 | 1.023 | 1.017 | | |
| 11.25 | 1.061 | 1.056 | 1,050 | 1.045 | 1.040 | 1.034 | 1.029 | 1.024 | 1.019 | | |
| 11.50 | 1.062 | 1.057 | 1.052 | 1.046 | 1.041 | 1.036 | 1.030 | 1.025 | 1.020 | | |
| 11.75 | 1.003 | 1.058 | 1.053 | 1.048 | 1.042 | 1.037 | 1.032 | 1.027 | 1.021 | | |
| 12.00 | 1.065 | 1.059 | 1.054 | 1.049 | 1.044 | 1.03A | 1.033 | 1.028 | 1.023 | | |

COST RATIUS = DISCOUNTED VALUE OF DISBURSEMENTS FOR INTERCONNECTED EXPANSION

NP ARK

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONOMIC FEASIBILITY STUDY

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS (TN \$1000)

| | FSCALATION RATES | | | | | | | | | | | |
|----------|------------------|--------|--------|--------|--------|--------|--------|--------|--------|--|--|--|
| DISCOUNT | 42 | 5* | 6% | 7 % | 82 | 97 | 102 | 112 | 122 | | | |
| RATE | ***** | ====== | | | | | | ===== | ****** | | | |
| A.00 | 27,096 | 26,190 | 24,824 | 55,956 | 20,414 | 17,198 | 13,177 | B,242 | 5,268 | | | |
| 8.25 | 27,259 | 26,456 | 25,212 | 23,456 | 21,110 | 18,086 | 14,288 | 9,608 | 3,927 | | | |
| A.50 | 27,400 | 26,695 | 25,567 | 23,94A | 21,760 | 18,921 | 15,337 | 10,902 | 5,503 | | | |
| 8.75 | 27,519 | 26,908 | 25,891 | 24,402 | 22,367 | 19,705 | 16,325 | 12,127 | 6,998 | | | |
| a'00 | 27,617 | 27,096 | 26,185 | 24,820 | 22,932 | 20,440 | 17,257 | 13,285 | 8,417 | | | |
| 9.25 | 27,695 | 27,259 | 26,450 | 25,205 | 23,456 | 21,127 | 18,133 | 14,379 | 9,761 | | | |
| 9.50 | 27,754 | 27,400 | 26,687 | 25,557 | 23,943 | 21,770 | 18,957 | 15,412 | 11,035 | | | |
| 9.75 | 27,795 | 27,519 | 26,899 | 25,879 | 24,393 | 22,370 | 19,731 | 16,387 | 12,241 | | | |
| 10.00 | 27,820 | 27,618 | 27,086 | 26,171 | 24,808 | 22,929 | 20,457 | 17,306 | 13,382 | | | |
| 10.25 | 27,828 | 27,697 | 27,250 | 26,434 | 25,189 | 23,448 | 21,136 | 18,171 | 14,460 | | | |
| 10.50 | 27,821 | 27,757 | 27,391 | 26,671 | 25,539 | 23,930 | 21,772 | 18,984 | 15,479 | | | |
| 10.75 | 27,749 | 27,800 | 27,511 | 26,883 | 25,859 | 24,376 | 22,366 | 19,749 | 16,440 | | | |
| 11.00 | 27,764 | 27,826 | 27,611 | 27,070 | 26,149 | 24,788 | 22,919 | 20,466 | 17,347 | | | |
| 11.25 | 27,715 | 27,836 | 27,691 | 27,234 | 26,412 | 25,167 | 23,454 | 21,138 | 18,201 | | | |
| 11.50 | 27,655 | 27,831 | 27,753 | 27,376 | 26,649 | 25,515 | 23,911 | 21,767 | 19,005 | | | |
| 11.75 | 27,583 | 27,811 | 27,797 | 27,497 | 26,860 | 25,833 | 24,354 | 22,355 | 19,760 | | | |
| 12.00 | 27,499 | 27,77B | 27,825 | 27,548 | 27,048 | 26,123 | 24,763 | 22,903 | 20,470 | | | |

1 ω

ш

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONUMIC FEASIBILITY STUDY

DISCOUNTED VALUE OF BASE YEAR (1979) INDEPENDENT SYSTEM COSTS IN \$1000

| | | | | FS | CALATION I | RATES | | | |
|----------|----------|---------|---------|---------|------------|-----------|-----------|-----------|-----------|
| DISCOUNT | 47 | 5% | 6% | 77. | 82 | 9% | 10% | 112 | 12% |
| RATE | | | | | | | ======= | 3312525 | ======= |
| A.00 | 646,867 | 708,932 | 777,234 | 852,386 | 935,064 | 1,026,007 | 1,126,021 | 1,235,993 | 1,356,889 |
| R. 25 | 632,139 | 692,645 | 759,218 | R32,456 | 913,013 | 1,001,606 | 1,099,020 | 1,206,114 | 1,323,827 |
| 9.50 | 617,813 | 676,806 | 741,701 | P13,080 | 891,578 | 977,892 | 1,072,784 | 1,177,086 | 1,291,712 |
| A.75 | 603. A77 | 661,401 | 724,667 | 794,242 | 870,742 | 954,844 | 1,047,287 | 1,148,882 | 1,260,512 |
| 9.00 | 590, 320 | 646,415 | 70P,101 | 775,923 | 850,484 | 932,439 | 1,022,507 | 1,121,474 | 1,230,199 |
| 9,25 | 577,128 | 631,838 | 691,987 | 758,109 | A30,787 | 910,658 | 998,420 | 1,094,83A | 1,200,744 |
| 9.50 | 564,292 | 617,654 | 616,312 | 740,783 | A11,632 | 889,481 | 975,006 | 1,068,948 | 1,172,120 |
| 9.75 | 551,799 | 603,854 | 601,003 | 723,929 | 793,004 | 868,888 | 952,241 | 1,043,783 | 1,144,300 |
| 10.00 | 539,640 | 540,424 | 646,225 | 707,534 | 774,885 | 848,863 | 930,107 | 1,019,317 | 1,117,258 |
| 10.25 | 527, B04 | 577,353 | 631,787 | 691,583 | 757,260 | A29,386 | 908,583 | 945,530 | 1,090,971 |
| 10.50 | 516,282 | 564,630 | 617,737 | 676,003 | 740,113 | 810,441 | 887,650 | 972,400 | 1,065,414 |
| 10.75 | 505,063 | 552,246 | 604,061 | 660,959 | 723,430 | 792,011 | A67,290 | 949,907 | 1,040,564 |
| 11.00 | 494,139 | 540,188 | 590,749 | 646,260 | 707,196 | 774,081 | 847,485 | 928,031 | 1,016,399 |
| 11.25 | 483,501 | 528,448 | 577,791 | 631,952 | 691,398 | 756,635 | 828,218 | 906,752 | 992,899 |
| 11.50 | 473.141 | 517,016 | 565,174 | 618,025 | 676,022 | 739,658 | 809,472 | A86,052 | 970,041 |
| 11.75 | 463.049 | 505,883 | 552,889 | 604,467 | 661,056 | 723,136 | 791,231 | 865,913 | 947,807 |
| 12.00 | 453,218 | 495,040 | 540,925 | 591,265 | 646,486 | 707,055 | 773,480 | 846,31A | 926,177 |

DISCOUNTED VALUE OF BASE YEAR (1979) INTERCONNECTED SYSTEM COSTS IN \$1000

| | | | | FS(| CALATION F | RATES | | | |
|----------|------------|---------|------------|---------|------------|-----------|-----------|-----------|-----------|
| DISCOUNT | 4 z | 52 | 6 % | 7 % | 82 | 92 | 102 | 112 | 152 |
| RATE | | ******* | 1211121 | ======= | ======= | ======= | | ====== | ====== |
| 9,00 | 619,771 | 682,743 | 752,410 | R29,460 | 914,651 | 1,008,809 | 1,112,844 | 1,227,751 | 1,354,622 |
| 8.25 | 604,879 | 666,189 | 734,006 | 809,000 | 891,903 | 983,520 | 1,084,732 | 1,196,506 | 1,319,900 |
| 8.50 | 590,413 | 650,110 | 716,134 | 789,133 | 869,81R | 958,971 | 1,057,447 | 1,166,184 | 1,286,209 |
| A.75 | 576,359 | 634,492 | 698,776 | 769,840 | 848,375 | 935,139 | 1,030,962 | 1,136,755 | 1,253,514 |
| 9.00 | 562,703 | 619,320 | 681,916 | 751,103 | A27,552 | 911,999 | 1,005,250 | 1,108,189 | 1,221,783 |
| 9,25 | 549,434 | 604,579 | 665,537 | 732,904 | 807,330 | 889,530 | 980,287 | 1,080,458 | 1,190,983 |
| 9.50 | 536,53A | 591,255 | 649,625 | 715,226 | 787,690 | 867,711 | 956,048 | 1,053,536 | 1,161,085 |
| 9.75 | 524,004 | 576,335 | 634,164 | 69A,051 | 768,611 | 846,518 | 932,510 | 1,027,396 | 1,132,059 |
| 10.00 | 511,821 | 562,846 | 619,139 | 681,364 | 750,077 | 825,934 | 909,650 | 1,002,011 | 1,103,876 |
| 10.25 | 499,977 | 549,650 | 604,537 | 665,149 | 732,071 | 805,938 | 887,447 | 977,359 | 1,076,511 |
| 10.50 | 488,461 | 536,873 | 590,345 | 649,391 | 714,574 | 786,511 | 865,87A | 953,416 | 1,049,935 |
| 10.75 | 477.264 | 524,446 | 576,550 | 634,076 | 697,571 | 767,635 | 844,924 | 930,158 | 1,024,123 |
| 11.00 | 406,376 | 512,302 | 563,139 | 619,190 | 681,047 | 749,293 | A24,566 | 907,564 | 949,052 |
| 11.25 | 455,786 | 500,612 | 550,099 | 604,71B | 664,986 | 731,46A | 804,784 | BH5,613 | 974,69R |
| 11.50 | 445,486 | 489,186 | 537,421 | 590,649 | 649,373 | 714,143 | 785,560 | 864,284 | 951,037 |
| 11.75 | 435,406 | 478,072 | 525,091 | 576,970 | 634,196 | 697,303 | 766,877 | 843,55R | 928,047 |
| 12.00 | 425,719 | 467,201 | 513,100 | 563,66R | 619,439 | 680,932 | 748,717 | A23,415 | 905,70A |

E - 9

44.4

New York

ALASKA PUWER AUTHORITY ANCHURAGE - FAIRBANKS INTERTIE ECONOMIC FEASIBILITY STUDY

5 APRIL 79

ALC: NO

)

Ĩ

FUEL COMPONENT OF OPERATING COSTS CAPITAL DISBURSEMENTS IN \$1000 FOR IN \$1000 FOR ALTERNATIVE SYSTEM EXPANSIONS ALTERNATIVE SYSTEM EXPANSIONS INDEPENDENT INTERCONNECTED INDEPENDENT INTERCONNECTED ESCALATED \$ CUSIS - \$79 , COSIS - \$79 ESCALATED S 1979 1980 1981 4,621 1982 2,009 15,594 48,814 1983 20,060 81,942 10,959 1984 1985 37,172 31,539 1986 21,127 2,004 1987 7,152 8,037 7,555 1988 30,139 1989 23,110 1990 21,420 42,652 1991 82,200 43,047 1992 101, 580 89,352 1993 58,450 108,400 74,830 1994 29,840 23, 435 55,450 1995 1996 17,630 ADDITIONAL DISBURSEMENTS SUSITNA CONSTRUCTION POWER COSTS IN \$1000 FUR IN \$1000 FOR UNDERLYING TRANSMISSION SYSTEM ALTERNATIVE MODES OF SUPPLY DIESEL GENERATION INTERTIE TAPLINE INDEPENDENT INTERCONNECTED COSTS - \$79 CUSTS - \$79 COSTS - \$79 COSTS - \$79 1979 1980 1981 1982 1983 1984 2,835 267 1985 483 695 1986 481 697 1,356 1987 6,646 478 696 1988 3,055 752 1989 902 1,324 1990 187 734 1991 623 430 1992 2,004 1993 623 419 1494 -500 504 1995 1996

and the second

ALASKA POWER AUTHURITY ANCHURAGE - FAIRBANKS INTERTIE ECONOMIC FEASIBILITY STUDY

DISCOUNTED COST KATIOS FUR RANGE OF BASE YEAR (1979) COSTS ESCALATED OVER EXPANSION PERIOD - 1979 TO 1996

| | ESCALATION KATES | | | | | | | | | | |
|----------|------------------|--------|-------|--------|-------|-------|-------|-------|-------|--|--|
| DISCUUNT | 42 | 5% | 6% | 7 % | 8% | 9X | 10% | 112 | 12% | | |
| RATE | *==== | ====== | | ====== | ===== | ===== | ===== | ===== | | | |
| 8.00 | 1.070 | 1.063 | 1.055 | 1.047 | 1.040 | 1.032 | 1.025 | 1.018 | 1.011 | | |
| 8.25 | 1.072 | 1.005 | 1.057 | 1.049 | 1.042 | 1.034 | 1.027 | 1.020 | 1.013 | | |
| 8.50 | 1.074 | 1.006 | 1.059 | 1.051 | 1.044 | 1.036 | 1.029 | 1.022 | 1.015 | | |
| 8.75 | 1.076 | 1.068 | 1.061 | 1.053 | 1.045 | 1.038 | 1.031 | 1.024 | 1.017 | | |
| 9.00 | 1.078 | 1.070 | 1.062 | 1.055 | 1.047 | 1.040 | 1.033 | 1.025 | 1.018 | | |
| 9.25 | 1.080 | 1.072 | 1.064 | 1.057 | 1.049 | 1.042 | 1.034 | 1.027 | 1.020 | | |
| 9.50 | 1.081 | 1.074 | 1.066 | 1.059 | 1.051 | 1.044 | 1.036 | 1.029 | 1.022 | | |
| 9.75 | 1.083 | 1.076 | 1.008 | 1.060 | 1.053 | 1.045 | 1.038 | 1.031 | 1.024 | | |
| 10.00 | 1.005 | 1.0/7 | 1.070 | 1.062 | 1.055 | 1.047 | 1.040 | 1.033 | 1.025 | | |
| 10.25 | 1.087 | 1.079 | 1.0/2 | 1.064 | 1.057 | 1.049 | 1.042 | 1.034 | 1.027 | | |
| 10.50 | 1.048 | 1.081 | 1.073 | 1.066 | 1.058 | 1.051 | 1.043 | 1.036 | 1.029 | | |
| 10.75 | 1.090 | 1.083 | 1.075 | 1.068 | 1.000 | 1.053 | 1.045 | 1.038 | 1.031 | | |
| 11.00 | 1.092 | 1.084 | 1.077 | 1.070 | 1.062 | 1.055 | 1.047 | 1.040 | 1.033 | | |
| 11.25 | 1.094 | 1.086 | 1.079 | 1.071 | 1.064 | 1.056 | 1.049 | 1.042 | 1.034 | | |
| 11.50 | 1.095 | 1.088 | 1.081 | 1.073 | 1.066 | 1.058 | 1.051 | 1.043 | 1.036 | | |
| 11.75 | 1.097 | 1.090 | 1.082 | 1.075 | 1.067 | 1.060 | 1.053 | 1.045 | 1.038 | | |
| 12.00 | 1.099 | 1.091 | 1.064 | 1.077 | 1.069 | 1.062 | 1.054 | 1.047 | 1.040 | | |

DISCOUNTED VALUE OF DISBURSEMENTS FUR INDEPENDENT EXPANSION

CUST RATIOS = DISCUUNTED VALUE OF DISBURSEMENTS FOR INTERCONNECTED EXPANSION

E - 11

ECON. ANAL.NU 3

41

ALASKA PUNER AUTHORITY ANCHURAGE - FAIRBANKS INTERTIE ECONOMIC FEASIBILITY STUDY

DIFFERENTIAL DISCUUNTED VALUE OF BASE YEAR (1979) COSTS INDEPENDENT SYSTEM CUSTS MINUS INTERCONNECTED SYSTEM COSTS (IN \$1000)

| | ESCALATION RATES | | | | | | | | | | |
|----------|------------------|--------|--------|--------|------------|--------|--------|--------|--------|--|--|
| DISCUUNT | 42 | 5% | 6% | 7% | 8 X | 92 | 102 | 112 | 12% | | |
| RATE | 122123 | ====== | ====== | ===== | *==== | ===== | | ===== | ====== | | |
| 8.00 | 25,042 | 24,722 | 24,003 | 23,008 | 21,494 | 19,450 | 16,798 | 13,451 | 9,313 | | |
| 8.25 | 25,074 | 24,829 | 24,259 | 23,309 | 21,918 | 20,019 | 17,534 | 14,381 | 10,465 | | |
| 8.50 | 25,090 | 24,916 | 24,431 | 23,582 | 22,309 | 20,548 | 18,224 | 15,256 | 11,554 | | |
| 8.75 | 25,091 | 24,985 | 24,581 | 23,828 | 22,668 | 21,039 | 18,869 | 16,079 | 12,583 | | |
| 9.00 | 25,078 | 25,036 | 24,109 | 24,048 | 55,996 | 21,494 | 19,472 | 16,853 | 13,554 | | |
| 9.25 | 25,051 | 25,070 | 24,817 | 24,243 | 23,296 | 21,915 | 20,054 | 17,579 | 14,464 | | |
| 9.50 | 25,011 | 25,089 | 24,906 | 24,410 | 23,567 | 22,302 | 20,557 | 18,260 | 15,332 | | |
| 9.75 | 24,458 | 25,092 | 24,976 | 24,566 | 23,812 | 22,659 | 21,043 | 18,897 | 16,143 | | |
| 10.00 | 24,895 | 25,081 | 25,029 | 24,696 | 24,032 | 22,485 | 21,494 | 19,443 | 10,906 | | |
| 10.25 | 24,820 | 25,057 | 25,066 | 24,805 | 24,228 | 23,283 | 21,911 | 20,048 | 17,623 | | |
| 10.50 | 24,735 | 25,020 | 25,087 | 24,895 | 24,401 | 23,553 | 55,546 | 20,500 | 18,295 | | |
| 10.75 | 24,641 | 24,971 | 25,093 | 24,968 | 24,552 | 23,197 | 22,649 | 21,047 | 18,924 | | |
| 11.00 | 24,551 | 24,910 | 25,084 | 25,023 | 24,682 | 24,017 | 22,974 | 21,494 | 19,513 | | |
| 11.25 | 24,425 | 24,839 | 25,065 | 25,061 | 24,793 | 24,213 | 23,210 | 21,907 | 20,063 | | |
| 11.50 | 24,305 | 24,757 | 25,029 | 25,084 | 24,885 | 24,386 | 23,539 | 22,289 | 20,575 | | |
| 11./5 | 24,177 | 24,000 | 24,982 | 25,093 | 24,959 | 24,538 | 23,785 | 22,640 | 21,052 | | |
| 12.00 | 24,042 | 24,500 | 24,925 | 25,087 | 25,015 | 24,669 | 24,002 | 22,462 | 21,494 | | |

гп 1 12 5 APRIL 79

Internet

÷.

7,648.4

ALASKA PUWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONUMIC FEASIBILITY STUDY

DISCOUNTED VALUE OF BASE YEAR (1979) INDEPENDENT SYSTEM COSTS IN \$1000

a superior de la constante de

----- ESCALATION RATES ------DISCOUNT 4Z 5% 7% 62 82 92 102 112 122 RATE ======= ****** ======= 2222222 ______ ******* 8.00 381,019 419,402 461,886 508,913 560,973 618,607 682,411 753,044 831,230 312,300 409,734 451,083 547,488 8.25 496,843 603,542 665,583 734,247 810,239 303,958 8,50 400,344 440,594 405,127 534,401 588,925 649,258 716,017 789,885 8.75 355,789 391,222 430,408 4/3,/52 521,698 514,740 633,419 698,335 770,146 9.00 347,851 302,300 420,515 462,706 509,367 560,973 618,051 681,181 751,002 340,136 373,750 410,905 451,980 447,394 547,610 9.25 603,137 732,432 664,538 9.50 332,030 305,302 401,508 441,562 485,769 534,638 714,417 588,663 648,389 474,479 9.75 325,346 357,250 342,497 431,442 522,043 574,013 632,717 696,937 318,257 349,346 463,513 619,476 10.00 385,681 421,610 509,813 560,973 617,506 10.25 311,364 341,661 375,114 412,057 452,862 497,936 547,/30 602,741 663,515 10.50 304,600 334,190 366,186 402,774 442,514 486,400 534,870 588,406 647,538 10.75 298,140 326,925 358,691 343,153 432,459 475,194 522,381 574,488 632,028 11.00 291,796 319,860 350,820 384,984 422,688 464,307 560,473 616,971 510,251 205,025 312,488 343,167 415,193 453,730 11.25 316,459 498,468 547,847 602,351 274,620 306,303 403,963 443,450 11.50 335,724 481,020 535,099 588,154 368,171 11.75 273,776 249,144 328,484 394,990 433,461 475,897 360,112 522,714 574,300 321,442 560,973 12.00 880,885 243,471 352,275 386,267 423,750 465,089 510,682

+ DISCOUNTED VALUE OF HASE YEAR (1979)INTERCONNECTED SYSTEM COSTS IN \$1000

| 47 | 5% | 6% | 7% | 82 | 9% | 102 | 112 | 122 | | | |
|---------|--|--|--|---|---|--|--|---|--|--|--|
| ===== | ****** | ====== | ====== | ======= | | | ******* | ====== | | | |
| 355,977 | 394,680 | 431,822 | 485,905 | 539,479 | 599,157 | 665,613 | 739,592 | 821,917 | | | |
| 347,291 | 304,905 | 426,824 | 473,534 | 525,570 | 583,523 | 648,048 | 719,800 | 799,774 | | | |
| 338,008 | 375,427 | 416,163 | 461,545 | 512,092 | 568,317 | 631,034 | 700,761 | 778,331 | | | |
| 330,648 | 306,237 | 405,827 | 449,924 | 499,030 | 553,701 | 614,550 | 682,256 | 757,564 | | | |
| 322,775 | 357,324 | 395,806 | 438,659 | 486,370 | 539,474 | 598,580 | 664,328 | 737,440 | | | |
| 315,085 | 348,679 | 386,087 | 421,136 | 474,098 | 525,095 | 585,104 | 646,959 | 717,963 | | | |
| 307,626 | 540,294 | 376,662 | 417,146 | 462,201 | 512,335 | 568,106 | 630,129 | 649,085 | | | |
| 300,397 | 332,158 | 367,520 | 406,875 | 450,666 | 499,384 | 553,570 | 613,820 | 680.194 | | | |
| 243,302 | 324,264 | 358,652 | 396,914 | 439,481 | 486,828 | 539,479 | 598,013 | 603,069 | | | |
| 280,544 | 310,004 | 350,048 | 387,252 | 428,634 | 474,053 | 525,819 | 582,692 | 645,892 | | | |
| 279,925 | 309,170 | 341,700 | 377,879 | 418,113 | 462,847 | 512,575 | 567,840 | 629,243 | | | |
| 213,499 | 301,954 | 353,598 | 368,785 | 407,907 | 451,397 | 499,732 | 553,441 | 613,104 | | | |
| 207,259 | 244,950 | 325,736 | 359,961 | \$98,006 | 440,290 | 487,218 | 539,479 | 547,450 | | | |
| 261,200 | 200,149 | 318,104 | 351,398 | 388,400 | 429,517 | 475,198 | 525,940 | 542,248 | | | |
| 255,315 | 281,546 | 310,695 | 343,087 | 379,078 | 414,065 | 463,481 | 512,810 | 501,574 | | | |
| 244,544 | 275,133 | 303,502 | 335,019 | 370,032 | 408,925 | 452,115 | 500,074 | 553,314 | | | |
| 244,040 | 208,905 | 246,517 | 321,188 | 361,252 | 349,041 | 441,057 | 487,720 | 534,474 | | | |
| | 4%
======
355,977
347,291
358,608
330,698
322,773
315,0%5
307,626
300,5%7
295,362
245,362
245,449
267,259
261,200
255,315
249,549
244,046 | 4% 5% 355,977 394,680 347,291 364,905 358,668 375,427 30,698 366,237 322,773 357,324 315,085 348,679 307,626 340,294 300,587 352,158 295,362 324,264 286,544 316,604 279,925 309,170 273,499 301,954 267,259 244,950 261,200 266,149 255,315 281,546 249,549 275,133 244,046 268,905 | 47 5% 6% ===== ===== ===== ===== 355,977 394,680 437,822 347,291 364,905 426,824 358,668 375,427 416,163 330,698 366,237 405,827 322,773 357,324 395,806 315,085 348,679 366,087 307,626 340,294 376,662 300,387 352,158 367,520 293,362 324,264 358,652 286,544 316,604 350,048 279,925 309,170 341,700 213,499 301,954 333,598 267,259 244,950 325,736 261,200 266,149 318,104 255,315 281,546 303,502 244,046 268,905 296,517 | 4χ 5χ 6χ 7χ ================ $355, 977$ $394, 680$ $457, 822$ $485, 905$ $347, 291$ $364, 905$ $426, 824$ $473, 534$ $538, 608$ $375, 427$ $416, 163$ $461, 545$ $330, 698$ $366, 237$ $405, 827$ $449, 924$ $322, 773$ $357, 324$ $395, 806$ $438, 659$ $315, 085$ $340, 294$ $376, 662$ $417, 146$ $300, 587$ $352, 158$ $567, 520$ $406, 875$ $293, 362$ $324, 264$ $358, 652$ $396, 914$ $286, 544$ $316, 604$ $350, 048$ $367, 252$ $279, 925$ $309, 170$ $341, 700$ $377, 879$ $213, 499$ $301, 954$ $355, 736$ $359, 961$ $261, 200$ $286, 149$ $318, 104$ $351, 398$ $255, 315$ $281, 546$ $310, 695$ $343, 087$ $244, 964$ $275, 153$ $303, 502$ $35, 019$ | 4χ 5χ 6χ 7χ 8χ 22222232 5χ 6χ 7χ 8χ 22222245,977 $394,680$ $437,822$ $485,905$ $539,479$ $347,291$ $364,905$ $426,824$ $473,534$ $525,570$ $358,668$ $375,427$ $416,163$ $461,545$ $512,092$ $30,698$ $366,237$ $405,827$ $449,924$ $499,030$ $322,773$ $357,324$ $395,806$ $438,659$ $486,370$ $315,085$ $348,679$ $386,087$ $427,736$ $474,098$ $307,626$ $340,294$ $376,662$ $417,146$ $462,201$ $300,387$ $352,158$ $567,520$ $406,875$ $450,666$ $293,362$ $324,264$ $358,652$ $396,914$ $439,481$ $286,544$ $316,604$ $350,048$ $367,252$ $428,634$ $279,925$ $309,170$ $341,700$ $377,879$ $418,113$ $273,299$ $244,950$ $325,736$ $559,961$ $98,006$ $261,200$ $266,149$ $318,104$ $351,398$ $368,400$ $255,315$ $281,546$ $310,952$ $343,067$ $370,073$ $244,046$ $268,905$ $296,517$ $327,188$ $361,252$ | ESCALATION RATES 4χ 5χ 6χ 7χ 8χ 9χ ESCALATION RATES $355, 977$ $394, 680$ $437, 822$ $485, 905$ $539, 479$ $599, 157$ $347, 291$ $364, 905$ $426, 824$ $473, 534$ $525, 570$ $583, 523$ $358, 608$ $375, 427$ $416, 163$ $461, 545$ $512, 092$ $568, 3/7$ $330, 698$ $366, 237$ $405, 827$ $449, 924$ $499, 030$ $553, 701$ $322, 773$ $357, 324$ $395, 806$ $438, 659$ $486, 370$ $539, 479$ $315, 085$ $348, 679$ $366, 087$ $427, 736$ $474, 098$ $525, 695$ $307, 626$ $340, 294$ $376, 662$ $417, 146$ $462, 201$ $512, 335$ $300, 387$ $352, 158$ $567, 520$ $406, 875$ $450, 666$ $499, 384$ $293, 362$ $324, 264$ $358, 652$ $396, 914$ $439, 481$ $486, 828$ $286, 544$ $316, 604$ $350, 048$ $367, 252$ $428, 634$ $474, 653$ $279, 925$ $309, 170$ $341, 700$ $377, 879$ $418, 113$ $462, 847$ $213, 499$ $301, 954$ $353, 598$ $564, 785$ $407, 907$ $451, 397$ $267, 259$ $244, 950$ $325, 736$ $559, 961$ $398, 0006$ $440, 290$ $261, 200$ $260, 149$ $318, 104$ $351, 398$ $388, 400$ $429, 517$ $255, 315$ $281, 546$ $310, 695$ $343, 007$ $370, 073$ $4108, 925$ 24 | ESCALATION RATES 4χ 5χ 6χ 7χ 8χ 9χ 10χ 10111011101110111011101110121011 </td <td>ESCALATION RATES475767778797107117255,977394,680437,822485,905539,479599,157665,613739,592347,291364,905426,824473,534525,570583,523648,048719,866358,668375,427416,163461,545512,092568,3/7631,034700,761330,648366,237405,827449,924499,030553,701614,550682,256322,773357,324395,806438,659446,370539,479598,580664,328315,085348,679386,007427,736474,098525,695583,104646,959307,626340,294376,662417,146462,201512,335568,106630,129300,387352,158367,520406,875450,666499,584553,570613,820293,362324,264358,652396,914439,481466,828539,479598,013286,544316,604350,048367,252428,634474,653525,819582,692279,925309,170341,700377,879418,113462,847512,575567,840273,499301,954353,598364,785407,907451,397499,732553,441267,259244,950325,736359,961398,006440,290487,278539,479261,200266,149318,104351,398368,400429,517475,178</td> | ESCALATION RATES475767778797107117255,977394,680437,822485,905539,479599,157665,613739,592347,291364,905426,824473,534525,570583,523648,048719,866358,668375,427416,163461,545512,092568,3/7631,034700,761330,648366,237405,827449,924499,030553,701614,550682,256322,773357,324395,806438,659446,370539,479598,580664,328315,085348,679386,007427,736474,098525,695583,104646,959307,626340,294376,662417,146462,201512,335568,106630,129300,387352,158367,520406,875450,666499,584553,570613,820293,362324,264358,652396,914439,481466,828539,479598,013286,544316,604350,048367,252428,634474,653525,819582,692279,925309,170341,700377,879418,113462,847512,575567,840273,499301,954353,598364,785407,907451,397499,732553,441267,259244,950325,736359,961398,006440,290487,278539,479261,200266,149318,104351,398368,400429,517475,178 | | | |

100

16.01

5 APRIL 79

THE OWNER OF THE OWNER OF

ECON, AVAL. NO 5

ALASKA POWER AUTHORITY ANCHORAGE - FAIRMANKS INTERTIE ECONOMIC FEASIBILITY STUDY

| CAPITAL | DISBURSEMENIS | FUEL COMPONENT O | F OPERATING COSTS |
|--------------|--------------------|-------------------|-------------------|
| IN | \$1000 FOR | IN \$10 | 00 FUR |
| ALTERNATIVE | SYSTEM EXPANSIONS | ALTERNATIVE SYS | TEM EXPANSIONS |
| INDEPENDENT | INTERCONNECTED | INDEPENDENT | INTERCONNECTED |
| CUSIS - \$79 | CUSTS - \$79 | ESCALATED \$ | ESCALATED S |
| | | | |
| | | | |
| | 4,621 | | |
| 2,004 | 15,594 | | |
| 25,600 | 48,874 | | |
| 81,942 | 10,959 | | |
| 37,172 | 31,539 | | |
| 21,127 | | | |
| 7,152 | 2,009 | | |
| 7,555 | 8,037 | | |
| 23,110 | 30,139 | | |
| 51,950 | 42,652 | | |
| 85,500 | 45,047 | | |
| 101, 580 | 89,352 | | |
| 58,450 | 108,400 | | |
| 29,840 | 74,830 | | |
| 23,935 | 55,850 | | |
| 17,630 | | | |
| ADDITIONA | L DISBURSEMENTS | SUSITNA CONSTRUC | TION POWER COSTS |
| ÍN | \$1000 FOR | IN \$10 | 00 FOR |
| UNDERLYING T | RANSMISSION SYSTEM | ALTERNATIVE M | ODES OF SUPPLY |
| INDEPENDENT | INTERCONNECTED | DIESEL GENERATION | INTERTIE TAPLINE |
| COSTS - \$79 | COSTS - \$79 | CUSTS - \$79 | COSTS - \$79 |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| 6,646 | 1,356 | | |
| | | | |
| | | | |
| | | | |
| | | | |
| 2,004 | | | |
| | | | |
| | | | |
| | | | |
| | | | |

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONOMIC FEASIBILITY STUDY

DISCOUNTED COST RATIOS FOR RANGE OF BASE YEAR (1979) COSTS ESCALATED OVER EXPANSION PERIOD - 1979 TO 1996

| | ESCALATION RATES | | | | | | | | | | | |
|----------|------------------|--------|-------|--------|-------|-------|-------|-------|-------|--|--|--|
| DISCOUNT | 42 | 5% | 6% | 72 | 82 | 92 | 102 | 11% | 12% | | | |
| RATE | | 223322 | | 212222 | | | | | | | | |
| 8.00 | 1.060 | 1.053 | 1.045 | 1.038 | 1.031 | 1.024 | 1.017 | 1.010 | 1.004 | | | |
| 8.25 | 1.062 | 1.055 | 1.047 | 1.040 | 1.033 | 1.026 | 1.019 | 1.012 | 1.005 | | | |
| 8.50 | 1.064 | 1.056 | 1.049 | 1.042 | 1.034 | 1.027 | 1.020 | 1.014 | 1.007 | | | |
| 8.75 | 1.066 | 1.058 | 1.051 | 1.044 | 1.036 | 1.029 | 1.022 | 1.015 | 1.009 | | | |
| 9.00 | 1.067 | 1.060 | 1.053 | 1.045 | 1.038 | 1.031 | 1.024 | 1.017 | 1.010 | | | |
| 9.25 | 1.059 | 1.062 | 1.054 | 1.047 | 1.040 | 1.033 | 1.026 | 1.019 | 1.012 | | | |
| 9.50 | 1.071 | 1.063 | 1.056 | 1.049 | 1.042 | 1.034 | 1.027 | 1.020 | 1.014 | | | |
| 9.75 | 1.072 | 1.065 | 1.058 | 1.051 | 1.043 | 1.035 | 1.029 | 1.022 | 1.015 | | | |
| 10.03 | 1.074 | 1.067 | 1.060 | 1.052 | 1.045 | 1.038 | 1.031 | 1.024 | 1.017 | | | |
| 10.25 | 1.076 | 1.069 | 1.061 | 1.054 | 1.047 | 1.040 | 1.033 | 1.026 | 1.019 | | | |
| 10,50 | 1.078 | 1.070 | 1.063 | 1.056 | 1.049 | 1.042 | 1.034 | 1.027 | 1.021 | | | |
| 10.75 | 1.079 | 1.072 | 1.005 | 1.058 | 1.050 | 1.043 | 1.030 | 1.029 | 1.025 | | | |
| 11.00 | 1.081 | 1.074 | 1.067 | 1.059 | 1.052 | 1.045 | 1.038 | 1.031 | 1.024 | | | |
| 11.25 | 1.083 | 1.075 | 1.068 | 1.061 | 1.054 | 1.047 | 1.040 | 1.033 | 1.026 | | | |
| 11.50 | 1.084 | 1.077 | 1.070 | 1.005 | 1.056 | 1.049 | 1.041 | 1.034 | 1.027 | | | |
| 11.75 | 1.086 | 1.079 | 1.072 | 1.065 | 1.057 | 1.050 | 1.043 | 1.050 | 1.029 | | | |
| 12.00 | 1.087 | 1.080 | 1.073 | 1.066 | 1.059 | 1.052 | 1.045 | 1.038 | 1.031 | | | |

COST RATIOS = DISCOUNTED VALUE OF DISBURSEMENTS FOR INDEPENDENT EXPANSION DISCOUNTED VALUE OF DISBURSEMENTS FOR INTERCONNECTED EXPANSION

ALASKA POWER AUTHORITY Anchorage - Fairbanks intertie Economic feasibility study

A set of the set of th

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS (IN \$1000)

| | ESCALATION RATES | | | | | | | | | | |
|----------|------------------|--------|--------|--------|--------|--------|--------|--------|--------|--|--|
| DISCOUNT | 4% | 5% | 6% | 12 | 82 | 9% | 102 | 112 | 12% | | |
| NATE | 222221 | | ****** | ====== | | ====== | ====== | ***** | 222222 | | |
| 8.00 | 21,225 | 20,637 | 19,694 | 18,339 | 16,509 | 14,133 | 11,132 | 7,418 | 2,846 | | |
| A.25 | 21,319 | 20,810 | 19,960 | 18,715 | 17,014 | 14,787 | 11,958 | 8,443 | 4,149 | | |
| 8.50 | 21,397 | 50,965 | 501505 | 19,052 | 17,483 | 15,399 | 12,730 | 9,412 | 5,337 | | |
| 8.75 | 21,458 | 21,095 | 20,420 | 19,381 | 17,920 | 15,9/3 | 13,469 | 10,328 | 6,464 | | |
| 9.00 | 21,503 | 21,209 | 20,016 | 19,673 | 18,324 | 16,509 | 14,157 | 11,193 | 7,531 | | |
| 9.25 | 21,534 | 21,305 | 20,790 | 19,939 | 18,699 | 17,009 | 14,804 | 12,008 | 8,541 | | |
| 9.50 | 21,551 | 21,385 | 20,943 | 20,180 | 19,044 | 17,475 | 15,410 | 12,777 | 9,496 | | |
| 9.15 | 21,554 | 21,448 | 21,078 | 20,399 | 19,361 | 17,908 | 15,978 | 13,501 | 10,400 | | |
| 10.00 | 21,545 | 21,496 | 21,193 | 20,595 | 19,652 | 18,310 | 16,509 | 14,181 | 11,253 | | |
| 10.25 | 21,525 | 21,529 | 51,291 | 20,770 | 19,918 | 18,682 | 17,005 | 14,821 | 12,058 | | |
| 10.50 | 21,493 | 21,548 | 21,372 | 20,924 | 20,159 | 19,025 | 17,467 | 15,421 | 12,817 | | |
| 10,75 | 21,450 | 21,555 | 21,438 | 21,000 | 20,378 | 19,342 | 17,897 | 15,983 | 13,532 | | |
| 11.00 | 21,398 | 21,549 | 21,488 | 21,177 | 20,574 | 19,632 | 18,296 | 16,509 | 14,205 | | |
| 11.25 | 21,336 | 21,551 | 21,523 | 21,277 | 20,750 | 19,897 | 18,066 | 17,001 | 14,837 | | |
| 11.50 | 21,205 | 21,502 | 21,545 | 21,360 | 20,905 | 20,138 | 19,007 | 17,459 | 15,431 | | |
| 11.75 | 21,185 | 21,462 | 21,554 | 21,427 | 21,042 | 20,357 | 19,322 | 17,886 | 15,988 | | |
| 12.00 | 890.15 | 21,413 | 21,551 | 21,479 | 21,161 | 20,554 | 19,611 | 18,282 | 16,509 | | |

E - 16

S APRIL 79

ECON, ANAL.NO 5

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONUMIC FEASIBILITY STUDY

DISCOUNTED VALUE OF BASE YEAR (1979) INDEPENDENT SYSTEM COSTS IN \$1000

| | FSCALATION RATES | | | | | | | | | | | |
|----------|------------------|---------|---------|----------|---------|---------|---------|---------|---------|--|--|--|
| DISCOUNT | 42 | 5% | 6% | 72 | 8% | 97 | 102 | 112 | 12% | | | |
| RATE | | ******* | | | | 1222222 | ======= | ****** | | | | |
| 8.00 | 373,662 | 411,407 | 453,201 | 499,483 | 550,738 | 601,502 | 670,367 | /39,985 | 817,076 | | | |
| 8.25 | 365,154 | 401,898 | 442,573 | 451,603 | 537,460 | 592,662 | 653,783 | 721,456 | 796,376 | | | |
| 8.50 | 356,889 | 392,003 | 432,253 | 476,072 | 524,575 | 578,265 | 637,698 | 103,487 | 176,307 | | | |
| 8.75 | 348,859 | 383,693 | 422,253 | 464,878 | 512,069 | 564,295 | 622,094 | 686,059 | 756,845 | | | |
| 9.00 | 341,057 | 374,980 | 412,501 | 454,009 | 499,930 | 550,738 | 606,954 | 669,154 | 731,912 | | | |
| 9.25 | 535,474 | 306,514 | 403,049 | 443,455 | 488,145 | 537,580 | 542,264 | 652,754 | 719,666 | | | |
| 9.50 | 326,104 | 358,289 | 395,867 | 433,205 | 476,704 | 524,808 | 578,007 | 636,843 | 701,909 | | | |
| 9.15 | 518,940 | 350,295 | 384,947 | 423,250 | 465,593 | 512,408 | 564,170 | 621,402 | 684,682 | | | |
| 10.00 | 311,975 | 342,520 | 376,219 | 415,579 | 454,803 | 500,369 | 550,738 | 606,417 | 607,966 | | | |
| 10.25 | 305,203 | 354,913 | 367,856 | 404,183 | 444,322 | 488,678 | 537,698 | 591,873 | 051,740 | | | |
| 10.50 | 298,618 | 327,631 | 359,669 | \$95,054 | 434,142 | 471,325 | 525,037 | 517,754 | 636,004 | | | |
| 10.75 | 292,213 | 320,492 | 351,711 | 386,182 | 424,250 | 466,297 | 512,742 | 564,047 | 620,123 | | | |
| 11.00 | 285,983 | 313,550 | 345,975 | 377,559 | 414,640 | 455,584 | 500,801 | 550,738 | 605,840 | | | |
| 11.25 | 219,922 | 306,799 | 356,453 | 369,178 | 405,300 | 445,176 | 489,202 | 537,814 | 591,489 | | | |
| 11.50 | 274,025 | 300,232 | 329,138 | 361,030 | 346,223 | 435,065 | 477,936 | 525,261 | 577,506 | | | |
| 11.75 | 268,286 | 295,845 | 322,024 | 353,108 | 387,399 | 425,236 | 466,989 | 513,069 | 563,927 | | | |
| 12.00 | 262,702 | 207,027 | 315,105 | 345,404 | 378,821 | 415,684 | 456,353 | 501,225 | 550,738 | | | |

DISCOUNTED VALUE OF BASE YEAR (1979)INTERCONNECTED SYSTEM COSTS IN \$1000

| | ESCALATION RATES | | | | | | | | | | | |
|----------|------------------|---------|---------|----------|---------|---------|---------|---------|---------|--|--|--|
| DISCOUNT | 42 | 5% | 62 | 7 % | 82 | 92 | 10% | 112 | 122 | | | |
| RATE | | ====== | 2222222 | ****** | 3225233 | ======= | ======= | | | | | |
| 8.00 | 352,437 | 390,771 | 433,508 | 481,144 | 534,229 | 593,369 | 659,235 | 732,567 | 814,140 | | | |
| 8.25 | 345,834 | 381,088 | 422,612 | 468,888 | 520,446 | 577,876 | 641,825 | 713,012 | 792,227 | | | |
| 8.50 | 335,492 | 371,701 | 412,051 | 457,010 | 507,091 | 562,866 | 624,962 | 694,074 | 770,969 | | | |
| 8.75 | 327,401 | 302,598 | 401,813 | 445,497 | 494,149 | 548,322 | 608,625 | 675,731 | 750,382 | | | |
| 9.00 | 319,554 | 353,771 | 391,886 | 434, 536 | 481,606 | 534,229 | 592,791 | 657,962 | 730,441 | | | |
| 9.25 | 311,940 | 345,209 | 382,260 | 423,510 | 469,447 | 520,571 | 577,460 | 640,746 | 711,120 | | | |
| 9.50 | 304,554 | 530,904 | 372,924 | 413,025 | 457,660 | 507,333 | 562,597 | 624,065 | 692,413 | | | |
| 9.15 | 297,386 | 328,847 | 363,869 | 402,851 | 446,232 | 494,500 | 548,192 | 607,901 | 614,282 | | | |
| 10.00 | 290,450 | 321,030 | 355,080 | 392,984 | 435,151 | 482,059 | 534,229 | 592,236 | 656,714 | | | |
| 10.25 | 283,679 | 513,445 | 340,505 | 383,413 | 424,405 | 469,446 | 520,693 | 577,052 | 659,688 | | | |
| 10.50 | 277,125 | 390,043 | 338,297 | 374,129 | 413,982 | 458,299 | 507,570 | 562,334 | 623,187 | | | |
| 10.75 | 270,163 | 244,438 | 330,214 | 365,122 | 403,873 | 446,955 | 494,845 | 548,064 | 607,192 | | | |
| 11.00 | 264,585 | 242,002 | 322,487 | \$56,382 | 394,065 | 435,953 | 482,505 | 534,229 | 541,085 | | | |
| 11.25 | 258,546 | 245,268 | 314,929 | 347,901 | 384,550 | 425,280 | 470,537 | 520,813 | 576,052 | | | |
| 11.50 | 252,760 | 278,730 | 301,593 | 539,670 | 375,317 | 414,925 | 458,928 | 507,802 | 562,075 | | | |
| 11.75 | 247,101 | 212,301 | 300,470 | 331,681 | 366,351 | 404,879 | 447,667 | 495,183 | 547,939 | | | |
| 12.00 | 241,004 | 200,215 | 293,554 | 323,925 | 357,661 | 395,131 | 436,142 | 482,943 | 534,229 | | | |

5 APRIL 79

.

ECON.ANAL.NO 7

falities to

100

) under

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONOMIC FEASIBILITY STUDY

ALC: NO

Ť

1

1

-

ŝ

CAPITAL DISBURSEMENTS FUEL COMPONENT OF OPERATING COSTS IN \$1000 FOR IN \$1000 FOR ALTERNATIVE SYSTEM EXPANSIONS ALTERNATIVE SYSTEM EXPANSIONS INDEPENDENT INTERCONNECTED INDEPENDENT INTERCONNECTED ESCALATED S ESCALATED \$ CUSIS - \$79 CUSIS - \$79 1979 1980 4,675 1981 1982 2,009 17,349 1983 26,666 69,844 81,942 10,959 1984 37,172 31,539 1985 21,127 1986 1987 2,009 7,152 7,555 8,037 1988 1949 23,110 30,139 1990 21,920 42,652 1991 82,200 43,047 89,352 1992 101,380 58,450 108,400 1993 29,840 74,830 1994 1995 23,935 52,820 1996 17,630 SUSITNA CONSTRUCTION POWER COSTS. ADDITIONAL DISBURSEMENTS IN \$1000 FUR IN \$1000 FOR ALTERNATIVE MODES OF SUPPLY UNDERLYING TRANSMISSION SYSTEM INDEPENDENT INTERCONNECTED DIESEL GENERATION INTERTIE TAPLINE COSTS - \$79 COSTS - \$79 COSTS - \$79 COSTS - \$79 1979 1980 1981 1982 1983 1984 1985 1986 1987 1988 1989 1990 1991 1995 1993 1994 1995

5 APRIL 79

ŧ

.

SI Keen

.

1996

ti de la companya de

1

E - 18

MARK

ſ

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONOMIC FEASIBILITY STUDY

DISCOUNTED COST RATIOS FOR RANGE OF BASE YEAR (1979) COSTS ESCALATED UVER EXPANSION PERIOD = 1979 TO 1996

| | ESCALATION RATES | | | | | | | | | | | |
|----------|------------------|------|------|-------|------|--------|--------|------|------|--|--|--|
| DISCOUNT | 42 | 5% | 6% | 72 | 82 | 9% | 10% | 112 | 12% | | | |
| RATE | ======= | | | ===== | | ====== | ====== | | | | | |
| 8.00 | .990 | .987 | .983 | .979 | .976 | .972 | .968 | .964 | .460 | | | |
| 8.25 | .991 | .988 | .984 | .980 | .977 | .973 | .969 | .965 | .961 | | | |
| 8.50 | .992 | .989 | .985 | .981 | .978 | .974 | .970 | .966 | .962 | | | |
| 8,75 | .943 | .989 | .986 | .982 | .978 | .975 | .971 | .967 | .953 | | | |
| 9.00 | 994 | .990 | .987 | .983 | .979 | .976 | .972 | .968 | .964 | | | |
| 9.25 | .994 | .991 | .988 | .984 | .980 | .977 | .973 | .969 | .965 | | | |
| 9.50 | .995 | .992 | .989 | .985 | .981 | .978 | .974 | .970 | .966 | | | |
| 9.75 | .996 | .993 | .989 | .986 | .982 | .978 | .975 | .971 | .967 | | | |
| 10.00 | 996 | .993 | .990 | .987 | .983 | .979 | .976 | .972 | .968 | | | |
| 10.25 | 997 | .994 | .991 | .988 | .984 | .980 | .977 | .973 | .969 | | | |
| 10.50 | 998 | .995 | .992 | .988 | .985 | .981 | .977 | .974 | .970 | | | |
| 10.75 | .998 | .996 | .993 | .989 | .986 | .982 | .978 | .975 | .971 | | | |
| 11.00 | .999 | .996 | .993 | .990 | .987 | .983 | .979 | .976 | .972 | | | |
| 11.25 | 1.000 | .997 | .994 | .991 | .987 | .984 | .980 | .977 | .973 | | | |
| 11.50 | 1.000 | .998 | ,995 | . 492 | ,988 | ,985 | .981 | .977 | .974 | | | |
| 11.75 | 1.001 | .998 | .995 | .992 | .989 | .986 | .982 | .978 | .975 | | | |
| 12,00 | 1.001 | .949 | .996 | .993 | .990 | .987 | .983 | .979 | .976 | | | |

COST RATIOS = DISCOUNTED VALUE OF DISBURSEMENTS FOR INDEPENDENT EXPANSION DISCOUNTED VALUE OF DISBURSEMENTS FOR INTERCONNECTED EXPANSION

5 APRIL 79

-

- Hallerin

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONOMIC FEASIBILITY STUDY

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS (IN \$1000)

| DISCOUNT | 4% | 5% | 6% _ | 7% | 8% | 97 | 102 | 112 | 122 | | |
|----------|--------|------------|--------|---------|---------|---------|---------|---------|---------|--|--|
| RATE | ===== | == = = = = | | ===== | ====== | ===== | ====== | ====== | | | |
| 8.00 | -3,562 | -5,375 | -7,604 | -10,311 | -13,564 | -17,438 | -22,016 | -27,391 | -33,665 | | |
| 8.25 | -3,183 | -4,899 | -7,016 | -9,594 | -12,698 | -16,400 | -20,781 | -25,932 | -31,950 | | |
| 8.50 | -2,825 | -4,449 | -6,459 | -8,912 | -11,872 | -15,409 | -19,602 | -24,536 | -30,308 | | |
| 8.75 | -2,488 | -4,024 | -5,931 | -8,205 | -11,086 | -14,465 | -18,475 | -23,201 | -28,736 | | |
| 9.00 | -2,171 | -3,622 | -5,430 | -7,649 | -10,338 | -13,564 | -17,399 | -21,925 | -27,232 | | |
| 9.25 | -1,873 | -3,243 | -4,956 | -7,065 | -9,621 | -12,705 | -16,372 | -20,705 | -25,792 | | |
| 9.50 | -1,594 | -2,885 | -4,507 | -6,510 | -8,949 | -11,887 | -15,392 | -19,539 | -24,414 | | |
| 9.75 | -1,331 | -2,548 | -4,082 | -5,984 | -8,306 | -11,108 | -14,456 | -18,426 | -23,097 | | |
| 10.00 | -1,086 | -2,250 | -3,681 | -5,485 | -7,694 | •10,365 | -13,564 | -17,361 | -21,836 | | |
| 10.25 | -856 | -1,952 | -3,302 | -5,012 | -7,112 | -9,658 | -12,713 | -16,345 | -20,631 | | |
| 10.50 | -641 | -1,651 | -2,944 | -4,564 | -6,560 | -8,986 | -11,902 | -15,375 | -19,479 | | |
| 10.75 | -441 | -1,387 | -2,607 | -4,141 | -6,036 | -8,346 | -11,128 | -14,448 | -18,377 | | |
| 11.00 | -254 | -1,140 | -2,289 | -3,740 | -5,539 | -1,737 | -10,392 | -13,564 | -17,324 | | |
| 11.25 | -80 | -909 | -1,989 | -3,361 | -5,068 | -/,159 | -9,690 | -12,720 | -16,318 | | |
| 11.50 | 80 | -693 | -1,708 | -3,003 | -4,621 | -6,610 | -9,022 | -11,916 | -15,358 | | |
| 11.75 | 229 | -491 | -1,443 | -2,665 | -4,198 | -6,088 | -8,386 | -11,149 | -14,440 | | |
| 12.00 | 367 | -302 | -1,195 | -2,347 | -3,798 | -5,592 | -7,781 | -10,417 | -13,564 | | |

E - 20

5 APRIL 79

(INCOME)

5 APRIL 79

•

ALASKA POWER AUTHORITY Anchorage - Fairbanks intertie Economic feasibility study

ECON, ANAL.NO 7

L'utain

DISCOUNTED VALUE OF BASE YEAR (1979) INDEPENDENT SYSTEM COSTS IN \$1000

| | ESCALATION RATES | | | | | | | | | | |
|----------|------------------|---------|---------|----------|---------|---------|---------|---------|-----------------|--|--|
| DISCOUNT | 42 | 5% | 6% | 72 | 82 | 97 | 102 | 11% | 12% | | |
| RATE | | ****** | ======= | ====== | ******* | ====== | 1012111 | ====== | ==== === | | |
| 8.00 | 367,521 | 404,713 | 445,907 | 491,538 | 542,088 | 598,088 | 660,126 | 728,848 | 804,970 | | |
| 8.25 | 359,139 | 395,342 | 435,430 | 479,824 | 528,991 | 583,447 | 643,759 | 710,556 | 784,529 | | |
| 8.50 | 350,998 | 386,242 | 425,258 | 468,454 | 516,283 | 569,243 | 627,885 | 692,818 | 764,711 | | |
| 8.75 | 343,088 | 377,404 | 415,382 | 457,417 | 503,949 | 555,461 | 612,487 | 675,615 | 745,495 | | |
| 9.00 | 335,403 | 368,819 | 405,791 | 446,703 | 441,979 | 542,088 | 597,548 | 658,929 | 726,861 | | |
| 9.25 | 327.936 | 360,480 | 396,476 | 436,299 | 480,358 | 529,110 | 583,054 | 642,744 | 708,789 | | |
| 9.50 | 320.678 | 352,377 | 387,429 | 426,196 | 469,077 | 516,512 | 568,988 | 627,041 | 691,260 | | |
| 9.75 | 313,624 | 344.503 | 378,639 | 416, 584 | 458,123 | 504,284 | 555,338 | 611,804 | 674,255 | | |
| 10.00 | 306.766 | 336,850 | 370,099 | 406,853 | 447,486 | 492,412 | 542,088 | 597,018 | 657,757 | | |
| 10.25 | 300.098 | 329,412 | 361.801 | 397,594 | 437,154 | 480,884 | 529,226 | 582,668 | 641,748 | | |
| 10.50 | 243.615 | 322,182 | 355.136 | 388,598 | 427,119 | 469,689 | 516,738 | 568,739 | 626,213 | | |
| 10.75 | 287.309 | 315,152 | 345.898 | 379,856 | 417.370 | 458,817 | 504,613 | 555,217 | 611,134 | | |
| 11.00 | 281.177 | 508.316 | 338,278 | 371, 501 | 407,898 | 448,256 | 492,837 | 542,088 | 596,498 | | |
| 11.25 | 275.211 | 501.669 | 330.869 | 363,104 | 398,694 | 437,996 | 481,401 | 529,340 | 582,289 | | |
| 11.50 | 269.407 | 295.203 | 323.666 | 355.077 | 389.749 | 428.028 | 470.292 | 516,960 | 568,494 | | |
| 11.75 | 263,759 | 288.914 | 316,661 | 547.273 | 381,055 | 418,341 | 459,499 | 504,936 | 555,098 | | |
| 12.00 | 258,263 | 282,795 | 309,847 | 339,686 | 372,604 | 408,928 | 449,014 | 493,256 | 542,088 | | |

DISCOUNTED VALUE OF BASE YEAR (1979)INTERCONNECTED SYSTEM COSTS IN \$1000

| | ESCALATION RATES | | | | | | | | | | |
|----------|------------------|---------|---------|---------|---------|---------|---------|---------|---------|--|--|
| DISCOUNT | 42 | 5% | 6% | 72 | 82 | 9% | 102 | 117 | 12% | | |
| RATE | | | 211111 | ======= | ======= | 2222222 | | ======= | | | |
| 8.00 | 371,083 | 410,087 | 453,511 | 501,849 | 555,652 | 615,526 | 682,142 | 756,239 | 838,635 | | |
| 8.25 | 362,322 | 400,241 | 442,446 | 489,418 | 541,689 | 599,846 | 664,540 | 736,487 | 816,479 | | |
| 8.50 | 353,823 | 390,691 | 431,717 | 477,367 | 528,155 | 584,652 | 647,487 | 717,354 | 795,019 | | |
| 8.75 | 345,577 | 381,428 | 421,312 | 465,682 | 515,036 | 569,926 | 630,962 | 698,816 | 774,231 | | |
| 9.00 | 337,575 | 372,441 | 411,221 | 454,352 | 502,317 | 555,652 | 614,947 | 680,855 | 754,093 | | |
| 9.25 | 329,809 | 363,722 | 401,432 | 443,364 | 489,985 | 541,815 | 599,426 | 663,449 | 734,581 | | |
| 9.50 | 322,272 | 355,261 | 391,936 | 432,706 | 478,026 | 528,400 | 584,380 | 646,580 | 715,674 | | |
| 9.75 | 314,955 | 347,050 | 382,722 | 422,367 | 466,428 | 515,391 | 569,794 | 630,229 | 697,352 | | |
| 10.00 | 307.851 | 339,081 | 373.780 | 412,338 | 455,179 | 502,177 | 555,652 | 614,379 | 679,593 | | |
| 10.25 | 100.954 | 331,344 | 365,103 | 402,606 | 444,266 | 490,542 | 541,939 | 599,013 | 662,379 | | |
| 10.50 | 294,256 | 323,853 | 350,680 | 393,162 | 433,679 | 478,675 | 528,640 | 584,113 | 645,691 | | |
| 10.75 | 287.750 | 316,539 | 348.504 | 383,997 | 423,406 | 467,163 | 515,741 | 569,665 | 629,511 | | |
| 11.00 | 281.431 | 309.457 | 340.566 | 3/5,100 | 413,437 | 455,993 | 503,229 | 555,652 | 613,822 | | |
| 11.25 | 275,291 | 302.578 | 342.858 | 366.464 | 403,762 | 445,155 | 491,090 | 542,060 | 598,608 | | |
| 11.50 | 269.326 | 295.896 | 325,373 | 358,080 | 394.370 | 434.637 | 479,313 | 528,876 | 583,851 | | |
| 11 75 | 264.540 | 289.405 | 518,104 | 349.958 | 385,253 | 424.429 | 467,885 | 516,084 | 569.538 | | |
| 12.00 | 257,897 | 283,098 | 311,042 | 342,032 | 376,402 | 414,520 | 456,794 | 503,673 | 555,652 | | |

| | x | 2 | | | 7 | | 4 | F | 2 | Ŧ | 1 | i i | \$ | 1 | à. | i. |
|---|------------|---|---|---|---|---|---|----|---|---|---|-----|----|---|----|----|
| 1 | 1. Support | | Ê | Ŧ | F | 1 | Ţ | ŝ. | | i | ê | ā | ţ | 1 | į. | 3 |

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONUMIC FEASIBILITY STUDY

5 APRIL 79

| | CAPITAL DI
IN \$1
ALTERNATIVE SY
INDEPENDENT
COSTS - \$79 | SBURSEMENTS
000 FOR
STEM EXPANSIONS
INTERCONNECTED
COSTS - \$79 | FUEL COMPONENT O
IN \$10
ALTERNATIVE SYS
INDEPENDENT
ESCALATED \$ | F OPERATING COSTS
00 FOR
TEM EXPANSIONS
INTERCONNECTED
ESCALATED \$ |
|--|--|---|--|---|
| 1979
1980
1981
1982
1983
1984
1985 | 2,009
26,666
81,942
37,172
27,727 | 4,011
14,228
46,967
10,959
31,539
5,480 | 8,468
9,324 | 7,648
8,498 |
| 1988
1987
1988
1989
1990
1991
1992
1993 | 33,552
106,555
145,210
94,760
119,475
101,380
58,450 | 23,929
90,237
135,530
115,330
112,834
89,352
108,400 | 6,851
7,212 | 8,324
8,654
8,016 |
| 1994
1995
1996 | 29,840
23,935
17,630
ADDITIONAL
IN \$
UNDERLYING TR | 74,830
22,820
DISBURSEMENTS
1000 FOR
ANSMISSION SYSTEM | 8,654
9,015
SUSITNA CONSTRUC
IN \$10
ALTERNATIVE | 8,745
9,109
Ction Power Costs
Doo For
Modes of Supply |
| 1979
1980
1981 | INDEPENDENT
COSTS - \$79 | INTERCONNECTED
COSTS - \$79 | DIESEL GENERATION
CUSIS - \$79 | INTERTIE TAPLINE
COSTS - \$79 |
| 1982
1983
1984
1985
1986
1987
1988
1989
1990
1990
1990
1993
1993
1993 | | | 2,835
695
697
696
3,055
1,324
187
623
623
623
-500 | 267
483
481
478
752
902
734
430
419
304 |

• 22

1996

Ē

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONOMIC FEASIBILITY STUDY

DISCOUNTED COST RATIOS FOR RANGE OF BASE YEAR (1979) COSTS ESCALATED OVER EXPANSION PERIOD - 1979 TO 1996

| | ESCALATION RATES | | | | | | | | | | | |
|----------|------------------|-------|-------|--------|------------|-------|--------|-------|--------|--|--|--|
| DISCOUNT | 4% | 5% | 6% | 7% | 8 x | 9% | 10% | 112 | 12% | | | |
| RATE | 121211 | ===== | ===== | ====== | | | 322222 | | ====== | | | |
| 8.00 | 1.050 | 1.044 | 1.039 | 1.033 | 1.028 | 1.022 | 1.017 | 1.012 | 1.006 | | | |
| 8,25 | 1.051 | 1,045 | 1.040 | 1.034 | 1.029 | 1.024 | 1.018 | 1.013 | 1.008 | | | |
| 8.50 | 1.052 | 1.047 | 1.041 | 1.036 | 1.030 | 1.025 | 1.020 | 1.014 | 1.009 | | | |
| 8.75 | 1.054 | 1.048 | 1.043 | 1.037 | 1.032 | 1.026 | 1.021 | 1.016 | 1.010 | | | |
| 9.00 | 1.055 | 1.050 | 1.044 | 1.039 | 1.033 | 1.028 | 1.022 | 1.017 | 1.012 | | | |
| 9.25 | 1.056 | 1.051 | 1.046 | 1.040 | 1.035 | 1.029 | 1.024 | 1.018 | 1.013 | | | |
| 9.50 | 1.058 | 1.052 | 1.047 | 1.041 | 1.036 | 1.030 | 1.025 | 1.020 | 1.014 | | | |
| 9.75 | 1.059 | 1.054 | 1.048 | 1.043 | 1.037 | 1.032 | 1.026 | 1.021 | 1.016 | | | |
| 10.00 | 1.061 | 1.055 | 1.050 | 1.044 | 1.039 | 1.033 | 1.028 | 1.022 | 1.017 | | | |
| 10.25 | 1.062 | 1.056 | 1.051 | 1.046 | 1.040 | 1.035 | 1.029 | 1.024 | 1.018 | | | |
| 10.50 | 1.063 | 1.058 | 1.052 | 1.047 | 1.041 | 1.036 | 1.031 | 1.025 | 1.020 | | | |
| 10.75 | 1.065 | 1.059 | 1.054 | 1.048 | 1.043 | 1.037 | 1.032 | 1.027 | 1.021 | | | |
| 11.00 | 1.066 | 1.061 | 1.055 | 1.050 | 1.044 | 1.039 | 1.033 | 1.028 | 1.023 | | | |
| 11.25 | 1.067 | 1.062 | 1.056 | 1.051 | 1.046 | 1.040 | 1.035 | 1.029 | 1.024 | | | |
| 11.50 | 1.059 | 1.063 | 1.058 | 1.052 | 1.047 | 1.041 | 1.036 | 1.031 | 1.025 | | | |
| 11,75 | 1.070 | 1.065 | 1.059 | 1.054 | 1.048 | 1.043 | 1.037 | 1.032 | 1.027 | | | |
| 12.00 | 1.071 | 1.066 | 1.060 | 1.055 | 1.050 | 1.044 | 1.039 | 1.033 | 1.028 | | | |

COST RATIOS = DISCOUNTED VALUE OF DISBURSEMENTS FOR INDEPENDENT EXPANSION DISCOUNTED VALUE OF DISBURSEMENTS FOR INTERCONNECTED EXPANSION

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONUMIC FEASIBILITY STUDY

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS (IN \$1000)

| | | | | ESC | ALATION RA | TFS | | | |
|----------|--------|--------|--------|--------|------------|--------|--------|--------|--------|
| DISCOUNT | 4% | 5% | 6% | 7 X | 8% | 9% | 10% | 112 | 12% |
| RATE | ====== | ====== | | ====== | ===== | ===== | | ====== | ====== |
| 8.00 | 30,913 | 30,276 | 29,194 | 27,595 | 25,399 | 22,515 | 18,844 | 14,275 | 8,685 |
| 8.25 | 31,014 | 30,476 | 29,511 | 28,050 | 26,015 | 23,319 | 19,865 | 15,546 | 10,243 |
| 8.50 | 31,094 | 30,649 | 29,796 | 28,467 | 26,586 | 24,070 | 20,824 | 16,746 | 11,720 |
| 8.75 | 31,153 | 30,798 | 30,051 | 28,848 | 27,115 | 24,771 | 21,725 | 17,878 | 13,117 |
| 9.00 | 31,192 | 30,922 | 30,278 | 29,195 | 27,604 | 25,425 | 22,571 | 18,945 | 14,440 |
| 9.25 | 31,212 | 31,024 | 30,477 | 29,509 | 28,053 | 26,033 | 23,363 | 19,950 | 15,689 |
| 9.50 | 31,214 | 31,104 | 30,650 | 29,793 | 28,466 | 26,597 | 24,104 | 20,895 | 16,870 |
| 9.75 | 31,199 | 31,164 | 30,798 | 30,046 | 28,844 | 27,120 | 24,796 | 21,783 | 17,985 |
| 10.00 | 31,169 | 31,204 | 30,923 | 30,271 | 29,188 | 27,604 | 25,442 | 22,617 | 19,035 |
| 10.25 | 31,123 | 31,225 | 31,025 | 30,470 | 29,500 | 28,049 | 26,042 | 23,398 | 20,025 |
| 10.50 | 31,063 | 31,229 | 31,106 | 30,642 | 29,781 | 28,458 | 26,601 | 24,130 | 20,957 |
| 10.75 | 30,990 | 31,216 | 31,166 | 30,791 | 30,033 | 28,832 | 27,118 | 24,813 | 21,833 |
| 11.00 | 30,903 | 31,188 | 31,208 | 30,916 | 30,258 | 29,174 | 27,596 | 25,451 | 22,655 |
| 11.25 | 30,805 | 31,144 | 31,231 | 31,019 | 30,455 | 29,483 | 28,037 | 26,045 | 23,427 |
| 11.50 | 30,695 | 31,086 | 31,236 | 31,100 | 30,628 | 29,163 | 28,443 | 26,597 | 24,149 |
| 11.75 | 30,575 | 31,015 | 31,226 | 31,162 | 50,777 | 30,014 | 28,814 | 27,110 | 24,824 |
| 12.00 | 30,444 | 30,932 | 31,199 | 31,205 | 30,902 | 30,238 | 29,154 | 27,583 | 25,455 |

5 APRIL 79

ECON.ANAL.NO 8

-14

ALASKA POWER AUTHORITY ANCHORAGE - FAIRBANKS INTERTIE ECONOMIC FEASIBILITY STUDY

DISCOUNTED VALUE OF BASE YEAR (1979) INDEPENDENT SYSTEM COSTS IN \$1000

| | | | | ES(| CALATION P | RATES | | | |
|----------|---------|---------|---------|---------|------------|-----------|---------------|------------------|-----------|
| DISCOUNT | 4% | 5% | 6% | 7% | 8% | 92 | 102 | 112 | 12% |
| RATE | ======= | ====== | ====== | ======= | ======= | ======= | ZZZZZZ | :=== : :: | 2022233 |
| 8.00 | 654,225 | 716,927 | 785,918 | 861,816 | 945,299 | 1,037,112 | 1,138,066 | 1,249,052 | 1,371,043 |
| 8.25 | 639,351 | 700,481 | 767,729 | 841,690 | 923,041 | 1,012,486 | 1,110,819 | 1,218,906 | 1,337,690 |
| 8.50 | 624,883 | 684,486 | 750,042 | 822,135 | 901,405 | 988,552 | 1,084,343 | 1,189,617 | 1,305,290 |
| 8.75 | 610,808 | 668,929 | 732,842 | 803,116 | 880,371 | 965,288 | 1,058,612 | 1,161,157 | 1,273,813 |
| 9.00 | 597,114 | 653,796 | 716,114 | 784,621 | 859,921 | 942,674 | 1,033,604 | 1,133,501 | 1,243,229 |
| 9,25 | 583,790 | 634,073 | 699,842 | 766,634 | 840,035 | 920,688 | 1,009,294 | 1,106,622 | 1,213,510 |
| 9.50 | 570,824 | 624,748 | 684,013 | 749,139 | 820,697 | 899,311 | 985,661 | 1,080,495 | 1,184,627 |
| 9.75 | 558,205 | 610,809 | 668,613 | 732,121 | 801,890 | 878,523 | 962,684 | 1,055,098 | 1,156,555 |
| 10.00 | 545,922 | 597,244 | 653,628 | 715,506 | 783,596 | 858,306 | 940,342 | 1,030,406 | 1,129,267 |
| 10.25 | 533,965 | 584,041 | 639,046 | 699,457 | 765,799 | 838,643 | 918,615 | 1,006,398 | 1,102,740 |
| 10.50 | 522,324 | 571,189 | 624,854 | 683,783 | 748,485 | 819,516 | 897,484 | 983,052 | 1,076,948 |
| 10.75 | 510,990 | 558,678 | 611,041 | 668,530 | 751,639 | 800,408 | 876,930 | 960,348 | 1,051,869 |
| 11.00 | 499,953 | 546,498 | 597,595 | 653,684 | 715,245 | 782,804 | 856,935 | 938,266 | 1,027,480 |
| 11.25 | 489,205 | 534,637 | 584,505 | 639,233 | 699,291 | 765,188 | 837,483 | 916,785 | 1,003,761 |
| 11.50 | 478,736 | 523,088 | 571,759 | 625,166 | 683,763 | 748,045 | 818,556 | 895,889 | 980,689 |
| 11.75 | 468,539 | 511,839 | 559,349 | 611,471 | 668,647 | 731,361 | 800,139 | 875,558 | 958,246 |
| 12.00 | 458,604 | 500,883 | 547,263 | 598,136 | 653,932 | 715,121 | 782,215 | 855,775 | 936,412 |

DISCOUNTED VALUE OF BASE YEAR (1979)INTERCONNECTED SYSTEM COSTS IN \$1000

| | | | | ES(| CALATION P | RATES | | | |
|----------|---------|---------|---------|---------|------------|-----------|-----------|-----------|-----------|
| DISCOUNT | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 112 | 12% |
| RATE | | | | | ======= | 2222222 | ====== | | ====== |
| 8.00 | 623,312 | 686,652 | 756,724 | 834,221 | 919,901 | 1,014,597 | 1,119,222 | 1,234,777 | 1,362,358 |
| 8.25 | 608,336 | 670,005 | 738,218 | 813,646 | 897,026 | 989,167 | 1,090,955 | 1,203,360 | 1,327,446 |
| 8,50 | 593,789 | 653,837 | 720,246 | 793,608 | 874,819 | 964,482 | 1,063,519 | 1,172,871 | 1,293,570 |
| 8.75 | 579,655 | 638,131 | 702,791 | 7/4,268 | 853,256 | 940,517 | 1,036,887 | 1,143,279 | 1,260,696 |
| 9.00 | 565,923 | 622,873 | 685,836 | 755,426 | 832,317 | 917,249 | 1,011,033 | 1,114,556 | 1,228,790 |
| 9,25 | 552,579 | 608,049 | 669,365 | 737,125 | 811,982 | 894,655 | 985,931 | 1,086,672 | 1,197,820 |
| 9.50 | 539,610 | 593,644 | 653,363 | 719,347 | 792,231 | 872,713 | 961,557 | 1,059,600 | 1,167,757 |
| 9.75 | 527,005 | 579,646 | 637,814 | 702,075 | 773,046 | 851,403 | 937,888 | 1,033,314 | 1,138,570 |
| 10.00 | 514,753 | 566,040 | 622,705 | 685,294 | 754,408 | 830,703 | 914,900 | 1,007,789 | 1,110,232 |
| 10.25 | 502,842 | 552,816 | 608,021 | 668,988 | 736,299 | 810,594 | 892,572 | 983,000 | 1,082,714 |
| 10.50 | 491,261 | 539,961 | 593,748 | 653,141 | 718,704 | 791,058 | 870,883 | 958,922 | 1,055,991 |
| 10.75 | 480,000 | 527,402 | 579,875 | 637,739 | 701,605 | 772,076 | 849,812 | 935,535 | 1,030,036 |
| 11,00 | 469,050 | 515,310 | 566,337 | 622,768 | 684,988 | 753,631 | 829,339 | 912,814 | 1,004,825 |
| 11.25 | 458,400 | 503,493 | 553,274 | 608,215 | 668,836 | 735,705 | 809,446 | 890,740 | 980,334 |
| 11.50 | 448,041 | 492,001 | 540,523 | 594,060 | 653,135 | 718,282 | 790,113 | 809,291 | 956,541 |
| 11,75 | 437,964 | 480,824 | 528,123 | 540,308 | 637,870 | 701,340 | 771,325 | 848,448 | 933,422 |
| 12.00 | 428,100 | 409,952 | 516,063 | 500,931 | 623,030 | 684,883 | 753,002 | 828,192 | 910,958 |

I. 25

Ē

APPENDIX F

TRANSMISSION LINE FINANCIAL ANALYSIS

APPENDIX F

TRANSMISSION LINE FINANCIAL ANALYSIS

ANCHORAGE-FAIRBANKS INTERCONNECTION

SEMI-ANNUAL DISBURSEMENTS

FOR

TRANSMISSION INTERTIE FACILITIES

(TLFAP)

1979

BASE-LINE

AND

ESCALATED

COSTS

| | | | UNINFLATED 1979 LEVEL COSTS | | | | | | | | | | |
|--------|------------|-----------------------------|-----------------------------|-----------|------------|----------|--------|--------|-------|--|--|--|--|
| | LINE
NÜ | | 1981-1 | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TUTAL | | | | |
| | 102.0 | 1. TRANSMISSIUN LINE | | | | | | | | | | | |
| | 104.0 | ENGINEERING AND CONSTRUCTI | ÚN . | | | | | | | | | | |
| | 105.0 | SUPERVISION | • 452 | 153 | 0 | 392 | 643 | 123 | 3012 | | | | |
| | 106.0 | RIGHT OF WAY | U | 2209 | 6628 | υ | 0 | U | 8837 | | | | |
| | 108.0 | FOUNDATIONS | U | Û | 0 | 2580 | 6165 | U | 8445 | | | | |
| | 110.0 | TOWERS | 0 | 0 | 0 | 0 | 9727 | 11888 | 21615 | | | | |
| | 112.0 | HARDWARE | 0 | Û | 0 | υ | 12 | 405 | 477 | | | | |
| | 114.0 | INSULATORS | U | U | 0 | Ú | 75 | 428 | 503 | | | | |
| | 116.0 | CONDUCTOR | 0 | 0 | · O | 0 | 1614 | 9147 | 10761 | | | | |
| | 119.0 | | | | | | | | | | | | |
| | 120.0 | SUB-TOTAL | 452 | 2962 | 6628 | 2672 | 18346 | 22591 | 53650 | | | | |
| | 155.0 | | | | | | | | | | | | |
| | 130.0 | 2. SUBSTATIONS | | | | | | | | | | | |
| | 132.0 | ENGINEERING & CONSTRUCTION | | | | | | | | | | | |
| | 133.0 | SUPERVISION | 503 | 503 | 563 | 563 | 282 | 282 | 2816 | | | | |
| | 134.0 | LAND | 81 | U | 0 | 0 | 0 | 0 | 81 | | | | |
| | 136.0 | TRANSFORMERS | 0 | 0 | . 341 | 596 | 596 | 170 | 1703 | | | | |
| | 138.0 | CIRCUIT BREAKERS | 0 | 0 | 391 | 684 | 684 | 195 | 1953 | | | | |
| | 140.0 | STATION EQUIPMENT | 0 | 0 | 269 | 471 | 471 | 135 | 1345 | | | | |
| -11 | 141.0 | STRUCTURES & ACCESSORIES | U | 0 | 805 | 1610 | 1610 | 0 | 4026 | | | | |
| | 145.0 | | | ********* | | | | | | | | | |
| • | 146.0 | SUB-TUTAL | 644 | 563 | 2369 | 3924 | 3642 | 782 | 11924 | | | | |
| \sim | 149.0 | | | | | | | | | | | | |
| | 150.0 | 3. CONTROL AND COMMUNICATIO | NS | | | | | | | | | | |
| | 152.0 | ENGINEERING AND INSTALLATI | 0 N | | | | | | | | | | |
| | 153.0 | SUPERVISION | 0 | 0 | 0 | υ | 71 | 94 | 165 | | | | |
| | 154.0 | EQUIPMENT | 0 | 0 | 0 | 0 | 1254 | 1881 | 3135 | | | | |
| | 156.0 | | | | | ******** | | | | | | | |
| | 158.0 | SUB-TUTAL | Û | U | 0 | 0 | 1325 | 1975 | 3300 | | | | |
| | 160.0 | | | | | | | | | | | | |
| | 162.0 | TOTAL | 1096 | 3525 | 8996 | 6596 | 23313 | 25348 | 68874 | | | | |
| | 164.0 | | | | | | | | | | | | |
| | 166.0 | TOTAL FOR YEAR | 0 | 4621 | . 0 | 15592 | 0 | 48661 | 68874 | | | | |

ANCHURAGE - FAIRMANKS INTERCUNNECTION SEMI-ANNUAL DISHURSEMENTS FOR TRANSMISSION TUTERTIE FACTUATIES

24 APRIL 79

•

| 24 APRIL 79 | | ANCHORAGE - FAIRBANKS INTERCONNECTION | | | | | | | | | | |
|--------------------|----------------------|---------------------------------------|-----------|------------|-------------------|------------|------------|-------|--|--|--|--|
| | SEMI | -ANNUAL | DISBURSE | MENTS FUR | IRANSMISSI | ON INTERTI | E FACILITI | ËS | | | | |
| | | | CUSIS | INFLATED F | ROM 1979 B | ASELINE | | | | | | |
| LINE
NO | 19 | 81-1 | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TOTAL | | | | |
| 173 A 1 TOANSMI | ISSTON I THE | | | | | | | | | | | |
| 172.0 I. TRANSMI | TANGTO SUPPOV | 452 | 783 | 0 | 440 | 810 | ж79 | 1205 | | | | |
| 176 0 RIGHT OF | WAY | 0 | 2298 | 7169 | 0 | 0 | 0 | 9466 | | | | |
| 178.0 FOUNDAD1 | INS | Ŭ | 0 | U U | 2565 | 7212 | õ | 9777 | | | | |
| 180.0 IOWERS | | 0 | ů | õ | 0 | 113/9 | 14464 | 25843 | | | | |
| 182.0 HARDWARE | | õ | 0 | Ű | Ŭ | 84 | 493 | 577 | | | | |
| 184-0 INSULATO | ₹S | õ | õ | Ŭ | Ŭ | 88 | 520 | 608 | | | | |
| 186.0 CONDUCTO | 2 | Ű | 0 | 0 | Ő | 1888 | 11129 | 13017 | | | | |
| 189.0 | | | | | | ******** | | | | | | |
| 190.0 SUB-IC | TAL | 452 | 3081 | 7169 | 3005 | 21462 | 27485 | 62653 | | | | |
| 191.0 | | | | | | | | | | | | |
| 200.0 2. SUBSTA | IONS | | | | | | | | | | | |
| 202.0 ENGRG & (| CUNST. SUPERV. | 563 | 586 | 609 | 634 | 329 | 343 | 3064 | | | | |
| 204.0 LAND | | 81 | 0 | 0 | 0 | 0 | 0 | 81 | | | | |
| 206.0 TRANSFOR: | 1ERS | Û | 0 | 368 | 670 | 697 | 207 | 1943 | | | | |
| 208.0 CIRCUIT | REAKERS | 0 | Ú | 422 | 769 | 800 | 238 | 2229 | | | | |
| 210.0 STATION | EQUIPMENT | 0 | Ű | 291 | 530 | 551 | 164 | 1535 | | | | |
| 211.0 STRUCTUR | ES & ACCESSORIES | 0 | 0 | 871 | 1811 | 1884 | 0 | 4566 | | | | |
| 215.0 | | | | | | | | | | | | |
| 216.0 SUBTO | TAL | 644 | 586 | 2562 | 4414 | 4261 | 951 | 13418 | | | | |
| | | | | | | | | | | | | |
| 1 218.0 3. CONTROL | _ AND COMMUNICATIONS | | | | | | | | | | | |
| 219.0 ENGINEER | ING AND INSTALLATION | _ | | | | | | | | | | |
| ~ 220.0 SUPERVIS | SIUN | 0 | 0 | U | 0 | 83 | 114 | 197 | | | | |
| 222.0 EQUIPMEN | | 0 | 0 | 0 | 0 | 1467 | 2289 | 3/56 | | | | |
| 224.0 | ***** | · | | | | | | | | | | |
| 226.0 SUB-TO |)TAL | 0 | U | Û | 0 | 1550 | 2405 | 3953 | | | | |
| 0.855 | | | • • • • • | 0770 | 7410 | | 70070 | 40034 | | | | |
| 230.0 IUIAL | | 1095 | 3600 | 9730 | 7419 | 21213 | 20924 | 80024 | | | | |
| 232.0 | | | | | | | | | | | | |
| 254.0 SUMMARY O | PRICE ESCALATION | | | 77. | 0.7." | 7040 | E #03 | | | | | |
| 235.0 AT 8.0% I | A | U | 141 | 154 | 824 | 2400 | 5472 | 11120 | | | | |

ANCHORAGE-FAIRBANKS INTERCONNECTION

FINANCIAL PLAN A

BASE-CASE

(TLFAP)

70% REA LOAN AT 5% INTEREST RATE 30% MUNICIPAL BONDS AT 7.5% BONDING RATE 100% COMBINED SOURCES AT 5.7% COMPOSITE RATE

F - 4

| 24 APRIL 79 | | ANCHORA
INT | IGE - FAIRE
FUNDING
EREST DURI | BANKS INTER
Sources An
Ing Cunstru | CONNECTION
ID
ICTION | ٩ | |
|------------------------------------|--------|----------------|--------------------------------------|--|----------------------------|--------|-------|
| LINE
NO | 1981-1 | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TUTAL |
| 400.0 FUNDING SOURCES | | | | | | | |
| 401.0 APA BONDS | 0 | 0 | 0 | 0 | Û | 0 | 0 |
| 402.0 REA LOANS | 767 | 2567 | 6811 | 5193 | 19091 | 21588 | 56017 |
| 403.0 CFC LOANS | 0 | Û | . 0 | 0 | 0 | 0 | 0 |
| 404.0 FFB-LOANS | U | 0 | Ű | 0 | 0 | υ | 0 |
| 405.0 AMU BONUS | 164 | 550 | 1460 | 1113 | 4091 | 4626 | 12004 |
| 406.0 FMU BONDS | 164 | 550 | 1460 | 1113 | 4091 | 4626 | 12004 |
| 408.0 | | | | | | | |
| 409.0 TUTAL | 1096 | 3666 | 9730 | 7419 | 27273 | 30839 | 80024 |
| 410.0 | | | | | | | |
| 411.0 INTEREST DURING CONSTRUCTION | ÛN | | | | | | |
| 412.0 APA BONDS | υ | 0 | 0 | Û | 0 | 0 | 0 |
| 413.0 REA LOANS | U | 19 | 83 | 254 | 383 | 861 | 1600 |
| 414.0 CFC LOANS | 0 | 0 | 0 | 0 | Û | 0 | 0 |
| 415.0 FFB LUANS | 0 | 0 | 0 | 0 | 0 | U | 0 |
| 416.0 AMU BONDS | 0 | 6 | 27 | 83 | 128 | 286 | 529 |
| 417.0 FMU BONDS | Ű | 6 | 27 | 83 | 128 | 286 | 529 |
| 420.0 | | | | | | | |
| 421.0 TOTAL | 0 | 32 | 137 | 419 | 639 | 1432 | 2659 |
| 422 0 | _ | | | | | | |

Ч

ł

σī

| 24 APRIL 79 | ANCHORAGE - FAIRBANKS INTERCONNECTION
DEBT TABLE AND
CUMPOSITE INTEREST RATE | | | | | | | | | | |
|------------------------------|--|----------|--------|--------|--------|--------|---------|--|--|--|--|
| LINE
NO | 1981-1 | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TUTAL | | | | |
| 430.0 % DEBT ASSUMED BY EACH | UTILITY | | | | | | | | | | |
| 432.0 AML & P | 15.00 | 0.0 | υ.Ο | 0.0 | 0.0 | 0.0 | 15.00 | | | | |
| 434.0 CEA | 30.00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 30.00 | | | | |
| 436.0 MEA | 5.00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 3.00 | | | | |
| 438.0 HEA | 1.00 | 0.0 | 0.0 | U. O | 0.0 | 0.0 | 1.00 | | | | |
| 442.0 FMUS | 15.00 | 0.0 | 0.0 | U.O | 0.0 | 0.0 | 15.00 | | | | |
| 444.0 GVEA | 36.00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 36.00 | | | | |
| 446.0 CVEA | 0.0 | U.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | | | | |
| 447.0 | | | | | | | | | | | |
| 448.0 | | | | | | | | | | | |
| 449.0 | | | | | | | | | | | |
| 450.0 DEBT ASSUMED BY EACH U | TILITY | | | | | | | | | | |
| 452.0 AML & P | 164 | 550 | 1460 | 1113 | 4091 | 4626 | 12004 | | | | |
| 454.0 CEA | 329 | 1100 | 2919 | 5556 | 8182 | 9252 | 24007 | | | | |
| 456.0 MEA | 33 | 110 | 292 | 223 | 818 | 925 | 2401 | | | | |
| 458.0 HEA | 11 | 37 | 97 | 74 | 273 | 308 | 800 | | | | |
| 462.0 FMUS | 164 | 550 | 1460 | 1113 | 4091 | 4626 | 12004 | | | | |
| 464.0 GVEA | 395 | 1320 | 3503 | 2671 | 9818 | 11102 | 28809 | | | | |
| 466.0 CVEA | 0 | 0 | Û | 0 | 0 | 0 | 0 | | | | |
| 468.0 | | ******** | | | | | ******* | | | | |
| 470.0 TOTAL DEBI | 1096 | 3666 | 9730 | 7419 | 27273 | 30839 | 80024 | | | | |
| 472.0 | | | | | | | | | | | |
| 474.0 | | | | | | | | | | | |
| 476.0 | | | | | | | | | | | |
| 500.0 COMPOSITE INTEREST RAT | E CALCULATIONS | | | | | | | | | | |
| 501.0 APA BUNDS | . 0 | 0 | 0 | 0 | Û | 0 | 0 | | | | |
| 502.0 REA LUANS | 2801 | 0 | 0 | 0 | U | 0 | 2801 | | | | |
| 503.0 CFC LUANS | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | | | |
| 504.0 FFB LOANS | 0 | 0 | 0 | 0 | Û | 0 | 0 | | | | |
| 505.0 AMU BONDS | 900 | 0 | 0 | 0 | Û | 0 | 900 | | | | |
| 506.0 FMU BONDS | 900 | 0 | 0 | Q | U | 0 | 900 | | | | |
| 508.0 | | | | | | | | | | | |
| 510.0 COMPOSITE RATE | 0.057 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.057 | | | | |

δ

| z <u>s t t t</u> | | |
|------------------|--|--|
| | | |

| | | | | | DEBT SF | WICE SCH | EDULE | | | | | | |
|------------|---------------------|---------|-------|-----------|---------|----------|-------|--------|---------|-------|-------------|-----------------|---------|
| LINE
NU | | 1984 | 1985 | 1986 | 1987 | 1988 | 1989 | 1990 | 1991 | 1992 | 1993 | 1994 | 1995 |
| 152.0 | APA | | | | | | | | | | | | |
| 154.0 | SINKING FUND | 0 | Ú | v | 0 | U | 0 | U | U | 0 | 0 | 0 | 0 |
| 156.0 | INTEREST DUE | U | 0 | 0 | 0 | 0 | 0 | 0 | 0 | Û | 0 | 0 | 0 |
| 158.0 | ••• | | | - | | | | | | | ••••••••••• | ·•============= | ····· |
| 160.0 | S.FUND+INTEREST | U | v | 0 | U | v | Ū | 0 | Ū | v | v | v | v |
| 166.0 | REA | | | | | | | | | | | | |
| 168.0 | REPAYMENT | 1600 | 1600 | 1600 | 1600 | 1600 | 1600 | 1600 | 1600 | 1600 | 1600 | 1600 | 1600 |
| 171.0 | OUTSIANDING | 54416 | 52816 | 51216 | 49615 | 48015 | 46414 | 44814 | 43213 | 41613 | 40012 | 38412 | 36811 |
| 172.0 | INTEREST DUE | 2801 | 2721 | 2641 | 2561 | 2481 | 2401 | 2321 | 2241 | 2161 | 2081 | 2001 | 1921 |
| 174.0 | | | | | | | | | | | | | |
| 176.0 | DEBT SERVICE | 4401 | 4321 | 4241 | 4161 | 4081 | 4001 | 3921 | 3841 | 3761 | 3681 | 3601 | 3521 |
| 177.0 | 656 | | | | | | | | | | | | |
| 182.0 | DEDAVMENT | A | 0 | 0 | 0 | ٥ | 0 | 0 | 0 | • | • | 0 | 0 |
| 187 0 | OUTSTANDING | 0 | . 0 | ů | | 0 | | | 0 | 0 | | Ň | v |
| 188.0 | INTEREST | | ő | ŏ | ů | õ | ŏ | ŏ | ő | ő | ŏ | ŏ | 0 |
| 190.0 | | | | | | | | | | | | | |
| 192.0 | DEBT SERVICE | Û | U | 0 | U | U | 0 | 0 | 0 | Û | 0 | 0 | Û |
| 193.0 | | | | | | | | | | | | | |
| 198.0 | FFB | | | | | | | | | | | | |
| | REPAYMENT | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 1 202.0 | OUTSTANDING | 0 | 0 | 0 | U | Û | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ~ 204.0 | S FUNDATNTEDEST | | | | | | · | · | | | | | |
| 207.0 | S.FORD TRIEREST | v | v | v | v | v | v | v | v | v | v | v | v |
| 212-0 | AMU | | | | | | | | | | | | |
| 214.0 | SINKING FUND | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 |
| 216.0 | INTEREST DUE | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 |
| 218.0 | | | | | | | | | ******* | | | | ******* |
| 220.0 | S.FUND+INTEREST | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 |
| 221.0 | | | | | | | | | | | | | |
| 228.0 | FMU | | | | | | | | | | | | |
| 230.0 | SINKING FUND | 81 | 81 | 81 | 81 | 61 | 81 | 81 | 81 | 81 | 81 | 81 | 81 |
| 232.0 | INTEREST DUE | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 |
| 236.0 | S EUND+INTEREST | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 |
| 250.0 | TOTAL REPAYMENTS OR | IVEI | 1.451 | | 1461 | | | 1.45.1 | 1.5 | 1.461 | | | |
| 251.0 | S. FUND PAYMENTS | 1763 | 1763 | 1763 | 1763 | 1763 | 1763 | 1763 | 1763 | 1763 | 1763 | 1763 | 1763 |
| 253.0 | TOT INTEREST DUE | 4681 | 4601 | 4521 | 4441 | 4361 | 4281 | 4201 | 4121 | 4041 | 3961 | 3881 | 3801 |
| 255.0 | | | | | | | | | | | ******** | | |
| 257.0 | TOTAL DEBT SERVI | 6444 | 6364 | 6284 | 6204 | 6124 | 6044 | 5964 | 5884 | 5804 | 5724 | 5644 | 5564 |

24 APRIL 79 ANCHURAGE - FAIRBANKS INTERCONNECTION DEBT SERVICE SCHEDULE

| ĩ | 7 | 1 | 1 | ě. | 2 | k | 2 | 2 | 8 | 2 | 1 | 1 | ì | 1 |) | ŧ | ł. |
|---|---|---|---|----|----|---|---|---|---|---|---|---|---|---|---|---|----|
| | , | | ĸ | • | ¥. | 8 | , | , | 1 | ¥ | 1 | Ŧ | î | | 1 | 1 | ş |

ANCHORAGE - FAIRBANKS INTERCONNECTION

| 24 | APRIL 79 | | | ANCHOR | | | | | | | | | |
|-------|--------------------------------------|---------|--------|--------|--------|--------|---------|---------|-------|---------|-------|-------|---------|
| L | INE | 1996 | 1947 | 1998 | 1999 | 2000 | 2001 | 2005 | 2003 | 2004 | 2005 | 2006 | 2007 |
| 15 | 2.0 APA | | | | | 6 | | | | | | | |
| 15/ | 4.0 SINKING FUND
6.0 INTEREST DUE | U
0 | 0
U | U
U | U
U | U
U | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 15 | 8.0 | | | | · | | | | · | | | | |
| 16 | 1.0 | 0 | U | U | v | | v | v | U | v | v | Ŭ | v |
| 16 | 6.0 REA | 1400 | 1400 | 1400 | 1600 | 1500 | 1600 | 1600 | 1600 | 1600 | 1600 | 1600 | 1400 |
| 10 | 1.0 OUTSTANDING | 35211 | 33610 | 32010 | 30409 | 28809 | 27208 | 25608 | 24007 | 22407 | 20806 | 19206 | 17605 |
| 17 | 2.0 INTEREST DUE | 1841 | 1761 | 1681 | 1600 | 1520 | 1440 | 1360 | 1280 | 1200 | 1120 | 1040 | 960 |
| 17 | 4.0
6.0 DENT SERVICE | 3441 | 3361 | 3281 | 3201 | 3121 | 3041 | 2961 | 2881 | 2801 | 2721 | 2641 | 2561 |
| 17 | 7.0 | | | | | | | | | | | | |
| 18 | 2.0 CFC
4.0 REPAYMENT | U | 0 | 0 | U | 0 | Û | 0 | 0 | 0 | 0 | 0 | 0 |
| 18 | 7.0 OUTSTANDING | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 18 | B.O INTEREST | 0 | 0 | 0 | 0 | 0 | 0
 | 0 | U
 | 0 | 0 | . 0 | 0 |
| 19 | 2.0 DEBT SERVICE | V | U | 0 | U U | 0 | 0 | 0 | Û | 0 | 0 | 0 | 0 |
| 19 | 3.0
8.0 FF8 | | | | | | | | | | | | |
| -1 20 | 0.0 REPAYMENT | 0 | Û | U | 0 | Û | 0 | U | 0 | 0 | 0 | 0 | 0 |
| 1 20 | 2.0 OUTSTANDING | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ∞ 20 | 6.0 S.FUND+INTEREST | 0 | Ŷ | 0 | 0 | Ű | U | 0 | 0 | 0 | 0 | 0 | 0 |
| 21 | 2.0 AMU | | | | | | | | | | | | |
| 21 | 4.0 SINKING FUND | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 |
| 210 | B.U INTEREST DUE
B.U | 940
 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 740 |
| 22 | 0.0 S.FUND+INTEREST | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1051 | 1021 | 1021 |
| 22 | 1.0
8.0 FMU | | | | | | | | | | | | |
| 23 | 0.0 SINKING FUND | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 |
| 23 | 2.0 INTEREST DUE | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 |
| 23 | 6.0 S.FUND+INTEREST | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 |
| 25 | 0.0 TOTAL REPAYMENTS OR | | | | | | . 7 / 7 | . 7 . 7 | 1747 | . 7 / 7 | | | . 7 4 7 |
| 25 | 3.0 TOT INTEREST DUE | 3721 | 3640 | 3560 | 1765 | 1/05 | 3320 | 3240 | 3160 | 3080 | 3000 | 2920 | 2840 |
| 25 | 5.0 | | | | | | | | | | | | |
| 25 | 7.0 TOTAL OFBT SERVE | 5483 | 5463 | 5323 | 5243 | 5163 | 5083 | 5003 | 4925 | 4843 | 4763 | 4683 | 4603 |
| - | | | | | DEBT SE | RVICE SCH | EUULE | | | | | |
|-----------|-----------------------|-------|-------|----------|---------|-----------|-----------|----------|----------|-------|--------|------------------|
| LIN
NO | E | 5008 | 2009 | 2010 | 2011 | 2012 | 2015 | 2014 | 2015 | 2016 | 2017 | 2018 |
| 152. | 0 APA | | | | | | | | | | | |
| 154. | U SINKING FUND | 0 | U | U | 0 | 0 | U | 0 | 0 | 0 | 0 | 0 |
| 156. | D INTEREST DUE | v | U | U | 0 | U | | U | U | U | U | 0 |
| 150. | U S.FUND+INTEREST | 0 | | | 0
0 | 0 | | <u>د</u> | 0 | 0 | | 0 |
| 161 | 0 | · · | Ū | v | v | • | • | • | • | • | • | • |
| 166. | 0 REA | | | | | | | | | | | |
| 168. | 0 REPAYMENT | 1600 | 1600 | 1600 | 1600 | 1600 | 1600 | 1600 | 1600 | 1600 | 1600 | 1600 |
| 171. | 0 UUTSTANDING | 16005 | 14404 | 12804 | 11203 | 4603 | 8002 | 6402 | 4801 | 3201 | 1600 | 0 |
| 172. | O INTEREST DUE | 880 | 800 | 720 | 640 | 560 | 480 | 400 | 320 | 240 | 160 | 80 |
| 174 | | | | ******* | | | | | | | | |
| 177 | DEBI SERVICE | 2481 | 2401 | 2321 | 2241 | 2101 | 2001 | 2001 | 1921 | 1041 | 1761 | 1001 |
| 182 | 0 CEC | | | | | | | | | | | |
| 184 | 0 REPAYMENT | 0 | 0 | 0 | Û | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 187 | 0 OUTSTANDING | ů | ŏ | ŏ | ŏ | Ō | ŏ | õ | ō | ŏ | ŏ | ŏ |
| 188. | 0 INTEREST | 0 | Ő | 0 | 0 | 0 | 0 | Û | 0 | 0 | 0 | 0 |
| 190. | 0 | | | ******** | | | ********* | | | | | ****** |
| 192. | DEBT SERVICE | 0 | 0 | 0 | 0 | Ŭ | O | 0 | 0 | 0 | 0 | 0 |
| 193.0 | | | | | | | | | | | | |
| 198.0 | U FFB | 0 | • | 0 | 0 | 0 | 0 | 0 | • | • | • | 0 |
| 202 | | 0 | 0 | 0
() | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 204.0 | 0 | | | | | | | | | | | |
| 206. | S.FUND+INTEREST | Ú | O | 0 | 0 | 0 | U | 0 | 0 | 0 | 0 | 0 |
| 207.0 | 0 | | | | | | | | | | | |
| 212. | D AMU | | | | | | | | | | | |
| 214. | 0 SINKING FUND | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 |
| 216.0 | D INTEREST DUE | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | Q | 0 | 0 |
| 220 | | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | | | 84 888 88 |
| 221 | | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 01 | 01 | 01 |
| 228.0 | 0 FMU | | | | | | | | | | | |
| 230. | O SINKING FUND | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 | 81 |
| 232. | D INTEREST DUE | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 | 940 |
| 234.0 | 0 | | | | | | | | ******** | | | |
| 236. | D S.FUND+INTEREST | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 | 1021 - | 1021 |
| 250.0 | D TOTAL REPAYMENTS OR | | | | | | | | | | | |
| 251.0 | D S. FUND PAYMENTS | 1763 | 1763 | 1763 | 1763 | 1763 | 1763 | 1/63 | 1763 | 1763 | 1763 | 1763 |
| 255 | D TUT INTEREST DUE | 2/60 | 2680 | 2000 | 2520 | 2440 | 2360 | 2280 | 2200 | 1180 | 1100 | 1020 |
| 257 | TOTAL DEBT SERVI | 4501 | | | // 281 | 4203 | | | 1961 | 20/13 | 2863 | 2787 |

ANCHORAGE - FAIRBANKS INTERCONNECTION

24 APRIL 79

| | 24 APRIL 79 | | | ANCHOR
DEB | AGE - FAI
T REPAYME
Allucat | RBANKS IN
NT AND SI
TON BY UT | ITERCUNNEC
NKING FUN
ILITY | :110n
10 | | | | | |
|--------|--|-----------------------------|------------------------------|------------------------------|-----------------------------------|-------------------------------------|----------------------------------|------------------------------|------------------------------|------------------------------|------------------------------|------------------------------|------------------------------|
| | L INE
NU | 1984 | 1985 | 1986 | 1987 | 1489 | 1989 | 1440 | 1991 | 1992 | 1993 | 1994 | 1995 |
| | 352.0 AML & P
354.0 REPAYMENT AMOUNT
358.0 OUTSTANDING
360.0 INTEREST DUE
361.0 | 264
8991
702 | 264
8727
690 | 264
8462
618 | 264
8198
666 | 264
7433
654 | 264
7669
642 | 26 <u>4</u>
7405
630 | 264
7140
618 | 264
6876
606 | 264
6611
594 | 264
6347
582 | 264
6082
570 |
| | 362.0 CEA
364.0 REPAYMENT AMOUNT
368.0 OUISTANDING
370.0 INTEREST DUE
371.0 | 529
17982
1404 | 529
17454
1380 | 529
16925
1356 | 529
16396
1332 - | 529
15867
1308 | 529
15338
1284 | 529
14809
1260 | 529
14280
1236 | 529
13751
1212 | 529
13222
1168 | 529
12693
1164 | 529
12165
1140 |
| | 372.0 MEA
374.0 REPAYMENT AMOUNT
378.0 DUTSFANDING
380.0 INTEREST DUE
381.0 | 53
1798
140 | 53
1745
138 | 53
1692
136 | 53
1640
133 | 53
1587
131 | 53
1534
128 | 53
1481
126 | 53
1428
124 | 53
1375
121 | 53
1322
119 | 53
1269
116 | 53
1216
114 |
| | 382.0 MEA
384.0 REPAYMENT AMOUNT
388.0 OUTSTANDING
390.0 INTEREST DUE
391.0 | 18
599
47 | 18
582
46 | 18
564
45 | . 18
547
44 | 18
524
44 | 18
511
43 | 18
494
42 | 18
476
41 | 18
458
40 | 18
44 1
40 | 18
423
39 | 18
405
38 |
| F - 10 | 402.0 FMUS
404.0 REPAYMENT AMOUNT
408.0 OUTSTANDING
410.0 INFEREST DUE
411.0 | 264
8991
702 | 264
8727
690 | 264
8462
678 | 264
8198
666 | 264
7933
654 | 264
7669
642 | 264
7405
630 | 264
7140
618 | 264
6876
606 | 264
6611
594 | 264
6347
582 | 264
6082
570 |
| | 412.0 GVEA
414.0 REPAYMENT AMOUNT
416.0 CUMULATIVE
418.0 OUTSTANDING
420.0 INTEREST DUE
421.0 | 635
635
21579
1685 | 635
1269
20944
1656 | 635
1904
20310
1627 | 635
2539
19675
1599 | 635
3173
19040
1570 | 635
3808
18406
1541 | 635
4443
17771
1512 | 635
5077
17136
1483 | 635
5712
16502
1455 | 635
6347
15867
1426 | 635
6981
15232
1397 | 635
7616
14598
1368 |
| | 422.0 CVEA
424.0 REPAYMENT AMOUNT
426.0 CUMULATIVE
428.0 OUTSTANDING
430.0 INTEREST DUE | 0
0
0
0 | U
0
0
0 | 0
0
0
0 | 0
0
0
0 | 0
0
0
0 | 0
0
0 | 0
0
0
0 | 0
0
0 | 0
0
0
0 | 0
0
0
0 | 0
0
0
0 | 0
0
0 |

| 24 APRIL 79 | | | ANCHOR
DEB | AGE - FAI
T REPAYME
ALLUCAT | RUANKS IN
NI AND SI
IUN NY UT | TERCONNEC
NKING FUN
ILITY | TIUN
D | | | | | |
|------------------------|-------|-------|---------------|-----------------------------------|-------------------------------------|---------------------------------|-----------|-------|-------|----------|-------|------------|
| LINE
NO | 1990 | 1997 | 1998 | 1999 | 2000 | 2001 | 2005 | 2003 | 2004 | 2005 | 2006 | 2007 |
| 352.0 AML & P | | | | | | | | | 24.4 | . | 5.4 | 7/ // |
| 354.0 REPAYMENT AMOUNT | 264 | 204 | 264 | 204 | 264 | 264 | 264 | 264 | 264 | 264 | 204 | 204 |
| 358.0 OUTSTANDING | 5818 | 5553 | 5289 | 5025 | 4760 | 4496 | 4231 | 5967 | 3702 | 5458 | 51/5 | 2909 |
| 360.0 INTEREST DUE | 558 | 546 | 534 | 522 | 510 | 498 | 486 | 4/4 | 462 | 450 | 430 | 420 |
| 361.0 | | | | | | | | | | | | |
| 362.0 CEA | | | | | | | · | c 2.0 | 5.20 | r 20 | E 20 | 5 20 |
| 364.0 REPAYMENT AMOUNT | 529 | 529 | 529 | 529 | 529 | 529 | 529 | 529 | 529 | 529 | 529 | 527 |
| 368.0 OUISTANDING | 11636 | 11107 | 10578 | 10049 | 9520 | 8991 | 8462 | 1935 | /405 | 6876 | 0347 | 2010 |
| 370.0 INTEREST DUE | 1116 | 1092 | 1068 | 1044 | 1020 | 996 | 972 | 948 | 924 | 900 | 8/0 | 852 |
| 371.0 | | | | | | | | | | | | |
| 372.0 MEA | | | | | | | | | | | F 7 | F 7 |
| 374.0 REPAYMENT AMOUNT | 53 | 53 | 53 | 53 | 53 | 55 | 53 | 22 | | 22 | 22 | 22 |
| 378.0 OUTSTANDING | 1164 | 1111 | 1058 | 1005 | 952 | 899 | 846 | /93 | 740 | 000 | 520 | 202 |
| 380.0 INTEREST DUE | 112 | 109 | 107 | 104 | 102 | 100 | 97 | 95 | . 92 | 90 | 00 | 60 |
| 381.0 | | | | | | | | | | | | |
| 382.0 HEA | | | | | | | | | | | | |
| 384.0 REPAYMENT AMOUNT | 18 | 18 | 18 | - 18 | 18 | 18 | 18 | 18 | 18 | 18 | 10 | 10 |
| 388.0 OUTSTANDING | 388 | 370 | 353 | 335 | 317 | 300 | 282 | 264 | 241 | 229 | 212 | 194 |
| 390.0 INTEREST DUE | 37 | 36 | 36 | 35 | 34 | 33 | 32 | 32 | 31 | 30 | 29 | 20 |
| 391.0 | | | | | | | | | | | | |
| 1 402.0 FMUS | | | | | | • · · | | | | 24.6 | 744 | 24.11 |
| 404.0 REPAYMENT AMOUNT | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 204 |
| 408.0 OUTSIANDING | 5818 | 5553 | 5289 | 5025 | 4760 | 4496 | 4231 | 3967 | 5702 | 5458 | 5175 | 2909 |
| 410.0 INTEREST DUE | 558 | 546 | 534 | 522 | 510 | 498 | 486 | 474 | 462 | 450 | 438 | 420 |
| 411.0 | | | | | | | | | | | | |
| 412.0 GVEA | | | | | | | | | | | (76 | 475 |
| 414.0 REPAYMENT AMOUNT | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 |
| 416.0 CUMULATIVE | 8251 | 8885 | 9520 | 10155 | 10789 | 11424 | 12059 | 12693 | 13328 | 13963 | 14598 | 15232 |
| 418.0 OUTSTANDING | 13963 | 13328 | 12693 | 12059 | 11424 | 10789 | 10155 | 9520 | 8885 | 8251 | /616 | 6901 |
| 420.0 INTEREST DUE | 1339 | 1311 | 1282 | 1253 | 1224 | 1195 | 1167 | 1138 | 1109 | 1080 | 1051 | 1022 |
| 421.0 | | | | | | | | | | | | |
| 422.0 CVEA | | | | | | | | | | | | - |
| 424.0 REPAYMENT ANOUNT | Ű | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 426.0 CUMULATIVE | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 428.0 OUTSTANDING | 0 | 0 | U | 0 | 0 | Û | Û | 0 | 0 | 0 | 0 | 0 |
| 430.0 INTEREST DUE | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

| i e | a (| | • | | | | | - | | | | | |
|-------|-----|-----|---|---|---|---|-------|-----|--|-----|---|-----|--|
| | , | 1 1 | 1 | | ž | 1 |
1 | 8 1 | | t . | | , \ | |
|
* | * | | | • | • | |
 | | | | | | |
| | | | | | | | | | | • | 4 | | |

1 income

24 APRIL 79

ANCHORAGE - FAIRBANKS INTERCONNECTION DEBT REPAYMENT AND SINKING FUND ALLUCATION BY UTILITY

| LIN | Ε | 2008 | 2009 | 2010 | 2011 | 2015 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 |
|--------|--------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| NÜ | | | | | | | | | | | | |
| 352. | O AML & P | | | | | | | | | | • | |
| 354. | 0 REPAYMENT AMOUNT | 264 | 264 | 264 | 264 | 264 | 264 | 204 | 264 | 264 | 264 | 264 |
| 358. | 0 UUTSTANDING | 2644 | 2360 | 2116 | 1851 | 1587 | 1322 | 1058 | 793 | 529 | 264 | 0 |
| 360. | 0 INTEREST DUE | 414 | 402 | 390 | 378 | 366 | 354 | 342 | 330 | 177 | 165 | 153 |
| 361. | 0 | | | | | | | | | | | |
| 362. | 0 CEA | | | | | | | | | | | |
| 364. | 0 REPAYMENT AMOUNT | 529 | 529 | 529 | 529 | 529 | 529 | 529 | 529 | 529 | 529 | 529 |
| 368. | 0 OUISIANDING | 5289 | 4760 | 4231 | 3702 | 3173 | 2644 | 2116 | 1587 | 1058 | 529 | 0 |
| 370. | O INTEREST DUE | 828 | 804 | 780 | 750 | 732 | 708 | 684 | 660 | 354 | 330 | 306 |
| 371. | Ü | | | | | | | | | | | |
| 372. | 0 MEA | | | | | | | | | | | |
| 374.0 | U REPAYMENT AMOUNT | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 |
| 378. | 0 OUISTANDING | 529 | 470 | 423 | 370 | 317 | 264 | 212 | 159 | 106 | 53 | 0 |
| 380. | D INTEREST DUE | 83 | 80 | 78 | 76 | 73 | 71 | 68 | 66 | 35 | 33 | - 31 |
| 381.0 | 0 | | | | | | | | | | | |
| 382. | 0 HEA | | | | | | | | | | | |
| 384. | 0 REPAYMENT AMOUNT | 18 | 18 | 18 | - 18 | 18 | 18 | 18 | 18 | 18 | 18 | 18 |
| 388. | 0 OUTSTANDING | 176 | 159 | 141 | 123 | 106 | 88 | 71 | 53 | 35 | 18 | 0 |
| 390. | O INTEREST DUE | 28 | 27 | 26 | 25 | 24 | 24 | 23 | 22 | 12. | 11 | 10 |
| 391.0 | 0 | | | | | | | | | | | |
| 402. | 0 FMUS | | | | | | | | | | | |
| 404. | 0 REPAYMENT AMOUNT | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 | 264 |
| µ 408. | 0 OUISTANDING | 2644 | 2380 | 2116 | 1,851 | 1587 | 1322 | 1058 | 793 | 529 | 264 | 0 |
| № 410. | 0 INTEREST DUE | 414 | 402 | 390 | 378 | 366 | 354 | 342 | 330 | 177 | 165 | 153 |
| 411. | 0 | | | | | | | | | | | |
| 412. | 0 GVEA | | | | | | | | | | | |
| 414. | O REPAYMENT AMOUNT | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 | 635 |
| 416. | 0 CUMULATIVE | 15867 | 16502 | 17136 | 17771 | 18406 | 19040 | 19675 | 20310 | 20944 | 21579 | 22214 |
| 418. | 0 OUTSTANDING | 6347 | 5712 | 5077 | 4443 | 3808 | 3173 | 2539 | 1904 | 1269 | 635 | 0 |
| 420. | 0 INTEREST DUE | 994 | 965 | 936 | 907 | 878 | 850 | 821 | 792 | 425 | 396 | 367 |
| 421.0 | 0 | | | | | | | | | | | |
| 422. | D CVEA | | | | | | | | | | | |
| 424. | D REPAYMENT AMOUNT | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 426. | D CUMULATIVE | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | U | 0 |
| 428. | D OUTSTANDING | 0 | 0 | 0 | v | 0 | 0 | U | 0 | 0 | 0 | 0 |
| 430.0 | D INTEREST DUE | 0 | 0 | 0 | 0 | Û | 0 | 0 | 0 | 0 | . 0 | 0 |

ANCHORAGE-FAIRBANKS INTERCONNECTION

FINANCIAL COMPARISON

0F

LOAN PACKAGES

(COMPARE)

10/15/5% CFC LOANS AT 8.75% INTEREST RATE

10/5/5% FFB LOANS AT 9.375% INTEREST RATE

| 1 I I | <u>8</u> 8 a | f 3 | ¥ 5 | 3 7 |
1 | |
|-------|--------------|-----|-----|-------|-------|--|
| | 1 1 1 | î î | | 1) 1 | | |

PRESENT VALUE COMPARISON OF CFC/FFB PROPORTIONATE LOAN PACKAGES Basecase: 10% CFC Funds @ 8.75%/10% FFB Funds @ 9.375%

| | | Co | nstr. P | eriod | | | | Year A | mortiza | tion Pe | riod | | |
|-----------------------------------|------------------------|-------------------------|------------|---------------|-----------------|------------|-----------------|------------|------------|------------|------------|------------|------------|
| Year | 0 | 1 | 2 | 3 | • 4 | ٩ | 6 | 7 | 8 | 9 | 10 | 11 | 12 |
| DEBT SERVICE AND F
CFC
FFB | FEES FOR
0
0 | ALL LOANS
73
76 | 156
164 | 453
484 | 929
979 | 909
957 | 889
936 | 869
915 | 849
893 | 829
872 | 809
850 | 789
829 | 769
807 |
| TOTAL | 0 | 149 | 320 | 936 | 1908 | 1866 | 1825 | 1783 | 1742 | 1700 | 1659 | 1618 | 1576 |
| DISCOUNTED VALUE
Present value | 0
16672 | 139
0 | 279
0 | 764
0 | 1455
0 | 1331
0 | 1216
0 | 1111
0 | 1014
0 | 925
0 | 843
0 | 768
0 | 700
0 |
| Year | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 |
| DEBT SERVICE AND S
CFC
FFB | FEES FOR
749
786 | ALL LOANS
729
764 | 709
743 | 689
722 | 669
700 | 649
679 | 629
657 | 609
636 | 589
614 | 569
593 | 549
572 | 529
550 | 509
529 |
| TOTAL | 1535 | 1493 | 1452 | 1410 | 1369 | 1327 | 1286 | 1245 | 1203 | 1162 | 1120 | 1079 | 1037 |
| DISCOUNTED VALUE
PRESENT VALUE | 637
0 | 579
0 | 526
0 | 478
0
• | 433
0 | 393
0 | 356
0 | 322
0 | 291
0 | 0
262 | 236
0 | 213
0 | 191
0 |
| Year | 26 | 27 | 28 | 29 | 30 | 31 | 32 | 33 | 34 | 35 | 36 | 37 | 38 |
| DEBT SERVICE AND F
CFC
FFB | FEES FOR
489
507 | ALL LOANS
469
486 | 449
464 | 429 | 409
422 | 389
400 | 369
379 | 349
357 | 329
336 | 309
314 | 289
293 | 269
271 | 249
250 |
| TOTAL | 996 | 955 | 913 | 872 | 830 | 789 | 747 | 706 | 664 | 623 | 582 | 540 | 499 |
| DISCOUNTED VALUE
Present value | 172
0 | 154
0 | 137
0 | 123 | 109 | 97
0 | 86
0 | 76
0 | 67
0 | 58
0 | 51
0 | 44
0 | 38
0 |

| | | | * | | | | 1 | 3 | 1 | 2 | T | 1 | 1 | ž – | 1 | (| ž |
|----|-----|---|---|---|---|-----|---|---|---|---|---|---|---|-----|---|----|---|
| 2 | i i | ř | ĩ | Ť | Ť | É . | à | • | 1 | f | ŝ | 1 | P | ; | 5 | \$ | ÷ |
| Į. | 1 | 5 | 2 | | | | • | x | • | • | • | | - | | | | |

PRESENT VALUE COMPARISON OF CFC/FFB PROPORTIONATE LOAN PACKAGES Sub-Case 1: 15% CFC Funds @ 8.75%/5% FFB Funds @ 9.375%

14446

| Year | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 |
|------------------------------------|-------------------------|--------------------------|-------------|---------------------|-------------|-------------|-------------|-------------|-------------|-------------|------------------------|-------------|------------|
| DEBT SERVICE AND CFC
FFB | FEES FOR
0
0 | ALL LOANS
110
38 | 233
82 | 679
242 | 1393
489 | 1363
479 | 1333
468 | 1303
457 | 1273
447 | 1243
436 | 1213
425 | 1183
414 | 1153 |
| TOTAL | 0 | 147 | 315 | 921 | 1883 | 1842 | 1801 | 1760 | 1720 | 1679 | 1638 | 1598 | 1557 |
| DISCOUNTED VALUE
Present value | 0
16470 | 138
0 | 276
0 | 752
0 | 1436
0 | 1313
0 | 1200
0 | 1096
0 | 1001
0 | 913
0 | 833
0 | 759
0 | 691
0 |
| Year | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 |
| DEBT SERVICE AND F
CFC
FFB | FEES FOR
1123
393 | ALL LOANS
1093
382 | 1063
372 | 10 33
361 | 1003
350 | 973
339 | 943
329 | 913
318 | 883
307 | 853
297 | 8 23
286 | 793
275 | 763
264 |
| TOTAL | 1516 | 1475 | 1435 | 1394 | 1353 | 1312 | 1272 | 1231 | 1190 | 1150 | 1109 | 1068 | 1027 |
| DISCOUNTED VALUE
PRESENT VALUE | 629
0 | 572
0 | 520
0 | 472
0 | 428
0 | 388
0 | 352
0 | 318
0 | 287
0 | 259
0 | 234
0 | 211 | 189
0 |
| Year | 26 | 27 | 28 | 29 | 30 | 31 | 32 | 33 | 34 | 35 | 36 | 37 | 38 |
| DEBT SERVICE AND F
-CFC
-FFB | EES FOR
733
254 | ALL LOANS
703
243 | 673
232 | 643
221 | 613
211 | 583
200 | 553
189 | 523
179 | 493
168 | 463
157 | 433
146 | 403
136 | 373
125 |
| TOTAL | 987 | 946 | 905 | 865 | 824 | 783 | 742 | 702 | 661 | 620 | 579 | 539 | 498 |
| DISCOUNTED VALUE
Present value | 170
0 | 152
0 | 136 | 122 | 108 | 96
0 | 85
0 | 75
0 | 66
0 | 58
0 | 51 | 44
0 | 38
0 |

F - 15

| 1 | ĭ | ì | 1 | 1 | | ł | 1 | 1 | ţ | 1 | 1 | 1 | 1 | 1 | 1 | 3
F | 1 |
|---|---|-----|----|---|---|---|----|---|---|----|---|---|---|---|---|--------|---|
| ÷ | 5 | E . | ę. | , | , | • | \$ | ŝ | 1 | ş. | | 1 | r | , | 7 | , | ; |

PRESENT VALUE COMPARISON OF CFC/FFB PROPORTIONATE LOAN PACKAGES Sub-Case 2: 5% CFC Funds @ 8.75%/15% FFB Funds @ 9.375%

| Year | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 |
|-----------------------------------|-------------------|------------------------|----------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|----------------|
| DEBT SERVICE AND F
CFC
FFB | EES FOR
0
0 | ALL LOANS
37
113 | 5
78
246 | 226
726 | 464
1468 | 454
1436 | 444
1404 | 434
1372 | 424
1340 | 414
1307 | 404
1275 | 394
1243 | 384
1211 |
| TOTAL | 0 | 150 | 324 | 952 | 1933 | 1890 | 1848 | 1806 | 1764 | 1722 | 1680 | 1638 | 1595 |
| DISCOUNTED VALUE
PRESENT VALUE | 0
16873 | 140
0 | 283
0 | 777
0 | 1474
0 | 1348
0 | 1232
0 | 1125
0 | 1027
0 | 937
0 | 854
0 | 778
0 | 708
0 |
| Year | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 |
| DEBT SERVICE AND F | EES FOR | ALL LUANS | 1 | | | | | | | | | | |
| CFC
FFB | 374
1179 | · 364
1147 | 354
1115 | 344
1082 | 334
1050 | 324
1018 | 314
986 | 304
954 | 294
922 | 284
890 | 274
857 | 264
825 | 254
793 |
| TOTAL | 1553 | 1511 | 1469 | 1427 | 1385 | 1342 | 1 3 0 0 | 1258 | 1216 | 1174 | 1132 | 1090 | 1047 |
| DISCOUNTED VALUE
PRESENT VALUE | 645
0 | 586
0 | 532
0 | 483
0 | 438
0 | 397
0 | 360
0 | 325
0 | 294
0 | 265
0 | 239
0 | 215
0 | 193
0 |
| Year | 26 | 27 | 28 | 29 | 30 | 31 | 32 | 33 | 34 | 35 | 36 | 37 | 38 |
| DEBT SERVICE AND F | FFS FOR | ALL LOANS | | | | | | | | | | | |
| CFC
FFB | 244 | 234
729 | 224 | 214 | 204 | 194 | 184 | 174 | 164
504 | 154 | 144 | 134 | 124 |
| TOTAL | 1005 | 963 | 921 | 879 | 837 | 794 | 752 | 710 | 668 | 626 | 584 | 542 | 499 |
| DISCOUNTED VALUE
Present value | 173 | 155
0 | 139
0 | 124 | 110 | 98
0 | 86
0 | 76
0 | 67
0 | 59
0 | 51
0 | 44
0 | 58
0 |

F - 16

ANCHORAGE-FAIRBANKS INTERCONNECTION

FINANCIAL PLAN B

CHANGE-CASE 1

(TLFAP)

50% REA LOAN AT 5% INTEREST RATE 15% CFC LOAN AT 8.75% INTEREST RATE 5% FFB LOAN AT 9.375% INTEREST RATE 30% MUNICIPAL BONDS AT 7.25% BONDING RATE 100% COMBINED SOURCES AT 6.5% COMPOSITE RATE

| | | | 1 N T | FUNDING
Frest duri | SOURCES AN
NG CONSTRU | 10
101100 | | |
|------------|------------------------------|--------|--------|-----------------------|--------------------------|--------------|--------|-------|
| LINE
NO | | 1961-1 | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TOTAL |
| 400.0 | FUNDING SUURCES | | | | | | | |
| 401.0 | APA BONDS | 0 | U | υ | 0 | 0 | 0 | 0 |
| 402.0 | REA LOANS | 548 | 1833 | 4865 | 3710 | 13636 | 15420 | 40012 |
| 403.0 | CFC LUANS | 164 | 550 | 1460 | 1113 | 4091 | 4626 | 12004 |
| 404.0 | FFB LOANS | 55 | 183 | 487 | 571 | 1364 | 1542 | 4001 |
| 405.0 | AMU BUNDS | 164 | 550 | 1460 | 1113 | 4091 | 4626 | 12004 |
| 406.0 | FMU BONDS | 164 | 550 | 1460 | 1113 | 4091 | 4626 | 12004 |
| 408.0 | | | | | | | | |
| 409.0 | TOTAL | 1096 | 3666 | 9730 | 7419 | 27273 | 30839 | 80024 |
| 410.0 | | | | | | | | |
| 411.0 | INTEREST DURING CONSTRUCTION | | | • | | | | |
| 412.0 | APA BUNDS | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 413.0 | REA LOANS | 0 | 14 | 60 | 181 | 274 | 615 | 1143 |
| 414.0 | CFC LUANS | 0 | 7 | 31 | 95 | 144 | 323 | 600 |
| 415.0 | FFB LOANS | Ō | 3 | 11 | 34 | 51 | 115 | 214 |
| 416.0 | AMU BONDS | 0 | 6 | 26 | 80 | 123 | 276 | 511 |

6 . 26

ANCHORAGE - FAIRBANKS INTERCONNECTION

24 APRIL 79

417.0 FMU BONDS

421.0 FOTAL

420.0

422.0

-77

| 24 APRIL 79 | | ANCHURAGE - FAIRBANKS INTERCONNECTION
DEBT TAGLE AND
COMPOSITE INTEREST RATE | | | | | | | | | | |
|-------------------------|--------------------|--|--------|--------|--------------|--------|--------|-------|--|--|--|--|
| L INE
Nû | | 1981-1 | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TUTAL | | | | |
| 430.0 × DEB | T ASSUMED BY EACH | UTILITY | | | | | | | | | | |
| 432.0 AML | * P | 15.00 | 0.0 | 0 . J | U.U | 0.0 | 0.0 | 15.00 | | | | |
| 434.0 CEA | | 30.00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 30.00 | | | | |
| 436.0 MEA | | 3.00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 3.00 | | | | |
| 438.0 HEA | | 1.00 | 0.0 | Ú, Ð | Ú.O | U_Ŭ | 0.0 | 1.00 | | | | |
| 442.0 FMUS | | 15.00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 15.00 | | | | |
| 444.0 GVEA | | 36.00 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 36.00 | | | | |
| 446.0 CVEA | | 0.0 | 0.0 | 0.0 | Ŭ . O | 0.0 | 0.0 | 0.0 | | | | |
| 447.0 | | | | | | | | | | | | |
| 448.0 | | | | | | | | | | | | |
| 449.0 | | | | | | | | | | | | |
| 450.0 DEBI | ASSUMED BY EACH UT | | | | | | 111 34 | 12004 | | | | |
| 452.0 AML | & P | 164 | 550 | 1460 | 1113 | 4091 | 4020 | 12004 | | | | |
| 474.V LEA | | 329 | 1100 | 2919 | 2220 | 0102 | 9272 | 24007 | | | | |
| 400.0 MEA | | 33 | 110 | 676 | 223 | 010 | 765 | 2401 | | | | |
| 400.U NEA
450.E ENIO | | 1. | 57 | 1460 | 1117 | 2/3 | 4626 | 12004 | | | | |
| 402.0 FM03 | | 104 | 1220 | 1400 | 2671 | 9071 | 11102 | 28800 | | | | |
| 464.0 GVEA | | 373 | 1320 | 0 | 20/1 | 4610 | 11102 | 20009 | | | | |
| 450.0 000 | | | | | | | | | | | | |
| 470.0 TOTA | E DEBT | 1096 | 3666 | 9730 | 7419 | 27273 | 30839 | 80024 | | | | |
| 472.0 | 0001 | ••••• | 2000 | ., | | 2.2.5 | | | | | | |
| 474.0 | | | | | | | | | | | | |
| 476.0 | | | | | | | | | | | | |
| 500.0 COMPO | SITE INTEREST RATE | CALCULATIONS | | | | | | | | | | |
| 501.0 APA | BONDS | 0 | 0 | Û | 0 | 0 | 0 | 0 | | | | |
| 502.0 REA | LOANS | 2001 | 0 | 0 | 0 | 0 | 0 | 2001 | | | | |
| 503.0 CFC | LUANS | 1050 | 0 | Û | 0 | 0 | 0 | 1050 | | | | |
| 504.0 FFB | LUANS | 375 | Ú | 0 | Û | 0 | Û | 375 | | | | |
| 505.0 AMU | BONDS | 870 | 0 | 0 | 0 | Û | 0 | 870 | | | | |
| 506.0 FMU | BONDS | 870 | 0 | 0 | 0 | 0 | Û | 870 | | | | |
| 508.0 | - | | | | | | | | | | | |
| 510.0 COMP | USITE RATE | 0.065 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.065 | | | | |

| | | | | | | | | | h- | | | | | | |
|---|-----|-----|---|------|---|---|---|---|-----|---|---|---|----|---|---|
| | | 8 | * | ē. 2 | 8 | 8 | 4 | 8 | | 9 | 3 | ê | ē. | 3 | |
| | t ? | i i | 1 | 7 8 | | | ĩ | ē | | ÷ | 2 | 2 | , | £ | £ |
| 1 | 1 1 | 5 | , | , , | | | , | | r . | 8 | 3 | f i i i i i i i i i i i i i i i i i i i | 3 | * | Ŷ |
| 4 | s / | | | | | - | | | F | | - | - | - | | |

| | 24 APF | RIL 79 | | | ANCHOR | AGE - FAI
DEBT SE | REANKS IN | TERCUNNEC
1edule | 1104 | | | | | |
|-----|------------|-------------------------|-------|-------|--------|----------------------|-----------|---------------------|-------|-------|-----------|------------|------------|-------|
| | LINE
NO | | 1984 | 1985 | 1986 | 1987 | 1988 | 1989 | 1990 | 1991 | 1992 | 1993 | 1994 | 1995 |
| | 152.0 | ΑΡΑ | | | | | | | | | | | | |
| | 154.0 | SINKING FUND | Ű | 0 | 0 | o | υ | U | 0 | O | 0 | 0 | 0 | 0 |
| | 156.0 | INTEREST DUE | U | Û | U | 0 | Û | Û | 0 | υ | υ | 0 | 0 | 0 |
| | 158.0 | •••
• EANIX (STEDECT | | | | | | | | | | | | ····· |
| | 161.0 | S.FUNDTINIERESI | v | U | v | Ŭ | U | v | U | v | U | v | v | v |
| | 166.0 | REA | | | | | | | | | | | | |
| | 168.0 | REPAYMENT | 1143 | 1143 | 1145 | 1143 | 1143 | 1143 | 1143 | 1143 | 1143 | 1143 | 1143 | 1143 |
| | 171.0 | OUTSTANDING | 38869 | 3/726 | 36583 | 35439 | 34296 | 33153 | 32010 | 30866 | 29723 | 28580 | 27437 | 26294 |
| | 172.0 | INTEREST DUE | 2001 | 1943 | 1885 | 1829 | 1772 | 1715 | 1658 | 1600 | 1543 | 1486 | 1429 | 1372 |
| | 174.0 | DEBT SERVICE | 3144 | 3087 | 4029 | 2972 | 2915 | 2858 | 2801 | 2744 | 2687 | 2629 | 2572 | 2515 |
| | 177.0 | DEST DERVICE | 2144 | 3007 | 502. | 2772 | 2715 | 2030 | 2001 | | Loor | 2027 | 2372 | |
| | 182.0 | CFC | | | | | | | | | | | | |
| | 184.0 | REPAYMENT . | 343 | 343 | 343 | 343 | 343 | 343 | 343 | 343 | 343 | 343 | 343 | 343 |
| | 187.0 | OUTSTANDING | 11661 | 11318 | 10975 | 10632 | 10289 | 9946 | 9603 | 9260 | 8917 | 8574 | 8231 | 720 |
| | 190.0 | INTEREST | 1050 | 1020 | 790 | 900 | 930 | | 07V | | 010
 | /00 | / 50 | |
| | 192.0 | DEBT SERVICE | 1393 | 1363 | 1333 | 1303 | 1273 | 1243 | 1213 | 1183 | 1153 | 1123 | 1093 | 1063 |
| | 193.0 | | | | | | | | | | | | | |
| | 198.0 | FFB | | | | | | | 4 | | | | | |
| ч | 200.0 | | 114 | 114 | 114 | 114 | 114 | 114 | 114 | 114 | 114 | 114 | 114 | 2629 |
| ı | 202.0 | 00131ANDING | | | |
 | J4JV | | | | 27/2 | | | |
| 20 | 206.0 | S.FUND+INTEREST | 4001 | 3887 | 3773 | 3658 | 3544 | 3430 | 3315 | 3201 | 3087 | 2972 | 2858 | 2744 |
| , U | 207.0 | | | | | | | | | | | | | |
| | 212.0 | AMU | | | | | | <u>.</u> | | ~ . | | a / | 0.4 | 9.4 |
| | 214.0 | SINKING FUND | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86
907 | 86
907 | 907 | 907 |
| | 218.0 | INTEREST DUE | | | 707 | 747 | | 707
••======== | | | 707 | | | |
| | 220.0 | S.FUND+INIEREST | 993 | 993 | 993 | 993 | 993 | 993 | 993 | 993 | 993 | 993 | 993 | 993 |
| | 221.0 | | | | | | | | | | | | | |
| | 228.0 | FMU | | | | | | | | | | | A (| |
| | 230.0 | SINKING FUND | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 007 |
| | 234 0 | INTEREST DUE | 907 | 907 | 907 | 907 | 907 | 907 | 907 | | 907 | 907
 | 707 | |
| | 236.0 | S.FUND+INTEREST | 993 | 943 | 993 | 995 | 993 | 993 | 993 | 993 | 993 | 993 | 993 | 993 |
| | 250.0 | TOTAL REPAYMENTS OR | | | | | | | | | | | | |
| | 251.0 | S. FUND PAYMENTS | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 |
| | 255.0 | TUT INTEREST DUE | 8752 | 8551 | 8349 | 8148 | /947 | 7745 | 7544 | / 542 | /141 | 6939 | 0/30 | 0220 |
| | 257.0 | TOTAL DEBT SERVI | 10524 | 10323 | 10121 | 992ú | 9718 | 9517 | 9315 | 9114 | 8912 | 8711 | 8509 | 8308 |

24 APRIL 79

ANCHORAGE - FAIRBANKS INTERCONNECTION DEBT SERVICE SCHEDULE

| | LINE
NO | | 1996 | 1997 | 1998 | 1999 | 2000 | 2001 | 5005 | 2003 | 2004 | 2005 | 2006 | 2007 |
|----|-------------------------|----------------------|-------|--|-------|-------------|-------|-------|-------|----------|----------|-------|----------|-------|
| | 152.0 | APA | | | | | | | | | | | | |
| | 154.0 | SINKING FUND | 0 | 0 | U | ú | U | U | Û | Û | 0 | 0 | 0 | 0 |
| | 156.0 | INTEREST DUE | 0 | 0 | 0 | U | U | U | U | 0 | 0 | 0 | 0 | 0 |
| | 158.0
160.0
161.0 | S.FUND+INTEREST | 0 | 0 | 0 | 0 | 0 | U | 0 | 0 | 0 | 0 | 0 | 0 |
| | 166.0 | REA | | | | | | | | | | | | |
| | 168.0 | REPAYMENT | 1143 | 1143 | 1143 | 1143 | 1143 | 1143 | 1143 | 1143 | 1143 | 1143 | 1143 | 1143 |
| | 171.0 | OUTSTANDING | 25150 | 24007 | 22864 | 21721 | 20578 | 19434 | 18291 | 17148 | 16005 | 14862 | 13718 | 12575 |
| | 172.0 | INTEREST DUE | 1315 | 1258 | 1200 | 1145 | 1086 | 1029 | 972 | 915 | 857 | 800 | 745 | 000 |
| | 174.0 | DEBT SERVICE | 2458 | 2401 | 2344 | 2286 | 2229 | 2172 | 2115 | 2058 | 2001 | 1943 | 1886 | 1829 |
| | 182.0 | CFC | | | | | | | | | | | | |
| | 184.0 | REPAYMENT | 343 | 343 | 343 | 343 | 343 | 345 | 343 | 343 | 343 | 343 | 343 | 343 |
| | 187.0 | OUTSTANDING | 7545 | 7202 | 6859 | 6516 | 6173 | 5830 | 5487 | 5144 | 4801 | 4458 | 4116 | 3773 |
| | 188.0 | INTEREST | 690 | 660 | 630 | 600 | 570 | 540 | 510 | 480 | 450 | 420 | 390 | 360 |
| | 190.0 | UENT SERVICE | 1033 | 1003 | 973 | 943 | 913 | 883 | 853 | 823 | 793 | 763 | 733 | 703 |
| | 195.0 | E E 0 | | | | | | | | | | | | |
| | 200 0 | REPAYMENT | 114 | 114 | 114 | 114 | 114 | 114 | 114 | 114 | 114 | 114 | 114 | 114 |
| -1 | 202.0 | OUTSIANDING | 2515 | 2401 | 2286 | 2172 | 2058 | 1943 | 1829 | 1715 | 1600 | 1486 | 1372 | 1258 |
| i | 204.0 | | | | | | | | | | ******** | | | |
| N | 206.0 | S.FUND+INTEREST | 2629 | 2515 | 2401 | 2286 | 2172 | 2058 | 1943 | 1829 | 1715 | 1600 | 1486 | 1372 |
| Ч | 207.0 | | | | | | | | | | | | | |
| | 212.0 | AMU | | | | | | | | | | | | _ |
| | 214.0 | SINKING FUND | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 |
| | 216.0 | INTEREST DUE | 907 | 907 | 907 | 907 | 907 | 907 | 907 | 907 | 907 | 907 | 907 | 907 |
| | 218.0 | S.FUND+INTEREST | 493 | 943 | 943 | 993 | 993 | 993 | 993 | 993 | 993 | 993 | 993 | 993 |
| | 221.0 | E 444 | | | | | | | | | | | | |
| | 228.0 | FMU
STAR ING FUND | 86 | 86 | нь | 11 L | 8.6 | 86 | 86 | 86 | 86 | 86 | 86 | 86 |
| | 230.0 | INTEREST OUF | 907 | 967 | 907 | 907 | 907 | 907 | 907 | 907 | 907 | 907 | 907 | 907 |
| | 234 0 | INTEREST DOL | | ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,, | | | | , | | ******** | | | | |
| | 236.0 | S_FURD+INTEREST | 993 | 993 | 993 | 992 | 993 | 993 | 993 | 993 | 993 | 993 | 993 | 993 |
| | 250.0 | TOTAL REPAYMENTS OF | 1 | | | | | | | | | | | |
| | 251.0 | S. FUND PAYMENTS | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 |
| | 253.0 | TOT INTEREST DUE | 6335 | 6133 | 5932 | 5730 | 5529 | 5327 | 5126 | 4924 | 4723 | 4521 | 4320 | 4118 |
| | 255.0 | | | | | | | | | | | | ******** | |
| | 257.0 | TOTAL DEBI SERVI | 8107 | 7905 | 7704 | 7502 | 7301 | 7099 | 6898 | 6696 | 6495 | 6293 | 6092 | 5890 |

24 APRIL 79

ANCHORAGE - FAIRBANKS INTERCONNECTION DEBT SERVICE SCHEDULE

| LIN | E | 2008 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 |
|-------|--------------------|-------|-------|---------|---------|------|-----------|------|------|-------|------|---------|
| N0 | | | | | | | | | | | | |
| 152. | U APA | | | | | | | | | | | |
| 154. | 0 SINKING FUND | 0 | Û | Û | 0 | 0 | · U | υ | 0 | 0 | 0 | 0 |
| 156. | O INTEREST DUE | 0 | 0 | 0 | ú | 0 | 0 | 0 | U | 0 | 0 | 0 |
| 158. | 0 | | | | | | | | | | | |
| 160. | 0 S.FUND+INTEREST | 0 | 0 | 0 | 0 | Û | Ű | 0 | 0 | 0 | 0 | 0 |
| 161. | 0 - | | | | | | | | | | | |
| 166. | | 11/14 | 1147 | 1147 | 1 4 / 7 | | | 7 | 7 | | | |
| 171 | | 1143 | 10280 | 0145 | 1145 | 1145 | 1145 | 1145 | 1145 | 114.5 | 1145 | 1145 |
| 172 | A INTEREST DUE | 629 | 572 | 514 | 457 | 400 | 3/10 | 286 | 2420 | 171 | 1145 | 57 |
| 174. | 0 | | | | | | | | | | 114 | |
| 176. | O DEBT SERVICE | 1772 | 1715 | 1658 | 1600 | 1543 | 1486 | 1429 | 1372 | 1315 | 1258 | 1200 |
| 177. | 0 | | | • - • - | | | • • • • • | | | | | |
| 182. | 0 CFC | | | | | | | | | | | |
| 184. | 0 REPAYMENT | 343 | 343 | 543 | 343 | 343 | 343 | 343 | 343 | 343 | 343 | 343 |
| 187. | U DUISTANDING | 3430 | 3087 | 2744 | 2401 | 2058 | 1715 | 1372 | 1029 | 686 | 343 | 0 |
| 188. | 0 INTEREST | 330 | 300 | 270 | 240 | 210 | 180 | 150 | 120 | 90 | 60 | 30 |
| 190. | 0 | | | | | | | | | | | |
| 192. | O DEAT SERVICE | 673 | 643 | 613 | 583 | 553 | 523 | 493 | 463 | 433 | 403 | 373 |
| 193. | 0 | | | | | | | | | | | |
| 198. | U FFB | • • 4 | | | | | | | | | | |
| 200. | | 114 | 1020 | 114 | 114 | 114 | 114 | 114 | 114 | 114 | 114 | 114 |
| 202. | 0 00131200103 | 1143 | 1027 | 715 | | 000 | 372 | 437 | 343 | 227 | 114 | |
| N 206 | 0 S.FUND+INTEREST | 1258 | 1143 | 1029 | 915 | 800 | | 572 | 457 | 343 | 220 | 114 |
| 207. | 0 | 1230 | | 1000 | | | 000 | 572 | | 545 | 227 | • • • |
| 212. | 0 AMU | | | | | | | | | | | |
| 214. | 0 SINKING FUND | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 |
| 216. | 0 INTEREST DUE | 907 | 907 | 907 | 907 | 907 | 907 | 907 | 907 | 0 | 0 | 0 |
| 218. | 0 | | | | | | | | | | | ******* |
| 220. | 0 S.FUND+INTEREST | 993 | 993 | 993 | 993 | 993 | 993 | 993 | 993 | 86 | 86 | 86 |
| 221. | 0 | | | | | | | | | | | |
| 228. | 0 FHU | | | | | | | | | | | |
| 230. | 0 SINKING FUND | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 | 86 |
| 232. | O INTEREST DUE | 907 | 907 | 907 | 907 | 907 | 907 | 907 | 907 | 907 | 907 | 907 |
| 234. | | | | | 063 | | | | | | | |
| 230. | U SAFUNUTINIERESI | 442 | 442 | 773 | 443 | 442 | 443 | 442 | 442 | 442 | 442 | 442 |
| 250. | O S. FUND PAYMENTS | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1772 | 1773 |
| 251 | O TOT INTEREST DUF | 3917 | 3715 | 3514 | 3312 | 3111 | 2909 | 2708 | 2506 | 1397 | 1196 | 994 |
| 255 | 0 | ***** | | | | | | | | | 1170 | ,,, |
| 257. | O TOTAL DEBT SERVI | 5689 | 5487 | 5280 | 5084 | 4883 | 4681 | 4480 | 4278 | 3169 | 2968 | 2766 |

| 24 | APHI | L | 79 |
|----|------|---|----|
|----|------|---|----|

ANCHORAGE - FAIRBANKS INTERCONNECTION DEBT REPAYMENT AND SINKING FUND ALLUCATION BY UTILITY

| | LINE
NU | | 1984 | 1985 | 1986 | 1987 | 1988 | 1989 | 1990 | 1991 | 1992 | 1993 | 1994 | 1995 |
|-----------------|------------|-----------------------------|-------|-------|-------|-------|-------|--------|-------|-------|-------|-------|-------|-------|
| | 352.0 | AML & P
Repayment amount | 266 | 266 | 266 | 266 | 266 | 266 | 200 | 266 | 266 | 266 | 266 | 266 |
| | 358.0 | OUTSTANDING | 8510 | 8200 | 8010 | 7759 | 7509 | 7259 | 7009 | 6758 | 6508 | 6258 | 6008 | 5757 |
| | 360.0 | INTEREST DUE | 1313 | 1283 | 1252 | 1555 | 1192 | 1162 | 1132 | 1101 | 1071 | 1041 | 1011 | 980 |
| | 361.0 | 1 | | | | | | | | | | | | |
| | 302.0 | | 673 | 673 | 673 | 513 | 573 | 573 | 672 | 572 | 512 | 572 | 512 | 532 |
| | 504.0 | REPAIMENT AMOUNT | 17020 | 14570 | 14019 | 15510 | 15018 | 1/1518 | 14017 | 13517 | 13016 | 12516 | 12015 | 11515 |
| | 300.0 | UUISIANUING | 17020 | 10250 | 10017 | 2000 | 218/ | 2224 | 2263 | 2203 | 21/2 | 2082 | 2021 | 1961 |
| | 371.0 | INTEREST DUE | 2020 | 2303 | . 502 | 2444 | 2304 | 6764 | 2205 | 2205 | 6146 | 2002 | 6751 | 1701 |
| | 372.0 | MEA | | | | | | | | | | | | |
| | 374.0 | REPAYMENT AMOUNT | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 |
| | 378.0 | OUTSTANDING | 1702 | 1052 | 1602 | 1552 | 1502 | 1452 | 1402 | 1352 | 1302 | 1252 | 1202 | 1151 |
| | 380.0 | INTEREST DUE | 263 | 257 | 250 | 244 | 238 | 232 | 226 | 250 | 214 | 208 | 202 | 196 |
| | 381.0 | | | | | | | | | | | | | |
| | 382.0 | HEA | 2 m. | | | | | | | | | 4.0 | | |
| | 384.0 | REPAYMENT AMOUNT | 18 | 18 | 18 | • 18 | 18 | 18 | 18 | 18 | 18 | 18 | 10 | 10 |
| | 388.0 | OUTSTANDING | 567 | 551 | 534 | 517 | 501 | 484 | 467 | 451 | 434 | 417 | 401 | 204 |
| -+ - | 390.0 | INTEREST DUE | 88 | 86 | 83 | 81 | 19 | | /5 | / 5 | /1 | 09 | ¢7 | 63 |
| ., | 391.0 | | | | | | | | | | | | | |
| • | 402.0 | FMUS | | | 244 | 2// | 74.4 | 344 | 74.4 | 744 | 74.4 | 34.4 | 344 | 266 |
| 2 | 404.0 | REPAYMENT AMOUNT | 266 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 6003 | 5757 |
| ω | 408.0 | UUISIANDING | 0510 | 1 200 | 1252 | 1139 | 1102 | 1163 | 1172 | 1101 | 1071 | 10/1 | 1011 | 980 |
| | 410.0 | INTEREST DUE | 1515 | 1602 | 1252 | 1222 | 1192 | 1102 | 1156 | 1101 | 1071 | 1041 | 1011 | 400 |
| | 411.0 | | | | | , | | | | | | | | |
| | 412.0 | | 470 | 479 | 474 | 479 | 678 | £ 7.8 | 618 | 478 | 678 | 618 | 638 | 638 |
| | 414.0 | REPATMENT AMOUNT | 630 | 1276 | 1014 | 2552 | 7180 | 2827 | 4465 | 5103 | 57/1 | 6379 | 7017 | 7655 |
| | 410.0 | | 2010 | 10471 | 10227 | 18622 | 18022 | 17/21 | 16820 | 16220 | 15610 | 15019 | 14418 | 13817 |
| | 418.0 | UUISTANDING | 20424 | 17023 | 17225 | 2022 | 2861 | 2788 | 2716 | 26/13 | 2571 | 2//98 | 2426 | 2353 |
| | 420.0 | INTEREST DUE | 2121 | 3010 | 3000 | 2755 | 2001 | 2700 | 2/10 | 2043 | 23/1 | 2470 | 2420 | 2333 |
| | 421.0 | CVEA | | | | | | | | | | | | |
| | 422.0 | | 0 | 0 | 0 | 0 | · 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| | 424.0 | CUMULATIVE | 0 | 0 | 0 | 0 | õ | 0 | 0 | 0 | 0 | õ | õ | ŏ |
| | 420.0 | OHIGTANDING | 0 | 0 | 0 | 0 | ő | ő | ő | 0 | õ | 0 | 0 | 0 |
| | 420.0 | THE PEST ANE | 0 | 0 | 0 | 0 | | ů | 0 | 0 | ő | 0 | 0 | Ő |
| | 430.0 | THICKEST DUC | 0 | | • | | | | • | • | • | • | | • |

. .

24 APRIL 79

-----1 24

ANCHORAGE - FAIRBARKS INTERCONNECTION DEBT REPAYMENT AND SINKING FUND ALLUCATION BY UTILITY

| LINE | | 1996 | 1997 | 1998 | 1999 | 2000 | 2001 | 2005 | 2003 | 2004 | 2005 | 2006 | 2007 |
|-------|---------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| NO | | | | | | | | | | | | | |
| 352.0 | AML & P | | | | | | | | | | | | |
| 354.0 | REPAYMENT AMOUNT | 266 | 200 | 260 | 266 | 206 | 206 | 200 | 260 | 266 | 266 | 266 | 266 |
| 358.0 | OUTSTANDING | 5507 | 5257 | 5007 | 4756 | 4506 | 4250 | 4006 | 3755 | 3505 | 3255 | 3005 | 2754 |
| 360.0 | INTEREST DUE | 950 | 920 | 890 | 860 | 829 | 799 | 769 | 739 | 708 | 678 | 648 | 618 |
| 361.0 | | | | | | | | | | | | | |
| 362.0 | CEA | | | | | | | | | | | | |
| 364.0 | REPAYMENT AMOUNT | 532 | 532 | 532 | 532 | 532 | 532 | 532 | 532 | 532 | 532 | 532 | 532 |
| 508.0 | OUTSTANDING | 11014 | 10514 | 10013 | 9513 | 9012 | 8512 | 8011 | 7511 | 7010 | 6510 | 6009 | 5509 |
| 370.0 | INTEREST DUE | 1900 | 1840 | 1779 | 1719 | 1659 | 1598 | 1538 | 1477 | 1417 | 1356 | 1296 | 1235 |
| 371.0 | | | | | | | | | | | | | |
| 372.0 | MEA | | | | | | | | | | | | |
| 374.0 | REPAYMENT AMOUNT | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 |
| 378.0 | OUTSTANDING | 1101 | 1051 | 1001 | 951 | 901 | 851 | 801 | 751 | 701 | 651 | 601 | 551 |
| 380.0 | INTEREST DUE | 190 | 184 | 178 | 172 | 166 | 160 | 154 | 148 | 142 | 136 | 130 | 124 |
| 381.0 | | | | | | | | | | | | | |
| 382.0 | HEA | | | | | | | | | | | | |
| 384.0 | REPAYMENT AMOUNT | 18 | 18 | 18 | 18 | 18 | 18 | 18 | 18 | 18 | 18 | 18 | 18 |
| 388.0 | OUTSTANDING | 367 | 350 | 334 | 317 | 300 | 284 | 267 | 250 | 234 | 217 | 200 | 184 |
| 390.0 | INTEREST DUE | 63 | 61 | 59 | 57 | 55 | 53 | 51 | 49 | 47 | 45 | 43 | 41 |
| 391.0 | | | | | | | | | | | | | |
| 402.0 | FMUS | | | | | | | | | | | | |
| 404.0 | REPAYMENT AMOUNT | 266 | 266 | 266 | 206 | 266 | 266 | 266 | 266 | 266 | 266 | 266 | 200 |
| 408.0 | OUTSTANDING | 5507 | 5257 | 5007 | 4756 | 4506 | 4256 | 4006 | 3755 | 3505 | 3255 | 3005 | 2154 |
| 410.0 | INTEREST DUE | 950 | 920 | 890 | 860 | 829 | 799 | 769 | 739 | 708 | 678 | 648 | 618 |
| 411.0 | | | | | | | | | | | | | |
| 412.0 | GVEA | | | | | | | | | | | | (7.0 |
| 414.0 | REPAYMENT AMOUNT | 638 | 638 | 638 | 638 | 638 | 638 | 638 | 638 | 638 | 638 | 658 | 630 |
| 416.0 | CUMULATIVE | 8293 | 8930 | 9568 | 10206 | 10844 | 11482 | 12120 | 12758 | 13396 | 14034 | 146/1 | 15309 |
| 418.0 | OUISIANDING | 13217 | 12616 | 12016 | 11415 | 10815 | 10214 | 9613 | 9013 | 8412 | 7812 | /211 | 0010 |
| 420.0 | INTEREST DUE | 2280 | 2508 | 2135 | 2063 | 1990 | 1918 | 1845 | 1773 | 1700 | 1628 | 1555 | 1485 |
| 421.0 | • · · · • · | | | | | | | | | | | | |
| 422.0 | CVEA | | | | | | | | - | | | • | |
| 424.0 | REPAYNENT AMOUNT | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 426.0 | CUMULATIVE | 0 | 0 | 0 | 0 | 0 | 0 | Ö | 0 | 0 | 0 | 0 | 0 |
| 428.0 | UUISTANDING | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 430.0 | INTEREST DUE | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | U |

. .

24 APRIL 79 ANCHORAGE - FAIRBANKS INTERCONNECTION DEBT REPAYMENT AND SINKING FUND ALLOCATION BY UTILITY LINE 2008 2009 2010 2011 2012 2015 2014 2015 2016 2017 2018

| NG | | 2000 | 2007 | | | | LVIJ | | 2015 | LUIO | 2017 | 2010 |
|---------|--------------------|-------|-------|-------|-------|--------|-------|-------|-------|-------|-------|---|
| NO | | | | | | | | | | | | |
| 352. | O AML & P | | | | | | | | | | | |
| 354. | O REPAYMENT AMOUNT | 200 | 266 | 200 | 260 | 266 | 266 | 266 | 266 | 266 | 266 | 266 |
| 358. | 0 OUTSIANDING | 2504 | 2254 | 2004 | 1753 | 1503 | 1253 | 1003 | 752 | 502 | 252 | 2 |
| 360. | 0 INTEREST DUE | 588 | 557 | 527 | 497 | 467 | 456 | 406 | 376 | 210 | 179 | 149 |
| 301. | 0 . | | | | | | | | | | | |
| 362. | 0 ÇEA | | | | | | | | | | | |
| 364. | O REPAYNENT AMOUNT | 532 | 532 | 532 | 532 | 532 | 532 | 532 | 532 | 532 | 532 | 532 |
| 368. | U UUTSTANDING | 5008 | 4508 | 4007 | 3507 | 3006 | 2506 | 2005 | 1505 | 1004 | 504 | 3 |
| 370. | 0 INTEREST DUE | 1175 | 1115 | 1054 | 994 | 933 | 873 | 812 | 752 | 419 | 359 | 298 |
| 371. | 0. | | | | | | | | | | | |
| 372. | 0 14EA | | | | | | | | | | | |
| 374. | U REPAYMENT AMOUNT | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 | 53 |
| 378. | 0 OUTSTANDING | 501 | 451 | 401 | 351 | 301 | 251 | 201 | 150 | 100 | 50 | 0 |
| 380. | O INTEREST DUE | 118 | 111 | 105 | 99 | 93 | 87 | 81 | 75 | 42 | 36 | 30 |
| 381. | 0 | | | | | | | | | | | |
| 382. | UHEA | | | | | | | | | | | |
| 384. | O REPAYMENT AMOUNT | 18 | 18 | 18 | 18 | 18 | 18 | 18 | 18 | 18 | 18 | 18 |
| 388. | 0 DUISTANDING | 167 | 150 | 134 | 117 | 100 | 84 | 67 | 50 | 33 | 17 | 0 |
| 390. | O INTEREST DUE | 39 | 37 | | 53 | 51 | 29 | 27 | 25 | 14 | 12 | 10 |
| 391. | 0 | | | | | | | | | | | |
| ., 402. | 0 FMUS | 2 | 2.4 | 244 | 24.4 | 2// | 244 | 244 | 244 | 244 | 24.4 | 244 |
| 1 404. | U REPATMENT AMUUNT | 266 | 200 | 205 | 200 | 200 | 200 | 200 | 266 | 266 | 266 | 200 |
| N 408. | U UUISIANDING | 2504 | 2254 | 2004 | 1/53 | 1505 | 1255 | 1005 | 152 | 502 | 252 | <u>ک</u> |
| 410. | U INTEREST DUE | 200 | 221 | 521 | 441 | 467 | 430 | 400 | 3/0 | 210 | 179 | 149 |
| 411. | | | | | | | | | | | | |
| 412. | | 678 | 474 | 674 | 678 | 478 | 618 | 678 | 674 | 479 | 479 | 478 |
| 414. | COMPLEXITY | 159/7 | 14585 | 17223 | 17861 | 18/190 | 10137 | 10775 | 20412 | 21050 | 21688 | 22226 |
| 410. | DUISTANDING | 6010 | 5/109 | 4809 | 4208 | 3607 | 3007 | 2406 | 1806 | 1205 | 21000 | 22320 |
| 410. | A INTEREST DUE | 1410 | 1237 | 1265 | 1102 | 1120 | 1047 | 975 | 902 | 503 | 431 | 358 |
| 420. | | 1410 | 1257 | 1205 | 1172 | 1120 | 1047 | | 702 | 202 | 431 | ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,, |
| 422 | 0 6764 | | | | | | | | | | | |
| 424 | B REPAYMENT AMOUNT | 0 | 0 | 0 | 0 | 0 | ú | 0 | 0 | 0 | 0 | 0 |
| 426 | 0 CUMULALIVE | 0 | ő | õ | ő | 0 | 0 | 0 | 0 | 0 | 0 | ő |
| 428 | DUTSTANDING | 0 | o | 0 | 0 | 0 | 0 | 0 | ő | 0 | . 0 | ő |
| 430 | INTEREST DUE | 0 | ő | 0 | 0 | õ | 0 | 0 | ő | 0 | 0 | 0 |
| -200 | | · | • | • | • | · | • | • | · | · | · | • |