

SUSITNA HYDROELECTRIC PROJECT

FERC LICENSE APPLICATION

EXHIBIT B FIRST DRAFT SEPTEMBER 17, 1982

Prepared by:

- 0



ALASKA POWER AUTHORITY

EXHIBIT B - STATEMENT OF PROJECT OPERATION AND RESOURCE UTILIZATION

List of Tables List of Figures

1 - DAMSITE SELECTION

1.1 - Previous Studies

- (a) Early Studies of Hydroelectric Potential
- (b) U.S. Bureau of Reclamation 1953 Study
- (c) U.S. Bureau of Reclamation 1961 Study
- (d) Alaska Power Administration 1974 Study
- (e) Kaiser Proposal for Development
- (f) U.S. Army Corps Engineers 1975 and 1979 Studies

Page

- 1.2 Plan Formulation and Selection Methodology
- 1.3 Damsite Selection
 - (a) Site Screening
 - (b) Engineering Layouts
 - (c) Capital Costs
- 1.4 Formulation of Susitna Basin Development Plans
 - a) Tunnel Alternatives
 - (b) Selected Basin Development Plans
- 1.5 Evaluation of Basin Development Plans
 - a) Evaluation Methodology
 - (b) Evaluation Criteria
 - (c) Results of Evaluation Process
- 1.6 Preferred Susitna Basin Development Plan

2 - ALTERNATIVE FACILITY DESIGN, PROCESSES AND OPERATIONS

- 2.1 Susitna Hydroelectric Development
- 2.2 Watana Project Formulation
 - (a) Selection of Reservoir Level
 - (b) Selection of Installed Capacity
 - (c) Selection of Spillway Design Floods
 - (d) Main Dam Alternatives
 - (e) Diversion Scheme Alternatives
 - (f) Spillway Facilities Alternatives
 - (g) Power Facilities Alternatives

2.3 - Selection of Watana General Arrangement

- (a) Selection Methodology
- (b) Design Data and Criteria
- (c) Evaluation Criteria
- (d) Preliminary Review
- (e) Intermediate Review
- (f) Final Review

2.4 - Devil Canyon Project Formulation

- (a) Selection of Reservoir Level
- (b) Selection of Installed Capacity
- (c) Selection of Spillway Capacity
- (d) Main Dam Alternatives
- (e) Diversion Scheme Alternatives
- (f) Spillway Alternatives
- (g) Power Facilities Alternatives

Table of Contents (Continued)

2.5 - Selection of Devil Canyon General Arrangements

Page

(a) Selection Methodology

(b) Design Data Criteria

Preliminary Review (c)

(d) Final Review

2.6 - Selection of Access Road Corridor

2.7 - Selection of Transmission Line Corridor

2.8 - Selection of Project Operation

3 - DESCRIPTION OF PROJECT OPERATION

3.1 - Operation within Railbelt Power System

3.2 - Plant and System Operation Requirements

- 3.3 General Power Plant and System Railbelt Criteria
 - (a) Installed Generating Capacity
 - (b) Transmission System Capability
 - (c) Summary
- 3.4 Economic Operation of Units

(a) Merit-Order Schedule

(b) Optimum Load Dispatching

(c) Operating Limits of Units

(d) Optimum Maintenance Program

- 3.5 Unit Operation Reliability Criteria
 - (a) Power System Analyses
 - (b) System Response and Load-Frequency Control
 - (c) Protective Relaying System and Devices
- 3.6 Dispatch Control Centers

4 - ENERGY PRODUCTION AND SUPPORTING DATA

4.1 - Hydrology

- (a) Historical Streamflow Data
- (b) Water Resources
- (c) Streamflow Extension
- (d) Critical Streamflow Used for Dependable Capacity
- (e) Floods
- (f) Flow Adjustments
- 4.2 Reservoir Data
 - (a) Reservoir Storage
 - (b) Rule Curves

8.

- 4.3 Operating Capabilities of Susitna Units
 - (a) Watana
 - (b) Devil Canyon
- 4.4 Tailwater Rating Curve
- 5 STATEMENT OF POWER NEEDS AND UTILIZATION
 - 5.1 Railbelt Load Forecasts
 - (a) Scope of Studies
 - Electricity Demand Profiles (b)
 - Battelle Load Forecasts (c)

Table of Contents (Continued)

- 5.2 Marketing and Price for Watana Output in 1994
 - (a) Contractual Preconditions for Susitna Energy Sale
 - (b) Market Price for Watana Output 1995-2001
 - (c) Market Price for Watana and Devil Canyon Output in 2003

0

- (d) Potential Impact of State Appropriations
- (e) Conclusions
- 5.3 Sale of Power

1. 4

6 - FUTURE SUSITNA BASIN DEVELOPMENT

Exhibit B - Statement of Project Operation and Resource Utilization

LIST CF FIGURES

Title Number B.1 Location Map B.2 Damsites Proposed by Others Susitna Basin Plan Formulation and Selection Process .. B.3 Profile Through Alternative Sites **B.4** Mutually Exclusive Development Alternatives B.5 B.6 Devil Canyon Hydro Development Fill Dam Watana Hydro Development Fill Dam **B.7 B.8** Watana Staged Fill Dam **B.9** High Devil Canyon Hydro Development B.10 Susitna III Hydro Development B.11 Vee Hydro Development B.12 Denali and Maclaren Hydro Developments Schematic Representation of Conceptual Tunnel Schemes . B.13 B.14 Preferred Tunnel Scheme 3 Plan Views B.15 Preferred Tunnel Scheme 3 Sections Generation Scenario with Susitna Plan E1.3 **B.16** Generation Scenario with Susitna Plan E2.3 B.17 B.18 Generation Scenario with Susitna Plan E3.1 B.19 Watana Reservoir - Dam Crest Elevation/Present Worth of Product Costs B.20 Watana - Arch Dam Alternatives Watana - Alternative Dam Axes B.21 B.22 Watana Diversion - Headwater Elevation/Tunnel Diameter. **B.23** Watana Diversion - Upstream Cofferdam Costs B.24 Watana Diversion - Tunnel and Cofferdam Cost/Tunnel Diameter Watana Diversion - Total Cost/Tunnel Diameter B.25 B.26 Watana - Preliminary Schemes B.27 Watana - Scheme WP1 - Plan B.28 Watana - Scheme WP3 - Sections B.29 Watana - Scheme WP2 and WP 3 B.30 Watana - Scheme WP2 - Sections B.31 Watana - Scheme WP4 - Plan Watana - Scheme WP4 - Sections B.32 B.33 Watana - Scheme WP3A B.34 Watana - Scheme WP4A Devil Canyon Diversion - Headwater Elevation Tunnel B.35 Diameter Devil Canyon Diversion - Total Cost Tunnel Diameter ... B.36 **B.37** Devil Canyon - Scheme DC1 Devil Canyon - Scheme DC2 B.38

LIST OF FIGURES

Î

| Number | <u>Title</u> . |
|--|---|
| B.39 B.40 B.41 B.42 B.43 B.43 B.44 | Devil Canyon - Scheme DC3 Devil Canyon - Scheme DC4 Devil Canyon - Selected Scheme Typical Load Variation in Alaska Railbelt System Data Collection Stations Average Annual Flow Distribution Within the Susitna |
| B.45 B.46 | Monthly Average Flows in the Susitna River at Gold Creek Flow Duration Curve Mean Monthly Inflow at Watana Pre-Project |
| B.47 | Flow Duration Curve Mean Monthly Inflow at Devil Canyon Pre-Project |
| B.48 | Frequency Analysis of Average Annual Energy for Susitna Developments |
| B.49 B.50 | Hydrological Data - Sheet 2 Hydrological Data - Sheet 2 |
| B.51 B.52 | Hydrological Data - Sheet 1 Hydrological Data - Sheet 1 |
| B.53 B.54 | Monthly Target Minimum Reservoir Levels |
| B.55 B.56 | Watana - Turbine Performance (at Rated Head) Watana - Unit Efficiency (at Rated Head) |
| B.57 B.58 | Devil Canyon - Unit Output Devil Canyon - Turbine Performance (at Rated Head) |
| B.59 B.60 | Devil Canyon - Unit Efficiency (at Rated Head) Railbelt Area of Alaska Showing Electrical Load Centers |
| B°0T | Historical Total Railbelt Utility Sales to Final Customers |
| B.62 | ISER 1980 Energy Forecasts Used for Development Selection Studies |
| B.63 B.64 | Electric Power Forecasting Process December 1981 Battelle Load and Energy Forecasts |
| B.65 | Used for Generation Planning Studies Energy Pricing Comparisons - 1994 |
| B.66 B.67 | System Costs Avoided by Developing Susitna Energy Cost Comparison - 100% Debt Financing and 7% |
| | Inflation |

.

Exhibit B - Statement of Project Operation and Resource Utilization

LIST OF TABLES

3

1

| Number | Title | Page |
|-----------------------------|--|------|
| B.1 B.2 B.3 B.4 | Potential Hydroelectric Development Cost Comparisons Dam Crest and Full Supply Levels Capital Cost Estimate Summaries - Susitna Basin Dam | |
| B.5 B.6 B.7 B.8 | Results of Screening Model Information on the Devil Canyon Dam and Tunnel Schemes. Tunnel Schemes Power Output and Average Annual Energy Capital Cost Estimate Summaries for Scheme 3 Tunnel | |
| B.9 B.10 B.11 B.12 | Susitna Development Plans Susitna Environmental Development Plans Results of Economic Analyses of Susitna Plans Results of Economic Analyses of Susitna Plans - Low and High Load Forecast | |
| B.13 B.14 B.15 | Economic Parameters Economic Backup Data for Evaluation of Plans Economic Evaluation of Devil Canyon Dam and Tunnel Schemes and Watana/Devil Canyon and High Devil Canyon/Vee Plans | |
| B.16 | Environmental Evaluation of Devil Canyon Dam and Tunnel Schemes | |
| B.17 | Social Evaluation of Susitna Basin Development | |
| B.18 | Energy Contribution Evaluation of the Devil Canyon | |
| B.19 | Overall Evaluation of Tunnel Scheme and Devil Canyon | |
| B.20 | Environmental Evaluation of Watana/Devil Canyon and | |
| B.21 | Energy Contribution Evaluation of the Watana/Devil | |
| B.22 | Overall Evaluation of the High Devil Canyon/Vee and | |
| B.23 B.24 B.25 | Combined Watana and Devil Canyon Operation Present Worth of Production Costs Design Data and Design Criteria for Final Review | |
| B.26 B.27 B.28 | Evaluation Criteria Summary of Comparative Cost Estimates Design Data and Design Criteria for Review of Alternative Layouts | |
| B.29 B.30 | Summary of Comparative Cost Estimates Energy Potential of Watana - Devil Canyon Developments for Different Reservoir Operating Rules | |

LIST OF TABLES (Continued)

j

| Number | Title |
|--------|--|
| B.31 | Average Annual and Monthly Flow at Gage in the Susitna Basin |
| B.32 | Watana Estimated Natural Flows |
| B.33 | Devil Canyon Estimated Natural Flows |
| B.34 | Peak Flows of Record |
| B.35 | Estimated Flow Peaks in Susitna River |
| B.36 | Estimated Evaporation Losses - Watana and Devil Canyon Reservoirs |
| B.37 | Monthly Flow Requirements |
| B.38 | Minimum Releases at Watana |
| B.39 | Minimum Releases at Devil Canyon |
| в.40 | Water Appropriations Within One Mile of the Susitna River |
| B.41 | Turbine Operating Conditions |
| B.42 | Historical Annual Growth Rates of Electric Utility Sales |
| B.43 | Annual Growth Rates in Utility Customers and |
| B.44 | Itility Sales by Pailbolt Dessent |
| B.45 | Summary of Railbelt Flootwicity Ducingti |
| B.46 | Forecast Total Generation and Peak Loads - Total Railbelt Region |
| B.47 | ISER 1980 Railbelt Region Load and Energy Forecasts Used for Generation Planning Studies for |
| D 10 | Development Selection |
| D.48 | December 1981 Battelle PNL Railbelt Region Load and Energy Forecasts Used for Generation Planning Studios |
| | |

4

EXHIBIT B - PROJECT OPERATION AND RESOURCE UTILIZATION

1 - DAMSITE SELECTION

° V

This section summarizes the previous site selection studies and the studies done during the Alaska Power Authority Susitna Hydroelectric Project Feasibility Study. Additional detail on this topic can be found in the Development Selection Report, Reference 1.

1.1 - Previous Studies

Prior to the undertaking of the Susitna Hydroelectric Project Feasibility Study by the applicant, the hydroelectric development potential of the Alaskan Railbelt had been studied by several entities.

(a) Early Studies of Hydroelectric Potential

Shortly after World War II ended, the United States Bureau of Reclamation (USBR) conducted an initial investigation of hydroelectric potential in Alaska and issued a report of the results in 1948. Responding to a recommendation made in 1949 by the nineteenth Alaska territorial legislature that Alaska be included in the Bureau of Reclamation program, the Secretary of Interior provided funds to update the 1948 work. The resulting report, issued in 1952, recognized the vast hydroelectric potential within the territory and placed particular emphasis on the strategic location of the Susitna River between Anchorage and Fairbanks as well as its proximity to the connecting Railbelt (see Figure B.1).

A series of studies was commissioned over the years to identify damsites and conduct geotechnical investigations. By 1961, the Department of the Interior proposed authorization of a two-dam power system on the Susitna River involving the Devil Canyon and the Denali sites (Figure B.2). The definitive 1961 report was subsequently updated by the Alaska Power Administration (an agency of the USBR) in 1974, at which time the desirability of proceeding with hydroelectric development was reaffirmed.

The Corps of Engineers (COE) was also active in hydropower investigations in Alaska during the 1950s and 1960s, but focused its attention on a more ambitious development at Rampart on the Yukon River. This project was capable of generating five times as much annual electric energy as the prior Susitna proposal. The sheer size and the technological challenges associated with Rampart captured the imagination of supporters and effectively diverted attention from the Susitna Basin for more than a decade. The Rampart report was finally shelved in the early 1970s because of strong environmental concerns and the uncertainty of marketing prospects for so much energy, particularly in light of abundant natural gas which had been discovered and developed in Cook Inlet.

The energy crisis precipitated by the OPEC oil boycott in 1973 provided some further impetus for seeking development of renewable resources. Federal funding was made available both to complete the Alaska Power Administration's update report on Susitna in 1974 and to launch a prefeasibility investigation by the COE. The State of Alaska itself commissioned a reassessment of the Susitna Project by the Henry J. Kaiser Company in 1974.

Although the gestation period for a possible Susitna Project has been lengthy, federal, state, and private organizations have been virtually unanimous over the years in recommending that the project proceed.

Salient features of the various reports to date are outlined in the following sections.

(b) U.S. Bureau of Reclamation - 1953 Study

The USBR 1952 report to the Congress on Alaska's overall hydroelectric potential was followed shortly by the first major study of the Susitna Basin in 1953. Ten damsites were identified above the railroad crossing at Gold Creek. These sites are identified on Figure B.2.

- Gold Creek;

- 01 son;

- Devil Canyon;

- Devil Creek;
- Watana;
- Vee;
- Maclaren;
- Denali:
- Butte Creek; and
- Tyone (on the Tyone River).

Fifteen more sites were considered below Gold Creek. However, more attention has been focused over the years on the Uppro-Susitna Basin where the topography is better suited to dam construction and where less impact on anadromous fisheries is expected. Field reconnaissance eliminated half the original Upper Basin list, and further USBR consideration centered on Olson, Devil Canyon, Watana, Vee, and Denali. All of the USBR studies since 1953 have regarded these sites as the most appropriate for further investigation.

(c) U.S. Bureau of Reclamation - 1961 Study

In 1961 a more detailed feasibility study resulted in a recommended five-stage development plan to match the load growth curve as it was then projected. Devil Canyon was to be the first development--a 635- foot-high arch dam with an installed capacity of about 220 MW. The reservoir formed by the Devil Canyon dam alone would not store enough water to permit higher capacities to be economically installed, since long periods of relatively low flow occur in the winter months. The second stage would have increased storage capacity by adding an earthfill dam at Denali in the upper reaches of the basin. Subsequent stages involved adding generating capacity to the Devil Canyon dam. Geotechnical investigations at Devil Canyon were more thorough than at Denali. At Denali, test pits were dug, but no drilling occurred.

(d) Alaska Power Administration - 1974

Little change from the basic USBR-1961, five-stage concept appeared in the 1974 report by the Alaska Power Administration. This later effort offered a more sophisticated design, provided new cost and schedule estimates, and addressed marketing, economics, and environmental considerations.

(e) Kaiser Proposal for Development

The Kaiser study, commissioned by the Office of the Governor in 1974, proposed that the initial Susitna development consist of a single dam known as High Devil Canyon located on Figure B.2. No field investigations were made to confirm the technical feasibility of the High Devil Canyon location because the funding level was insufficient for such efforts. Visual observations suggested the site was probably favorable. The USBR had always been uneasy about foundation conditions at Denali, but had to rely upon the Denali reservoir to provide storage during long periods of low flow. Kaiser chose to avoid the perceived uncertainty at Denali by proposing to build a rockfill dam at High Devil Canyon which, at a height of 810 feet, would create a large enough reservoir to overcome the storage problem. Although the selected sites were different, the COE reached a similar conclusion when it later chose the high dam at Watana as the first to be constructed.

Subsequent developments suggested by Kaiser included a downstream dam at the Olson site and an upstream dam at a site known as Susitna III (see Figure B.2). The information developed for these additional dams was confined to estimating energy potential. As in the COE study, future development of Denali remained a possibility if foundation conditions were found to be adequate and if the value of additional firm energy provided economic justification at some later date.

(f) U.S. Army Corps of Engineers - 1975 and 1979 Studies

The most comprehensive study of the Upper Susitna Basin prior to the current study was completed in 1975 by the COE. A total of 23 alternative developments were analyzed, including those proposed by the USBR, as well as consideration of coal as the primary energy source for Railbelt electrical needs. The COE agreed that an arch dam at Devil Canyon was appropriate, but found that a high dam at the Watana site would form a large enough reservoir for seasonal storage and would permit continued generation during low flow periods.

The COE recommended an earthfill dam at Watana with a height of 810 feet. In the longer term, development of the Denali site remained a possibility which, if constructed, would increase the amount of firm energy available in dry years.

An ad hoc task force was created by Governor Jay Hammond upon completion of the 1975 COE Study. This task force recommended endorsement of the COE request for Congressional authorization, but pointed out that extensive further studies, particularly those dealing with environmental and socioeconomic questions, were necessary before any construction decision could be made.

At the federal level, concern was expressed at the Office of Management and Budget regarding the adequacy of geotechnical data at the Watana site as well as the validity of the economics. The apparent ambitiousness of the schedule and the feasibility of a thin arch dam at Devil Canyon were also questioned. Further investigations were funded and the COE produced an updated report in 1979. Devil Canyon and Watana were reaffirmed as appropriate sites, but alternative dam types were investigated. A concrete gravity dam was analyzed as an alternative for the thin arch dam at Devil Canyon and the Watana dam was changed from earthfill to rockfill. Subsequent cost and schedule estimates still indicated economic justification for the project.

1.2 - Plan Formulation and Selection Methodology

The proposed plan which is the subject of this license application was selected after a review and reassessment of all previously considered sites. Additional detail in support of the findings in this Exhibit is found in Reference 5.

This section of the report outlines the engineering and planning studies carried out as a basis for formulation of Susitna Basin development plans and selection of the preferred plan. In the description of the planning process, certain plan components and processes are frequently discussed. It is appropriate that three particular terms be clearly defined:

Damsite

- An individual potential damsite in the Susitna Basin, referred to in the generic process as "candidate."

<u>Basin Development</u> - A plan for developing energy within the Upper Susitna Basin involving one or more dams, each of specified height, and corresponding power plants of specified capacity. Each plan is identified by a plan number and subnumber indicating the staging sequence to be followed in developing the full potential of the plan over a period of time.

<u>Generation</u> Scenario

- A specified sequence of implementation of power generation sources capable of providing sufficient power and energy to satisfy an electric load growth forecast for the 1980-2010 period in the Railbelt area. This sequence may include different types of generation sources such as hydroelectric and coal, gas or oil- fired thermal. These generation scenarios were developed for the comparative evaluations of Susitna Basin generation versus alternative methods of generation.

In applying the generic plan formulation and selection methodology, five basic steps are required; defining the objectives, selecting candidates, screening, formulation of development plans, and, finally,, a detailed evaluation of the plans (see Figure 8.3). The objective is to determine the optimum Susitna Basin development plan. The various steps required are outlined in subsections of this section.

Throughout the planning process, engineering layout studies were made to refine the cost estimates for power generation facilities or water storage development at several damsites within the basin. These data were fed into the screening and plan formulation and evaluation studies.

The second objective, the detailed evaluation of the various plans, is satisfied by comparing generation scenarios that include the selected Susitna Basin development plan with alternative generation scenarios, including all-thermal and a mix of thermal plus alternative hydropower developments.

1.3 - Damsite Selection

In previous Susitna Basin studies, twelve damsites were identified in the upper portion of the basin, i.e., upstream from Gold Creek. These sites are listed in Table B.1 with relevant data concerning facilities, cost capacity, and energy.

The longitudinal profile of the Susitna River and typical reservoir levels associated with these sites are shown in Figure B.4. Figure B.5 illustrates which sites are mutually exclusive, i.e., those which cannot be developed jointly, since the downstream site would inundate the upstream site.

All relevant data concerning dam type, capital cost, power, and energy output were assembled and are summarized in Table B.1. For the Devil Canyon, High Devil Canyon, Watana, Susitna III, Vee, Maclaren, and Denali sites, conceptual engineering layouts were produced and capital costs were estimated based on calculated quantities and unit rates. Detailed analyses were also undertaken to assess the power capability and energy yields. At the Gold Creek, Devil Creek, Maclaren, Butte Creek, and Tyone sites, no detailed engineering or energy studies were undertaken; data from previous studies were used with capital cost tial average energy yield at the Butte Creek and Tyone sites were undertaken to assess the relative importance of these sites as energy producers.

The data presented in Table B.1 show that Devil Canyon, High Devil Canyon, and Watana are the most economic large energy producers in the basin. Sites such as Vee and Susitna III have only medium energy production, and slightly more costly that the previously mentioned damsites. Other sites such as Olson and Gold Creek are competitive provided they have additional upstream regulation. Sites such as Denali and Maclaren produce substantially higher cost energy than the other sites but can also be used to increase regulation of flow for downstream use.

(a) <u>Site Screening</u>

The objective of this screening process was to eliminate sites which would obviously not feature in the initial stages of the Susitna Basin development plan and which, therefore, did not deserve further study at this stage. Three basic screening criteria were used: environmental, alternative sites, and energy contribution.

The screening process involved eliminating all sites falling in the unacceptable environmental impact and alternative site categories. Those failing to meet the energy contribution criteria were also eliminated unless they had some potential for upstream regulation. The results of this process, described in detail in Reference 5, are as follows:

- The "unacceptable site" environmental category eliminated the Gold Creek, Olson, and Tyone sites.
- The alternative sites category eliminated the Devil Creek and Butte Creek sites.
- No additional sites were eliminated for failing to meet the energy contribution criteria. The remaining sites upstream from Vee, i.e., Maclaren and Denali, were retained to insure that further study be directed toward determining the need and viability of providing flow regulation in the headwaters of the Susitna.

(b) Engineering Layouts

In order to obtain a uniform and reliable data base for studying the seven sites remaining, it is necessary to develop engineering layouts and reevaluate the costs. In addition, staged developments at several of the larger dams were studied.

The basic objective of these layout studies was to establish a uniform and consistent development cost for each site. These layouts are consequently conceptual in nature and do not necessarily represent optimum project arrangements at the sites. Also, because of the lack of geotechnical information at several of the sites, judgmental decisions had to made on the appropriate foundation and abutment treatment. The accuracy of cost estimates made in these studies is of the order of plus or minus 30 percent.

(i) Design Assumptions

In order to maximize standardization of the layouts, a set of basic design assumptions was developed. These assumptions covered geotechnical, hydrologic, hydraulic, civil, mechanical, and electrical considerations and were used as guidelines to determine the type and size of the various components within the overall project layouts. As stated previously, other than at Watana, Devil Canyon, and Denali, little information regarding site conditions was available. Broad assumptions were made on the basis of the limited data, and those assumptions and the interpretation of data have been conservative.

It was assumed that the relative cost differences between rockfill and concrete dams at the site would either be marginal or greatly in favor of the rockfill. The more detailed studies carried out subsequently for the Watana and Devil Canyon sites support this assumption. Therefore, a rockfill dam has been assumed at all developments in order to eliminate cost discrepancies that might result from a consideration of dam-fill unit costs compared to concrete unit costs at alternative sites.

(ii) General Arrangements

A brief description of the general arrangements developed for the various sites is given below. Descriptions of Watana and Devil Canyon in this section are of the preliminary layouts and should not be confused with the proposed layouts in Exhibit A and Exhibit F. Figures B.6 to B.12 illustrate the layout details. Table B.2 summarizes the crest levels and dam heights considered.

In laying out the developments, conservative arrangements have been adopted, and whenever possible there has been a general standardization of the component structures.

- <u>Devil Canyon</u> (Figure B.6)

The development at Devil Canyon, located at the upper end of the canyon at its narrowest point, consists of a rockfill dam, single spillway, power facilities incorporating an underground powerhouse, and a tunnel diversion.

The rockfill dam would rise above the valley on the left abutment and terminate in an adjoining saddle dam of similar construction. The dam would be 675 feet above the lowest foundation level with a crest elevation of 1470 and a volume of 20 million cubic yards.

The spillway would be located on the right bank and would consist of a gated overflow structure and a concrete-lined chute linking the overflow structure with intermediate and terminal stilling basins. Sufficient spillway capacity would be provided to pass the Probable Maximum Flood safetly.

The power facilities would be located on the right abutment. The massive intake structure would be founded within the rock at the end of a deep approach channel and would consist of four integrated units, each serving individual tunnel penstocks. The powerhouse would house four 150-MW vertically mounted Francis type turbines driving overhead 165 MVA umbrella type generators.

As an alternative to the full power development in the first phase of construction, a staged powerhouse

alternative was also investigated. The dam would be completed to its full height but with a initial plant installed capacity in 300-MW range. The complete powerhouse would be constucted together with penstocks and a tailrace tunnel for the initial two 150-MW units, together with concrete foundations for the future units.

- Watana (Figure B.7 and B.8)

For initial comparative study purposes, the dam at Watana is assumed to be a rockfill structure located on a similar alignment to that proposed in the previous COE studies. It would be similar in construction to the dam at Devil Canyon with an impervious core founded on sound bedrock and an outer shell composed of blasted rock excavated from a single quarry located on the left abutment. The dam would rise 880 feet from the lowest point on the foundation and have an overall volume of approximately 63 million cubic yards for a crest elevation of 2225.

The spillway would be located on the right bank and would be similar in concept to that at Devil Canyon with an intermediate and terminal stilling basin.

The power facilities located within the left abutment with similar intake, underground powerhouse, and water passage concepts to those at Devil Canyon would incorporate four 200-MW turbine/generator units giving a total output of 800-MW.

As an alternative to the initial full development at Watana, staging alternatives were investigated. These included staging of both dam and powerhouse construction. Staging of the powerhouse would be similar to that at Devil Canyon, with a Stage I installation of 400-MW and a further 400-MW in Stage II.

In order to study the alternative dam staging concept it was assumed that the dam would be constructed for a maximum operating water surface elevation some 200 feet lower than that in the final stage (see Figure B.8).

The powerhouse would be completely excavated to its final size during the first stage. Three oversized 135-MW units would be installed together with base concrete for an additional unit. A low level control structure and twin concrete-lined tunnels leading into a downstream stilling basin would form the first stage spillway.

For the second stage, the dam would be completed to its full height, the impervious core would be appropriately raised, and additional rockfill would be placed on the downstream face. It was assumed that before construction commences the top 400 feet of the first stage dam would be removed to ensure the complete integrity of the impervious core for the raised dam. A second spillway control structure would be constructed at a higher level and would incorporate a downstream chute leading to the Stage I spillway structure. The original spillway tunnels would be closed with concrete plugs. A new intake structure would be constructed utilizing existing gates and hoists, and new penstocks would be driven to connect with the existing ones. The existing intake would be sealed off. One additional 200 MW unit would be installed and the required additional penstock and tailrace tunnel constructed. The existing 135-MW units would be upgraded to 200 MW.

- <u>High Devil Canyon</u> (Figure B.9)

The development would be located between Devil Canyon and Watana. The 855 feet high rockfill dam would be similar in design to Devil Canyon, containing an estimated 48 million cubic yards of rockfill with a crest elevation of 1775. The left bank spillway and the right bank powerhouse facilities would also be similar in concept to Devil Canyon, with an installed capacity of 800-MW.

Two stages of 400-MW were envisaged in each which would be undertaken in the same manner as at Devil Canyon, with the dam initially constructed to its full height.

- <u>Susitna III</u> (Figure B.10)

The development would involve a rockfill dam with an impervious core approximately 670 feet high, a crest elevation of 2360, and a volume of approximately 55 million cubic yards. A concrete-lined spillway chute and a single stilling basin and would be located underground and the two diversion tunnels on the left bank.

- Vee (Figure B.11)

A 610 feet high rockfill dam founded on bedrock with a crest elevation of 2350 and total volume fo 10 million cubic yards was considered.

Since Vee is located further upstream than the other major sites the flood flows are correspondingly lower, thus

allowing for a reduction in size of the spillway facilities. A spillway utilizing a gated overflow structure, chute, and flip bucket was adopted.

The power facilities would consist of a 400-MW underground powerhouse located in the left bank with a tailrace outlet well downstream of the main dam. A secondary rockfill dam would also be required in this vicinity to seal off a low point. Two diversion tunnels would be provided on the right bank.

- Maclaren (Figure B.12)

The development would consist of a 185 feet high earthfill dam founded on pervious riverbed materials. The crest elevation of the dam would be 2405. This reservoir would essentially be used for reglating purposes. Diversion would occur through three conduits located in a open cut on the left bank and floods would be discharged via a side chute spillway and stilling basin on the right bank.

- Denali (Figure B.12)

Denali is similar in concept to Maclaren. The dam would be 230 feet high, of earthfill construction, and would have a crest elevation of 2555. As for Maclaren, no generating capacity would be included. A combined diversion and spillway facility would be provided by twin concrete conduits founded in open cut excavation in the right bank and discharging into a common stilling basin.

(c) <u>Capital Costs</u>

For purposes of initial comparisons of alternatives, construction quantities were determined for items comprising the major works and structures at the site. Where detail or data were not sufficient for certain work, quantity estimates were made on the basis of previous Acres' experience and the general knowledge of site conditions reported in the literature. In order to determine total capital costs for various structures, unit costs have been developed for the items measured. These have been estimated on the basis of review of rates used in previous studies, and of rates used on similar works in Alaska and elsewhere. Where applicable, adjustment factors based on geography, climate, manpower and accessibility were used. Technical publications have also been reviewed for basic rates and escalation factors.

The total capital costs developed are shown in Table B.1 and B.2. It should be noted that the capital costs for Maclaren and Denali shown in Table B.1 have been adjusted to incorporate the costs of generation plants with capacities of 55-MW and 60-MW, respectively. Additional data on the projects are summarized in Table B.3.

1.4 - Formulation of Susitna Basin Development Plans

The results of the site screening process described above indicate that the Susitna Basin development plan should incorporate a combination of several major dams and powerhouses located at one or more of the following sites:

- Devil Canyon;

- High Devil Canyon;
- Watana;
- Susitna III; or

- Vee.

Supplementary upstream flow regulation could be provided by structures at:

- Maclaren; and - Denali.

Cost estimates of these projects are itemized on Table B.4.

A computer assisted screening process identified the plans that are most economic as those of Devil Canyon/Watana or High Devil Canyon/Vee. In addition to these two basic development plans, a tunnel scheme which provides potential environmental advantages by replacing the Devil Canyon dam with a long power tunnel and a development plan involving Watana Dam was also introduced.

The criteria used at this stage of the process for selection of preferred Susitna Basin development plans are mainly economic (see Figure B.3). Environmental considerations are incorporated into the further assessment of the plans finally selected.

The results of the screening process are shown in Table B.5. Because of the simplifying assumptions that were made in the screening model, the three best solutions from an economic point of view are included in the table.

The most important conclusions that can be drawn are as follows:

- For energy requirements of up to 1,150 Gwh, the High Devil Canyon, Devil Canyon or the Watana sites individually provided the most economic energy. The difference between the costs shown on Table B.4 is around 10 percent, which is similar to the accuracy that can be expected from the screening model. - For energy requirements of between 1,750 and 3,500 Gwh, the High Devil Canyon site is the most economic.

- For energy requirements of between 3,500 and 5,250 Gwh the combinations of either Watana and Devil Canyon or High Devil Canyon and Vee are most economic.
- The total energy production capability of the Watana/Devil Canyon developments is considerably larger than that of the High Devil Canyon/Vee alternative and is the only plan capable of meeting energy demands in the 6,000 Gwh range.

(a) Tunnel Alternative

A scheme involving a long power tunnel could conceivably be used to replace the Devil Canyon dam is the Watana/Devil Canyon development plan. It could develop similar head for power generation and may provide some environmental advantages by avoiding inundation of Devil Canyon. Obviously, because of the low winter flows in the river, a tunnel alternative could be considered only as a second stage to the Watana development.

Conceptually, the tunnel alternatives would comprise the following major components in some combination, in addition to the Watana dam reservoir and associated powerhouse:

- Power tunnel intake works;

- One or two power tunnels of up to forty feet in diameter and up to thirty miles in length;
- A surface or underground powerhouse with a capacity of up to 1200 MW;
- A re-regulation dam if the intake works are located downstream from Watana; and
- Arrangements for compensation flow in the bypassed river reach.

Four basic alternative schemes were developed and studied. Figure B.13 is a schematic illustration of these schemes. All schemes assumed an initial Watana development with full reservoir supply level at Elevation 2200 and the associated powerhouse with an installed capacity of 800 MW. Table B.6 lists all the pertinent technical information. Table B.7 lists the power and energy yields for the four schemes. Table B.8 itemizes the capital cost estimate.

Based on the foregoing economic information, Scheme 3 (Figures B.14 and B.15) produces the lowest cost energy by a factor of nearly 2.

A review of the environmental impacts associated with the four tunnel schemes indicates that Scheme 3 would have the least impact, primarily because it offers the best opportunities for regulating daily flows downstream from the project. Based on this assessment, and because of its almost 2 to 1 economic advantage, Scheme 3 was selected as the only scheme worth further study (see Development Selection Report for detailed analysis). The capital cost estimate for Scheme 3 appears in Table B.8. The estimates also incorporate single and double tunnel options. For purposes of these studies, the double tunnel option has been selected because of its superior reliability. It should also be recognized that the cost estimates associated with the tunnels are probably subject to more variation than those associated with the dam schemes due to geotechnical uncertainties. In an attempt to compensate for these uncertainties, economic sensitivity analyses using both higher and lower tunnel costs have been conducted.

(b) Additional Basin Development Plan

As noted, the Watana and High Devil Canyon dam sites appear to be individually superior in economic terms to all others. An additional plan was therefore developed to assess the potential for developing these two sites together. For this scheme, the Watana dam would be developed to its full potential. The High Devil Canyon dam would be constructed to a crest elevation of 1470 feet to fully utilize the head downstream from Watana.

(c) <u>Selected Basin Development Plans</u>

The essential objectives of this step in the development selection process is defined as the identification of those plans which appear to warrant further, more detailed evaluation. The results of final screening process indicate that the Watana/Devil Canyon and the High Devil Canyon/Vee plans are clearly superior to all other dam combinations. In addition, it was decided to study further tunnel Scheme 3 as an alternative to the High Devil Canyon dam and a plan combining a Watana,'High Devil Canyon.

Associated with each of these plans are several options for staged development. For this more detailed analysis of these basic plans, a range of different approaches to staging the developments was considered. In order to keep the total options to a reasonable number and also to maintain reasonably large staging steps consistent with the total development size, staging of only the two larger developments, i.e., Watana and High Devil Canyon, was considered. The basic staging concepts adopted for these developments involved staging both dam and powerhouse construction, or alternatively just staging powerhouse construction. Powerhouse stages were considered in 400 MW increments. Four basic plans and associated subplans are briefly described below. Plan 1 involves the Watana-Devil Canyon sites, Plan 2 the High Devil Canyon-Vee sites, Plan 3 the Watana-tunnel concept, and Plan 4 the Watana-High Devil Canyon sites. Under each plan several alternative subplans were identified, each involving a different staging concept. Summaries of these plans are given in Table B.9.

(i) Plan 1

4

- <u>Subplan 1.1</u>: The first stage involves constructing Watana dam to its full height and installing 800 MW. Stage 2 involves constructing Devil Canyon dam and installing 600 MW.

- <u>Subplan 1.2</u>: For this Subplan, construction of the Watana dam is staged from a crest elevation of 2060 feet to 2225 feet. The powerhouse is also staged from 400 MW to 800 MW. As for Subplan 1.1, the final stage involves Devil Canyon with an installed capacity of 600 MW.
- <u>Subplan 1.3</u>: This Subplan is similar to Subplan 1.2 except that only the powerhouse and not the dam at Watana is staged.

(ii) <u>Plan 2</u>

- <u>Subplan 2.1</u>: This Subplan involves constructing the High Devil Canyon dam first with an installed capacity of 800 MW. The second stage involves constructing the Vee dam with an installed capacity of 400 MW.
- <u>Subplan 2.2</u>: For this Subplan, the construction of High Devil Canyon is staged from a crest elevation of 1630 to 1775 feet. The installed capacity is also staged from 400 to 800 MW. As for Subplan 2.1, Vee follows with 400 MW of installed capacity.
- <u>Subplan 2.3</u>: This Subplan is similar to Subplan 2.2 except that only the powerhouse and not the dam at High Devil Canyon is staged.

(iii) <u>Plan 3</u>

- <u>Subplan 3.1</u>: This Subplan involves initial construction of Watana and installation of 800 MW capacity. The next stage involves the construction of the downstream reregulation dam to a crest elevation of 1500 feet and a 15 mile long tunnel. A total of 300 MW would be installed at the end of the tunnel and a further 30 MW at the reregulation dam. An additional 50 MW of capacity would be installed at the Watana powerhouse to facilitate peaking operations. - <u>Subplan 3.2</u>: This Subplan is essentially the same as Subplan 3.1 except that construction of the initial 800 MW powerhouse at Watana is staged.

(iv) <u>Plan 4</u>

This single plan was developed to evaluate the development of the two most economic dam sites, Watana and High Devil Canyon, jointly. Stage 1 involves constructing Watana to its full height with an installed capacity of 400 MW. Stage 2 involves increasing the capacity at Watana to 800 MW. Stage 3 involves constructing High Deveil Canyon to a crest elevation of 1470 feet so that the reservoir extends to just downstream of Watana. In order to develop the full head between Watana and Portage Creek, an additional smaller dam is added downstream of High Devil Canyon. This dam would be located just upstream from Portage Creek so as not to interfere with the anadromous fisheries and would have a crest elevation of 1030 feet and an installed capacity of 150 MW. For purposes of these studies, this site is referred to as the Portage Creek site.

1.5 - Evaluation of Basin Development Plan

The overall objective of this step in the evaluation process was to select the preferred basin development plan. A preliminary evaluation of plans was initially undertaken to determine broad comparisons of the available alternatives. This wis followed by appropriate adjustments to the plans and a more detailed evaluation and comparison.

In the process of initially evaluating the final four schemes, it became apparent that there would be environmental problems associated with allowing daily peaking operations from the most downstream reservoir in each of the plans described above. In order to avoid these potential problems while still maintaining operational flexibility to peak on a daily basis, re-regulation facilities were incorporated in the four basic plans. These facilities incorporate both structural measures such as re-regulation dams and modified operational procedures. Details of these modified plans, referred to as E1 to E4, are listed in Table B.10.

The plans listed in Table B.10 were subjected to a more detailed analysis as described in the following section.

(a) Evaluation Methodology

The approach to evaluating the various basin development plans described above is twofold:

- For determining the optimum staging concept associated with each basic plan (i.e., the optimum subplan), only economic criteria are used and the least cost staging concept is adopted.
- For assessing which plan is the most appropriate, a more detailed evaluation process incorporating economic, environmental, social and energy contribution aspects is taken into account.

Economic evaluation of any Susitna Basin development plan requires that the impact of the plan on the cost of energy to the Railbelt area consumer be assessed on a systemwide basis. Since the consumer is supplied by a large number of different generating sources, it is necessary to determine the total Railbelt system cost in each case to compare the various Susitna Basin development options.

The primary tool used for system costs was the mathematical model developed by the Electricity Utility Systems Engineering Department of the General Electric Company. The model is commonly known as OGP5 or Optimized Generation Planning Model, Version 5. The following information is paraphrased from GE literature on the program.

The OGP5 program was developed over ten years to combine the three main elements of generation expansion planning (system reliability, operating and investment costs) and automate generation addition decision analysis. OGP5 will automatically develop optimum generation expansion patterns in terms of economics, reliability and operation. Many utilities use OGP5 to study load management, unit size, capital and fuel costs, energy storage, forced outage rates, and forecast uncertainty.

The OGP5 program requires an extensive system of specific data to perform its planning function. In developing an optimal plan, the program considers the existing and committed units (planned and under construction) available to the system and the characteristics of these units including age, heat rate, size and outage rates as the base generation plan. The program then considers the given load forecast and operation criteria to determine the need for additional system capacity based on given reliability criteria. This determines "how much" capacity to add and "when" it should be installed. If a need exists during any monthly iteration, the program will consider additions from a list of alternatives and select the available unit best fitting the system needs. Unit selection is made by computing production costs for the system for each alternative included and comparing the results.

The unit resulting in the lowest system production cost is selected and added to the system. Finally, an investment cost analysis of the capital costs is completed to answer the question of "what kind" of generation to add to the system. The model is then further used to compare alternative plans for meeting variable electrical demands, based on system reliability and production costs for the study period.

A minor limitation inherent in the use of the OGP5 model is that the number of years of simulation is limited to 20. To overcome this, the study period of 1980 to 2040 has been broken into three separate segments for study purposes. These segments are common to all system generation plans.

The first segment has been assumed to be from 1980 to 1990. The model of this time period included all committed generation units and is assumed to be common to all generation scenarios.

The end point of this model becomes the beginning of each 1990-2010 model.

The model of the first two time periods considered (1980 to 1990, and 1990 to 2010) provides the total production costs on a yearto-year basis. These total costs include, for the period of modeling, all costs of fuel and operation and maintenance of all generating units included as part of the system. In addition, the completed production costs includes the annualized investment costs of any production plans added during the period of study. A number of factors which contribute to the ultimate cost of power to the consumer, are not included in this model. These are common to all scenarios and include:

- All investment costs to plants in service prior to 1981;

- Costs of transmission systems in service both at the transmission and distribution level; and

- Administrative costs of utilities for providing electric service to the public.

Thus, it should be recognized that the production costs modeled represent only a portion of ultimate consumer costs and in effect are only a portion, albeit major, of total costs.

The third period, 2010 to 2040, was modeled by assuming that production costs of 2010 would recur for the additional 30 years to 2040. This assumption is believed to be reasonable given the limitations on forecasting energy and load requirements for this period. The additional period to 2040 is required to at least take into account the benefit derived or value of the addition of hydroelectric power plant which has a useful life of fifty years or more. The selection of the preferred generation plan is based on numerous factors. One of these is the cost of the generation plan. To provide a consistent means of assessing the production cost of a given generation scenario, each production cost total has been converted to a 1980 present worth basis. The present worth cost of any generation scenario is made up of three cost amounts. The first is present worth cost (PWC) of the first ten years of study (1981 to 1990), the second is the PWC of the scenario assumed during 1990 to 2010 and the third the PWC of the scenario in 2010 assumed to recur for the period 2010 to 2040. In this way the long-term (60 years) PWC of each generation scenario in 1980 dollars can be compared.

A summary of the input data to the model and a discussion of the results follow.

(i) Initial Economic Analyses

Table B.11 lists the results of the first series of economic analyses undertaken for the basic Susitna Basin development plans listed in Table B.10. The information provided includes the specified on-line dates for the various stages of the plans, the OGP5 run index number, the total installed capacity at year 2010 by category, and the total system present-worth cost in 1980 for the period 1980 to 2040. Matching of the Susitna development to the load growth for Plans El, E2, and E3 is shown in Figure B.16, B.17 and B.18 After 2010, steady state conditions are respectively. assumed and the then-existing generation mix and annual costs for 2010 are applied to the years 2011 to 2040. This extended period of time is necessary to ensure that the hydroelectric options being studied, many of which only come on-line around 2000, are simulated as operating for periods approaching their economic lives and that their full impact on the cost of the generation system is taken into account.

- Plan El - Watana/Devil Canyon

. Staging the dam at Watana (Plan E1.2) is not as economic as constructing it to its full height (Plan E1.1 and E1.3). The present worth advantage of not staging the dam amounts to \$180 million in 1980 dollars.

The results indicate that, with the level of analysis performed, there is no discernible benefit in staging construction of the Watana powerhouse (Plan E1.1 and E1.3). However, Plan E1.4 results indicates that, should the powerhouse size at Watana be restricted to 400 MW, the overall system present worth would increase. Additional runs performed for variations of Plan E1.3 indicated that system present worth would increase by \$1,110 million if the Devil Canyon dam was not constructed. A five year delay in construction of the Watana dam would increase system present worth by \$220 million.

- Plan E2 - High Devil Canyon/Vee

. The results for Plan E2.3 indicate that the system present worth is \$520 million more than Plan E1.3. Present worth increases also occur if the Vee dam stage is not constructed. A reduction in present worth of approximately \$160 million is possible if the Chakachamna hydroelectric project is constructed instead of the Vee dam.

. The results of Plan E2.1 indicate that total system present worth would increase by \$250 million if the total capacity at High Devil Canyon were limited to 400 MW.

- Plan E3 - Watana/Tunnel

The results for Plan E3.1 illustrate that the tunnel scheme versus the Devil Canyon dam scheme (E1.3) adds approximately \$680 million to the total system present worth cost. The availability of reliable geotechnical data would undoubtedly have improved the accuracy of the cost estimates for the tunnel alternative. For this reason, a sensitivity analysis was made as a check to determine the effect of halving the tunnel costs. This analysis indicates that the tunnel scheme is still more costly than constructing the Devil Canyon dam.

- Plan E4 - Watana/High Devil Canyon/Portage Creek

The results indicate that system present worth associated with Plan E4.1, excluding the Portage Creek site development, are \$200 million more than the equivalent E1.3 plan. If the Portage Creek development is included, the present worth difference would be even greater.

(ii) Load Forecast Sensitivity Analyses

The plans with the lowest present-worth cost were subjected to further sensitivity analyses to assess the economic impacts of various load growths. These results are summarized in Table B.12. The results for low load forecasts illustrate that the most viable Susitna Basin development plan is the Watana-Devil Canyon plan with a capacity of 800 MW, which has a present worth cost of \$210 million less than its closest competitor, the High Devil Canyon-Vee plan.

For the high load forecasts, the results indicate that the Plan E1.3 has a present worth cost of \$1040 million less than E2.3.

(b) Evaluation Criteria

The following criteria were used to evaluate the shortlisted basin development plans. These criteria generally contain the requirements of the generic process with the exception that an additional criterion, energy contribution, is added in order to ensure that full consideration is given to the total basin energy potential developed by the various plans.

(i) <u>Economic</u>

Plans were compared using long-term present worth costs, calculated using the OGP5 generation planning model. The parameters used in calculating the total present-worth cost of the total Railbelt generating system for the period 1980 to 2040 are listed in Table B.13 and B.14. Load forecasts used in the analysis are presented in Section 5.1(b).

(ii) Environmental

A qualitative assessment of the environmental impact on the ecological, cultural, and aesthetic resources is undertaken for each plan. Emphasis is placed on identifying major concerns so that these could be combined with the other evaluation attributes in an overall assessment of the plan.

(iii) Social

This attribute includes determination of the potential nonrenewable resource displacement, the impact on the state and local economy, and the risks and consequences of major structural failures due to seismic events. Impacts on the economy refer to the effects of an investment plan on economic variables.

(iv) Energy Contribution

The parameter used is the total amount of energy produced from the specific development plan. An assessment of the energy development foregone is also undertaken. The energy loss that is inherent to the plan and cannot easily be recovered by subsequent staged developments is of greatest concern.

(c) <u>Results of Evaluation Process</u>

The various attributes outlined above have been determined for each plan and are summarized in Tables B.15 through B.23. Some of the attributes are quantitative while others are qualitative. Overall evaluation is based on a comparison of similar types of attributes for each plan. In cases where the attributes associated with one plan all indicate equality or superiority with respect to another plan, the decision as to the best plan is clear In other cases where some attributes indicate superiority cut. and others inferiority, differences are highlighted and trade-off decisions are made to determine the preferred development plan. In cases where these trade-offs have had to be made, they were relatively straightforward, and the decision-making process can, therefore, be regarded as effective and consistent. In addition, these trade-offs are clearly identified so the recorder can independently assess the judgment decisions made.

The overall evaluation process is conducted in a series of steps. At each step, only two plans are compared. The superior plan is then taken to the next step for evaluation against a third plan.

(i) Devil Canyon Dam Versus Tunnel

· · · · ·

ſ.

The first step in the process involves the comparison of the Watana-Devil Canyon dam plan (E1.3) and the Watana-Tunnel plan (E3.1). Since Watana is common to both plans, the evaluation is based on a comparison of the Devil Canyon dam and Scheme 3 tunnel alternative.

In order to assist in the evaluation in terms of economic criteria, additional information obtained by analyzing the results of the OGP5 computer runs is shown in Table B.15. This information illustrates the breakdown of the total system present worth cost in terms of capital investment, fuel, and operation and maintenance costs.

- Economic Comparison

From an economic point of view, the Watana-Devil Canyon dam scheme is superior. As summarized in Tables B.15 and B.16, on a present worth basis the tunnel scheme is \$680 million more expensive than the dam scheme. For a low demand growth rate, this cost difference would be reduced slightly to \$650 million. Even if the tunnel scheme costs are halved, the total cost difference would still amount to \$380 million. As highlighted in Table B.16 consideration of the sensitivity of the basic econopmic evaluation to potential changes in capital cost estimate, the period of economic analysis, the discount rate, fuel costs, fuel cost escalation, and economic plant life do not change the basic economic superiority of the dam scheme over the tunnel scheme.

- Environmental Comparison

The environmental comparison of the two schemes is summarized in Table B.17. Overall, the tunnel scheme is judged to be superior because:

. It offers the potential for enhancing anadromous fish populations downstream of the re-regulation dam due to the more uniform flow distribution that will be achieved in this reach;

. It would inundate 13 miles less of resident fisheries habitat in river and major tributaries;

- . It has a lower potential for inundating archeological sites due to smaller reservoir involved; and
- . It would preserve much of the characteristics of the Devil Canyon gorge which is considered to be an aesthetic and recreational resource.

- <u>Social Comparison</u>

Table B.18 summarizes the evaluation in terms of the social criteria of the two schemes. In terms of impact on state and local economics and risks because of seismic exposure, the two schemes are rated equal. However, the dam scheme has, due to its higher energy yield, more potential for displacing nonrenewable energy resources, and therefore has a slight overall advantage in terms of the social evaluation criteria.

- Energy Comparison

Table B.19 summarizes the evaluation in terms of the energy contribution criteria. The results shown that the dam scheme has a greater potential for energy production and develops a larger portion of the basin's potential. The dam scheme is therefore judged to be superior from the energy contribution standpoint.

- Overall Comparison

The overall evaluation of the two schemes is summarized in Table B.20. The estimated cost saving of \$680 million in favor of the dam scheme plus the additional energy produced are considered to outweigh the reduction in the overall environmental impact of the tunnel scheme. The dam scheme is therefore judged to be superior overall.

(ii) Watana-Devil Canyon Versus High Devil Canyon-Vee

The second step in the development selection process involves an evaluation of the Watana-Devil Canyon (E1.3) and the High Devil Canyon-Vee (E2.3) development plans.

- Economic Comparison

In terms of the economic criteria (see Table B.15 and B.16) the Watana-Devil Canyon plan is less costly by \$520 willion. Consideration of the sensitivity of this decision to potential changes in the various parameters considered (i.e., load forecast, discounted rates, etc.) does not change the basic superiority of the Watana-Devil Canyon Plan.

- Environmental Comparison

The evaluation in terms of the environmental criteria is summarized in Table B.21. In assessing these plans, a reach-by-reach comparison was made for the section of the Susitna River between Portage Creek and the Tyone River. The Watana-Devil Canyon scheme would create more potential environmental impacts in the Watana Creek area. However, it is judged that the potential environmental impacts which would occur above the Vee Canyon dam with a High Devil Canyon-Vee development are more severe in overall comparison.

Of the seven environmental factors considered in Table B.17, except for the increased loss of river valley, bird and black bear habitat the Watana-Devil Canyon development plan is judged to be more environmentally acceptable than the High Canyon-Vee plan.

- Energy Comparison

The evaluation of the two plans in terms of energy contribution criteria is summarized in Table B.22. The Watana-Devil Canyon scheme is assessed to be superior because of its higher energy potential and the fact that it develops a higher proportion of the basin's energy potential.

- Social Comparison

Table B.18 summarizes the evaluation in terms of the social criteria. As in the case of the dam versus tunnel comparison, the Watana-Devil Canyon plan is judged to have a slight advantage over the High Devil Canyon-Vee plan. This is because of its greater potential for displacing nonrenewable resources.

1.6 - Preferred Susitna Basin Development Plan

One-on-one comparisons of the Watana-Devil Canyon plan with the Watanatunnel plan and the High Devil Canyon-Vee plans are judged to favor the Watana-Devil Canyon plan in each case.

The Watana-Devil Canyon plan was therefore selected as the preferred Susitna Basin development plan, and the basis for continuation of more detailed design optimization and environmental studies.

υ

2 - ALTERNATIVE FACILITY DESIGNS, PROCESSES AND OPERATIONS

2.1 - Susitna Hydroelectric Development

As originally conceived the Watana project initially comprised an earthfill dam, with a crest elevation of 2225 and 400 MW of generating capacity scheduled to commence operation in 1993. An additional 400 MW would be brought on-line in 1996. At Devil Canyon an additional 400 MW would be installed to commence operation in the year 2000. Detailed studies of each project have led to refinement and optimization of designs in terms of a number of key factors, including updated load forecasts and economics. Geotechnical and environmental constraints identified as a result of continuing field work have also greatly influenced the currently recommended design concepts.

Plan formulation and alternative facility designs considered for the Watana and Devil Canyon developments are discussed in this section.

This section includes the alternatives studied and the reason for selecting the proposed plan. Background information on the site characteristics as well as additional detail on the plan formulation process are included in the Design Report of Exhibit F and the referenced reports.

2.2 - Watana Project Formulation

This section describes the evolution of the general arrangement of the Watana project which, together with the Devil Canyon project, comprises the development plan proposed. The process by which reservoir operating levels and the installed generating capacity of the power facilities were established is presented, together with the means of handling floods expected during construction and subsequent project operation.

The main components of the Watana development are as follows:

- Main dam;

- Diversion facilities:
- Spillway facilities:
- Outlet facilities;
- Emergency release facilities; and
- Power facilities.

A number of alternatives are available for each of these components and they can be combined in a number of ways. The following paragraphs

describe the various components and methodology for the preliminary, intermediate, and final screening and review of alternative general arrangement of the components, together with a brief description of the selected scheme. This section presents the alternative urrangements studied for the Watana project.

(a) Selection of Reservoir Levels

The selected elevation of the Watana dam crest is based on considerations of the value of the hydroelectric energy produced from the associated reservoir, geotechnical constraints on reservoir levels, and freeboard requirements. Firm energy, average annual energy, construction costs, and operation and maintenance costs were determined for the Watana development with dam crest elevations of 2240, 2190, and 2140. The relative value of energy produced in terms of the present worth of the long-term production costs (LTPW) for each of these three dam elevations was determined by means of the OGP5 generation planning model described in Section 1 of this Exhibit. The physical constraints imposed on dam height and reservoir elevation by geotechnical considerations were reviewed and incorporated into the crest elevation selection process. Finally, freeboard requirements for the PMF and settlement of the dam after construction or as a result of seismic activity were taken into account.

(i) Methodology

Firm and average annual energy produced by the Susitna development are based on 32 years of hydrological records. The energy produced was determined by using a multireservoir simulation of the operation of the Watana and Devil Canyon reservoirs. A variety of reservoir drawdowns were examined, and drawdowns producing the maximum firm energy consistent with engineering feasibility and cost of the intake structure were selected. Minimum flow requirements were established at both project sites based on downstream fisheries considerations.

To meet system demand the required maximum generating capability at Watana in the period 1993 and 2010 ranges from 665 MW to 908 MW. For the reservoir level determinations, energy estimates were made on the basis of assumed average annual capacity requirements of 680 MW at Watana in 1993, increasing to 1020 MW at Watana in 2007, with an additional 600 MW at Devil Canyon coming online in the year 2002. The long term present worth costs of the generation system required to meet the Railbelt energy demand were then determined for each of the three crest elevations of the Watana dam using the OGP5 model. The construction cost estimates used in the OGP5 modeling process for the Watana and Devil Canyon projects were based on preliminary conceptual layouts and construction schedules. Further refinement of these layouts has taken place during the optimization process. These refinements have no significant impact on the reservoir level selection.

(ii) Economic Optimization

Economic optimization of the Watana reservoir level was based on an evaluation of three dam crest elevations of 2240, 2190, and 2140. These crest elevations apply to the central portion of the embankment with appropriate allowances for freeboard and seismic settlement, and correspond to maximum operating levels of the reservoir of 2215, 2165, and 2115 feet, respectively. Average annual energy calculated for each case using the reservoir simulation model are given in Table B.24, together with corresponding project construction costs.

In the determination of LTPW, the Susitna capital costs were adjusted to include an allowance for interest during construction and then used as input to the OGP5 model. Simulated annual energy yields were distributed on a monthly basis by the reservoir operation model to match as closely as possible the projected monthly energy demand of the Railbelt and then input to the OGP5 model. The LTPW of meeting the Railbelt energy demand using the Susitna development as the primary source of energy was then determined for each of the three reservoir levels.

The results of these evaluations are shown in Table B.25, and plots showing the variation of the LTPW with dam crest elevation are shown in Figure B.19. This figure indicates that on the basis of the assumptions used, the minimum LTPW occurs at a Watana crest elevation ranging from approximately 2160 to 2200 (reservoir levels 2140 to 2180 feet). A higher dam crest will still result in a development which has an overall net economic benefit relative to thermal energy sources. However, it is also clear that as the height of the Watana dam is increased, the unit costs of additional energy produced at Watana is somewhat greater than for the displaced thermal energy source. Hence, the LTPW of the overall system would increase. Conversely, as the height of the dam is lowered, and thus Watana produces less energy, the unit cost of the energy produced by a thermal generation source to replace the lost Susitna energy is more expensive than Susitna energy. In this case also, the LTPW increases.
(iii) Geotechnical Considerations

On the north side of the reservoir created by the Watana dam a relict channel of considerable depth connects the reservoir to Tsusena Creek. As the water surface elevation of the reservoir is increased up to and beyond 2200 feet, a low area in the relict channel would require costly water retaining structures to be built and other measures to be taken. In addition to the cost the technical feasibility of these measures is not as certain as desired on a project of this magnitude. Because of the considerations relating to seismic stability, seepage problems and permafrost conditions in the relict channel area, the hydraulic head at the upstream end of the relict channel should be limited wherever possible. By comparing normal reservoir levels plus flood surcharge to ground surface contours, it was determined that with normal reservoir levels of 2185 and a small freeboard dike the following conditions would exist:

- For flood magnitudes up to the 1:10,000-year event, there would be no danger of overtopping the lowest point in the relict channel.
- For the PMF a freeboard dike in the low area of up to 10 feet in height would provide adequate protection. This dike would be wetted only a few days during a PMF event.
- If seismic settlement or settlement due to permafrost melting did occur, the combination of the 10 feet freeboard dike constructed on a suitable foundation plus normal reservoir level of 2185 feet would ensure that breakthrough in the relict channel area would not occur.

With this approach, the Watana project will develop the maximum energy reasonably available without incurring the need for costly water retaining structures in the relict channel area.

(iv) Conclusions

It is important to establish clearly the overall objective used as a basis for setting the Watana reservoir level. An objective which would minimize the LTPW energy cost would lead to selection of a slightly lower reservoir level than an objective which would maximize the amount of energy which can be obtained from the available resource, while doing so with a technically sound project.

The three values of LTPW developed by the OGP5 computer runs defined a relationship between LTPW and Watana dam

height which is relatively insensitive to dam height. This is highlighted by the curve of LTPW versus dam height in Figure B.19. This figure shows there is only a slight variation in the LTPW for the range of dam heights included in the analysis. Thus, from an economic standpoint the optimum crest elevation could be considered as varying over a range of elevations from 2140 to 2220 with little effect on project economics. The main factors in establishing the upper limit of dam height were consequently the geotechnical considerations discussed in (c) above.

The normal maximum operating level of the reservoir was therefore set at Elevation 2185, allowing the objective of maximizing the economic use of the Susitna resource still to be satisfied.

(b) Selection of Installed Capacity

The generating capacity to be installed at both Watana and Devil Canyon was determined on the basis of generation planning studies described in Sections 6 and 8 of Reference 4 together with appropriate consideration of the following:

- Available firm and average energy from Watana and Devil Canyon;
- The forecast energy demand and peak load demand of the system;
- Available firm and average energy from other existing and committed plant;
- Capital cost and annual operating costs for Watana and Devil Canyon;
- Capital cost and annual operating costs for alternative sources of energy and capacity;

- Environmental constraints on reservoir operation; and

- Turbine and generator operating characteristics.

(i) Methodology

The following procedure was used to select the installed capacity at Watana:

- The firm and average energy available at both Watana and Devil Canyon was determined using a reservoir simulation program.
- A determination was then made of the generating capacity required to utilize the available energy from the Susitna Project in the hydrological years of record, based on the following assumptions:

. In a wet year, energy developed at either Watana or Devil Canyon displaces excess thermal energy (from coal, gas turbine, combined cycle, or diesel plants).

- . In an average year where thermal energy is required to meet system energy demand, hydro energy is used either to satisfy peak demand with thermal energy supplying base load (Option 1) or to supply base load requirements with thermal energy at peak demand (Option 2). The actual choice is based on dispatching the most economic energy first.
- . Devil Canyon energy is used predominantly as base load energy because of environmental constraints on downstream flow variations.
- . The maximum installed capacity was determined on the basis of the established peak generating capacity required plus any hydro standby or spinning reserve equipment.

(ii) Watana Installed Capacity

The required total capacity at Watana in a wet year, excluding standby and spinning reserve capacity, is summarized below. The capacities are based on the medium load forecast.

| | Capacity (MW) | | | | | |
|----------------------------------|----------------|-----------------|-------------------------|----------------|-----------------|-------------------------|
| | Option 1 | | Option 2 | | | |
| Demand Year | Watana Peak | Thermal Base | Devil Canyon Base | Watana Base | Thermal Peak | Devil Canyon Base |
| 1993 | 801 | 0 | 0 | 801 | 0 | 0 |
| 1995 | 839 | 0 | 0 | 839 | 0 | 0 |
| 2000 | 974 | 66 | 0 | 742 | 198 | 0 |
| 2002 (Including Devil Canyon) | 660 | 0 | 354 | 660 | 0 | 354 |
| 2005 (Including Devil Canyon) | 750 | 0 | 376 | 750 | 0 | 376 |
| 2010 (Including Devil Canyon) | 900 | 0 | 493 | 900 | 0 | 493 |

On the basis of this evaluation, the ultimate power generation capability at Watana was selected as 1020 MW for design purposes to allow a margin for hydro spinning reserve and standby for forced outage. This installation also provides a small margin in the event that the load growth exceeds the medium load forecast.

(iii) Unit Capacity

Selection of the unit size for a given total capacity is a compromise between the initial least cost solution, generally involving a scheme with a smaller number of large capacity units, and the improved plant efficiency and security of operation provided by a larger number of smaller capacity units. Other factors include the size of each unit as a proportion of the total system load and the minimum anticipated load on the station. Any requirement for a minimum downstream flow would also affect the selection. Growth of the actual load demand is also a significant factor, since the installation of units may be phased to match the actual load growth. The number of units and their individual ratings were determined by the need to deliver the required peak capacity in the peak demand month of December at the minimum December reservoir level with the turbine wicket gates fully open.

An examination was made of the economic impact on power plant production costs of various combinations of a number of units and rated capacity which would provide the selected total capacity of 1020 MW. For any given installed capacity, plant efficiency increases as the number of units increases. The assumed capitalized value used in this evaluation was \$1.00 per average annual kWh over project life, based on the economic analysis completed for the thermal generation system. Variations in the number of units and capacity will affect the cost of the power intakes, penstocks, powerhouse, and tailrace. The differences in these capital costs were estimated and included in the evaluation. The results of this analysis are presented below.

| Number of Units | Rated Capacity of Unit (MW) | Capitalized Value of Additional Energy (\$ Millions) | Additional Capital Cost (\$ Millions) | Net Benefit (\$ Millions) |
|--------------------|--------------------------------------|--|---|------------------------------|
| 4 | 250 | 0 | 0 | 0 |
| . 6 | 170 | 40 | 31 | 9 |
| 8 | 125 | 50 | 58 | -8 |

It is apparent from this analysis that a six-unit scheme with a net benefit of approximately \$9 million is the most economic alternative. This scheme also offers a higher degree of flexibility and security of operation compared to the four-unit alternative, as well as advantages if unit installation is phased to match actual load growth. The net economic benefit of the six unit scheme is \$17 million greater than that of the eight-unit scheme, while at the same time no significant operational or scheduling advantages are associated with the eight-unit scheme.

A scheme incorporating six units each with a rated capacity of 170 MW, for a total of 1020 MW, has been adopted for all Watana alternatives.

(c) Selection of the Spillway Design Flood

Normal design practice for projects of this magnitude, together with applicable design regulations, require that the project be capable of passing the Probable Maximum Flood (PMF) routed through the reservoir without endangering the dam.

In addition to this requirement, the project should have sufficient spillway capacity to safely pass a major flood of lesser magnitude than the PMF without damaging the main dam or ancillary structures. The frequency of occurrence of this flood, known as the spillway design flood or Standard Project Flood (SPF), is generally selected on the basis of an evaluation of the risks to the project if the spillway design flood is exceeded, compared to the costs of the structures required to safely discharge the flood. For this study, a spillway design flood with a return frequency of 1:10,000 years was selected for Watana. A list of spillway design flood frequencies and magnitudes for several major projects is presented below.

| | Spillway Design Flood | | Basin | Spillway Capacity | |
|----------------------------------|-----------------------|----------------------|--------------|-------------------------|--|
| Project | Frequency | Peak Inflow (cfs) | PMF (cfs) | After Routing (cfs)* | |
| Mica, Canada | PMF | 250,000 | 250,000 | 150,000 | |
| Churchill Falls, 。 Canada | 1:10,000 | 600,000 | 1,000,000 | 230,000 | |
| New Bullards, USA | PMF | 226,000 | 226,000 | 170,000 | |
| Oroville, USA | 1:10,000 | 440,500 | 711,400 | 440,500 | |
| Guri, Venezuela (final stage) | PMF | 1,000,000 | 1,000,000 | 1,000,000 | |
| Itaipu, Brazil | PMF | 2,195,000 | 2,195,000 | 2,105,000 | |
| Sayano, USSR | 1:10,000 | 480,000 | N/A | 680,000 | |

*All spillways except fays : have capacity to pass PMF with surcharge.

The flood frequency analysis produced the following values:

| Flood | Frequency | Inflow Peak |
|-------------------------------------|----------------|----------------------------|
| Probable Maximum Spillway Design | 1:10,000 years | 326,000 cfs 156,000 cfs |

Additional capacity required to pass the PMF will be provided by an emergency spillway consisting of a fuse plug and rock channel on the right bank.

(d) Main Dam Alternatives

This section describes the alternative types of dams considered at the Watana site and the basis for the selected alternative.

(i) Comparison of Embankment and Concrete Type Dams

The selection between an embankment type or a concrete type dam is usually based on the configuration of the valley, the condition of the foundation rock, depth of the overburden, and the relative availability of construction

Previous studies by the COE envisaged materials. an embankment dam at Watana. Initial studies completed as part of this current evaluation included comparison of an earthfill dam with a concrete arch dam at the Watana site. An arrangement for a concrete arch dam alternative at Watana is presented in Figure B.20. The results of this analysis indicated that the cost of the embankment dam was somewhat lower than the arch dam, even though the concrete cost rates used were significantly lower than those used for the Devil Canyon Dam. This preliminary evaluation did not indicate any overall cost savings in the project in spite of some savings in the earthworks and concrete structures for the concrete dam layout. A review of the overall construction schedule indicated a minimal savings in time for the concrete dam project.

Based on the above and the likelihood that the cost of the arch dam would increase relative to that of the embankment dam, the arch dam alternative was eliminated from further consideration.

- (ii) <u>Concrete-face Rockfill Type Dam</u> (to be written)
- (iii) Selection of Dam Type

-

Selection of the configuration of the embankment dam cross-section was undertaken within the context of the following basic considerations:

- The availability of suitable construction materials within economic haul distance, particularly core material;
- The requirement that the dam be capable of withstanding the effects of a significant earthquake shock (Reference 2) as well as the static loads imposed by the reservoir and its own weight;
- The relatively limited construction season available for placement of compacted fill materials.

The main dam would consist of a compacted core protected by fine and coarse filter zones on both the upstream and downstream slopes of the core. The upstream and downstream outer supporting fill zones would contain relatively free draining compacted gravel or rockfill, providing stability to the overall embankment structure. The location and inclination of the core is fundamental to the design of the embankment. Two basic alternatives exist in this regard:

- A vertical core located centrally within the dam; and - An inclined core with both faces sloping upstream.

A central vertical core was chosen for the embankment based on a review of precedent design and the nature of the available impervious material.

The exploration program undertaken during 1980-81 indicated that adequate quantities of materials suitable for dam construction were located within reasonable haul distance from the site. The well-graded silty sand material is considered the most promising source of impervious fill. Compaction tests indicate a natural moisture content slightly on the wet side of optimum moisture content, so that control of moisture content will be critical in achieving a dense core with high shear strength.

Potential sources for the upstream and downstream shells include either river gravel from borrow areas along the Susitna River or compacted rockfill from quarries or exca-vations for spillways.

During the intermediate review process, the upstream slope of the dam was flattened from 2.5H:1V used during the initial review to 2.75H:1V. This slope was based on a conservative estimate of the effective shear strength parameters of the available construction materials, as well as a conservative allowance in the design for the effects of earthquake loadings on the dam.

During the final review stage, the exterior upstream slope of the dam was steepened from 2.75H:1V to 2.4H:1V, reflecting the results of the preliminary static and dynamic design analyses being undertaken at the same time as the general arrangement studies. As part of the final review, the volume of the dam with an upstream slope of 2.4H:1V was computed for four alternative dam axes. The location of these alternative axes are shown on Figure B.21. The dam volume associated with each of the four alternative axes is listed below:

| Alternative Axis Number | Total Volume (million yd ³) |
|--|--|
| | 69.2 |
| $\frac{2}{3}$, and $\frac{2}{3}$, the set of the | 71.7 |
| 4 | 71.9 |

A section with a 2.4H:1V upstream slope and a 2H:1V downstream slope located on alternative axis number 3 was used for the final review of alternative schemes.

(e) <u>Diversion Scheme Alternatives</u>

The topography of the site generally dictates that diversion of the river during construction be accomplished using diversion tunnels with upstream and downstream cofferdams protecting the main construction area.

The configuration of the river in the vicinity of the site favors location of the diversion tunnels on the right bank, since the tunnel length for a tunnel on the left bank would be approximately 2,000 feet greater. In addition, rock conditions on the right bank are more favorable for tunneling and excavation of intake and outlet portals.

(i) <u>Design Flood for Diversion</u>

The recurrence interval of the design flood for diversion is generally established based on the characteristics of the flow regime of the river, the length of the construction period for which diversion is required and the probable consequences of overtopping of the cofferdams. Design criteria and experience from other projects similar in scope and nature have been used in selecting the diversion design flood.

At Watana, damage to the partially completed dam could be significant, or more importantly would probably result in at least a one-year delay in the completion schedule. A preliminary evaluation of the construction schedule indicates that the diversion scheme would be required for 4 or 5 years until the dam is of sufficient height to permit initial filling of the reservoir. A design flood with a return frequency of 1:50 years was selected based on experience and practice with other major hydroelectric projects. This approximates a 90 percent probability that the cofferdam will not be overtopped during the 5-year construction The diversion design flood together with average period. flow characteristics of the river significant to diversion are presented below:

| Average annual flow | 7.940 cfs |
|----------------------------------|-------------------|
| Maximum average monthly flow | 23,100 cfs (June) |
| Minimum average monthly flow | 890 cfs (March) |
| Design flood inflow (1:50 years) | 81,100 cfs |

(ii) Cofferdams

For the purposes of establishing the overall general arrangement of the project and for subsequent diversion optimization studies, the upstream cofferdam section

adopted comprises an initial closure dam structure approximately 30 feet high placed in the wet.

(iii) Diversion Tunnels

1

Concrete-lined tunnels and unlined rock tunnels were com-Preliminary hydraulic studies indicated that the pared. design flood routed through the diversion scheme would result in a design discharge of approximately 80,500 cfs. For concrete-lined tunnels, design velocities of the order of 50 ft/s have been used in several projects. For unlined tunnels, maximum design velocities ranging from 10 ft/s in good quality rock to 4 ft/s in less competent material are typical. Thus, the volume of material to be excavated using an unlined tunnel would be at least 5 times that for a lined tunnel. The reliability of an unlined tunnel is more dependent on rock conditions than is a lined tunnel, particularly given the extended period during which the diversion scheme is required to operate. Based on these considerations, given a considerably higher cost, together with the somewhat questionable feasibility of four unlined tunnels with diameters approaching 50 feet in this type of . rock, the unlined tunnels have been eliminated.

The following alternative lined tunnel schemes were examined as part of this analysis:

- Pressure tunnel with a free outlet;
- Pressure tunnel with a submerged outlet; and
- Free flow tunnel.

(iv) Emergency Release Facilities

The emergency release facilities influenced the number, type, and arrangement of the diversion tunnels selected for the final scheme.

At an early stage of the study, it was established that some form of low level release facility was required to permit lowering of the reservoir in the event of an extreme emergency, and to meet instream flow requirements during filling of the reservoir. The most economical alternative available would involve converting one of the diversion tunnels to permanent use as a low level outlet facility. Since it would be necessary to maintain the diversion scheme in service during construction of the emergency facilities outlet works, two or more diversion tunnels would be required. The use of two diversion tunnels also provides an additional measure of security to the diversion scheme in case of the loss of service of one tunnel.

The low level release facilities will be operated for approximately three years during filling of the reservoir. Discharge at high heads usually requires some form of energy dissipation prior to returning the flow to the river. Given the space restrictions imposed by the size of the diversion tunnel, it was decided to utilize a double expansion system constructed within the upper tunnel.

(v) Optimization of Diversion Scheme

Given the considerations described above relative to design flows, cofferdam configuration, and alternative types of tunnels, an economic study was undertaken to determine the optimum combination of upstream cofferdam height and tunnel diameter.

Capital costs were developed for three heights of upstream cofferdam embankment with a 30-foot-wide crest and exterior slopes of 2H:1V. A freeboard allowance of 5 feet for settlement and wave runup and 10 feet for the effects of down-stream ice jamming on tailwater elevations was adopted.

Capital costs for the 4,700 foot long tunnel alternatives included allowances for excavation, concrete liner, rock bolts, and steel supports. Costs were also developed for the upstream and downstream portals, including excavation and support. The cost of intake gate structures and associated gates was determined not to vary significantly with tunnel diameter and was excluded from the analysis.

Curves of headwater elevation versus tunnel diameter for the various tunnel alternatives with submerged and free outlets are presented in Figure B.22. The relationship between capital cost and crest elevation for the upstream cofferdam is shown in Figure B.23. The capital cost for various tunnel diameters with free and submerged outlets is given in Figure B.24.

The results of the optimization study are presented in Figure B.25 and indicate the following optimum solutions for each alternative.

| Type of Tunnel | Diameter (feet) | Cofferdam Crest Elevation (ft) | Total Cost (\$) |
|-----------------------|--------------------|-----------------------------------|-----------------|
| Two pressure tunnels | 30 | 1595 | 66,000,000 |
| Two free flow tunnels | 32.5 | 1580 | 68,000,000 |
| Two free flow tunnels | 35 | 1555 | 69,000,000 |

The cost studies indicate that a relatively small cost differential (4 to 5 percent) separates the various alternatives for tunnel diameter from 30 to 35 feet.

(vi) Selected Diversion Scheme

An important consideration at this point is ease of cofferdam closure. For the pressure tunnel scheme, the invert of the tunnel entrance is below riverbed elevation, and once the tunnel is complete diversion can be accomplished with a closure dam section approximately 10 feet high. The free flow tunnel scheme, however, requires a tunnel invert approximately 30 feet above the riverbed level, and diversion would involve an end-dumped closure section 50 feet high. The velocities of flows which would overtop the cofferdam before the water levels were raised to reach the tunnel invert level would be prohibitively higher resulting in complete erosion of the cofferdam and hence the dual free flow tunnel scheme was dropped from consideration.

Based on the preceeding considerations, a combination of one pressure tunnel and one free flow tunnel (or pressure tunnel with free outlet) was adopted. This will permit initial diversion to be made using the lower pressure tunnel, thereby simplifying the critical closure operation and avoiding potentially serious delays in the schedule. Two alternatives were re-evaluated as follows:

| | Upstream Cofferdam | | | |
|-----------------|--------------------|--------------------|--|--|
| Tunnel Diameter | Crest Elevation | Approximate Height | | |
| (feet) | (feet) | (feet) | | |
| 30 | 1595 | 150 | | |
| 35 | 1555 | 110 | | |

More detailed layout studies indicated that the higher cofferdam associated with the 30 foot diameter tunnel alternative would require locating the inlet portal further upstream into "The Fins" shear zone. Since good rock conditions for portal construction are essential and the 35 foot diameter tunnel alternative would permit a portal location downstream of "The Fins", this latter alternative was adopted. As noted in (v), the overall cost difference was not significant in the range of tunnel diameters considered, and the scheme incorporating two 35 foot diameter tunnels with an upstream cofferdam crest elevation of 1555 was incorporated as part of the selected general arrangement.

T----

(f) Spillway Facilities Alternatives

As discussed in Subsection (c) above, the project has been designed to safely pass floods with the following return frequencies:

| Flood | Frequency | Discharge (cfs) |
|-------------------------------------|----------------|-----------------|
| Spillway Design Probable Maximum | 1:10,000 years | 145,000 |

Discharge of the spillway design flood will require a gated service spillway on either the left or right bank. Three basic alternative spillway types were examined:

- Chute spillway with flip bucket;

- Chute spillway with stilling basin; and

- Cascade spillway.

Consideration was also given to combinations of these alternatives with or without supplemental facilities such as valved tunnels and an emergency spillway fuse plug for handling the PMF discharge.

Clearly, the selected spillway alternatives will greatly influence and be influenced by the project general arrangement.

(i) Emergy Dissipation

The two chute spillway alternatives considered achieved effective energy dissipation either by means of a flip bucket which directs the spillway discharge in the form of a free-fall jet into a plunge pool well downstream from the dam or a stilling basin at the end of the chute which dissipates energy in a hydraulic jump. The cascade type spillway limits the free fall height of the discharge by utilizing a series of 20 to 50 foot steps down to river level, with energy dissipation at each step. All spillway alternatives were assumed to incorporate a concrete ogee type control section controlled by fixed roller vertical lift gates. Chute spillway sections were assumed to be concrete-lined, with ample provision for air entrainment in the chute to prevent cavitation, and with pressure relief drains and rock anchors in the foundation.

(ii) Environmental Mitigation

During development of the general arrangements for both the Watana and Devil Canyon dams, a restriction was imposed on the amount of excess dissolved nitrogen permitted in the spillway discharges. Supersaturation occurs when aerated flows are subjected to pressures greater than 30 to 40 feet of head which forces excess nitrogen into solution. This occurs when water is subjected to the high pressures that occur in deep plunge pools or at large hydraulic jumps. The excess nitrogen would not be dissipated within the downstream Devil Canyon reservoir and a buildup of nitrogen concentration could occur throughout the body of water. It would eventually be discharged downstream from Devil Canyon with harmful effects on the fish population. On the basis of an evaluation of the related impacts and discussions with interested federal and state agencies, spillway facilities were designed to limit discharges of water from either Watana or Devil Canyon that may become supersaturated with nitrogen to a recurrence period of not less than 1:50 years.

(g) <u>Power Facilities Alternative</u>

Selection of the optimum power plant development involved consideration of the following:

- Location, type and size of the power plant;
- Geotechnical considerations;
- Number, type, size and setting of generating units;
- Arrangement of intake and water passages; and

- Environmental constraints.

(i) <u>Comparison of Surface and Underground Powerhouse</u>

Studies were carried out to compare the construction costs of a surface powerhouse and of an underground powerhouse at Watana. These studies were undertaken on the basis of preliminary conceptual layouts assuming six units and a total installed capacity of 840 MW. The comparative cost estimates for powerhouse civil works and electrical and mechanical equipment (excluding common items) indicated an advantage in favor of the underground powerhouse of \$16,300,000. The additional cost for the surface powerhouse arrangement is primarily associated with the longer penstocks and the steel linings required. Although construction cost estimates for a 1020 MW plant would be somewhat higher, the overall conclusion favoring the underground location would not change.

The underground powerhouse arrangement is also better suited to the severe winter conditions in Alaska, is less affected by river flood flows in summer, and is aesthetically less obtrusive. This arrangement has therefore been adopted for further development.

(ii) <u>Comparison of Alternative Locations</u>

Preliminary studies were undertaken during the development of conceptual project layouts at Watana to investigate both right and left bank locations for power facilities. The configuration of the site is such that left bank locations required longer penstock and/or tailrace tunnels and were therefore more expensive.

The location on the left bank was further rejected because of indications that the underground facilities would be located in relatively poor quality rock. The underground powerhouse was therefore located on the right bank such that the major openings lay between the two major shear features ("The Fins" and the "Fingerbuster").

(iii) Underground Openings

Because no construction adits or extensive drilling in the powerhouse and tunnel locations have been completed, it has been assumed that full concrete-lining of the penstocks and tailrace tunnels would be required. This assumption is conservative and is for preliminary design only; in practice, a large proportion of the tailrace tunnels would probably be unlined, depending on the actual rock quality encountered.

The minimum center-to-center spacing of rock tunnels and caverns has been assumed for layout studies to be 2.5 times the width or diameter of the larger excavation.

(iv) Selection of Turbines

The selection of turbine type is governed by the available head and flow. For the design head and specific speed, Francis type turbines have been selected. Francis turbines have a reasonably flat load-efficiency curve over a range from about 50 percent to 115 percent of rated output with peak efficiency of about 92 percent.

The number and rating of individual units is discussed in detail in Subsection (b) above. The final selected arrangement comprised six units producing 170 MW each, rated at minimum reservoir level (from reservoir simulation studies) in the peak demand month (December) at full gate. The unit output at best efficiency and a rated head of 680 feet is 181 MW.

(v) <u>Transformers</u>

The selection of transformer type, size, location and step-up rating is summarized below:

- Single phase transformers are required because of transport limitations on Alaskan roads and railways;
- Direct transformation from 15 kV to 345 kV is preferred for overall system transient stability;
- An underground transformer gallery has been selected for minimum total cost of transformers, cables, bus, and transformer losses; and
- A grouped arrangement of three sets of three single-phase transformers for each set of two units has been selected (a total of nine transformers) to reduce the physical size of the transformer gallery and to provide a transformer spacing comparable with the unit spacing.

(vi) <u>Power Intake and Water Passages</u>

The power intake and approach channel are significant items in the cost of the overall power facilities arrangement. The size of the intake is controlled by the number and minimum spacing between the penstocks, which in turn is dictated by geotechnical considerations.

The preferred penstock arrangement comprises six individual penstocks, one for each turbine. With this arrangement, no inlet valve is required in the powerhouse since turbine dewatering can be performed by closing the control gate at the intake and draining the penstocks and scroll case through a valved bypass to the tailrace. An alternative a. rangement with three penstocks was considered in detail to \ssess any possible advantages. This scheme would require a bifurcation and two inlet valves on each penstock and extra space in the powerhouse to accommodate the inlet valves. Estimates of relative cost differences are summarized below:

| | Cost Difference ($\$ \times 10^6$) | | |
|---|--------------------------------------|-------------------------|--|
| Item | 6 Penstocks | 3 Penstocks | |
| Intake Penstocks Bifurcations | Base Case O O | -20.0 - 3.0 + 3.0 | |
| Valves Powerhouse Capitalized Value of Extra Head Los | 0 0 s 0 | + 4.0 + 8.0 + 6.0 | |
| Total | 0 | - 2.0 | |

Despite a marginal saving of \$2 million (or less than 2 percent in a total estimated cost of \$120 million) in favor of three penstocks, the arrangement of six individual penstocks has been retained. This arrangement provides improved flexibility and security of operation.

The preliminary design of the power facilities involves two tailrace tunnels leading from a common surge chamber. An alternative arrangement with a single tailrace tunnel was also considered, but no significant cost saving was apparent.

Optimization studies on all water passages were carried out to determine the minimum total cost of initial construction plus the capitalized value of anticipated energy losses caused by conduit friction, bends and changes of section. For the penstock optimization, the construction costs of the intake and approach channel were included as a function of the penstock diameter and spacing. Similarly, in the optimization studies for the tailrace tunnels the costs of the surge chamber were included as a function of tailrace tunnel diameter.

(vii) Environmental Constraints

Apart from the potential nitrogen supersaturation problem discussed, the major environmental constraints on the design of the power facilities are:

- Control of downstream river temperatures; and
- Control of downstream flows.

The intake design has been modified to enable power plant flows to be drawn from the reservoir at four different levels throughout the anticipated range of reservoir drawdown for energy production in order to control the downstream river temperatures within acceptable limits.

Minimum flows at Gold Creek during the critical summer months have been studied to mitigate the project impacts on salmon spawning downstream of Devil Canyon. These minimum flows represent a constraint on the reservoir operation and influence the computation of average and firm energy produced by the Susitna development.

The Watana development will be operated as a daily peaking plant for load following. The actual extent of daily peaking will be dictated by unit availability, unit size, system demand, system stability, generating costs, etc.

2.3 - Selection of Watana General Arrangement

Preliminary alternative arrangements of the Watana Project were developed and subjected to a series of review and screening processes. The layouts selected from each screening process were developed in greater detail prior to the next review and, where necessary, additional layouts were prepared combining the features of two or more of the alternatives. Assumptions and criteria were evaluated at each stage and additional data incorporated as necessary. The selection process followed the general selection methodology established for the Susitna project and is outlined below.

(a) Selection Methodology

The determination of the project general arrangement at Watana was undertaken in three distinct review stages: preliminary, intermediate, and final.

(i) <u>Preliminary Review</u> (completed early in 1981)

This comprised four steps:

- Step 1: Assemble available data; Determine design criteria; and Establish evaluation criteria.
- Step 2: Develop preliminary layouts and design criteria based on the above data including all plausible alternatives for the constituent facilities and structures.
- Step 3: Review all layouts on the basis of technical feasibility, readily apparent cost differences, safety, and environmental impact.

- Step 4: Select those layouts that can be identified as most favorable, based on the evaluation criteria established in Step 1, and taking into account the preliminary nature of the work at this stage.
- (ii) <u>Intermediate Review</u> (completed by mid-1981)

This involved a series of 5 steps:

- Step 1: Review all data, incorporating additional data from other work tasks.

Review and expand design criteria to a greater level of detail.

Review evaluation criteria and modify, if necessary.

- Step 2: Revise selected layouts on basis of the revised criteria and additional data. Prepare plans and principal sections of layouts.
- Step 3: Prepare quantity estimates for major structures based on drawings prepared under Step 2.

Develop a preliminary construction schedule to evaluate whether or not the selected layout will allow completion of the project within the required time frame.

Prepare a preliminary contractor's type estimate to determine the overall cost of each scheme.

- Step 4: Review all layouts on the basis of technical feasibility, cost impact of possible unknown conditions and uncertainty of assumptions, safe-ty, and environmental impact.
- Step 5: Select the two most favorable layouts based on the evaluation criteria determined under Step 1.
- (iii) Final Review (completed early in 1982)
 - Step 1: Assemble and review any additional data from other work tasks.

Revise design criteria in accordance with additional available data.

Finalize overall evaluation criteria.

- Step 2: Revise or further develop the two layouts on the basis of input from Step 1 and determine overall dimensions of structures, water passages, gates, and other key items.
- Step 3: Prepare quantity take-offs for all major structures.

Review cost components within a preliminary contractor's type estimate using the most recent data and criteria, and develop a construction schedule.

Determine overall direct cost of schemes.

- Step 4: Review all layouts on the basis of practicability, technical feasibility, cost, impact of possible unknown conditions, safety, and environmental impact.
- Step 5: Select the final layout on the basis of the evaluation criteria developed under Step 1.
- (b) Design Data and Criteria

As discussed above, the review process included assembling relevant design data, establishing preliminary design criteria, and expanding and refining these data during the intermediate and final reviews of the project arrangement. The design data and design criteria which evolved through the final review are presented in Table B.26.

(c) Evaluation Criteria

The various layouts were evaluated at each stage of the review process on the basis of the criteria summarized in Table B.27. The criteria listed in Table B.27 illustrate the progressively more detailed evaluation process leading to the final selected arrangement.

(d) Preliminary Review

The development selection studies described in Section 8, Volume 1 of Reference 4, involved comparisons of hydroelectric schemes at a number of sites on the Susitna River. As part of these comparisons a preliminary conceptual design was developed for Watana incorporating a double stilling basin type spillway.

Eight further layouts were subsequently prepared and examined for the Watana project during this preliminary review process in addition to the scheme shown on Figure B.7. These eight layouts are shown in schematic form on Figure B.25. Alternative 1 of these layouts was the scheme recommended for further study in the Development Section Report, Reference 1.

This section describes the preliminary review undertaken of alternative Watana layouts.

(i) Basis of Comparison of Alternatives

Although it was recognized that provision would have to be made for downstream releases of water during filling of the reservoir and for emergency reservoir drawdown, these features were not incorporated in these preliminary layouts. These facilities would either be interconnected with the diversion tunnels or be provided for separately. Since the system selected would be similar for all layouts with minimal cost differences and little impact on other structures, it was decided to exclude these facilities from overall assessment at this early stage.

Ongoing geotechnical explorations had identified the two major shear zones crossing the Susitna River and running roughly parallel in the northwest direction. These zones enclose a stretch of watercourse approximately 4500 feet in Preliminary evaluation of the existing geological length. data indicated highly fractured and altered materials within the actual shear zones which would pose serious problems for conventional tunneling methods and would be unsuitable for founding of massive concrete structures. The originally proposed dam axis was located between these shear zones, and since no apparent major advantage appeared to be gained from large changes in the dam location, layouts generally were kept within the confines of these bounding zones.

An earth and rockfill dam was used as the basis for all layouts. The downstream slope of the dam was assumed as 2H:1V in all alternatives and upstream slopes varying between 2.5H:1V and 2.25H:1V were examined in order to determine the influence of variance in the dam slope on the congestion of the layout. In all preliminary arrangements except the one shown on Plate 8.2, cofferdams were incorporated within the body of the main dam.

Floods greater than the routed 1:10,000 year spillway design flood and up to the probable maximum flood were assumed to be passed by surcharging the spillways, except in cases where an unlined cascade or stilling basin type spillway served as the sole discharge facility. In such instances, under large surcharges, these spillways would not act as efficient energy dissipators but would be drowned out, acting as steep open channels with the possibility of their total destruction. In order to avoid such an occurrence the design flood for these latter spillways was considered as the routed probable maximum flood.

On the basis of information existing at the time of the preliminary review, it appeared that an underground powerhouse could be located on either side of the river. A surface powerhouse on the right bank appeared feasible but was precluded from the left bank by the close proximity of the downstream toe of the dam and the adjacent broad shear zone. Locating the powerhouse further downstream would require tunneling across the shear zone, which would be expensive, and would require excavating a talus slope. Furthermore, it was found that a left bank surface powerhouse would either interfere with a left bank spillway or would be directly impacted by discharges from a right bank spillway.

(ii) <u>Description of Alternative</u>

- Double Stilling Basin Scheme

The scheme as shown on Figure B.7 has a dam axis location similar to that originally proposed by the COE, and a right bank double stilling basin spillway. The spillway follows the shortest line to the river, avoiding interference with the dam and discharging downstream almost parallel to the flow into the center of the river. A substantial amount of excavation is required for the chute and stilling basins, although most of this material could probably be used in the dam. A large volume of concrete is also required for this type of spillway, resulting in a spillway system that would be very costly. The maximum head dissipated within each stilling basin is approximately 450 feet. Within world experience, cavitation and erosion of the chute and basing should not be a problem if the structures are properly designed. Extensive erosion downstream would not be expected.

The diversion follows the shortest route, cutting the bend of the river on the right bank, and has inlet portals as far upstream as possible without having to tunnel through "The Fins". It is possible that the underground powerhouse is in the area of "The Fingerbuster", but the powerhouse could be located upstream almost as far as the system of drain holes and galleries just downstream of the main dam grout curtain.

Alternative 1

This alternative is that recommended for further study in Reference 5 and is similar to the layout described above except that the right side of the dam has been rotated clockwise, the axis relocated upstream, and the spillway changed to a chute and flip bucket. The revised dam alignment resulted in a slight reduction in total dam volume compared to the above alternative. A localized downstream curve was introduced in the dam close to the right abutment in order to reduce the length of the spillway. The alignment of the spillway is almost parallel to the downstream section of the river and it discharges into a pre-excavated plunge pool in the river approximately 800 feet downstream from the flip bucket. This type of spillway should be considerably less costly than one incorporating a stilling basin, provided that excessive pre-excavation of bedrock within the plunge pool area is not required. Careful design of the bucket will be required, however, to prevent excessive erosion downstream causing undermining of the valley sides and/or build up of material downstream which could cause elevation of the tailwater levels.

Alternatives 2 through 2D

Alternative 2 consists of a left bank cascade spillway with the main dam axis curving downstream at the abutments. The cascade spillway would require an extremely large volume of rock excavation but it is probable that most of this material, with careful scheduling, could be used in the dam. The excavation would cross "The Fingerbuster" and extensive dental concrete would be required in that area. In the upstream portion of the spillway, velocities would be relatively high because of the narrow configuration of the channel, and erosion could take place in this area in proximity to the dam. The discharge from the spillway enters the river perpendicular to the general flow but velocities would be relatively low and should not cause substantial erosion problems. The powerhouse is in the most suitable location for a surface alternative where the bedrock is close to the surface and the overall rock slope is approximately 2H:1V.

Alternative 2A is similar to Alternative 2 except that the upper end of the channel is divided and separate control structures are provided. This division would allow the use of one structure or upstream channel while maintenance or remedial work is being performed on the other.

Alternative 2B is similar to Alternative 2 except that the cascade spillway is replaced by a double stilling basin type structure. This spillway is somewhat longer than the similar type of structure on the right bank in the alternative described above. However, the slope of the ground is less than the rather steep right bank and may be easier to construct, a factor which may partly mitigate the cost of the longer structure. The discharge is at a sharp angle to the river and more concentrated than the cascade, which could cause erosion of the opposite bank.

Alternative 2C is a derivative of 2B with a similar arrangement, except that the double stilling basin spillway is reduced in size and augmented by an additional emergency spillway in the form of an inclined, unlined rock channel. Under this arrangement the concrete spillway acts as the main spillway, passing the 1:10,000 year design flood with greater flows passed down the unlined channel which is closed at its upstream end by an erodable fuse plug. The problems of erosion of the opposite bank still remain, although these could be overcome by excavation and/or slope protection. Erosion of the chute would be extreme for significant flows, although it is highly unlikely that this emergency spillway would ever be used.

Alternative 2D replaces the cascade of Alternative 2 with a lined chute and flip bucket. The comments relative to the flip bucket are the same as for Alternative 1 except that the left bank location in this instance requires a longer chute, partly offset by lower construction costs because of the flatter slope. The flip bucket discharges into the river at an angle which may cause erosion of the opposite bank. The underground powerhouse is located on the right bank, an arrangement which provides an overall reduction of the length of the water passages.

Alternative 3

This arrangement has a dam axis location slightly upstream from Alternative 2, but retains the downstream

curve at the abutments. The main spillway is an unlined rock cascade on the left bank which passes the design Discharges beyond the 1:10,000 year flood would flood. be discharged through the auxiliary concrete-lined chute and flip bucket spillway on the right bank. A gated control structure is provided for this auxiliary spillway which gives it the flexibility to be used as a backup if maintenance should be required on the main spill-Erosion of the cascade may be a problem, as way. mentioned previously, but erosion downstream should be a less important consideration because of the low unit discharge and the infrequent operation of the spillway. The diversion tunnels are situated in the right abutment, as with previous arrangements, and are of similar cost for all these alternatives.

Alternative 4

This alternative involves rotating the axis of the main dam so that the left abutment is relocated approximately 1000 feet downstream from its Alternative 2 location. The relocation results in a reduction in the overall dam quantities but would require siting the impervious core of the dam directly over the "Fingerbuster" shear zone at maximum dam height. The left bank spillway, consisting of chute and flip bucket, is reduced in length compared to other left bank locations, as are the power facility water passages. The diversion tunnels are situated on the left bank; there is no advantage to a right bank location, since the tunnels are of similar length owing to the overall downstream relocation of the dam. Spillways and power facilities would also be lengthened by a right bank location with this dam configuration.

Selection of Schemes for Further Study

A basic consideration during design development was that the main dam core should not cross the major shear zones because of the obvious problems with treatment of the foundation. Accordingly, there is very little scope for realigning the main dam apart from a slight rotation to place it more at right angles to the river.

Location of the spillway on the right bank results in a shorter distance to the river and allows discharges almost parallel to the general direction of river flow. The double stilling basin arrangement would be extremely expensive, particularly if it must be designed to pass the probable maximum flood. An alternative such as 2C would reduce the magnitude of design flood to be passed by the spillway but would only be acceptable if an emergency spillway with a high degree of operational predictability could be constructed. A flip bucket spillway on the right bank, discharging directly down the river, would appear to be an economic arrangement, although some scour might occur in the plunge pool area. A cascade spillway on the left bank could be an acceptable solution providing most of the excavated material could be used in the dam, and adequate rock conditions exist.

The length of diversion tunnels can be decreased if they are located on the right bank. In addition, the tunnels would be accessible by a preliminary access road from the north, which is the most likely route. This location would also avoid the area of "The Fingerbuster" and the steep cliffs which would be encountered on the left side close to the downstream dam toe.

The underground configuration assumed for the powerhouse in these preliminary studies allows for location on either side of the river with a minimum of interference with the surface structures.

Four of the preceding layouts, or variations of them, were selected for further study:

- . A variation of the double stilling basin scheme, but with a single stilling basin main spillway on the right bank, a rock channel and fuse plug emergency spillway, a left bank underground powerhouse and a right bank diversion scheme;
- Alternative 1 with a right bank flip bucket spillway, an underground powerhouse on the left bank, and right bank diversion;
- . A variation of Alternative 2 with a reduced capacity main spillway and a right bank rock channel with a fuse plug serving as an emergency spillway; and
- . Alternative 4 with a left bank rock cascade spillway, a right bank underground powerhouse, and a right bank diversion.

(e) Intermediate Review

For the intermediate review process, the four schemes selected as a result of the preliminary review were examined in more detail and modified. A description of each of the schemes is given below and shown on Figures B.27 through B.32. The general locations of the upstream and downstream shear zones shown on these plates are approximate and have been refined on the basis of subsequent field investigations for the proposed project.

(i) Description of Alternative Schemes

The four schemes are shown on Figures B.27 through B.32.

Scheme WP1 (Figure B.27)

This scheme is a refinement of Alternative 1. The upstream slope of the dam is flattened from 2.5:1 to 2.75:1. This conservative approach was adopted to provide an assessment of the possible impacts on project layout of conceivable measures which prove necessary in dealing with severe earthquake design conditions. Uncertainty with regard to the nature of river alluvium also led to the location of the cofferdams outside the limits of the main dam embankment. As a result of these conditions, the intake portals of the diversion tunnels on the right bank are also moved upstream from "The Fins". A chute spillway with a flip bucket is located on the right bank. The underground powerhouse is located on the left bank.

Scheme WP2 (Figures B.29 and B.30)

This scheme is derived from the double stilling basin layout. The main dam and diversion facilities are similar to Scheme WP1 except that the downstream cofferdam is relocated further downstream from the spillway outlet and the diversion tunnels are correspondingly extended. The main spillway is located on the right bank, but the two stilling basins of the preliminary DSR scheme are combined into a single stilling basin at the river An emergency spillway is also located on the level. right bank and consists of a channel excavated in rock. discharging downstream from the area of the relict channel. The channel is closed at its upstream end by a compacted earthfill fuse plug and is capable of discharging the flow differential between the probable maximum flood and the 1:10,000-year design flood of the main spillway. The underground powerhouse is located on the left bank.

- Scheme WP3 (Figures B.28 and B.29)

This scheme is similar to Scheme WP1 in all respects except that an emergency spillway is added consisting of right bank rock channel and fuse plug.

- Scheme WP4 (Figures B.31 and B.32)

The dam location and geometry for Scheme WP4 are similar to that for the other schemes. The diversion is on the right bank and discharges downstream from the powerhouse tailrace outlet. A rock cascade spillway is located on the left bank and is served by two separate control structures with downstream stilling basins. The underground powerhouse is located on the right bank.

(ii) Comparison of Schemes

The main dam is in the same location and has the same configuration for each of the four layouts considered. The cofferdams have been located outside the limits of the main dam in order to allow more extensive excavation of the alluvial material and to ensure a sound rock foundation beneath the complete area of the dam. The overall design of the dam is conservative, and it was recognized during the evaluation that savings in both fill and excavation costs can probably be made after more detailed study.

The diversion tunnels are located on the right bank. The upstream flattening of the dam slope necessitates the location of the diversion inlets upstream from "The Fins" shear zone which would require extensive excavation and support where the tunnels pass through this extremely poor rock zone and could cause delays in the construction schedule.

A low-lying area exists on the right bank in the area of the relict channel and requires approximately a 50-foot high saddle dam for closure, given the reservoir operating level assumed for the comparison study. However, the finally selected reservoir operating level will require only a nominal freeboard structure at this location.

A summary of capital cost estimates for the four alternative schemes is given in Table B.28.

The results of this idearmediate analysis indicate that the chute spillway with flip bucket (Scheme WP1) is the least costly spillway alternative.

The scheme has the additional advantage of relatively simple operating characteristics. The control structure

has provision for surcharging to pass the design flood. The probable maximum flood can be passed by additional surcharging up to the crest level of the dam. In Scheme WP3 a similar spillway is provided, except that the control structure is reduced in size and discharges above the routed design flood are passed torough the rock channel emergency spillway. The arrangement in Scheme WP1 does not provide a backup facility to the main spillway, so that if repairs caused by excessive plunge pool erosion or damage to the structure itself require removal of the spillway from service for any length of time, no alternative discharge facility would be available. The additional spillway of Scheme WP3 would permit emergency discharge if it were required under extreme circumstances.

The stilling basin spillway (Scheme WP2) would reduce the potential for extensive erosion downstream, but high velocities in the lower part of the chute could cause cavitation even with the provision for aeration of the discharge. This type of spillway would be very costly, as can be seen from Table B.28.

The feasibility of the rock cascade spillway is entirely dependent on the quality of the rock, which dictates the amount of treatment required for the rock surface and also the proportion of the excavated material which can be used in the dam. For determining the capital cost of Scheme WP4, conservative assumptions were made regarding surface treatment and the portion of material that would have to be wasted.

The diversion tunnels are located on the right bank for all alternatives examined in the intermediate review. For Scheme WP2, the downstream portals must be located downstream from the stilling basin, resulting in an increase of approximately 800 feet in the length of the tunnels. Ine left bank location of the powerhouse requires its placement close to a suspected shear zone, with the tailrace tunnels passing through this shear zone to reach the river. A longer access tunnel is also required, together with an additional 1,000 feet in the length of the tailrace. The left-side location is remote from the main access road, which will probably be on the north side of the river, as will the transmission corridor.

(iii) Selection of Schemes for Further Study

Examination of the technical and economic aspects of Scheme WP1 through WP4 indicates there is little scope for adjustment of the dam axis owing to the confinement imposed by the upstream and downstream shear zones. In addition, passage of the diversion tunnels through the upstream shear zone could result in significant delays in construction and additional cost.

From a comparison of costs in Table B.28, it can be seen that the flip bucket type spillway is the most economical, but because of the potential for erosion under extensive operation it is undesirable to use it as the only discharge facility. A mid-level release will be required for emergency drawdown of the reservoir, and use of this release as the first-stage service spillway with the flip bucket as a backup facility would combine flexibility and safety of operation with reasonable cost. The emergency rock channel spillway would be retained for discharge of flows above the routed 1:10,000-year flood.

The stilling basin spillway is very costly and the operating head of 800 feet is beyond precedent experience. Erosion downstream should not be a problem but cavitation of the chute could occur. Scheme WP2 was therefore eliminated from further consideration.

The cascade spillway was also not favored for technical and economic reasons. However, this arrangement does have an advantage in that it provides a means of preventing nitrogen supersaturation in the downstream discharges from the project which could be harmful to the fish population. A cascade configuration would reduce the dissolved nitrogen content; hence, this alternative was retained for further evaluation. The capacity of the cascade was reduced and the emergency rock channel spillway was included to take the extreme floods.

The results of the intermediate review indicated that the following components should be incorporated into any scheme carried forward for final review:

- Two diversion tunnels located on the right bank of the river;

- An underground powerhouse also located on the right bank;

- An emergency spillway, comprising a rock channel excavated on the right bank and discharging well downstream from the right abutment. The channel is sealed by an erodible fuse plug of impervious material designed to fail if overtopped by the reservoir; and - A compacted earthfill and rockfill dam situated between the two major shear zones which traverse the project site.

As discussed above, two specific alternative methods exist with respect to routing of the spillway design flood and minimizing the adverse effects of nitrogen supersaturation on the downstream fish population. These alternatives are:

- A chute spillway with flip bucket on the right bank to pass the spillway design flood, with a mid-level release system designed to operate for floods with a frequency of up to about 1:50 years; or

- A cascade spillway on the left bank.

Accordingly, two schemes were developed for further evaluation as part of the final review process. These schemes are described separately in the paragraphs below.

(f) Final Review

The two schemes considered in the final review process were essentially derivations of Schemes WP3 and WP4.

(i) <u>Scheme WP3A</u> (Figure B.33)

This scheme is a modified version of Scheme WP3 described above. Because of scheduling and cost considerations, it is extremely important to maintain the diversion tunnels downstream from "The Fins." It is also important to keep the dam axis as far upstream as possible to avoid congestion of the downstream structures. For these reasons, the inlet portals to the diversion tunnels were located in the sound bedrock forming the downstream boundary of "The Fins." The upstream cofferdam and main dam are maintained in the upstream locations as shown on Figure B.33. As mentioned previously, additional criteria have necessitated modifications in the spillway configuration, and low-level and emergency drawdown outlets have been introduced.

The main modifications to the scheme are as follows:

- Main Dam

Continuing preliminary design studies and review of world practice suggest that an upstream slope of 2.4H:1V would be acceptable for the rock shell. Adoption of this slope

results not only in a reduction in dam fill volume but also in a reduction in the base width of the dam which permits the main project components to be located between the major shear zones.

The downstream slope of the dam is retained as 2H:1V. The cofferdams remain outside the limits of the dam in order to allow complete excavation of the riverbed alluvium.

- Diversion

In the intermediate review arrangements, diversion tunnels passed through the broad structure of "The Fins," an intensely sheared area of breccia, gouge, and infills. Tunneling of this material would be difficult, and might even require excavation in open cut from the surface. High cost would be involved, but more important would be the time taken for construction in this area and the possibility of unexpected delays. For this reason, the inlet portals have been relocated downstream from this zone with the tunnels located closer to the river and crossing the main system of jointing at approximately 45°. This arrangement allows for shorter tunnels with a more favorable orientation of the inlet and outlet portals with respect to the river flow directions.

A separate low-level inlet and concrete-lined tunnel is provided, leading from the reservoir at approximate Elevation 1550 to downstream of the diversion plug where it merges with the diversion tunnel closest to the river. This low-level tunnel is designed to pass flows up to 6000 cfs during reservoir filling. It would also pass up to 30,000 cfs under 500-foot head to allow emergency draining of the reservoir.

Initial closure is made by lowering the gates to the tunnel located closest to the river and constructing a concrete closure plug in the tunnel at the location of the grout curtain underlying the core of the main dam. On completion of the plug, the low-level release is opened and controlled discharges are passed downstream. The closure gates within the second diversion tunnel portal are then closed and a concrete closure plug constructed in line with the grout curtain. After closure of the gates, filling of the reservoir would commence.

- Outlet Facilities

As a provision for drawing down the reservoir in case of emergency, a mid-level release is provided. The intake

to these facilities is located at depth adjacent to the power facilities intake structures. Flows would then be passed downstream through a concrete-lined tunnel, discharging beneath the downstream end of the main spillway In order to overcome potential nitrogen flip bucket. supersaturation problems, Scheme WP3A also incorporates a system of fixed cone valves at the downstream end of the outlet facilities. The valves were sized to discharge in ccrjunction with the powerhouse operating at 7000 cfs capacity (flows up to the equivalent routed 50-year Six cone valves are required, located on flood). branches off a steel manifold and protected by individual upstream closure gates. The valves are partly incorporated into the mass concrete block forming the flip bucket of the main spillway. The rock downstream is protected from erosion by a concrete facing slab anchored back to the sound bedrock.

- Spillways

Î

As discussed above, the designed operation of the main spillway facilities was arranged to limit discharges of potentially nitrogen-supersaturated water from Watana to flows having an equivalent return period greater than 1:50 years.

The main chute spillway and flip bucket discharge into an excavated plunge pool in the downstream river bed. Releases are controlled by a three-gated ogee structure located adjacent to the outlet facilities and power intake structure just upstream from the dam centerline. The design discharge is approximately 114,000 cfs, corresponding to the routed 1:10,000-year flood (145,000 cfs) reduced by the 31,000 cfs flows attributable to outlet and power facilities discharges. The plunge pool is formed by excavating the alluvial river deposits to bedrock. Since the excavated plunge pool approaches the limits of the calculated maximum scour hole, it is not anticipated that, given the infrequent discharges, significant downstream erosion will occur.

An emergency spillway is provided by means of a channel excavated in rock on the right bank, discharging well downstream from the right abutment in the direction of Tsusena Creek. The channel is sealed by an erodible fuse plug of impervious material designed to fail if overtopped by the reservoir, although some preliminary excavation may be necessary. The crest level of the plug will be set at Elevation 2230, well below that of the main dam. The channel will be capable of passing the excess discharge of floods greater than the 1:10,000- year flood up to the probable maximum flood of 310,000 cfs.

- Power Facilities

The power intake is set slightly upstream from the dam axis deep within sound bedrock at the downstream end of the approach channel. The intake consists of six units with provision in each unit for drawing flows from a variety of depths covering the complete drawdown range of the reservoir. This facility also provides for drawing water from the different temperature strata within the upper part of the reservoir and thus regulating the temperature of the downstream discharges close to the natural temperatures of the river. For this preliminary conceptual arrangement, flow withdrawals from different levels are achieved by a series of upstream vertical shutters moving in a single set of guides and operated to form openings at the required level. Downstream from these shutters each unit has a pair of wheel-mounted closure gates which will isolate the individual penstocks.

The six penstocks are 18-foot-diameter, concrete-lined tunnels inclined at 55° immediately downstream from the intake to a nearly horizontal portion leading to the powerhouse. This horizontal portion is steel-lined for 150 feet upstream from the turbine units to extend the seepage path to the powerhouse and reduce the flow within the fractured rock area caused by blasting in the adjacent powerhouse cavern.

The six 170 MW turbine/generator units are housed within the major powerhouse cavern and are serviced by an overhead crane which runs the length of the powerhouse and into the service area adjacent to the units. Switchgear, maintenance room and offices are located within the main cavern, with the transformers situated downstream in a separate gallery excavated above the tailrace tunnels. Six inclined tunnels carry the connecting bus ducts from the main power hall to the transformer gallery. A vertical elevator and vent shaft run from the power cavern to the main office building and control room located at the surface. Vertical cable shafts, one for each pair of transformers, connect the transformer gallery to the switchyard directly overhead. Downstream from the transformer gallery, the underlying draft tube tunnels merge into two surge chambers (one chamber for

three draft tubes) which also house the draft tube gates for isolating the units from the tailrace. The gates are operated by an overhead traveling gantry located in the upper part of each of the surge chambers. Emerging from the ends of the chambers, two concrete-lined, lowpressure tailrace tunnels carry the discharges to the river. Because of space restrictions at the river, one of these tunnels has been merged with the downstream end of the diversion tunnel. The other tunnel emerges in a separate portal with provision for the installation of bulkhead gates.

The orientation of water passages and underground caverns is such as to avoid, as far as possible, alignment of the main excavations with the major joint sets.

Access

Access is assumed to be from the north (right) side of the river. Permanent access to structures close to the river is by a road along the right downstream river bank and then via a tunnel passing through the concrete forming the flip bucket. A tunnel from this point to the power cavern provides for vehicular access. A secondary access road across the crest of the dam passes down the left bank of the valley and across the lower part of the dam.

(ii) <u>Scheme WP4A</u> (Figure B.34)

This scheme is similar in most respects to Scheme WP3A previously discussed, except for the spillway arrangements.

- Main Dam

The main dam axis is similar to that of Scheme WP3A, except for a slight downstream rotation at the left abutment at the spillway control structures.

- Diversion

The diversion and low level releases are the same for the two schemes.

Outlet Facilities

The outlet facilities used for emergency drawdown are separate from the main spillway for this scheme. The outlet facilities consists of a low-level gated inlet structure discharging up to 30,000 cfs into the river through a concrete-lined, free-flow tunnel with a ski jump flip bucket. This facility may also be operated as an auxiliary outlet to augment the main left bank spillway.

Spillways

The main left bank spillway is capable of passing a design flow equivalent to the 1:10,000-year flood through a series of 50-foot drops into shallow preexcavated plunge pools. The emergency spillway is designed to operate during floods of greater magnitude up to and including the PMF.

Main spillway discharges are controlled by a broad multi-gated control structure discharging into a shallow stilling basin. The feasibility of this arrangement is governed by the quality of the rock in the area, requiring both durability to withstand erosion caused by spillway flows and a high percentage of sound rockfill material that can be used from the excavation directly in the main dam.

On the basis of the site information developed concurrently with the general arrangement studies, it became apparent that the major shear zone known to exist in the left bank area extended further downstream than initial studies have indicated. The cascade spillway channel was therefore lengthened to avoid the shear area at the lower end of the cascade. The arrangement shown on Figure B.34 for Scheme WP4A does not reflect this relocation, which would increase the overall cost of the scheme.

The emergency spillway consisting of rock channel and fuse plug is similar to that of the right bank spillway scheme.

Power Facilities

The power facilities are similar to those in Scheme WP3A.
(iii) Evaluation of Final Alternative Schemes

An evaluation of the dissimilar features for each arrangement (the main spillways and the discharge arrangements at the downstream end of the outlets) indicates a saving in capital cost of \$197,000,000, excluding contingencies and indirect cost, in favor of Scheme WP3A. If this difference is adjusted for the savings associated with using an appropriate proportion of excavated material from the cascade spillway as rockfill in the main dam, this represents a net overall cost difference of approximately \$110,000,000 including contingencies, engineering, and administration costs.

As discussed above, although limited information exists regarding the quality of the rock in the downstream area on the left bank, it is known that a major shear zone runs through and is adjacent to the area presently allocated to the spillway in Scheme WP4. This would require relocating the left bank cascade spillway several hundred feet farther downstream into an area where the rock quality is unknown and the topography less suited to the gentle overall slope of the cascade. The cost of the excavation would substantially increase compared to previous assumptions, irrespective of the rock quality. In addition, the resistance of the rock to erosion and the suitability for use as excavated material in the main dam would become less certain. The economic feasibility of this scheme is largely predicated on this last factor, since the ability to use the material as a source of rockfill for the main dam represents a major cost saving.

In conjunction with the main chute spillway, the problem of the occurrence of nitrogen supersaturation can be overcome by the use of a regularly operated dispersion type valve outlet facility in conjunction with the main chute spillway. Since this scheme presents a more economic solution with fewer potential problems concerning the geotechnical aspects of its design, the right bank chute arrangement (Scheme WP3A) has been adopted as the final selected scheme.

2.4 - Selection of Devil Canyon General Arrangement

This section describes the development of the general arrangement of the Devil Canyon project. The method of handling floods during construction and subsequent project operation is also outlined in this section.

The reservoir level fluctuations and inflow for Devil Canyon will essentially be controlled by operation of the upstream Watana project. This aspect is also briefly discussed in this section.

(a) <u>Selection of Reservoir Level</u>

The selected normal maximum operating level at Devil Canyon dam is Elevation 1455. Studies by the USBR and COE c. the Devil Canyon Project were essentially based on a similar reservoir level which corresponds to the tailwater level selected at the Watana site. Although the narrow configuration of the Devil Canyon site and the relatively low costs involved in increasing the dam height suggest that it might be economic to do so, it is clear that the upper economic limit of reservoir level at Devil Canyon is the Watana

Although significantly lower reservoir levels at Devil Canyon would lead to lower dam costs, the location of adequate spillway facilities in the narrow gorge would become extremely difficult and lead to offsetting increases in cost. In the extreme case, a spillway discharging over the dam would raise concerns regarding safety from scouring at the toe of the dam which have already led to rejection of such schemes.

(b) Selection of Installed Capacity

The methodology used for the preliminary selection of installed capacity at Watana and Devil Canyon is described in Section 2.2 (b).

The decision to operate Devil Canyon primarily as a base-loaded plant was governed by the following main considerations:

- Daily peaking is more effectively performed at Watana than at Devil Canyon; and
- Excessive fluctuations in discharge from the Devil Canyon dam may have an undesirable impact on mitigation measures incorporated in the final design to project the downstream fisheries.

Given this mode of operation, the required installed capacity at Devil Canyon has been determined as the maximum capacity needed to utilize the available energy from the hydrological flows of record, as modified by the reservoir operation rule curves. In years where the energy from Watana and Devil Canyon exceeds the system demand, the usable energy has been reduced at both stations in proportion to the average net head available, assuming that flows used to generate energy at Watana will also be used to generate energy at Devil Canyon. The total capacity required at Devil Canyon in a wet year, excluding standby and spinning reserve capacity, is summarized below. The capacity shown is based on the December 1981 medium load growth forecast.

| Demand Year | | Capacity MW | |
|-------------|------|-------------|--|
| | 2002 | 370 | |
| | 2005 | 410 | |
| | 2010 | 507 | |

The selected total installed capacity at Devil Canyon has been established as 600 MW for design purposes. This will provide some margin for standby during forced outage and possible accelerated growth in demand.

The major factors governing the selection of the unit size at Devil Canyon are the rate of growth of system demand, the minimum station output, and the requirement of standby capacity under forced outage conditions. The above tabulation indicates that station maximum load in December will increase by about 50 percent from 2002 to 2010 (from 370 MW to 507 MW). Station minimum output in July during the same period will vary from about 150 MW to 202 MW.

The power facilities at Devil Canyon have been developed using four units at 150 MW each. This arrangement will provide for efficient station operation during low load periods as well as during peak December loads. During final design, consideration of phasing of installed capacity to match the system demand may be desirable. However, the uncertainty of load forecasts and the additional contractual costs of mobilization for equipment installation are such that for this study it has been assumed that all units will be commissioned by 2002.

The Devil Canyon reservoir will usually be full in December; hence, any forced outage could result in spilling and a loss of available energy. The units have been rated to deliver 150 MW at maximum December drawdown occuring during an extremely dry year; this means that in an average year, with higher reservoir le ls the full station output can be maintained even with one unit on forced outage.

(c) Selection of Spillway Capacity

A flood frequency of 1:10,000 years was selected for the spillway design on the same basis as described for Watana. An emergency spillway with an erodible fuse plug will also be provided to safely discharge the probable maximum flood. The development plan envisages completion of the Watana project prior to construction at Devil Canyon. Accordingly, the inflow flood peaks at Devil Canyon will be less than pre-project flood peaks because of routing through the Watana reservoir. Spillway design floods are:

| 1:10.000 | years | | 165,000 |
|----------|---------|--|---------|
| Probable | Maximum | | 346,000 |

The avoidance of nitrogen supersaturation in the downstream flow for Watana also will apply to Devil Canyon. Thus, the discharge of water possibly supersaturated with nitrogen from Devil Canyon will be limited to a recurrence period of not less than 1:50 years by the use of solid cone valves similar to Watana.

(d) Main Dam Alternatives

The location of the Devil Canyon damsite was examined during previous studies by the USBR and COE. These studies focused on the narrow entrance to the canyon and led to the recommendation of a concrete arch dam. Notwithstanding this initial appraisal, a comparative analysis was undertaken as part of this feasibility study to evaluate the relative merits of the following types of structures at the same location:

- Thick concrete arch;

- Thin concrete arch; and

- Fill embankment.

(i) Comparison of Embankment and Concrete Type Dams

The geometry was developed for both the thin concrete arch and the thick concrete arch dam and the dams were analyzed and their behavior compared under static, hydrostatic, and seismic loading conditions. The project layouts for these arch dams were compared to a layout for a rockfill dam with its associated structures.

Consideration of the central core rockfill dam layout indicated relatively small cost differences from an arch dam cost estimate, based on a cross-section significantly thicker than the finally selected design. Furthermore, no information was available to indicate that impervious core material in the necessary quantities could be found within a reasonable distance of the damsite. The rockfill dam was accordingly dropped from further consideration. [It is further noted that since this alternative dam study, seismic analysis of the rockfill dam at Watana has resulted in an upstream slope 1:2.4, thus indicating the requirement to flatten the 1:1.25 slope adopted for the rockfill dam alternative at Devil Canyon.]

Neither of the concrete arch dam layouts were intended as the final site arrangement, but were sufficiently representative of the most suitable arrangement associated with each dam type to provide an adequate basis for comparison. Each type of dam was located just downstream from where the river enters Devil Canyon and close to the canyon's narrowest point, which is the optimum location for all types of dams. A brief description of each dam type and configuration is given below.

- Rockfill Dam

For this arrangement the dam axis is some 625 feet downstream of the crown section of the concrete dams. The assumed embankment slopes are 2.25 H:1V on the upstream face and 2H:1V on the downstream face. The main dam is continuous with the left bank saddle dam, and therefore no thrust blocks are required. The crest length is 2200 feet at Elevation 1470; the crest width is 50 feet.

The dam is constructed with a central impervious core, inclined upstream, supported on the downstream side by a semi-pervious zone. These two zones are protected upstream and downstream by filter and transition materials. The shell sections are constructed of rockfill obtained from blasted bedrock. For preliminary design all dam sections are assumed to be founded on rock; external cofferdams are founded on the river alluvium, and are not incorporated into the main dam. The approximate volume of material in the main dam is 20 million cubic yards.

A single spillway is provided on the right abutment to control all flood flows. It consists of a gate control structure and a double stilling basin excavated into rock; the chute sections and stilling basins are concrete-lined, with mass concrete gravity retaining walls. The design capacity is sufficient to pass the 1-in-10,000 year flood without damage; excess capacity is provided to pass the PMF, without damage to the main dam, by surcharging the reservoir and spillway.

The powerhouse is located underground in the right abutment. The multi-level power intake is constructed in a rock cut in the right abutment on the dam centerline, with four independent penstocks to the 150 MW Francis turbines. Twin concrete-lined tailrace tunnels connect the powerhouse to the river via an intermediate draft tube manifold.

- Thick Arch Dam

The main concrete dam would be a single center arch structure, acting partly as a gravity dam, with a vertical cylindrical upstream face and a sloping downstream face inclined at 1V:0.4H. The maximum height of the dam would be 635 feet with a uniform crest width of 30 feet, a crest length of approximately 1,400 feet, and a maximum foundation width of 225 feet. The crest elevation would be 1460. The center portion of the dam would be founded on a massive mass concrete pad constructed in the excavated river bed. This central section would incorporate the main spillway with sidewalls anchored into solid bedrock and gated orifice spillways discharging down the steeply inclined downstream face of the dam into a single large stilling basin set below river level and spanning the valley.

The main dam would terminate in thrust blocks high on the abutments. The left abutment thrust block would incorporate an emergency gated control spillway structure which would discharge into a rock channel running well downstream and terminating at a level high above the river valley.

Beyond the control structure and thrust block, a lowlying saddle on the left abutment would be closed by means of a rockfill dike founded on bedrock. The powerhouse would house four 150 MW units and will be located underground within the right abutment. The intake would be constructed integrally with the dam and connected to the powerhouse by vertical steel-lined penstocks.

The main spillway would be designed to pass the 1:10,000-year routed flood with larger floods discharged downstream via the emergency spillway.

Thin Arch Dam

. . The main dam would be a two-center, double-curved arch structure of similar height to the thick arch dam, but with a 20-foot uniform crest and a maximum base width of 90 feet. The crest elevation would be 1460. The center section would be founded on a concrete pad, and the extreme upper portion of the dam would terminate in concrete thrust blocks located on the abutments.

The main spillway would be located on the right abutment and would consist of a conventional gated control structure discharging down a concrete-lined chute terminating in a flip bucket. The bucket would discharge into an unlined plunge pool excavated in the riverbed alluvium and located sufficiently downstream to prevent undermining of the dam and associated structures. The main spillway would be supplemented by orifice type spillways located high in the center portion of the dam which would discharge into a concrete-lined plunge pool immediately downstream from the dam. An emergency spillway, consisting of a fuse plug discharging into an unlined rock channel terminating well downstream, would be located beyond the saddle dam on the left abutment.

The concrete dam would terminate in a massive thrust block on each abutment which, on the left abutment, would adjoin a rockfill saddle dam.

The main and auxiliary spillways would be designed to discharge the 1:10,000-year flood. Larger floods for storms up to the probable maximum flood would be discharged through the emergency left abutment spillway.

Comparison of Arch Dam Types

Sand and gravel for concrete aggregates are believed to be available in sufficient quantities within economic distance from the damsite. The gravel and sands are formed from the granitic and metamorphic rocks of the area; at this time it is anticipated that they will be suitable for the production of aggregates after screening and washing.

The bedrock geology of the site is discussed in Reference 3. At this time it appears that there are no geological or geotechnical concerns that would preclude either of the dam types from consideration.

Under hydrostatic and temperature loadings, stresses within the thick arch dam would be generally lower than for the thin arch alternative. However, finite element analysis has shown that the additional mass of the dam under seismic loading would produce stresses of a greater magnitude in the thick arch dam than in the thin arch dam. If the surface stresses approach the maximum allowable at a particular section, the remaining understressed area of concrete will be greater for the thick arch, and the factor of safety for the dam would be correspondingly higher. The thin arch is, however, a more efficient design and better utilizes the inherent properties of the concrete. It is designed around acceptable predetermined factors of safety and requires a much smaller volume of concrete for the actual dam structure.

(iii) Cofferdams

As at Watana, the considerable depth of riverbed alluvium at both cofferdam sites indicates that embankment-type cofferdam structures would be the only technically and economically feasible alternative at Devil Canyon. For the purposes of establishing the overall general arrangement of the project and for subsequent diversion optimization studies, the upstream cofferdam section adopted will comprise an initial closure section approximately 20 feet high constructed in the wet, with a zoned embankment constructed in the dry. The downstream cofferdam will comprise a closure dam structure approximately 30 feet high placed in the wet. Control of underseepage through the alluvium material may be required and could be achieved by means of a grouted zone. The coarse nature of the alluvium at Devil Canyon led to the selection of a grouted zone rather than a slurry wall.

(iv) Diversion Tunnels

Although studies for the Watana project indicated that concrete-lined tunnels were the most economically and technically feasible solution, this aspect was reexamined at Devil Canyon. Preliminary hydraulic studies indicated that the design flood routed through the diversion scheme would result in a design discharge of approximately 37,800 cfs. For concrete-lined tunnels, design velocities of approximately 50 ft/s would permit the use of one concrete-lined tunnel with an equivalent diameter of 30 feet. Alternatively, for unlined tunnels a maximum design velocity of 10 ft/s in good quality rock would require four unlined tunnels, each with an equivalent diameter of 35 feet, to pass the design flow. As was the case for the Watana diversion scheme, considerations of reliability and cost were considered sufficient to eliminate consideration of unlined tunnels for the diversion scheme.

For the purposes of optimization studies, only a pressure tunnel was considered, since previous studies indicated that cofferdam closure problems associated with free-flow tunnels would more than offset their other advantages.

(iii) Optimization of Diversion Scheme

Given the considerations described above relative to design flows, cofferdam configuration, and alternative types of tunnels, an economic study was undertaken to determine the optimum combination of upstream cofferdam elevation (height) and tunnel diameter. The thick arch arrangement did not appear to have a distinct technical advantage compared to a thin arch dam and would be more expensive because of the larger volume of concrete needed. Studies, therefore, continued on refining the feasibility of the thin arch alternative.

- (ii) <u>Concrete-face Rockfill Dam Alternative</u> (to be written)
- (e) Diversion Scheme Alternatives

In this section the selection of general arrangement and the basis for sizing of the diversion scheme are presented.

(i) General Arrangements

The steep walled valley at the site essentially dictated that diversion of the river during construction be accomplished using one or two diversion tunnels, with upstream and downstream cofferdams protecting the main construction area.

The selection process for establishing the final general arrangement included examination of tunnel locations on both banks of the river. Rock conditions for tunneling did not favor one bank over the other. Access and case of construction strongly favored the left bank or abutment, the obvious approach being via the alluvial fan. The total length of tunnel required for the left bank is approximately 300 feet greater; however, access to the right bank could not be achieved without great difficulty.

(ii) Design Flood for Diversion

The recurrence interval of the design flood for diversion was established in the same manner as for Watana dam. Accordingly, at Devil Canyon a risk of exceedence of 10 percent per annum has been adopted, equivalent to a design flood with a 1:10-year return period for each year of critical construction exposure. The critical construction time is estimated at 2.5 years. The main dam could be subjected to overtopping during construction without causing serious damage, and the existence of the Watana facility upstream will offer considerable assistance in flow regulation in case of an emergency. These considerations led to the selection of the design flood with a return frequency of 1:25 years.

The equivalent inflow, together with average flow characteristics of the river significant to diversion, are presented below:

- Average annual flow:

9,040 cfs

- Design flood inflow (1:25 years routed through Watana reservoir):

37,800 cfs

Capital costs were developed for a range of pressure tunnel diameters and corresponding upstream cofferdam embankment crest elevations with a 30-foot wide crest and exterior slopes of 2H:1V. A freeboard allowance of 5 feet was included for settlement and wave runup.

Capital costs for the tunnel alternatives included allowances for excavation, concrete liner, rock bolts, and steel supports. Costs were also developed for the upstream and downstream portals, including excavation and support. The cost of an intake gate scructure and associated gates was determined not to vary significantly with tunnel diameter and was excluded from the analysis.

The centerline tunnel length in all cases was estimated to be 2,000 feet.

Rating curves for the single-pressure tunnel alternatives are presented in Figure B.35. The relationship between capital costs for the upstream cofferdam and various tunnel diameters is given in Figure B.36.

The results of the optimization study indicated that a single 30-foot-diameter pressure tunnel results in the overall least cost (Figure B.36). An upstream cofferdam 60 feet high, with a crest elevation of 945, was carried forward as part of the selected general arrangement.

(f) <u>Spillway Alternatives</u>

The project spillways have been designed to safely pass floods with the following return frequencies:

| Inflow Peak Flood | Discharge Frequency | (cfs) | (cfs) |
|----------------------|------------------------|---------|---------|
| Spillway Design | 1:10,000 years | 165,000 | 165,000 |
| Probable Maximum | | 346,000 | 365,000 |

A number of alternatives were considered singly and in combination for Devil Canyon spillway facilities. These included gated orifices in the main dam discharging into a plunge pool, chute or tunnel spillways with either a flip bucket or stilling basin for energy dissipation, and open channel spillways. As described for Watana, the selection of the type of spillway was influenced by the general arrangement of the major structures. The main spillway facilities will discharge the spillway design flood through a gated spillway control structure with energy dissipation by a flip bucket which directs the spillway discharge in a free fall jet into a plunge pool in the river. As noted above, restrictions with respect to limiting nitrogen supersaturation in selecting acceptable spillway discharge structures have been applied. The various spillway arrangements developed in accordance with these considerations are discussed in Section 2.5.

(g) <u>Power Facilities Alternatives</u>

The selection of the optimum arrangements for the power facilities involved consideration of the same factors as described for Watana.

(i) Comparison of Surface and Underground Powerhouses

A surface powerhouse at Devil Canyon would be located either at the downstream toe of the dam or along the side of the canyon wall. As determined for Watana, costs favored an underground arrangement. In addition to cost, the underground powerhouse layout has been selected based on the following:

- Insufficient space is available in the steep-sided canyon for a surface powerhouse at the base of the dam;
- The provision of an extensive intake at the crest of the arch dam would be detrimental to stress conditions in the arch dam, particularly under earthquake loading, and would require significant changes in the arch dam geometry; and
- The outlet facilities located in the arch dam are designed to discharge directly into the river valley; these would cause significant winter icing and spray problems to any surface structure below the dam.
- (ii) <u>Comparison of Alternative Locations</u>

The underground powerhouse and related facilities have been located on the right bank for the following reasons:

- Generally superior rock quality at depth;
- The left bank area behind the main dam thrust block is unsuitable for the construction of the power intake; and

- The river turns north downstream from the dam, and hence the right bank power development is more suitable for extending the tailrace tunnel to develop extra head.

(iii) <u>Selection of Units</u>

The turbine type selected for the Devil Canyon development is governed by the design head and specific speed and by economic considerations. Francis turbines have been adopted for reasons similar to those discussed for Watana in Section 2.2(g).

The selection of the number and rating of individual units is discussed in detail in Section 2.4(b). The four units will be rated to deliver 150 MW each at full gate opening and minimum reservoir level in December (the peak demand month).

(iv) Transformers

Transformer selection is similar to Watana.

(v) Power Intake and Water Passages

For flexibility of operation, individual penstocks are provided to each of the four units. Detailed cost studies showed that there is no significant cost advantage in using two larger diameter penstocks with bifurcation at the powerhouse compared to four separate penstocks.

A single tailrace tunnel with a length of 6,800 feet to develop 30 feet of additional head downstream from the dam has been incorporated in the design. Detailed design may indicate that two smaller tailrace tunnels for improved reliability may be superior to one large tunnel since the extra cost involved is relatively small. The surge chamber design would be essentially the same with one or two tunnels.

The overall dimensions of the intake structure are governed by the selected diameter and number of the penstocks and the minimum penstock spacing. Detailed studies comparing construction cost to the value of energy lost or gained were carried out to determine the optimum diameter of the penstocks and the tailrace tunnel.

(vi) Environmental Constraints

In addition to potential nitrogen-saturation problems caused by spillway operation, the major impacts of the Devil Canyon power facilities development are:

- Changes in the temperature regime of the river; and
- Fluctuations in downstream river flows and levels.

Temperature modeling has indicated that a multiple level varying the intake design at Devil Canyon would not significantly affect downstream water temperatures, since these are effectively controlled by the water released from Watana. Consequently, the intake design at Devil Canyon incorporates a single level draw-off about 75 feet below maximum reservoir operating level (El 1455).

The Devil Canyon station will normally be operated as a base-loaded plant throughout the year, to satisfy the requirement of no significant daily variation in power flow.

2.5 General Arrangement Selection - Devil Canyon

The approach to selection of a general arrangement for Devil Canyon was a similar but simplified version of that used for Watana.

(a) Selection Methodology

Preliminary alternative arrangements of the Devil Canyon project were developed and selected using two rather than three review stages. Topographic conditions at this site limited the development of reasonably feasible layouts, and four schemes were initially developed and evaluated. During the final review, the selected layout was refined based on technical, operational and environmental considerations identified during the preliminary review.

(b) Design Data and Criteria

The design data and design criteria on which the alternative layouts were based are presented in Table B.29. Subsequent to selection of the preferred Devil Canyon scheme, the information was refined and updated as part of the on-going study program.

(c) Preliminary Review

Consideration of the options available for types and locations of various structures led to the development of four primary layouts for examination at Devil Canyon in the preliminary review phase. Previous studies had led to the selection of a thin concrete arch structure for the main dam, and indicated that the most acceptable technical and economic location was at the upstream entrance to the canyon. The dam axis has been fixed in this location for all alternatives.

(i) Description of Alternative Schemes

The schemes evaluated during the preliminary review are described below. In each of the alternatives evaluated, the dam is founded on the sound bedrock underlying the riverbed. The structure is 635 feet high, has a crest width of 20 feet, and a maximum base width of 90 feet. Mass concrete thrust blocks are founded high on the abutments, the left block extending approximately 100 feet above the existing bedrock surface and supporting the upper arches of the dam. The thrust block on the right abutment makes the cross-river profile of the dam more symmetrical and contributes to a more uniform stress distribution.

- <u>Scheme DC1</u> (Figure B.37)

In this scheme, diversion facilities comprise upstream and downstream earthfill and rockfill cofferdams and two 24-foot-diameter tunnels beneath the left abutment.

A rockfill saddle dam occupies the lower lying area beyond the left abutment running from the thrust block to the higher ground beyond. The impervious fill cutoff for the saddle dam is founded on bedrock approximately 80 feet beneath the existing ground surface. The maximum height of this dam above the foundation is approximately 200 feet.

The routed 1:10,000-year design flood of 135,000 cfs is passed by two spillways. The main spillway is located on the right abutment. It has a design discharge of 90,000 cfs, and flows are controlled by a three-gated ogee control structure. This discharges down a concrete-lined chute and over a flip bucket which ejects the water in a diverging jet into a pre-excavated plunge pool in the riverbed. The flip bucket is set at Elevation 925, approximately 35 feet above the river level. An auxiliary spillway discharging a total of 35,000 cfs is located in the center of the dam, 100 feet below the dam crest, and is controlled by three wheel-mounted gates. The orifices are designed to direct the flow into a concrete-lined plunge pool just downstream from the dam.

An emergency spillway is located in the sound rock south of the saddle dam. This is designed to pass discharges in excess of the 1:10,000-year flood up to a probable maximum flood of 270,000 cfs, if such an event should ever occur. The spillway is an unlined rock channel which discharges into a valley downstream from the dam leading into the Susitna River.

The upstream end of the channel is closed by an earthfill fuse plug. The plug is designed to be eroded if overtopped by the reservoir. Since the crest is lower than either the main or saddle dams, the plug would be washed out prior to overtopping of either of these structures.

The underground power facilities are located on the right bank of the river, within the bedrock forming the

dam abutment. The rock within this abutment is of better quality with fewer shear zones and a lesser degree of jointing than the rock on the left side of the canyon, and hence more suitable for underground excavation.

The power intake is located just upstream from the bend in the valley before it turns sharply to the right into Devil Canyon. The intake structure is set deep into the rock at the downstream end of the approach channel. Separate penstocks for each unit lead to the powerhouse.

The powerhouse contains four 150 MW turbine/generator units. The turbines are Francis type units coupled to overhead umbrella type generators. The units are serviced by an overhead crane running the length of the powerhouse and into the end service bay. Offices, the control room, switchgear room, maintenance room, etc., are located beyond the service bay. The transformers are housed in a separate upstream gallery located above the lower horizontal section of the penstocks. Two vertical cable shafts connect the gallery to the sur-The draft tube gates are housed above the draft face. tubes in separate annexes off the main powerhall. The draft tubes converge in two bifurcations at the tailrace tunnels which discharge, under free-flow conditions, to the river. Access to the powerhouse is by means of an unlined tunnel leading from an access portal on the right side of the canyon.

The switchyard is located on the left bank of the river just downstream from the saddle dam, and the power cables from the transformers are carried to it across the top of the dam.

Scheme DC2 (Figure B.38)

The layout is generally similar to Scheme DC1 except that the chute spillway is located on the left side of the canyon. The concrete-lined chute terminates in a flip bucket high on the left side of the canyon which drops the discharges into the river below. The design flow is 90,000 cfs, and discharges are controlled by a 3-gated, ogee-crested-control structure similar to that for Scheme DC1 which abuts the left side thrust block.

The saddle dam axis is straight, following the shortest route between the control structure at one end and the rising ground beyond the low-lying area at the other.

Scheme DC3 (See Figure B.39)

The layout is similar to Scheme DC1 except that the right side main spillway takes the form of a single tunnel rather than an open chute. A 2-gated, ogee-- control structure is located at the head of the tunnel and discharges into an inclined shaft 45 feet diameter at its upper end. The structure will discharge up to a maximum of 90,000 cfs.

The concrete-lined tunnel narrows to 35 feet diameter and discharges into a flip bucket which directs the flows in a jet into the river below as in Scheme DC1.

An auxiliary spillway is located in the center of the dam and an emergency spillway is excavated on the left abutment.

The layout of dams and power facilities are the same as for Scheme DC1.

Scheme DC4 (See Figure B.40)

The dam, power facilities, and saddle dam for this scheme are the same as those for Scheme DC1. The major difference is the substitution of a stilling-basin type spillway on the right bank for the chute and flip bucket. A 3-gated, ogee-control structure is located at the end of the dam thrust block and controls the discharges up to a maximum of 90,000 cfs.

The concrete-lined chute is built into the face of the canyon and discharges into a 500-feet-long by 115-feetwide by 100-feet-high concrete stilling basin formed below river level and deep within the right side of the canyon. Central orifices in the dam and the left bank rock channel and fuse plug form the auxiliary and emergency spillways, respectively, as in the other alternative schemes.

The concrete-lined chute is built into the face of the canyon and discharges into a 500-feet-long by 115-feetwide by 100-feet-high concrete stilling basin formed below river level and deep within the right side of the canyon. Central orifices in the dam and the left bank rock channel and fuse plug form the auxiliary and emergency spillways, respectively, as in the other alternative schemes.

The downstream cofferdam is located beyond the stilling basin, and the diversion tunnel outlets are located farther downstream to enable construction of the stilling basin.

(ii) <u>Comparison of Alternatives</u>

The arch dam, saddle dam, power facilities, and diversion vary only in a minor degree among the four alternatives. Thus, the comparison of the schemes rests solely on a comparison of the spillway facilities.

As can be seen from a comparison of the costs in Table B.30, the flip bucket spillways are substantially less costly to construct than the stilling-basin type of Scheme DC4. The left side spillway of Scheme DC2 runs at a sharp angle to the river and ejects the discharge jet from high on the canyon face toward the opposite side of the canyon. Over a longer period of operation, scour of the heavily jointed rock could cause undermining of the canyon sides and their subsequent instability. The possibility also exists of deposition of material in the downstream riverbed with a corresponding elevation of the tailrace. Construction of a spillway on the steep left side of the river could be more difficult than on the right side because of the presence of deep fissures and large unstable blocks of rock which are present on the left side close to the top of the canyon.

The two-right side flip bucket spillway schemes, based on either an open chute or a tunnel, take advantage of a downstream bend in the river to discharge parallel to the course of the river. This will reduce the effects of erosion but could still present a problem if the estimated maximum possible scour hole would occur.

The tunnel type spillway could prove difficult to construct because of the large diameter inclined shaft and tunnel paralleling the bedding planes. The high velocities encountered in the tunnel spillway could cause problems with the possibility of spiraling flows and severe cavitation both occuring.

The stilling basin type spillway of Scheme DC4 reduces downstream erosion problems within the canyon. However, cavitation could be a problem under the high-flow velocities experienced at the base of the chute. This would be somewhat alleviated by aeration of the flows. There is, however, little precedent for stilling basin operation at heads of over 500 feet; and even where floods of much less than the design capacity have been discharged, severe damage has occurred.

(iii) <u>Selection of Final Scheme</u>

The chute and flip bucket spillway of Scheme DC2 could generate downstream erosion problems which could require considerable maintenance costs and cause reduced efficiency in operation of the project at a future date. Hydraulic design problems exist with Scheme DC3 which may also have severe cavitation problems. Also, there is no cost advantage in Scheme DC3 over the open chute Scheme DC1. In Scheme DC4, the operating characteristics of a high head stilling basin are little known, and there are few examples of successful operation. Scheme DC4 also costs considerably more than any other scheme (Table B.30).

All spillways operating at the required heads and discharges will eventually cause some erosion. For all schemes, the use of solid cone valve outlet facilities in the lower portion of the dam to handle floods up to 1:50-year frequency is considered a more reasonable approach to reduce erosion and eliminate nitrogen supersaturation problems than the gated high level orifice outlets in the dam. Since the cost of the flip bucket type spillway in the scheme is considerably less than that of the stilling basin in Scheme DC4, and since the latter offers no relative operational advantage, Scheme DC1 has been selected for further study as the selected scheme.

(d) Final Review

The layout selected in the previous section was further developed in accordance with updated engineering studies and criteria. The major change compared to Scheme DC1 is the elimination of the high level gated orifices and introduction of low level solid cone valves, but other modifications that were introduced are described below.

The revised layout is shown on Figure 8.41. A description of the structures is as follows.

(i) Main Dam

The maximum operating level of the reservoir was raised to Elevation 1455 in accordance with updated information relative to the Watana tailwater level. This requires raising the dam crest to Elevation 1463 with the concrete parapet wall crest at Elevation 1466. The saddle dam was raised to Elevation 1472.

(ii) Spillways and Outlet Facilities

To eliminate the potential for nitrogen supersaturation problems, the outlet facilities were designed to restrict supersaturated flow to an average recurrence interval of greater than 50 years. This led to the replacement of high level gated orifice spillway by outlet facilities incorporating 7 fixed-cone valves, 3 with a diameter of 90 inches and 4 with a diameter of 102 inches, capable of passing a design flow of 38,500 cfs.

The chute spillway and flip bucket are located on the right bank, as in Scheme DC1; however, the chute length was decreased and the elevation of the flip bucket raised compared to Scheme DC1.

More recent site surveys indicated that the ground surface in the vicinity of the saddle dam was lower than originally estimated. The emergency spillway channel was relocated slightly to the south to accommodate the larger dam.

(iii) Diversion

The previous twin diversion tunnels were replaced by a single-tunnel scheme. This was determined to provide all necessary security and will cost approximately one-half as much as the two-tunnel alternative.

(iv) Power Facilities

The drawdown range of the reservoir was reduced, allowing a reduction in height of the power intake. In order to locate the intake within solid rock, it has been moved into the side of the valley, requiring a slight rotation of the water passages, powerhouse, and caverns comprising the power facilities.

3 - DESCRIPTION OF PROJECT OPERATION

Note: Adjustments may be made to this section due to operation studies currently underway in Anchorage.

3.1 - Operation Within Railbelt Power System

A staged development is planned for implementation of Susitna power generation. The following schedule for unit start-up is proposed:

| Start-up Date | <u>Dam Site</u> | No. and Size of Units (MW) Brought On-line | Total Susitna On-line Capacity* (MW) |
|------------------|-----------------|--|--|
| 1993 | Watana | 4 x 170 | 680 |
| 1994 | Watana | 2 x 170 | 1020 |
| 2002 | Devil Canvon | 4 x 150 | 1620 |

* Installed generating capacity.

As shown above, the first four units are scheduled to be on line at Watana in early 1993, followed by the remaining two Watana units in early 1994. Startup of all four units at Devil Canyon is planned for 2002.

Of the total project installed capacity of 1620 MW, 1280 MW were utilized as the basis for generation planning. The remaining 340 MW are planned to meet the needs for spinning reserve capacity.

This section describes the operation of the Watana and Devil Canyon power plants in the Railbelt electrical system. Under current conditions in the Railbelt, a total of nine utilities share responsibility for generation and distribution of electric power, with limited interconnections. The proposed arrangements for optimization and control of the dispatch of Susitna power to Railbelt load centers is based on the expectation that a single entity will eventually be set up for this purpose. In the year 2010 the projected Railbelt system, with Susitna on line, is projected to comprise:

| Coal-fired Steam: | 13 | MW |
|-------------------|------|----|
| Natural Gas GT: | 326 | MW |
| Diesel: | 6 | MW |
| Natural Gas CC: | 317 | MW |
| Hydropower: | 1680 | MW |
| TOTAL | 2482 | MW |

It is important to note that the Susitna project will be the single most significant power source in the system. The dispatch and distribution of power from all sources by the most economical and reliable means is therefore essential. The general principles of reliability of plant and system operation, reservoir regulation, stationary and spinning reserve requirements, and maintenance programming are discussed in this section. Estimates of dependable capacity and annual energy production for both Watana and Devil Canyon are presented. Operating and maintenance procedures are described, and the proposed performance monitoring system for the two projects is also outlined.

3.2 - Plant and System Operation Requirements

The main function of system planning and operation control is the allocation of generating plant on a short-term operational basis so that the total system demand is met by the available generation at minimum cost consistent with the security of supply. The objectives are generally the same for long-term planning or short-term operational load dispatching, but with important differences in the latter case. In the short-term case, the actual state of the system dictates system reliability requirements, overriding economic considerations in load dispatching. An important factor arising from economic and reliability considerations in system planning and operation is the provision of stationary reserve and spinning reserve capacity. Figure B.42 shows the daily variation in demand for the Railbelt system during typical winter and summer weekdays and the seasonal variation in monthly peak demands for estimated loads in a typical year (the year 2000).

3.3 - General Power Plant and System Railbelt Criteria

The following are basic reliability standards and criteria have been adopted for planning the Susitna project.

(a) Installed Generating Capacity

Sufficient generating capacity is installed in the system to insure that the probability of occurrence of load exceeding the available generating capacity shall not be greater than one day in ten years (Loss-of-load probability - LOLP - of 0.1).

(b) Transmission System Capability

The high-voltage transmission system should be operable at all load levels to meet the following unscheduled single or double contingencies without instability, cascading or interruption of load.

- The single contingency situation is the loss of any single generating unit, transmission line, transformer, or bus (in addition to normal scheduled or maintenance outages) without exceeding the applicable emergency rating of any facility; and - The double contingency situation is the subsequent outage of any remaining equipment, line or subsystem without exceeding the short time emergency rating of any facility.

In the single contingency situation, the power system must be capable of readjustment so that all equipment will be loaded within normal ratings, and in the double contingency situation, within emergency ratings for the probable duration of the outage.

During any contingency:

- Sufficient reactive power (MVAR) capacity with adequate controls is installed to maintain acceptable transmission voltage pro-
- The stability of the power system is maintained without loss of load or generation during and after a three-phase fault, cleared in normal time, at the most critical location.
- (c) Summary

Operational reliability criteria thus fall into four main categories:

- LOLP of 0.1, or one day in ten years, is maintained for the recommended plan of operation;
- The single and double contingency requirements are maintained for any of the more probable outages in the plant or transmission system;
- System stability and voltage regulation are assured from the electrical system studies. Detailed studies for load frequency control have not been performed, but it is expected that the stipulated criteria will be met with the more than adequate spinning reserve capacity with six units at Watana and four units at Devil Canyon; and
- The loss of all Susitna transmission lines on a single rightof-way has a low level of probability. In the event of the loss of all lines, the hydro plants at Watana and Devil Canyon are best suited to restore power supply quickly after the first line is restored since they are designed for "black start" operation. In this respect, hydro plans are superior to thermal_plants because of their inherent black start capability for restoration of supply to a large system.

3.4 - Economic Dispatch of Units

A Susitna Area Control Center will be located at Watana to control both the Watana and the Devil Canyon power plants as shown in Plate 34. The control center will be linked through the supervisory system to the Central Dispatch Control Center at Willow. The supervisory control of the entire Alaska Railbelt system will be done at the Central Dispatch Center at Willow. A high level of control automation with the aid of digital computers will be sought, but not a complete computerized direct digital control of the Watana and Devil Canyon power plants. Independent operator controlled local-manual and local-auto operations will still be possible at Watana and Devil Canyon power plants for testing/commissioning or during emergencies. The control system will be designed to perform the following functions at both power plants:

- Start/stop and loading of units by operator;
- Load-frequency control of units;
- Reservoir/water flow control;
- Continuous monitoring and data logging;
- Alarm annunciation; and
- Man-machine communication through visual display units (VDU) and console.

In addition, the computer system will be capable of retrieval of technical data, design criteria, equipment characteristics and operating limitations, schematic diagrams, and operating/maintenance records of the units.

The Susitna Area Control Center will be capable of completely independent control of the Central Dispatch Center in case of system emergencies. Similarly it will be possible to operate the Susitna units in an emergency situation from the Central Dispatch Center, although this should be an unlikely operation considering the size, complexity, and impact of the Susitna generating plants on the system.

The Central Dispatch Control Engineer decides which generating units should be operated at any given time. Decisions are made on the basis of known information, including an "order-of-merit" schedule, shortterm demand forecasts, limits of operation of units, and unit maintenance schedules.

(a) Merit-Order Schedule

In order to decide which generating unit should run to meet the system demand in the most economic manner, the Control Engineer is provided with information of the running cost of each unit in the form of an "order-of-merit" schedule. The schedule gives the capacity and fuel costs for thermal units, and reservoir regulation limits for hydro plants.

(b) Optimum Load Dispatching

One of the most important functions of the Control Center is the accurate forecasting of the load demands in the various areas of the system.

Based on the anticipated demand, basic power transfers between areas, and an allowance for reserve, the planned generating capacity to be used is determined by taking into consideration the reservoir regulation plans of the hydro plants. The type and size of the units should also be taken into consideration for effective load dispatching.

In a hydro-dominated power system such as the Railbelt system would be if Susitna is developed, the hydro unit will take up a much greater part of base load operation than in a thermal dominated power system. The planned hydro units at Watana typically are well suited to load following and frequency regulation of the system and providing spinning reserve. Greater flexibility of operation was a significant factor in the selection of six units of 170 MW capacity at Watana, rather than fewer larger-size

(c) <u>Operating Limits of Units</u>

There are strict constraints on the minimum load and the loading rates of machines: to dispatch load to these machines requires a systemwide dispatch program taking these constraints into consideration. In general, hydro units have excellent startup and load following characteristics; thermal units have good part- loading characteristics.

Typical plant loading limitations are given below:

(i) <u>Hydro Units</u>

- Reservoir regulation constraints resulting in not-toexceed maximum and minimum reservoir levels, daily or seasonally.

 Part loading of units is impossible in the zone of rough turbine operation (typically from above speed-no-load to 50 percent load) due to vibrations arising from hydraulic surges.

(ii) <u>Steam Units</u>

- Loading rates are slow (10 percent per minute).
- The units may not be able to meet a sudden steep rate of rise of load demand.
- The units have a minimum economic shutdown period (about 3 hours).
- The total cost of using conventional units includes banking, raising pressure and part-load operations prior to maximum economic operation.

(iii) Gas Turbines

- Cannot be used as spinning reserve because of very poor efficiency and reduced service life.
- Require 8 to 10 minutes for normal start-up from cold. Emergency start up times are of the order of 5 to 7 minutes.

(d) Optimum Maintenance Program

An important part of operational planning which can have a significant effect on operating costs is maintenance programming. The program specifies the times in the year and the sequence in which plant is released for maintenance.

3.5 - Unit Operation Reliability Criteria

During the operational load dispatching conditions of the power system, the reliability criteria often override economic considerations in scheduling of various units in the system. Also important in considering operational reliability are system response, load-frequency control, and spinning reserve capabilities.

(a) Power System Analyses

Load-frequency response studies determine the dynamic stability of the system due to the sudden forced outage of the largest unit (or generation block) in the system. The generation and load are not balanced, and if the pick-up rate of new generation is not adequate, loss of load will eventually result from under-voltage and under-frequency relay operation, or load-shedding. The aim of a well-designed high security system is to avoid load-shedding by maintaining frequency and voltage within the specified statutory limits.

(b) System Response and Load-Frequency Control

To meet the frequency requirements, it is necessary that the effective capacity of generating plant supplying the system at any given instant should be in excess of the load demand. In the absence of detailed studies, an empirical factor of 1-2/3 times the capacity of the largest unit in the system is normally taken as a design criterion to maintain system frequency within acceptable limits in the event of the instantaneous loss of the largest unit. It is recommended that a factor of 1-1/2 times the largest unit size be considered as a minimum for the Alaska Railbelt system, with 2 times the largest unit size as a fairly conservative value (i.e., 300 to 340 MW).

The quickest response in system generation will come from the hydro units. The large hydro units at Watana and Devil Canyon on spinning reserve can respond in the turbining mode within 30 seconds. This is one of the particularly important advantages of the Susitna hydro units. Gas turbines can only respond in a second stage operation within 5 to 10 minutes and would not strictly qualify as spinning reserve. If thermal units are run part-loaded (example, 75 percent), this would be another source of spinning reserve. Ideally, it would be advantageous to provide spinning reserve in the thermal generation as well, in order to spread spinning reserves evenly in the system, with a compromise to economic loading resulting from such an operation.

(c) Protective Relaying System and Devices

The primary protective relaying systems provided for the generators and transmission system of the Susitna project are designed to disconnect the faulty equipment from the system in the fastest possible time. Independent protective systems are installed to the extent necessary to provide a fast-clearing backup for the primary protective system so as to limit equipment damage, to limit the shock to the system and to speed restoration of service. The relaying systems are designed so as not to restrict the normal or necessary network transfer capabilities of the power system.

3.6 - Dispatch Control Centers

The operation of the Watana and Devil Canyon power plant in relation to the Central Dispatch Center can be considered to be the second tier of a three-tier control structure as follows:

- Central Dispatch Control Center (345 kV network) at Willow: manages the main system energy transfers, advises system configuration and checks overall security.
- Area Control Center (Generation connected to 345 kV system, for example, Watana and Devil Canyon): deals with the loading of generators connected directly to the 345 kV network, switching and safety precautions of local systems, checks security of interconnections to main system.
- District or Load Centers (138 kV and lower voltage networks): generation and distribution at lower voltage levels.

For the Anchorage and Fairbanks areas, the district center functions are incorporated in the respective area control centers.

Each generating unit at Watana and Devil Canyon is started up, loaded and operated and shut down from the Area Control Center at Watana according to the loading demands from the Central Dispatch Control Center with due consideration to:

- Watana reservoir regulation criteria;
- Devil Canyon reservoir regulation criteria;
- Turbine loading and de-loading rates;
- Part loading and maximum loading characteristics of turbines and generators;
- Hydraulic transient characteristics of waterways and turbines;
- Load-frequency control of demands of the system; and
- Voltage regulation requirements of the system.

The Watana Area Control Center is equipped with a computer-aided control system to efficiently carry out these functions. The computeraided control system allows a minimum of highly trained and skilled operators to perform the control and supervision of Watana and Devil Canyon plants from a single control room. The data information and retrieval system will enable the performance and alarm monitoring of ach unit individually as well as the plant/reservoir and project oper-

3.7 - Susitna Project Operation

Substantial seasonal as well as over-the-year regulation of the river flow is achieved with the two reservoirs. The simulation of the reservoirs and the power facilities at the two developments was carried out on a monthly basis to assess the energy potential of the schemes, river flows downstream and flood control possibilities with the reservoirs. The following paragraphs summarize the main features of reservoir operation.

An optimum reservoir operation was established by an iterative process to minimize net system operating costs while maximizing firm and usable energy production. Four alternative operating cases for the Watana reservoir (A, B, C, and D) were selected for study, to define the possible range of operation. Case A represents an optimum power and energy scenario, while Case D reflects a case of "no impact on downstream fisheries". Case; B and C are intermediate levels of power operation and downstream impact. These essentially define monthly minimum flows at Gold Creek that must be maintained while providing energy consistent with other project constraints. For feasibility report purposes, operation model "A" was adopted for project design. with appropriate fisheries mitigation measures were developed based on Case A flows at Gold Creek. Table B.31 presents a summary of potential energy generation with different operating rules for Watana and Devil Canyon developments.

Average annual energy potential of Watana development is 3460 GWh, and that of Devil Canyon development is 3340 GWh. A frequency analysis of the river hydrology was made to derive the firm annual energy potential (or the dependable capacity) of the hydro development.

The Federal Energy Regulatory Commission (FERC) defines the dependable capacity of hydroelectric plants as: "the capacity which, under the most adverse flow conditions of record can be relied upon to carry system load, provide dependable reserve capacity, and meet firm power obligations taking into account seasonal variations and other characteristics of the load to be supplied" (1). Based on the Railbelt system studies and previous experience on large hydroelectric projects, it was assumed that a dry hydrological sequence with a recurrence period of the order of 1:50 years would constitute an adequate reliability for the Railbelt electrical system.

An analysis of annual energy potential of the reservoirs showed that the lowest annual energy generation has a recurrence frequency of 1 in 300 years. The second lowest annual energy of 5400 GWh has a recurrence frequency of 1 in 70 years. This latter figure has been adopted as the firm energy from the development.

Expressed another way, the firm energy as defined may fall short of its value by about 5 percent once in 300 years. This is a conservative interpretation of the FERC definition.

The monthly distribution of firm annual energy as simulated in the reservoir simulation has been used in system generation planning studies. Average monthly energy based on the recorded sequence hydrology is used in the economic analysis.

4 - DEPENDABLE CAPACITY AND ENERGY PRODUCTION

4.1 - Hydrology

(a) Historical Streamflow Records

Historical streamflow data are available for several gaging stations on the Susitna River and its main tributaries. Continuous gaging records were available for the following eight stations on the river and its tributaries: Maclaren River near Paxson. Denali, Cantwell, Gold Creek and Susitna stations on the Susitna River, Chulitna Station on the Chulitna River, Talkeetna on the Talkeetna River, and Skwentna on the Skwentna River. The longest period of record available is for the station at Gold Creek (32 years from 1949 to 1981). At other stations, record length varies from 6 to 23 years. Gaging was continued at all these stations as part of the project study program. A gaging station was established at the Watana damsite in 1980, and streamflow records are available for the study period. Partial streamflow records are available at several other stations on the river for varying periods; the station locations are shown in Figure B.43. It should be noted that gaging will continue as the project progresses in order to improve the streamflow record, as well as after project completion at selected sites required for project operation.

(b) Water Resources

Above its confluence with the Chulitna River, the Susitna contributes approximately 20 percent of the mean annual flow measured at Susitna Station near Cook Inlet. Figure B.44 shows how the mean annual flow of the Susitna increases towards the mouth of the river at Cook Inlet.

Seasonal variation of flow in the river is extreme and ranges from very low values in winter (October to April) to high summer values (May to September). For the Susitna River at Gold Creek, the average winter and summer flows are 2,100 and 20,250 cfs respectively, i.e., a 1 to 10 ratio. This large seasonal difference is mainly due to effects of glacial and snow melt in the summer.

The monthly average flows in the Susitna River at Gold Creek are given in Figure B.45. Some 40 percent of the streamflow at Gold Creek originates above the Denali and Maclaren gages. This catchment generally comprises the glaciers and associated high mountains. On the average, approximately 88 percent of the streamflow recorded at Gold Creek station occurs during the summer months. At higher elevations in the basin, the distribution of flows is concentrated even more in the summer months. For the Maclaren River near Paxson (Elevation 4520), the average winter and summer flows are 144 and 2,100 cfs respectively, i.e. a 1 to 15 ratio. The monthly percent of annual discharge and mean monthly discharges for the Susitna River and tributaries at the gaging stations above the Chulitna confluence are given in Table B.32.

(c) Streamflow Extension

Synthesized flows at the Watana and Devil Canyon damsites are presented in Tables B.33 and B.34. Flow duration curves based on these monthly estimates are presented for Watana and Devil Canyon damsites in Figures B.46 and B.47.

The inhouse FILLIN computer program developed by the Texas Water Development Board was used to fill in gaps in historical streamflow records at the eight continuous gaging stations. The 32 year record (up to 1981) at Gold Creek was used as the base record. The procedure adopted for filling in the data gaps uses a multisite regression technique which analyzes monthly time-series data. Flow sequences for the 32-year period were generated at the remaining seven stations. Using these flows at Cantwell station and observed Gold Creek flows, 32-year monthly flow sequences at the Watana and Devil Canyon damsites were generated on the basis of prorated drainage areas. Recorded streamflows at Watana and Devil Canyon were included in the historical record where available.

(d) Critical Streamflow Used for Dependable Capacity

[Note: This section is subject to revision after selection of minimum downstream flow in October.]

Average annual energy potential of Watana development is 3460 GWh, and that of Devil Canyon development is 3340 GWh. A frequency analysis of the river hydrology was made to derive the firm annual energy potential (or the dependable capacity) of the hydro development. Based on the Railbelt system studies and previous experience on large hydroelectric projects, it was assumed that a dry hydrological sequence with a recurrence period of the order of 1:50 years would constitute an adequate reliability for the Railbelt electrical system.

An analysis of annual energy potential of the reservoirs showed that the lowest annual energy generation has a recurrence frequency of 1 in 300 years (see Figure B.48). The second lowest annual energy of 5400 GWh has a recurrence frequency of 1 in 70 years. This latter figure has been adopted as the firm energy from the development.

Expressed another way, the firm energy, as defined, may fall short of its value by about 5 percent once in 300 years. This is

a conservative interpretation of the FERC definition of dependable capacity.

(e) Floods

The most common causes of flood peaks in the Susitna River Basin are snowmelt or a combination of snowmelt and rainfall over a large area. Annual maximum peak discharges generally occur between May and October with the majority (approximately 60 percent) occurring in June. Some of the annual maximum flood peaks have also occurred in August or later and are the result of heavy rains over large areas augmented by significant snowmelt from higher elevations and glacial runoff. Table B.35 presents selected flood peaks recorded at different gaging stations.

A regional flood peak and volume frequency analysis was carried out using the recorded floods in the Susitna River and its principal tributaries. These analyses were conducted for two different time periods. The first period, after the ice breakup and before freezeup (May through October), contains the largest floods which must be accommodated by the project. The second period represents that portion of time during which ice conditions occur in the river (October through May). These floods, although smaller, can be accompanied by ice jamming and must be considered during the construction phase of the project in planning the design of cofferdams for river diversion.

A set of multiple linear regression equations were developed using physiographic basin parameters such as catchment area, stream length, precipitation, snowfall amounts, etc., to estimate flood peaks at ungaged sites in the basin. In conjunction with the analysis of shapes and volumes of recorded large floods at Gold Creek, a set of project design flood hydrographs of different recurrence intervals were developed (see Figures B.49 and B.50).

The results of the above analysis were used for estimating flood hydrographs at the damsites and ungaged streams and rivers along the access road alignments for design of spillways, culverts, etc. Table B.36 lists mean annual, 50-, 100-, and 10,000-year floods at the Watana and Devil Canyon damsites and at the Gold Creek gage. The proposed reservoirs at Watana and Devil Canyon would be classified as "large" and with "high hazard potential" according to the guidelines for safety inspection of dams laid out by the Corps of Engineers. This would indicate the need for the probable maximum flood (PMF) to be considered in the evaluation of the proposed projects. Estimated peak discharges during the PMF at selected locations are included in Table B.36, and the PMF hydrograph is presented in Figure B.50.

(f) Flow Adjustments

Evaporation from the proposed Watana and Devil Canyon Reservoirs has been evaluated to determine its significance. Evaporation is influenced by air and water temperatures, wind, atmospheric pressure, and dissolved solids within the water. However, the evaluation of these factors' effects on evaporation is difficult because of their interdependence on each other. Consequently, more simplified methods were preferred and have been utilized to estimate evaporation losses from the two reservoirs.

The monthly evaporation estimates for the reservoirs are presented in Table B.37. The estimates indicate that evaporation losses will be less than or equal to additions due to precipitation on the reservoir surface. Therefore, a conservative approach was taken, with evaporation losses and precipitation gains neglected in the energy calculations.

Leakage is not expected to result in significant flow losses. Seepage through the relict channel is estimated as less than onehalf of one percent of the average flow and therefore has been neglected in the energy calculations to date. This approach will be reviewed when further investigations of the relict channel are completed.

Minimum flow releases are required throughout the year to maintain downstream river stages. The most significant factor in determining the minimum flow value is the maintenance of downstream fisheries. The monthly flow requirements that were used in determination of project energy potential are given in Table B.38.

The numbers shown in Table B.38 represent the minimum stream flow required at Gold Creek. These requirements would remain constant for all phases of project development. The actual flows released from the project at Watana (when Watana is operating alone) and at Devil Canyon (for combined operation of both dams) will be less than the required Gold Creek flows, prorated on the basis of streamflow contributions from the intervening basin area. Tables B.39 and B.40 give the typical minimum required flow releases at Watana and Devil Canyon for a 32-year period of record.

After completion of Devil Canyon, flow releases from Watana will be regulated by system operation requirements. Because the tailwater of the Devil Canyon reservoir will extend upstream to the Watana tailrace, there will be no release requirements for streamflow maintenance of Watana for the Watana/Devil Canyon combined operating configuration.

Existing water rights in the Susitna Basin were investigated to determine impacts on downstream flow requirements. Based on inventory information provided by the Alaska Department of Natural Resources, it was determined that existing water users will not be affected by the project. A listing of all water appropriations located within one mile of the Susitna River is provided in Table B.41.

4.2 - Reservoir Data

(a) <u>Reservoir Storage</u>

Gross storage volume of the Watana reservoir at its normal maximum operating level of 2185 feet is 9.47 million ac/ft, which is about 1.6 times the mean annual flow (MAF) at the damsite. Live storage in the reservoir is about 4.3 million ac/ft (75 percent of MAF). Devil Canyon reservoir has a gross storage of about 1.1 million ac/ft and live storage of 0.34 million ac/ft.

The area-capacity curves for the Watana and Devil Canyon reservoirs are provided in Figure B.51 and Figure B.52, respectively.

(b) Rule Curves

Operation of the reservoirs for energy production is based on target water surface levels set for the end of each month. The target level represents that level below which no energy beyond firm energy can be produced. In other words, if the reservoir level drops below the target only firm energy will be produced. In wetter years when the reservoir level surpasses the target level, energies greater than firm energy can be produced, but only as great as the system energy demand allows.

With a reservoir rule curve which establishes minimum reservoir levels at different times during the year, it will be possible to produce more energy in wetter years during winter than by following a set energy pattern. At the same time, the rule curve ensures that low flow sequences do not materially reduce the energy potential below a set minimum or firm annual energy.

The rule curves for Watana and Devil Canyon under combined operation are shown in Figure B.53.

4.3 - Operating Capabilities of Susitna Units

The operating conditions of both the Watana and Devil Canyon turbines are summarized in Table B.42.

(a) Watana

The Watana powerhouse will have six generating units with a nominal capacity of 170 MW corresponding to the minimum December reservoir level (Elevation 2117).

The gross head on the plant will vary from 590 feet to approximately 735 feet. The maximum unit output will change with head, as shown on Figure 8.54. The rated head for the turbine has been established at 680 feet, which is the weighted average operating head on the station. Allowing for generator losses, the rated turbine output is 250,000 hp (186.5 MW) at full gate.

The rated output of the turbines will be 250,000 hp at 680 feet rated net head. Maximum and minimum heads on the units will be 728 feet and 576 feet, respectively. The full gate output of the turbines will be about 275,000 hp at 728 feet net head and 195,000 hp at 576 feet net head. Overgating of the turbines may be possible, providing approximately 5 percent additional power; however, at high heads the turbine output will be restricted to avoid overloading the generators. The best efficiency point of the turbines will be established at the time of preparation of bid documents for the generating equipment and will be based on a detailed analysis of the anticipated operating range of the turbines. For preliminary design purposes, the best efficiency (best gate) output of the units has been assumed as 85 percent of the full gate turbine output. This percentage may vary from about 80 percent to 90 percent; in general, a lower percentage reduces turbine cost.

The full gate and best gate efficiencies of the turbines will be about 91 percent and 94 percent respectively at rated head. The efficiency will be about 0.5 percent lower at maximum head and 1 percent lower at minimum head. The preliminary performance curve for the turbine is shown on Figure B.55.

The Watana plant output may vary from zero, with the units at standstill or at spinning reserve, to approximately 1200 when all six units are operating under maximum output at maximum head. A graph of plant efficiency versus output and the number of on-line units is shown in Figure B.56. The load following requirements of the plant results in widely varying loading, but because of the multiple unit installation the total plant efficiency varies only slightly.

(b) Devil Canyon

The Devil Canyon powerhouse will have four generating units with a nominal capacity of 150 MW based on the minimum December reservoir level (Elevation 1405) and a corresponding gross head of 555 feet in the station.

The gross head on the plant will vary from 555 feet to 605 feet. The maximum unit output will change with head as shown in Figure B.57.

The rated average operating head for the turbine has been established at 575 feet. Allowing for generator losses, this results in a rated turbine output of 225,000 hp (168 MW) at full gate. The generator rating has been selected as 180 MVA with a 90 percent power factor. The generators will be capable of continuous operation at 115 percent rated power. Because of the high capacity factor for the Devil Canyon station, the generators will therefore be sized on the basis of maximum turbine output at maximum head, allowing for a possible 5 percent addition in power from the turbine. This maximum turbine output (250,000 hp) is within the continuous overload rating of the generator.

Maximum and minimum heads on the units will be 542 feet and 600 feet, respectively. The full gate output of the turbines will be about 240,000 hp at maximum net head and 205,000 hp at minimum net head. Overgating of the turbines may be possible, providing approximately 5 percent additional power. For preliminary design purposes, the best efficiency (best gate) output of the units has been assumed at 85 percent of the full gate turbine output.

The full gate and best gate efficiencies of the turbines will be about 91 percent and 94 percent, respectively, at rated head. The efficiency will be about 0.2 percent lower at maximum head and 0.5 percent lower at minimum head. The preliminary performance curve for the turbine is shown in Figure B.58.

The Devil Canyon plant output may say from zero to 700 MW with all four units operating at maximum output. The combined plant efficiency varies with output and number of units operating as shown in Figure B.59. As with Watana, the plant efficiency varies only slightly with loading due to the load following capabilities of multiple units.

4.4 - Tailwater Rating Curve

ð

The tailwater rating curve for the Watana development is shown on Figure B.51 and for the Devil Canyon development on Figure B.52.

5 - STATEMENT OF POWER NEEDS AND UTILIZATION

5.1 - Railbelt Load Forecasts

In this section of the report, the electrical demand forecasts for the Railbelt region are described. Historical and projected trends are identified and discussed, and the forecasts used in Susitna generation planning studies are presented.

The feasibility of a major hydroelectric project depends in part upon the extent the available capacity and energy are consistent with the needs of the market to be served by the time the project comes on line. The Alaska Power Authority and the State of Alaska authorized load forecasts for the Alaska Railbelt region to be prepared independently of the Susitna feasibility study.

The Railbelt region, shown in Figure B.60, contains three electrical load centers: the Anchorage-Cook-Inlet area, the Fairbanks-Tanana Valley area, and the Glennallen-Valdez area. These areas are represented by the shaded areas in the figure. Because of the relatively small electrical requirements of the Glennallen-Valdez load center (approximately 2 percent of the demand of the Anchorage-Cook Inlet area) it is not specifically analyzed as an individual load center. For this study the Glennallen-Valdez load center is considered to be part of the Anchorage-Cook Inlet load center. The electrical demands for the Glennallen-Valdez area are determined as part of this study but are combined with the Anchorage-Cook Inlet loads. Future electrical requirements in excess of generating capacity are assumed to be served from the Anchorage area.

(a) Scope of Studies

There have been two forecasts developed and used during the feasibility study. In 1980, the Institute for Social and Economic Research (ISER) prepared economic and accompanying end use energy demand projections for the Railbelt. The end use forecasts were further refined as part of the feasibility study to estimate capacity demands and demand patterns. Also estimated was the potential impact on these forecasts of additional load management and energy conservation efforts. These forecasts were used in several portions of the feasibility study, including the development selection study, and initial economic, financial and sensitivity analyses. These forecasts are discussed in more detail in section (b) below.

In December 1981, Battelle Pacific Northwest Laboratories produced a series of revised load forecasts for the Railbelt. These forecasts were developed as a part of the Railbelt Alternatives Study,
completed by Battelle under contract to the State of Alaska. Battelle's forecasts were a result of further updating of economic projections by ISER and some revised end-use models developed by Battelle, which took into account price sensitivity and several other factors not included in the 1980 projections. The December 1981 Battelle forecasts were used in the final project staging, economic, financial and sensitivity analyses. The December 1981 Battelle forecasts are presented in section (c) below.

(b) Electricity Demand Profiles

This section reviews the historical growth of electricity consumption in the Railbelt and compares it to the national trend. Earlier forecasts of Railbelt electricity consumption by ISER, which were used in Susitna development selection studies, are also described.

(i) <u>Historical Trends</u>

Between 1940 and 1978, electricity sales in the Railbelt grew at an average annual rate of 15.2 percent. This growth was roughly twice that for the nation as a whole. Table B.43 shows U.S. and Alaskan annual growth rates for different periods between 1940 and 1978. The historical growth of Railbelt utility sales from 1965 is illustrated in Figure B.61.

Although the Railbelt growth rates consistently exceeded the national average, the gap has been narrowing in later years due to the gradual maturing of the Alaskan economy. Growth in the Railbelt has exceeded the national average for two reasons: population growth in the Railbelt has been higher than the national rate, and the proportion of Alaskan households served by electric utilities was lower than the U.S. average so that some growth in the number of customers occurred independently of population growth. Table B.44 compares U.S. and Alaskan growth rates in the residential and commercial sectors.

The distribution of electricity consumption between residential and commercial-industrial-government sectors has been fairly stable. By 1978, the commercial-industrialgovernment and residential sectors accounted for 52 percent and 47 percent respectively. In contrast, the 1978 nationwide shares were 65 percent and 34 percent, respectively.

Historical electricity demand in the Railbelt, disaggregated by regions, is shown in Table B.45. During the period from 1965 to 1978, Greater Anchorage accounted for about 75 percent of Railbelt electricity consumption followed by Greater Fairbanks with 24 percent and Glennallen-Valdez with 1 percent. The pattern of regional sharing during this period has been quite stable and no discernible trend in regional shift has emerged. This is mainly a result of the uniform rate of economic development in the Alaskan Railbelt.

(ii) ISER Electricity Consumption Forecasts

The methodology used by ISER to estimate electric energy sales for the Railbelt is summarized in this section and the results obtained are discussed.

Methodology

•

The ISER electricity demand forecasting model conceptualized in computer logic the linkage between economic growth scenarios and electricity consumption. The output from the model is in the form of projected values of electricity consumption for each of the three geographical areas of the Railbelt (Greater Anchorage, Greater Fairbanks and Glennallen-Valdez) and is classified by final use (i.e., heating, washing, cooling, etc.) and consuming sector (commercial, residential, etc). The model produces output on a five-year time basis from 1985 to 2010, inclusive.

The ISER model consists of several submodels linked by key variables and driven by policy and technical assumptions and state and national trends. These submodels are grouped into four economic models which forecast future levels of economic activity and four electricity consumption models which forecast the associated electricity requirements by consuming sectors. For two of the consuming sectors it was not possible to set up computer models and simplifying assumptions were made.

Forecasting Uncertainty

To adequately address the uncertainty associated with the prediction of future demands, a number of different economic growth scenarios were considered. These were formulated by alternatively combining high, moderate and low growth rates in the area of special projects and industry with State government fiscal policies aimed at stimulating either high, moderate or low growth. This resulted in a total of nine potential growth scenarios for the state. In addition to these scenarios, ISER also considered the potential impact of a price reduced shift towards increased electricity demand. A short list of six future scenarios was selected. These concentrated around the mid-range or "base case" estimate of the upper and lower and extremes (see Table B.46).

Demand Forecasts

An important factor to be considered in generation planning studies is the peak power demand associated with a forecast of electric energy demand. The overall approach to derivation of the peak demand forecasts for the Railbelt region was to examine the available historical data with regard to the generation of electrical energy and to apply the observed generation patterns to existing sales forecasts. Information routinely supplied by the Railbelt utilities to the Federal Energy Regulatory Commission was utilized to determine these load patterns.

The first step involved an adjustment to the allocated sales to reflect losses and energy unaccounted for. The adjustment was made by increasing the energy allocated to each utility by a factor computed from historical sales and generation levels. This resulted in a gross energy generation for each utility.

The factors determined for the monthly distribution of total annual generation were then used to distribute the gross generation for each year. The resulting hourly loads for each utility were added together to obtain the total Railbelt system load pattern for each forecast year. Table B.47 summarizes the total energy generation and the peak loads for each of the low, medium, and high ISER sales forecasts, assuming moderate government expenditure.

Adjusted ISER Forecasts

Three of the initial ISER energy forecasts were considered in generation planning studies for development selection studies. These included the base case (MES-GM) or <u>medium</u> forecast, a <u>low</u> forecast and a <u>high</u> forecast. The low forecast was that corresponding to the low economic growth as proposed by ISER with an adjustment for low government expenditure (LES-GL). The high forecast corresponded to the ISER high economic growth scenario with an adjustment for high government expenditure (HES-GH).

The electricity forecasts summarized in Table B.47 represent total utility generation and include projections for self-supplied industrial and military generation sectors. Included in these forecasts are transmission and distribution losses in the range of 9 to 13 percent depending upon the generation scenario assumed. These forecasts, ranging from 2.71 to 4.76 percent average annual growth, were adjusted for use in generation planning studies.

The self-supplied industrial energy primarily involves drilling and offshore operations and other activities which are not likely to be connected into the Railbelt supply system. This component, which varies depending upon generation scenario, was therefore omitted from the forecasts used for planning purposes.

The military is likely to continue purchasing energy from the general market as long as it remains economic. However, much of their generating capacity is tied to district heating systems which would presumably continue operation. For study purposes, it was therefore assumed that 30 percent of the estimated military generation would be supplied from the grid system.

The adjustments made to power and energy forecasts for use in self-supplied industrial and military sectors are reflected in Table B.47 and in Figure B.62. The power and energy values given in Table B.48 are those developed by ISER and used in the development selection studies. Annual growth rates range from 1.99 to 5.96 percent for very low and high forecasts with a mediur generation forecast of 3.96 percent.

(c) Battelle Load Forecasts

As part of its study of Alaska Railbelt Electric Energy Alternatives, Reference 6, Battelle did extensive work in reviewing the 1980 ISER forecasts, methodology, and data, and produced a new series of forecasts. These forecasts built on the base of information and modeling established by ISER's 1980 work and, with the assistance of ISER, developed new models for forecasting Railbelt economic activity and resulting electrical energy demands. The resulting forecasts were adopted directly for use in final generation planning studies under this feasibility study. These revised forecasts included both an energy and peak capacity projection for each year of the study period (1982~2010). The projection left out portions of electrical demand which would be self-supplied, such as much of the military demand and some of the industrial demand. In addition, these forecasts took into account the conservation technology and market penetration likely to take place. Details of the Battelle forecasts and methodology are available in a report produced by Battelle in early 1982 (8). The demand forecasting process is summarized in the following three paragraphs.

Figure B.63 shows the electricity demand forecasting process used by Battelle. The forecasting process contains two steps. The first step combines sets of consistent economic and policy assumptions (scenarios) with economic models from the ISER to produce forecasts of future economic activity, population, and households in the Railbelt region and its three load centers. In the second step, these forecasts are combined with data on current end uses of electricity in the residential sector, data on the size of the Railbelt commercial building stock, data on the cost and performance of conservation, assumptions concerning the future prices of electricity and other fuels, and future uses of electricity to produce demand forecasts.

The economic and population forecasts, energy use data, and other assumptions are all entered into a computer-based electricity demand forecasting model called the Railbelt Electricity Demand (RED) Model. The RED model generates forecasts of housing stock and commercial building stock and the price-adjusted intensity of energy use in both the residential and commercial (including government) sectors. It also adds estimates of major industrial electrical energy demand and miscellaneous uses such as street lighting. These forecasts are adjusted for specific energy conservation policies, and then the major end-use sector forecasts are combined by the model into forecasts of future annual demand for electric energy for each of the Railbelt's load centers. The combined annual loads are adjusted by an annual load factor to estimate future annual peak demand by load center. Finally, the peak loads are added together and multiplied by a diversity factor (to adjust for the fact that peak loads for different load centers do not coincide) to derive peak demand for the Railbelt. More detail on the REO model can be found in Reference 7.

The projected cost of power affects these forecasts. Because the size of demand for power affects the size, number, and cost of generating facilities that may have to be built to meet the demand (which in turn affects the cost of power), several passes through the REO model with constant economic assumptions and varying costs of power are required to produce a final forecast.

The Battelle study produced numerous load forecasts which corresponded to different development plans. The plans varied due to different economic scenarios and costs of power. From these separate forecasts, a high, medium and low forecast were selected for project planning and economic and financial feasibility studies.

The Battelle forecasts are based on energy sales, and have therefore been adjusted by an addition of an estimated 8 percent for transmission losses to arrive at the supply forecast to be used in generation planning. Table B.49 and Figure B.64 present the three Battelle forecasts which were prepared to bracket the range of electrical demand for the future.

It should be noted that the load forecast figures vary in absolute values of peak demand and energy from those figures in the referenced Battelle studies. This minor variance (approximately 5-8 percent in the project development years) is due to the revision in the Battelle forecasts in 1982 after the feasibility work on Susitna proceeded using December 1981 numbers.

The Battelle forecasts were used in second stage generation planning studies. The second stage studies focused on the economic and financial feasibility of the selected Susitna project and the sensitivity of the analyses to variation of key study assumptions. The differences between the earlier ISER forecasts used in development selection studies and the revised Battelle forecasts are not considered to be significant enough to have altered the conclusions of the earlier studies. The Railbelt generation planning studies undertaken for Susitna feasibility assessment were based on the Battelle medium forecast. The high and low Battelle forecasts were used as a basis for sensitivity testing.

No additional information on load patterns relative to monthly and daily shifting of load shapes was developed in the Battelle forecasts. Thus, the historical data developed to use with the 1980 ISER forecasts were also used with the Battelle forecasts.

5.2 - Market and Price for Watana Output in 1994

It has been planned that Watana energy will be supplied at a single wholesale rate on a free market basis. This requires, in effect, that Susitna energy be priced so that it is attractive even to utilities with the lowest cost alternative source of energy. On this basis it is estimated that for the marketable 3315 GWh of energy generated by Watana in 1994 to be attractive, a price of 145 mills per kWh in 1994 dollars is required. Justification for this price is illustrated in Figure B.65. Note that the assumption is made that the only capital costs which would be avoided in the early 1990s would be those due to the addition of new coal-fired generating plants (i.e., the alternative 2×200 MW coal-fired Beluga station).

The financing considerations under which it would be appropriate for Watana energy to be sold at approximately 145 mills/kWh price are presented in Exhibit D; however, it should be noted that some of the energy which would be displaced by Watana's 3315 GWh would have been generated at a lower cost than 145 mills, and utilities might wish to delay accepting it at this price until the escalating cost of natural gas or other fuels made it more attractive. A number of approaches to the resolution of this problem can be postulated, including pre-contract arrangements.

(a) Contractual Preconditions for Susitna Energy Sale

8. T. .

It will be necessary to contract with Railbelt Utilities for the purchase of Susitna capacity and energy on a basis appropriate to support financing of the project.

Pricing policies for Susitna output are assumed to be constrained by both cost (as defined by State of Alaska Senate Bill 25) and by the price of energy from the best thermal option.

Marketing Susitna's output within these twin constraints would ensure that all state support for Susitna flowed through to consumers and under no circumstances were prices to consumers higher than they would have been under the best thermal option. In addition, consumers would also obtain the long-term economic benefits of Susitna's low cost energy.

(b) Market Price for Watana Output 1995-2001

After its initial entry into the system in 1994, the price and market for the 3315 Gwh of Watana output is consistently upheld over the years to 2001 by the projected 20 percent increase in total demand over this period.

There would, as a result, be a 70 percent increase in cost savings compared with the best thermal alternative. The increasing cost per unit of output from a system without Susitna is illustrated in Figure B.66.

(c) Market and Price for Watana and Devil Canyon Output in 2003

A diagramatic analysis of the total cost savings which the combined Watana and Devil Canyon output will confer on the system compared with the present thermal option in the year 2003 is shown in Figure B.67. These total savings are divided by the energy contributed by Susitna to indicate a price of 250 mills per kWh as the maximum price which can be charged for Susitna output. Here again, the problem of competing with lower cost combined cycle, gas turbines, etc., will have to be addressed; however, this problem is likely to be short term in nature, since by this time period these thermal power facilities will be approaching retirement. Only about 90 percent of the total Susitna output will be absorbed by the system in 2002; the balance of the output will be progressively absorbed over the following decade. This will provide increasing total savings to the system from Susitna with no associated increase in costs.

(d) Potential Impact of State Appropriations

In the preceding paragraphs the maximum price at which Susitna energy could be sold has been identified. Sale of the energy at these prices will depend upon the magnitude of any proposed state appropriation designed to reduce the cost of Susitna energy in the earlier years. At significantly lower prices it is likely that the total system demand will be higher than assumed. This, combined with a state appropriation to reduce the energy cost of Watana energy, would make it correspondingly easier to market the output from the Susitna development; however, as the preceding analysis shows, a viable and strengthening market exists for the energy from the development that would make it possible to price the output up to the cost of the best thermal alternative.

(e) <u>Conclusions</u>

Based on the assessment of the market for power and energy output from the Susitna Hydroelectric Project, it has been concluded that, with the appropriate level of state appropriation and with pricing as defined in Senate Bill 25, an attractive basis exists, particularly in the long term, for the Railbelt utilities to derive benefit from the project. It should be recognized that contractual arrangements covering purchase of Susitna output will be an essential precondition for the actual commencement of project construction. These contractual arrangements will be pursued during the licensing and design phase of the project.

5.3 - Sale of Power

Electrical energy from the Susitna Hydroelectric Project will be sold to utilities serving the Anchorage/Fairbanks net.

The potential customers for Susitna power utilities in the Railbelt include:

- Fairbanks Municipal Utility System;
- Homer Electric Association;
- Anchorage Municipal Light & Power Department;
- Chugach Electric Association;
- Golden Valley Electric Association;
- Matanuska Electric Association;
- Seward Electric System; and
- Copper Valley Electric Association.

A more detailed discussion of marketing can be found in Reference 8.

6 - FUTURE SUSITNA BASIN DEVELOPMENT

The Alaska Power Authority has no current plans for further development of the Watana/Devil Canyon system and no plans for further water power projects in the Susitna River Basin at this time.

Development of the proposed projects would preclude further major hydroelectric development in the Susitna basin, with the exception of major storage projects in the Susitna basin headwaters. Although these type of plans have been considered in the past, they are neither active nor anticipated to be so in the foreseeable future.

EXHIBIT B - STATEMENT OF PROJECT OPERATION AND RESOURCES UTILIZATION

LIST OF REFERENCES

- 1. Acres American Inc., Susitna Hydroelectric Project, Development Selection Report, prepared for the Alaska Power Authority, December 1981.
- Woodward-Clyde Consultants, Final Report on Seismic Studies for Susitna Hydroelectric Project, prepared for Acres American Inc., February 1982.
- 3. Acres American Inc., <u>Susitna Hydroelectric Project, 1980-81 Geo-</u> technical Report, prepared for the Alaska Power Authority, February 1982.
- 4. Acres American Inc., Susitna Hydroelectric Project, Feasibility Report, prepared for the Alaska Power Authority, March 1982.
- 5. General Electric Company, OGP5 User's Manual, May 1979.
- Battelle Pacific Northwest Laboratories, <u>Railbelt Electric Power</u> <u>Alternatives Study: Evaluation of Railbelt Electric Energy</u> <u>Plans</u>, prepared for the Office of the Governor, State of Alaska, August 1982.
- 7. Battelle Pacific Northwest Laboratories, <u>The Railbelt Electricity</u> <u>Demand (RED) Model Specifications Report</u>, prepared for the Office of the Governor, State of Alaska, August 1982.
- 8. Acres American Inc., <u>Susitna Hydroelectric Project Reference</u> <u>Report, Economic, Marketing and Financial Evaluation</u>, prepared for the Alaska Power Authority, April 1982.

| D | am | | | Capital Cost | Installed | Average Annual | Economic ¹ Cost of | Source |
|----------------------------------|------------------|---------------|------------------------|--|------------------|-------------------|----------------------------------|---|
| Site | Proposed Type | Height Ft. | Upstream Regulation | \$ million (1980) | Capacity (MW) | Energy Gwh | Energy \$/1000 kWh | of Data |
| Gold Creek ² | Fill | 190 | Yes | 900 | 260 | 1,140 | 37 | USBR 1953 |
| Olson (Susitna II) | Concrete | 160 | Үез | 600 | 200 | 915 | 31 | USBR 1953 KAISER 1974 COE 1975 |
| Devil Canyon | Concrete | 675 | No Yes | 830 1,000 | 250 600 | 1,420 2,980 | 27 17 | This Study |
| High Devil Canyon (Susitna I) | Fill | 855 | No | 1,500 | 800 | 3,540 | 21 | 1 |
| Devil Creek ² | Fill | Approx 850 | No | | | | | 0- |
| Watana | Fill | 880 | No | 1,860 | 800 | 3,250 | 28 | 1997 - |
| Susitna III | Fill | 670 | No | 1,390 | 350 | 1,580 | 41 | 11 |
| Vee | Fill | 610 | No | 1,060 | 400 | 1,370 | 37 | |
| Maclaren ² | Fill | 185 | No | 530 ⁴ | 55 | 180 | 124 . | ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ |
| Denali | Fill | 230 | No | 480 ⁴ | 60 | 245 | 81 | IT |
| Butte Creek ² | Fill | Approx 150 | No | | 40 | 130 ³ | | USBR 1953 |
| Tyone ² | Fill | Approx 60 | No | ار بر این کرد بر این کرد این | 6 | 22 ³ | | USBR 1953 |

TABLE B.1: POTENTIAL HYDROELECTRIC DEVELOPMENT

Notes:

2

Includes AFDC, Insurance, Amortization, and Operation and Maintenance Costs.
 No detailed engineering or energy studies undertaken as part of this study.
 These are approximate estimates and serve only to represent the potential of these two damsites in perspective.
 Include estimated costs of power generation facility.

| | | Capital Cost Estimate ² (1980 \$) | | | | | | | | | |
|----------------------------------|---------------------|--|----------------------------|----------------------------|----------------------------|----------------------------|--|--|--|--|--|
| DAM | | ACR | ES 1980 | | OTHERS | | | | | | |
| Site | Туре | Installed Capacity - MW | Capital Cost \$ million | Installed Capacity - MW | Capital Cost \$ million | Source and Date of Data | | | | | |
| Gold Creek | Fill | | | 260 ¹ | 890 | USR8 1968 | | | | | |
| Olson (Susitna II) | Concrete | | | 190 ¹ | 550 | COE 1975 | | | | | |
| Devil Canyon | Fill Concrete | 600 | 1,000 | | 1 | | | | | | |
| | Arch | | | 776 | 630 | COE 1975 | | | | | |
| | Concrete Gravity | - 1997 | | 776 | 910 | COE 1978 | | | | | |
| High Devil Canyon (Susitna I) | Fill | 800 | 1,500 | 700 | 1,480 | COE 1975 | | | | | |
| Devil Creek | Fill | | | | | | | | | | |
| Watana | Fill | 800 | 1,860 | 792 | 1,630 | COE 1978 | | | | | |
| Susitna III | Fill | 350 . | 1,390 | 445 | | KAISER 1974 | | | | | |
| Vee | Fill | 400 | 1,060 | | 770 | COE 1975 | | | | | |
| Maclaren | Fill | 55 | 530 | | | | | | | | |
| Denali | Fill | 60 | 480 | None | 500 | COE 1975 | | | | | |

TABLE B.2 - COST COMPARISONS

Notes:

(1) Dependable Capacity(2) Excluding Anchorage/Fairbanks transmission intertie, but including local access and transmission.

| | | • | | | |
|--|-------------------------------|-------------------------------|-----------------------------|-------------------------------------|-----------------------------------|
| Site | Staged Dam Construction | Full Supply Level - Ft. | Dam Crest Level - Ft. | Average Tailwater Level - ft. | Dam Height ¹ ft. |
| Gold Creek | No | 870 | 880 | ട്80 | 290 |
| Olson | No | 1,020 | 1,030 | 810 | 310 |
| Portage Creek | No | 1,020 | 1,030 | 870 | 250 |
| Devil Canyon - intermediate height | No | î,250 | 1,270 | 890 | 465 |
| Devil Canyon - full height | No | 1,450 | 1,470 | 890 | 675 |
| High Devil Canyor | n No No | 1,610 1,750 | 1,630 1,775 | 1,030 1,030 | . 710 855 |
| Watana | Yes | 2,000 | 2,060 | 1,465 | 680 |
| | Stage 2 | 2,200 | 2,225 | 1,465 | 880 |
| Susitna III | No - | 2,340 | 2,360 | 1,810 | 670 |
| Vee | No | 2,330 | 2,350 | 1,925 | 610 |
| Maclaren | No | 2,395 | 2,405 | 2,300 | 185 |
| Denali | No | 2,540 | 2,555 | 2,405 | 230 |
| | | | | | |

TABLE B.3: DAM CREST AND FULL SUPPLY LEVELS

Notes:

(1) To foundation level.

| | Item | Devil Canyon 1470 ft Crest 600 MW | High Devil Canyon 1775 ft Crest 800 MW | Watana 2225 ft Crest 800 MW | Susitna III 2360 ft Crest 330 MW | Vee 2350 ft Crest 400 MW | Maclaren 2405 ft Crest No power | Denali 2250 ft Crest No power |
|------------|-------------------------------|---|--|-----------------------------------|--|--------------------------------|---------------------------------------|-------------------------------------|
| 1) | Lands, Damages & Reservoirs | 26 | 11 | 46 | 13 | 22 | 25 | 38 |
| 2) | Diversion Works | 50 | 48 | 71 | 88 | 37 | 118 | 112 |
| 3) | Main Dam | 166 | 432 | 536 | 398 | 183 | 106 | 100 |
| 4) | Auxiliary Dam | 0 | 0 | 0 | 0 | 40 | 0 | ີ ເພື່ອເຫັນ ເປັນ ແມ່ນ ເປັນ |
| 5) | Power System | 195 | 232 | 244 | 140 | 175 | 0 | Đ. |
| 6) | Spillway System | 130 | 141 | 165 | 121 | 74 | 0 | ð |
| 7) | Roads and Bridges | 45 | 68 | 96 | 70 | 80 | 57 | 14 |
| 8) | Transmission Line | 10 | 10 | 26 | 40 | 49 | 0 | |
| 9) | Camp Facilities and Support | 97 | 140 | 160 | 130 | 100 | 53 | 50 |
| 10) | Miscellaneous ¹ | 8 | 8 | 8 | 8 | 8 | 5 | |
| <u>11)</u> | Mobilization and Preparation | <u> </u> | 47 | 57 | 45 | 35 | 15 | 14 |
| | Subtotal Contingency (20%) | 757 152 | 1137 227 | 1409 282 | 1053 211 | 803 161 | 379 76 | 333 67 |
| | Administration (12%) | 91 | 136 | 169 | 126 | 96 | 45 | 40 |
| - | TOTAL | 1000 | 1500 | 1860 | 1390 | 1060 | 500 | 440 |

TABLE B.4 - CAPITAL COST ESTIMATE SUMMARIESSUSITNA BASIN DAM SCHEMESCOST IN \$MILLION 1980

Notes:

ð

(1) Includes recreational facilities, buildings and grounds and permanent operating equipment.

TABLE B.5 - RESULTS OF SCREENING MODEL

| | Total | Demand | Optim | al Soluti | on | | First | : Suboptim | al Soluti | ion | Second | Subopti | mal Souli | tion |
|-------|------------|---------------|-------------------------|------------------------|---------------------|-----------------------------|-------------------------|------------------------|-----------------------|-----------------------------|---|------------------------|---------------------|-----------------------------|
| Run | Cap. MW | Energy GWh | Site Names | Max. Water Level | Inst. Cap. MW | Total Cost \$ million | Site Names | Max. Water Level | · Inst. Cap. MW | Total Cost \$ million | Site Names | Max. Water Level | Inst. Cap. MW | Total Cost \$ million |
| 1 | 400 | 1750 | High Devil Canyon | 1580 | 400 | 885 | Devil Canyon | 1450 | 400 | 970 | We tana | 1950 | 400 | 980 |
| 2 | 300 | 3500 | High Devil Canyon | 1750 | 800 | 1500 | Watana | 1900 | 450 | 1130 | Watana | 2200 | 800 | 1860 |
| | | | | | | | Devil Canyon | 1250 | 350 | 710 | | | | |
| | | | | | ¢ | | TOTAL | | 800 | 1840 | | | | |
| 3 | 1200 | 5250 | Watana | 2110 | 700 | 1690 | High Devil Canyon | 1750 | 800 | 1500 | High Devil Canyon | 17 50 | 820 | 1500 |
| · · · | | | Devil Canyon | 1350 | 500 | 800 | Vee | 2350 | 400 | 1060 | Susitna III | 2 /00 | 380 | 1260 |
| | | | TOTAL | | 1200 | 2490 | TOTAL | | 1200 | 2560 | TOTAL | | 1200 | 2760 |
| 4 | 1400 | 6150 | Watana | 2150 | 740 | 1770 | | | | | <u>marini de constante de constante de cons</u> tante de constante de constante de constante de constante de constante de | | | |
| | | | Devil Canyon | 1450 | 660 | 1000 | U N | 5 U L U | IIUN | | N | U 5 U I | | N |

.

6

| | Devil Canvon | <u> </u> | Tunnel Sch | eme | |
|---|----------------------------|-----------------------|-----------------------|----------------------|----------------------|
| Item | Dam | 1 | 2 | 3 | 4 |
| | | | | | |
| Reservoir Area (Acres) | 7,500 | 320 | 0 | 3,900 | 0 |
| River Miles Flooded | 31.6 | 2.0 | 0 | 15.8 | 0 |
| Tunnel Length (Miles) | 0 | 27 | 29 | 13.5 | 29 |
| Tunnel Volume (1000 Yd ²) | Q | 11,976 | 12,863 | 3,732 | 5,131 |
| Compensating Flow Release (cfs) | 0 | 1,000 | 1,000 | 1,000 | 1,000 |
| Reservoir Volume (1000 Acre-feet) | 1,100 | 9.5 | | 350 | |
| Dam Height (feet) | 625 | 75 | | 245 | |
| Typical Daily Range of Discharge From Devil Canyon Powerhouse (cfs) | ء 6,000 to 13,000 | 4,000 to 14,000 | 4,000 to 14,000 | 8,300 to 8,900 | 3,900 to 4,200 |
| Approximate Maximum Daily Fluctuations in Reservoir (feet) | 2 | 15 | | 4 | |

TABLE B.6: INFORMATION ON THE DEVIL CANYON DAM AND TUNNEL SCHEMES

Notes:

³ Estimated, above existing rock elevation.

| Stage | In Cap Watana | nstalled acity (MW) Devil Canyon Tunnel | Increase ¹ in Installed Capacity (MW) | Devil Canyon Average Annual Energy (Gwh) | 1 Increase in Average Annual Energy (Gwh) | Tunnel Scheme Total Project Costs \$ Million | Cost of Additional Energy ¹ (mills/kWh) |
|---|-------------------------|--|--|---|---|---|---|
| STAGE 1: | | | | | | | |
| Watana Dam | 800 | vite ess atta | | a <u>n in 19</u> | | | |
| STAGE 2: | | | | | | | |
| Tunnel: | | | | | | | |
| - Scheme 1 - Scheme 2 - Scheme 3 ² - Scheme 4 | 800 70 850 800 | 550 1,150 330 365 | 550 420 380 365 | 2,050 4,750 2,240 2,490 | 2,050 1,900 2,180 890 | 1980 2320 1220 1490 | 42.6 52.9 24.9 73.6 |

TABLE B.7 - DEVIL CANYON TUNNEL SCHEMES COSTS, POWER DUTPUT AND AVERAGE ANNUAL ENERGY

Notes:

/

(1) Increase over single Watana, 800 MW development 3250 Gwh/yr
(2) Includes power and energy produced at re-regulation dam
(3) Energy cost is based on an economic analysis (i.e. using 3 percent interest rate)

TABLE B.8 - CAPITAL COST ESTIMATE SUMMARIES TUNNEL SCHEMES COSTS IN \$MILLION 1980

. . .

2. ġ

.

a 1 2

| Item | | Two 30 ft dia tunne).s | | One 40 ft dia tunnel |
|--|-----|---------------------------|-----|-------------------------|
| Land and damages, reservoir clearing | | 14 | | 14 |
| Diversion works | | 3'5 | | 35 |
| Re-regulation dam | | 102 , |) | 102 |
| Power system (a) Main tunnels (b) Totake, powerbouse, tailrace | 557 | \$ 80 | 453 | 576 |
| and switchyard | 123 | | 123 | |
| Secondary power station | | 21 | | 21 |
| Spillway system | | 42 | | 42 |
| Roads and bridges | | 42 | | 42 |
| Transmission lines | | 15 | | 15 |
| Camp facilities and support | | 131 | | 117 |
| Missellaneous* | | 8 | | 8 |
| Mobilization and preparation | | 47 | | 47 |
| TOTAL CONSTRUCTION COST | | 1,137 | | 1,015 |
| Contingencies (20%) Engineering, and Owner's Administration | | 227 136 | | 203 122 |
| TOTAL PROJECT COST | | 1,500 | | 1,340 |

TABLE B.9. SUSITNA DEVELOPMENT PLANS

| Plan Stage Con | | | | Stage/Inc | | Cumulative System Data | | | |
|----------------|----------|--|-----------------------------|--------------------------|--------------------------|------------------------------|---------------------------------|-------------------------|-----------------|
| | | | Capital Cost \$ Millions | Earliest On-line 1 | Reservoir Full Supply | Maximum Seasonal Draw- | Annua Energ Produ Firm | l y ction Avg. | Plant Factor |
| Plan | Stage | Construction | (1980 values) | Date | Level - ft. | down-ft | GWH | GWH. | <u> </u> |
| 1.1 | 1 2 | Watana 2225 ft 800MW Devil Canyon 1470 ft | 1860 | 1993 | 2200 | 150 | 2670 | 3250 | 46 |
| | | 600 MW Total System 1400 MW | <u>1000</u> 2860 | 1996 | 1450 | 100 | 5500 | 6230 | 51 |
| 1.2 | 1 | Watana 2060 ft 400 MW | 1570 | 1992 | 2000 | 100 | 1710 | 2110 | 60 |
| | 2 | Watana raise to 2225 ft Watana add 400 MW | 360 | 1995 | 2200 | 150 | 2670 | 2990 | 85 |
| | 6 | capacity | 130 ² | 1995 | 2200 | 150 | 2670 | 3250 | 46 |
| | 4 | Devil Canyon 1470 ft 600 MW TOTAL SYSTEM 1400 MW | <u>1000</u> 3060 | 1996 | 1450 | 100 | 5500 | 6230 | 51 |
| | | | | | | | | | |
| 1.3 | 1 2 | Watana 2225 ft 400 MW Watana add 400 MW | 1740 | 1993 | 2200 | 150 | 2670 | 2990 | 85 |
| | 3 | capacity Devil Canvon 1470 ft | 150 | 1993 | 2200 | 150 | 2670 | 3250 | 46 |
| | | 600 MW TOTAL SYSTEM 1400 MW | <u>1000</u> 2890 | 1996 | 1450 | 100 | 5500 | 6230 | 51 |

0.

2.2

TABLE B.9 (Continued)

| · · · · · · · · · · · · · · · · · · · | | | • | Stage/Inc | 8 | Cumulative System Data | | | |
|---------------------------------------|-------------|--|------------------------------|---------------------------|--------------------------|------------------------------|---------------------------------|----------------------------|-----------------|
| | | | Capital Cost \$ Millions | Earliest On-line | Reservoir Full Supply | Maximum Seasonal Draw- | Annua Energ Produ Firm | il ly lction Avg. | Plant Factor |
| Plan | Stage | Construction | (1980 values) | Date ¹ | Level - ft. | down-ft. | GWH | GWH | ₩. |
| 2.1 | 1 | High Devil Canyon | | | | | | | |
| | 2 | 1775 ft 800 MW Vee 2350 ft 400 MW TOTAL SYSTEM 1200 MW | 1500 <u>1060</u> 2560 | 1994 ³ 1997 | 1750 2330 | 150 150 | 2460 3870 | 3400 4910 | 49 47 |
| 2.2 | 1 | High Devil Canyon | | | | | | | |
| | 2 | 1630 ft 400 MW High Devil Canyon add 400 MW Capacity | 1140 | 1993 ³ | 1610 | 100 | 1770 | 2020 | 58 |
| | 3 | raise dam to 1775 ft Vee 2350 ft 400 MW TOTAL SYSTEM 1200 MW | 500 <u>1030</u> 2700 | 1996 1997 | 1750 2330 | 150 150 | 2460 3870 | 3400 4910 | 49 47 |
| | • | | | | | | • | | |
| 2.3 | 1 | High Devil Canyon | | | | | | | |
| | 2 | 1775 ft 400 MW High Devil Canyon | 1390 | 1994 ³ | 1750 | 150 | 2400 | 2760 | 79 |
| | 3 | add 400 MW capacity Vee 2350 ft 400 MW TOTAL SYSTEM 1200 MW | - 140 <u>1060</u> 2590 | 1994 1997 | 1750 2330 | 150 150 | 2460 3870 | 3400 4910 | 49 47 |
| | | | | | | | | | |
| 3.1 | 1 2 | Watana 2225 ft 800 MW Watana add 50 MW | 1860 | 1993 | 2200 | 150 | 2670 | 3250 | 46 |
| | | tunnel 330 MW TOTAL SYSTEM 1180 MW | <u>1500</u> 3360 | 1995 | 1475 | 4 | 4890 | 5430 | 53 |

TABLE B.9 (Continued)

....

0

| | | | | Stage/Inc | remental Dat | 8 | | Cumulati System (| ive Data |
|------|----------|--|-----------------------------|---------------------|--------------------------|------------------------------|---------------------------------|--|-----------------|
| D1 | Ct | | Capital Cost \$ Millions | Earliest On-line | Reservoir Full Supply | Maximum Seasonal Draw- | Annua Energ Produ Firm | l y ction Avg. | Plant Factor |
| FIAN | Scaye | Construction | (1700 values) | Date | Level - IL. | DOWN-IC. | GMH | ษทก | <u>~</u> |
| 3.2 | 1 | Watana 2225 ft 400 MW Watana add 400 MW | 1740 | 1993 | 2200 | 150 | 2670 | 2990 | 85 |
| | | capacity | 150 | 1994 . | 2200 | 150 | 2670 | 3250 | 46 |
| | 5 | Tunnel 330 MW add 50 MW to Watana | <u>1500</u> 3390 | 1995 | 1475 | 4 | 4890 | 5430 | 53 |
| | | | | | | | | | |
| 4.1 | 1 | Watana | | 7 | | | | an a | |
| | | 2225 ft 400 MW | 1740 | 1995 | 2200 | 150 | 2670 | 2990 | 85 |
| | 2 | Watana add 400 MW capacity | 150 | 1996 | 2200 | 150 | 2670 | 3250 | 46 |
| | 3 | High Devil Canyon | | 4000 | | 100 | 4520 | 5200 | ÊO |
| | 4 | Portage Creek | Uag | 1998 | 1420 | 100 | 4520 | 2200 | 20 |
| | | 1030 Ft 150 MW TOTAL SYSTEM 1350 MW | <u> </u> | 2000 | 1020 | 50 | 5110 | 6000 | 51 |

NOTES:

(1) Allowing for a 3 year overlap construction period between major dams.

(2) Plan 1.2 Stage 3 is less expensive than Plan 1.3 Stage 2 due to lower mobilization costs.

(3) Assumes FERC license can be filed by June 1984, ie. 2 years later than for the Watana/Devil Canyon Plan 1.

TABLE B.10. SUSITNA ENVIRONMENTAL DEVELOPMENT PLANS

| | | | | Stage/Inc | | Cumulative System Data | | | |
|------------|--------|--|--|---------------------|--------------------------|------------------------------|---------------------------------|-------------------------|-----------------|
| Plan Stage | | Construction | Capital Cost \$ Millions (1980 values) | Earliest On-line | Reservoir Full Supply | Maximum Seasonal Draw- | Annua Energ Produ Firm | l y ction Avg. | Plant Factor |
| E1.1 | 1 | Watana 2225 Ft BOOWW | | Ja Dare | Level - ft. | down-ft | GWH | GWH. | ě |
| | 2 | and Re-Regulation Dam Devil Canyon 1470 ft | 1960 | 1993 | 2200 | 150 | 2670 | 3250 | 46 |
| | | 400MW Total System 1200MW | <u>900</u> 2860 | 1996 | 1450 | 100 | 5520 | 6070 | 58 |
| E1.2 | 1 2 | Watana 2060 ft 400MW Watana raise to | 1570 | 1992 | 2000 | 100 | 1710 | 2110 | . 60 |
| | 3 | 2225 ft Watana add 400MW capacity and | 360 | 1995 | 2200 | 150 | 2670 | 2990 | 85 |
| | 4 | Re-Regulation Dam Devil Canyon 1470 ft | 230 ² | 1995 | 2200 | 150 | 2670 | 3250 | 46 |
| | | 400MW TOTAL SYSTEM 1200MW | <u>900</u> 3060 | 1996 | 1450 | 100 | 5520 | 6070 | 58 |
| E1.3 | 1 2 | Watana 2225 ft 400MW Watana add 400MW capacity and | 1740 | 1993 | 2200 | 150 | 2670 | 2990 | 85 |
| | 3 | Re-Regulation Dam Devil Canyon 1470 ft | 250 | 1993 | 2200 | 150 | 2670 | 3250 | 46 |
| | | 400 MW TOTAL SYSTEM 1200MW | <u>900</u> 2890 | 1996 | 1450 | 100 | 5520 | 6070 | 58 |

1

TABLE B.10 (Continued)

| | | | <u> </u> | Stage/Inc | remental Date | | | Cumulati | ve |
|---------|-------|--|---------------------|-------------------|---------------|-------------------------|-------------------------|-----------------|--------|
| | | | Capital Cost | Earliest | Reservoir | Maximum Seasonal | Annua Energ Produ | l y ction | Plant |
| | | | \$ Millions | On-line | Full Supply | Draw- | Firm | Avg. | Factor |
| Plan | Stage | Construction | (1980 values) | Date | Level - ft. | down-ft. | GWH | GWH | 84 |
| E1.4 | 1 2 | Watana 2225 ft 400MW Devil Canyon 1470 ft | 1740 | 1993 | 2200 | 150 | 2670 | 2990 | 85 |
| | | 400MW TOTAL SYSTEM 800MW | <u>900</u> 2640 | 1996 | 1450 | 100 | 5190 | 5670 | 81 |
| E2.1 | 1 | High Devil Canyon 1775 ft 800MW and | | | | | | | |
| | | Re-Regulation Dam | 1600 | 1994 | 1750 | 150 | 2460 | 3400 | 49 |
| 1.1 | 2 | Vee 2350ft 400MW Total System 1200MW | <u>1060</u> 2660 | 1997 | 2330 | 150 | 3870 | 4910 | 47 |
| E2.2 | 1 | High Devil Canyon | | | | | | | |
| | 2 | 1630 ft 400MW High Devil Canyon | 1140 | 1993 ³ | 1610 | 100 | 1770 | 2020 | 58 |
| | | raise dam to 1775 ft add 400MW and | | | | | | | |
| | | Re-Regulation Dam | 600 | 1996 | 1750 | 150 | 2460 | 3400 | 49 |
| | 3 | Vee 2350 Ft 400 MW TOTAL SYSTEM 1200MW | <u>1060</u> 2800 | 1997 | 2330 | 150 | 3870 | 4910 | 4/ |
| E2.3 | 1 | High Devil Canyon | | | | | | | |
| | | 1775 ft 400MW | 1390 | 1994 ³ | 1750 | 150 | 2400 | 2760 | 79 |
| | 2 | High Devil Canyon add 400MW capacity and Re-Regulation | | | | | | | |
| | | Dam | 240 | 1995 | 1750 | 150 | 2460 | 3400 | 49 |
| | 3 | Vee 2350 ft 400MW Total system 7200 | <u>1060</u> 2690 | 1997 | 2330 | 150 | 3870 | 4910 | 47 |

TABLE B.10 (Continued)

1

| | | | | Stage/Inc | remental Dat | Ð | | Cumulat: System I | ive Data |
|------|--------|---|--|---------------------|--------------------------|------------------------------|---------------------------------|-------------------------|-----------------|
| Plan | Stace | Construction | Capital Cost \$ Millions (1980 values) | Earliest On-line | Reservoir Full Supply | Maximum Seasonal Draw- | Annua Energ Produ Firm | l y ction Avg. | Plant Factor |
| E2.4 | 1 | High Devil Canyon | (1)00 Values) | Date | Level - It. | down-ft. | GWH | GWH | × * |
| | 2 | 1755 ft 400MW High Devil Canyon add 400MW capacity | 1390 | 1994 ³ | 1750 | 150 | 2400 | 2760 | 79 |
| | 3 | and Portage Creek Dam 150 ft Vee 2350 ft | 790 | 1995 | 1750 | 150 | 3170 | 4080 | 49 |
| | | 400MW TOTAL SYSTEM | 1060 3240 | 1997 | 2330 | 150 | 4430 | 5540 | 47 |
| E3.2 | 1 2 | Watana 2225 ft 400MW Matana add 400 MW capacity and Re-Regulation | 1740 | 1993 | 2200 | 150 | 2670 | 2990 | 85 |
| | 3 | Dam Watana add 50MW Tunnel Scheme 330MW TOTAL SYSTEM 1180MW | 250 <u>1500</u> 3490 | 1994 1995 | 2200 1475 | 150 4 | 2670 4890 | 3250 5430 | 46 53 |
| E4.1 | 1 | Watana | | | | | | | |
| 3 | 2 | 2225 ft 400MW Watana add 400MW capacity and Re-Regulation | 1740 | 1995 ³ | 2200 | 150 | 2670 | 2990 | 85 |
| | 3 | Dam High Devil Canvon | 250 | 1996 | 2200 | 150 | 2670 | 3250 | 46 |
| | 4 | 1470 ft 400MW Portage Creek | 860 | 1998 | 1450 | 100 | 4520 | 5280 | 50 |
| | | 1030 Ft 150MW TOTAL SYSTEM 1350 MW | 650 3500 | 2000 | 1020 | 50 | 5110 | 6000 | 51 |

NOTES: (1) Allowing for a 3 year overlap construction period between major dams. (2) Plan 1.2 Stage 3 is less expensive than Plan 1.3 Stage 2 due to lower mobilization costs. (3) Assumes FERC license can be filed by June 1984, ie. 2 years later than for the Watana/Devil Canyon Plan 1.

| Susit | ina Deve | online | t Plan 1 e Dates | nc. | 0005 0 | Ins | Installed Capacity (MW) by Category in 2010 | | Total System Installed | Total System Present | Remarks Pertaining to | | |
|-------------------|--------------|--------------|---------------------|------|--------------|------------|--|----------|---------------------------|-------------------------|-----------------------|--------------|---|
| No. | 1 | 2 | ages 3 | 4 | Id. No. | Coal | Gas | Oil | Other | Susitna | 2010-MW | \$ Million | Development Plan |
| E1.1 | 1993 | 2000 | | | LXE7 | 300 | 426 | 0 | 144 | 1200 | 2070 | 5850 | |
| E1.2 | 1992 | 1995 | 1997 | 2002 | L5Y9 | 200 | 501 | 0 | 144 | 1200 | 2045 | 6030 | |
| E1.3 | 1993 1993 | 1996 1996 | 2000 | | L8J9 L7W7 | 300 500 | 426 651 | 0 0 | 144 144 | 1200 800 | 2070 2095 | 5850 6960 | Stage 3, Devil Canyon Dam not constructed |
| • | 1998 | 2001 | 2005 | | LAD7 | 400 | 276 | 30 | 144 | 1200 | 2050 | 6070 | Delayed implementation schedule |
| E1.4 | 1993 | 2000 | | | LCK5 | 200 | 726 | 50 | 144 | 800 | 1920 | 5890 | Total development limited to 800 MW |
| Modifie E2.1 | ed 1994 | 2000 | | | LB25 | 400 | 651 | 60 | 144 | 800 | 2055 | 6620 | High Devil Cenyon limited to 400 MW |
| E2.3 ¹ | 1993 1993 | 1996 1996 | 2000 | | L601 LE07 | 300 500 | 651 651 | 20 30 | 144 144 | 1200 800 | 2315 2125 | 6370 6720 | Stage 3, Vee Dam, not constructed |
| Modifi E2.3 | ed 1993 | 1996 | 2000 | | LEB3 | 300 | 726 | 220 | 144 | 1300 | 2690 | 6210 | Vee dam replaced by Chakachamna dam |
| 3.1 | 1993 | 1996 | 2000 | - | L607 | 200 | 651 | 30 | 144 | 1180 | 2205 | 6530 | |
| Specia 3.1 | 1 1993 | 1996 | 2000 | | L615 | 200 | 651 | 30 | 144 | 1180 | 2205 | 6230 | Capital cost of tunnel reduced by 50 percent |
| E4.1 | 1995 | 1996 | 1998 | | LTZ5 | 200 | 576 | 30 | 144 | 1200 | 2150 | 6050 | Stage 4 not constructed |

TABLE B.11 - RESULTS OF ECONOMIC ANALYSES OF SUSITNA PLANS - MEDIUM LOAD FORECAST

NOTES:

(1) Adjusted to incorporate cost of re-regulation dam

| Susitna Development Plan Inc. Online Dates | | nc. | | Insl | talled Categ | Capacit ory in | ey (MW) 1 2010 | ру | Total System Installed | Total System Present | Remarks Pertaining to | | |
|---|--------------|---|------|----------------------------------|-----------------|-------------------|-------------------|----------|---------------------------|-------------------------|-----------------------|--------------|--|
| Plan | | Ste | iges | | OGP5 Run | T | nermal | | Hyd | dro | Capacity In | Worth Cost | the Susitna Basin |
| NO. | | 2 | 3 | | 10. NO. | Coal | 686 | 011 | Uther | Susitna | 2010-MW | \$ M11110n | Development Plan |
| VERY L | OW FOREC | CAST ¹ | | | | | | | | | | | |
| E1.4 | 1997 | 2005 | | ~~ | L7B7 | 0 | 651 | 50 | 144 | 800 | 1645 | 3650 | |
| LOW LO | AD FORE | CAST | | | | · · · | | | | | | | |
| E1.3 | 1993 | 1996 | 2000 | | | | | | | | | | Low energy demand does not warrant plan capacities |
| E1.4 | 1993 1993 | 2002 | | | LCO7 LBK7 | 0 200 | 351 501 | 40 80 | 144 144 | 800 400 | 1335 1325 | 4350 4940 | Stage 2, Devil Canyon Dam, not constructed |
| E2.1 | 1993 | 2002 | | | LG09 | 100 | 426 | 30 | 144 | 800 | 1500 | 4560 | High Devil Canyon limited |
| | 1993 | | | | LBU1 | 400 | 501 | 0 | 144 | 400 | 1445 | 4850 | Stage 2, Vee Dam, not constructed |
| E2.3 | 1993 | 1996 | 2000 | | | | | | | | | | Low energy demand does not warrant plan capacities |
| Specia 3.1 | 1 1993 | 1996 | 2000 | 985 936 | L613 | 0 | 576 | 20 | 144 | 780 | 1520 | 4730 | Capital cost of tunnel reduced by 50 percent |
| 3.2 | 1993 | 2002 | | 2000 - 2000 - 2000 | L609 | 0 | 576 | 20 | 144 | 780 | 1520 | 5000 | Stage 2, 400 MW addition to Watana, not constructed |
| <u>HIGH L</u> | OAD FOR | ECAST | | | | | | | | | | | |
| E1.3 | 1993 | 1996 | 2000 | | LA73 | 1000 | 951 | 0 | 144 | 1200 | 3295 | 10680 | |
| Modifi E1.3 | ed 1993 | 1996 | 2000 | 2005 ² | LBV7 | 800 | 651 | 60 | 144 | 1700 | 3355 | 10050 | Chakachamna hydroelectric generating station (480 MW) brought on line as a fourth |
| E2.3 | 1993 | 1996 | 2000 | ana seta Seta Seta Seta | LBA3 | 1300 | 951 | 90 | 144 | 1200 | 3685 | 11720 | stage |
| Modifi | ed | an ann an tha Anns an tha Anns an tha | | | | | | | | | | | |
| E2.3 | 1993 | 1996 | 2000 | 2003 ² | LBY1 | 1000 | 876 | 10 | 144 | 1700 | 3730 | 11040 | Chakachamna hydroelactric generating station (480 MW) brought on line as a fourth stage |

TABLE B.12 - RESULTS OF ECONOMIC ANALYSES OF SUSITNA PLANS - LOW AND HIGH LOAD FORECAST

NOTE:

(1) Incorporating load management and conservation

TABLE B.13 - ANNUAL FIXED CARRYING CHARGES

| | er men sin en sin in met her men en get 18 To the etge ini year an | icanati Mandalan in ana ina matana ina ina ina ina ina ina ina ina ina | | Economic | Parameters |
|----------|--|--|-----------------------|-------------------|----------------|
| | Project Type | Economic Life - Years | Cost of Money % | Amortization % | Insurance % |
| Thermal | - Gas Turbine (Oil Fired) | 20 | 3.00 | 3.72 | 0.25 |
| | - Diesel, Gas Turbin (Gas Fired) and | e | | | • |
| | Large Steem Turbine | 30 | 3.00 | 2.10 | 0.25 |
| | - Small Steam Turbin | e 35 | 3.00 | 1.65 | 0.25 |
| Hydropow | Yer | 50 | 3.00 | 0.89 | 0.10 |

·} ;

. ...

FUEL COSTS AND ESCALATION RATES

| | Natural Gas | Coal | Distillate |
|-------------------------------|----------------|----------|------------|
| <u>Base Peric</u> | od (January 19 | 980) | |
| - Prices | (\$/million Bt | cu) | |
| Market Prices | \$1.05 | \$1.15 | \$4.00 |
| Shadow (Opportunity) Values | 2.00 | 1.15 | 4.00 |
| Real Escalatio | on Rates (Perc | centage) | |
| 1980 - 1985 | 1.79% | 9.56% | 3.38% |
| 1986 - 1990 | 6.20 | 2.39 | 3.09 |
| 1991 - 1995 | 3.99 | -2.87 | 4.27 |
| Composite (average) 1980-1995 | 3.98 | 2.93 | 3.58 |
| 1996 - 2005 | 3.98 | 2.93 | 3.58 |
| 2006 - 2010 | 0 | 0 | 0 |

| | | | PLAN | ТҮРЕ | | |
|---|--------------------------------|--------------|--------------|--------------|--------------|---|
| | | COAL-FIRED | STEAM | COMBINED | GAS | |
| Parameter | 500 MW | 250 MW | 100 MW | 250 MW | 75 MW | DIESEL 10 MW |
| Heat Rate (Btu/kWh) | 10,500 | 10,500 | 10,500 | 8,500 | 12,000 | 11,500 |
| O&M Costs | nan di Santa Santa Santa | | | | | |
| Fixed O&M (\$/yr/kW) Variable O&M (\$/MWH) | 0.50 1.40 | 1.05 1.80 | 1.30 2.20 | 2.75 0.30 | 2.75 0.30 | 0.50 5.00 |
| Outages | | | | | | |
| Planned Outages (%) Forced Outages (%) | 11 5 | 11 5 | 11 5 | 14 6 | 11 3.8 | 1 5 |
| Construction Period (yrs) | 6 | 6 | 5 | 3 | 2 | 1 |
| Start-up Time (yrs) | 6 | 6 | 6 | 4 | 4 | 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - |
| Total Capital Cost (\$ million) | | | | | | |
| Railbelt: Beluga: | - 1,130 | - 630 | - 290 | 175 | 26 | 7.7 |
| Unit Capital Cost (\$/kW) ¹ | | | | | | |
| Railbelt: Beluga: | - 2473 | - 2744 | - 3102 | 728 | 250 - | 778 |

TABLE B.14 - SUMMARY OF THERMAL GENERATING RESOURCE PLANT PARAMETERS

Notes:

j.

(1) Including AFDC at 0 percent escalation and 3 percent interest.

| | Tota | Total Present Worth Cost for 1981 - 2040 Period \$ Million (% Total) | | | | | | | |
|---------------------------|--|---|--|---------------------------------|--|--|--|--|--|
| Parameter | Generation Plan With High Devil Canyon - Vee | Generation Plan With Watana - Devil Canyon Dam | Generation Plan With Watana - Tunnel | All Thermal Generation Plans | | | | | |
| Capital Investment | 2800 (44) | 2740 (47) | 3170 (49) | 2520 (31) | | | | | |
| Fuel | 3220 (50) | 2780 (47) | 3020 (46) | 5240 (64) | | | | | |
| Operation and Maintenance | 350 (6) | 330 (6) | 340 (5) | 370 (5) | | | | | |
| TOTAL: | 6370 (100) | 5850 (100) | 6530 (100) | 8130 (100) | | | | | |

TABLE B.15 - ECONOMIC BACKUP DATA FOR EVALUATION OF PLANS

Ę

3

TABLE B.16 - ECONOMIC EVALUATION OF DEVIL CANYON DAM AND TUNNEL SCHEMES AND WATANA/DEVIL CANYON AND HIGH DEVIL CANYON/VEE PLANS

| | | Present worth of Net Ben | efit (\$ million) of total generation | |
|-------------------------------------|--|--|---|---|
| • • • • | | Devil Canyon Dam over the Tunnel Scheme | Watana/Devil Canyon Dams over the High Devil Canyon/Vee Dams | Remarks |
| ECONOMIC EVALUATION: - Base Case | | 680 | 520 | Economic ranking: Dewil Canyon dam scheme is superior to Tunnel scheme. Watana/Devil Canyon dam plan is superior to the High Devil Canyon dam/Vee dam plan. |
| SENSITIVITY ANALYSES: | | | | |
| - Load Growth | Low Hìgh | 650 N.A. | 210 1040 | The net benefit of the Watana/Devil Canyon plan remains positive for the range of load forecasts considered. No change in ranking. |
| - Capital Cost Estimate | | Higher uncertainty assoc- iated with tunnel scheme. | Higher uncertainty associated with H.D.C./Vee plan. | Higher cost uncertainties associ- ated with higher cost schemes/plans. Cost uncertainty therefore does not affect economic ranking. |
| - Period of Economic Analysis | Period shortened to (1980 – 2010) | 230 | 169 | Shorter period of evaluation decreases economic differences. Ranking remains unchanged. |
| - Discount Rate | 5% 8% (interpolated) 9% | | | |
| - Fuel Cost | 80% basic fuel cost | As both the capital and fu scheme and H.D.C./Vee Plan | el costs associated with the tunnel are higher than for Watana/Devil | Ranking remains unchanged. |
| - Fuel Cost Escalation | 0% fuel escalation 0% coal escalation | Devil Canyon or Watana/Dev | vil Canyon net benefit to below zero. | |
| - Economic Thermal Plant Life | 50% extension 0% extension | | | |

| Environmental Attribute | Concerns | Appraisal (Differences in impact of two schemes) | Identification of difference | Appraisal Judgement | scheme judge ne least pote iunnel | ntial impact |
|--|--|--|--|--|---|--------------|
| Ecological: | • | | | | FUNCT | |
| - Downstream Fisheries and Wildlife | Effects resulting from changes in water quantity and quality. | No significant differ- ence between achemes regarding effects down- stream of Devil Canyon. | | Not a factor in evaluation of scheme. | | |
| | | Difference in reach between Devil Canyon dam and tunnel re- regulation dam. | With the tunnel scheme con- trolled flows between regula- tion dam and downstream power- house offers potential for anadromous fisheries enhance- ment in this 11 mile reach of the river. | If fisheries enhancement oppor- tunity can be realized the tun- nel scheme offers a positive mitigation measure not available with the Davil Canyon day scheme. This opportunity is considered moderate and favors the tunnel scheme. However, there are no current plans for such enhancement and feasibil- ity is uncertain. Potential value is therefore not signi- ficant relative to additional cost of tunnel. | X | |
| <u>Resident Fisheries</u> : | Loss of resident fisheries habitat. | Minimel differences between schemes. | Devil Canyon dam would inundate 27 miles of the Susitna River and approximately 2 miles of Devil Creek. The tunnel scheme would inundate 16 miles of the Susitna River. | Loss of habitat with dam acheme is less than 5% of total for Susitna main stem. This reach of river is therefore not considered to be highly significant for resident fishedies and thus the difference between the schemes is minor and favors the tunnel scheme. | X | |
| <u>Wildlıfe</u> : | Loss of wildlifc habitat. | Minimal differences between schemes. | The most sensitive wildlife ha- bitat in this reach is upstream of the tunnel re-regulation dam where there is no significant difference between the schemes. The Devil Canyon dam scheme in addition inundates the river valley between the two dam sites resulting in a moderate increase in impects to wildlife. | Moderate wildlife populations of moose, black bear, weasel, fox, wolverine, other small mammals and songbirds and some riparian cliff habitat for ravens and raptors, in 11 miles of river, would be lost with the dam scheme. Thus, the difference in loss of wildlife habitat is considered moderate and favors the tunnel scheme. | X | |
| <u>Cultural</u> : | Inundation of archeological sites. | Potential differences between schemes. | Due to the larger area inun- .ated the probability of inun- dating archeological sites is increased. | Significant archeological sites, if identified, can proba- bly be excavated. Additional costs could range from several hundreds to hundreds of thousands of dollars, but are still consider- ably less than the additional cost of the tunnel acheme. This concern is not considered a factor in schem evaluation. | - | |
| Land Use: | Inundation of Devil Canyon. | Significant difference between schemes. | The Devil Canyon is considered a unique resource, 80 percent of which would be inundated by the Devil Canyon dam scheme. This would result in a loss of both an aesthetic value plus the potential for white water recreation. | The aesthetic and to some extent the recreational losses associ- ated with the development of the Devil Canyon dam is the main aspect favoring the tunnel scheme. However, current recreational uses of Devil Canyon are low due to limited access. Future possibility include major recreational develop- ment with construction of restau- rants, marinas, etc. Under such conditions, neither scheme would be more favorable. | 8 8 | |

TABLE B.17 - ENVIRONMENTAL EVALUATION OF DEVIL CANYON DAM AND TUNNEL SCHEME

OVERALL EVALUATION: The tunnel scheme has overall a lower impact on the environment.

è,È

-

عميها

| Social Aspect | Parameter | Tunnel Devil Canyon Scheme Dam Scheme | High Devil Canyon/ Vee Plan | Watana/Devil Canyon Plan | Remarks |
|--|---|--|---------------------------------|---------------------------------------|--|
| Potential non-renewable resource displacement Impact on state economy | Million tons Beluga coal over 50 years | 80 110 All projects would hav | 170 e similar impacts on the | 210 state and | Devil Canyon dam scheme potential higher than tunnel scheme. Watana/ Devil Canyon plan higher than High Devil Canyon/ Vee plan. |
| local economy | | TOCAL SCOTTONIA. | | | |
| Seismic exposure | Risk of major structural failure | All projects designed | to similar levels of saf | èty. | Essentially no difference between plans/schemes. |
| | Potential impact of failure on human life. | Any dam failures would population. | effect the same downstr | ream | |
| Gverall Evaluation | 1. Devil Canyo 2. Watana/Devi | dam superior to tunnel Canyon superior to Hig | h Devil Canyon/Vee plan. | • • • • • • • • • • • • • • • • • • • | |

بار م TABLE B.18 - SOCIAL EVALUATION OF SUSITNA BASIN DEVELOPMENT SCHEMES/PLANS

| Parameter | Dam | Tunnel | Remarks |
|---------------------------------------|------|--------|--|
| Total Energy Production Capability | | | |
| Annual Average Energy GWH | 2850 | 2240 | Devil Canyon dam annually |
| Firm Annual Energy GWH | 2590 | 2050 | develops 610 GWH and 540 GWH more average and firm |
| | | | energy respectively than the Tunnel scheme. |
| <u>& Basin Potential</u> | | | |
| Developed' | 43 | 32 | Devil Canyon schemes develops more of the basin potential. |
| Energy Potential Not | | | |
| Developed GWH | 60 | 380 | As currently envisaged, |
| | | | not develop 15 ft gross head between the Watana |
| | | | site and the Devil Canyon reservsoir. The tunnel |
| | | | scheme incorporates addi- tional friction losses in |
| | | | sation flow released from |
| | | | used in conjunction with head between re-regulation |
| | | | dam and Devil Canyon. |

TABLE B.19 - ENERGY CONTRIBUTION EVALUATION OF THE DEVIL CANYON DAM AND TUNNEL SCHEMES

Notes:

.

Î

· · ·

(1) Based on annual average energy. Full potential based on USBR four dam scheme.

TABLE B.20 - OVERALL EVALUATION OF TUNNEL SCHEME AND DEVIL CANYON DAM SCHEME

| ATTRIBUTE | SUPERIOR PLAN |
|------------------------|---|
| Economic | Devil Canyon Dam |
| Energy Contribution | Devil Canyon Dam |
| Environmental | Tunnel |
| Social | Devil Canyon Dam (Marginal) |
| Overall Evaluation | Devil Canyon dam scheme is superior |
| | Tradeoffs made: |
| | Economic advantage of dam scheme is judged to outweigh the reduced environmental impact associated with the tunnel scheme. |

. 1. e

TABLE B.21 - ENVIRONMENTAL EVALUATION OF WATANA/DEVIL CANYON AND HIGH DEVIL CANYON/VEE DEVELOPMENT PLANS

×

0

| Environmental Attribute | Plan Comparison | Appraisel Judgement | Plan judged to have the least potential impact HDC/V W/DC |
|-----------------------------|---|---|---|
| Ecological: {} Fisheries | No significant difference in effects on downstream anadromous fisheries. | Due to the avoidance of the Tyone River, lesser inundation of resident fisheries habitat and no atomificant difference in the | X |
| | HDC/V would inundate approximately 95 miles of the Susitna River and 28 miles of tributary streams, in- cluding the Tyone River. | effects on anadromous fisheries, the W/OC plan is judged to have less impact. | |
| | W/DC would inundate approximately 84 miles of the Susitna River and 24 miles of tributery streams, including Watana Creek. | | |
| 2) Wildlife a) Moose | HDC/Y would inundate 123 miles of critical winter river bottom habitat. | Due to the lower potential for direct impact on moose populations within the Susitna, the W/DC plan is judged superior. | X |
| | W/DC would inundate 108 miles of this river bottom habitat. | | |
| | HDC/V would inundate a large area upstream of Vee utilized by three sub-populations of moose that range in the cortheast section of the basin. | | |
| | W/DC would inundate the Watana Creek area utilized by moose. The condition of this sub-population of moose and the quality of the habitat they are using appears | | A second sec second second sec |
| | to be decreasing. | | |
| b) Caribou • | The increased length of river flooded, especially up- atream from the Vee dam site, would result in the HDC/V plan creating a greater potential division of the Nelchina herd's range. In addition, an increase in range would be directly 'nundated by the Vee res- ervoir. | Due to the potential for a greater impact on the Nelchina caribou herd, the HDC/V scheme in considered inferior. | X |
| c) Furbearers | The area flooded by the Vee reservoir is considered important to some key furbearers, particularly red fox. This area is judged to be more important then the Watana Creek area that would be inundated by the W/DC plan. | Due to the lesser potential for impact on fur- bearers the W/DC is judged to be superior. | X |
| d) Birds and Boars | Forest habitat, important for birds and black bears, exist along the valley slopes. The loss of this habi- tat would be greater with the W/DC plan. | The HDC/V plan is judged superior. | * |
| <u>Culturel</u> : | There is a high potential for discovery of archeologi- cal sites in the easterly region of the Upper Susitna Basin. The HDC/V plan has a greater potential of affecting these sites. For other reaches of the river the difference between plans is considered minimal. | The W/DC plan is judged to have a lower po- tential effect on archeological sites. | * |

TABLE B.21 (Continued)

| | | | | Plan judged to have the least potential impact | |
|-------------------------|---|---|--|---|--|
| Environmental Attribut | te Plan Comparison | Appraisal Judgement | HOC/V | W/DC | |
| Aesthetic/ Leod Use | | | | | |
| | With either scheme, the aest/letic quality of both Devil Canyon and Vee Canyon would be impaired. The HDC/V plan would also inundate Tsusena Falls. | Both plans impact the valley æsthetics. The difference is considered minimal. | 1.211 <u>-</u> 1.211-1.211 1.211-1.211 | | |
| | Due to construction at Vee Dam site and the size of the Vee Reservoir, the HDC/V plan would inherently create access to more wilderness area than would the W/DC plan. | As it is easier to extend access than to limit it, inherent access requirements were considered detrimental and the W/DC plan is judged superior. The ecological sensitivity of the area opened by the HDC/V plan rein- forces this judgement. | | X | |
| OVERALL EVALUATION: THE | he W/DC plan is judged to be <i>n</i> uperior to the HDC/V plan. The lower impact on birds and bears associated with HDC/V plan he other impacts which favour the W/DC plan.) | is considered to be outweighed by all | | | |
| NOTES: | | | | | |

W = Watana Dam DC = Devil Canyon Dam HDC = High Devil Canyon Dam V = Vee Dam

* 0

.

A
TABLE B.22 - ENERGY CONTRIBUTION EVALUATION OF THE WATANA/DEVIL CANYON AND HIGH DEVIL CANYON/VEE PLANS

| Parameter | Watana/ Devil Canyon | High Devil Canyon/Vee | Remarks |
|---------------------------------------|-------------------------|--------------------------|---|
| Total Energy Production Capability | | | |
| Annual Average Energy GWH | 6070 | 4910 | Watana/Devil Canyon |
| Firm Annual Energy GWH | 5520 | 3870 | plan annually devel- ops 1160 GWH and 1650 GWH more averag |
| | | | and firm energy re- pectively than the High Devil Canyon/Ve Plan. |
| Basin Potential Developed (1) | 91 | 81 | Watana/Devil Canyon plan develops more o the basin potential |
| nergy Potential Not | | | |
| Neveloped GW/H (2) | 60 | 650 | As currently con- ceived, the Watana/- Devil Canyon Plan does not develop 15 |
| | | | ft of gross head between the Watana site and the Devil |
| | | | The High Devil Canyon/Vee Plan does not develop 175 ft |
| | | | Vee site and High Devil reservoir. |

Notes:

1

2

(1) Based on annual average energy. Full potential based on USBR four dam schemes.

(2) Includes losses due to unutilized head.

TABLE B.23 - OVERALL EVALUATION OF THE HIGH DEVIL CANYON/VEE AND WATANA/DEVIL CANYON DAM PLANS

| ATTRIBUTE | SUPERIOR PLAN |
|------------------------|---|
| Economic | Watana/Devil Canyon |
| Energy Contribution | Watana/Devil Canyon |
| Environmental | Watana/Devil Canyon |
| Social | Watana/Devil Canyon (Marginal) |
| Overall Evaluation | Plan with Watana/Devil Canyon is superior |
| | Tradeoffs made: None |

e ‡

| Watana Dam Crest Elevation (ft MSL) | Watana* Cost <u>(\$ x 10⁶)</u> | Devil Canyon* Cost (\$ x 10 ⁶) | Total Cost (\$ x 10 ⁶) | Average Annual Energy (CWb) |
|---|---|--|--|-----------------------------------|
| 2240 (2215 reservoir elevation) | 4,076 | 1,711 | 5,787 | - <u>(4,809</u> |
| 2190 (2165 reservoir elevation) | 3,785 | 1,711 | 5,496 | 6.586 |
| 2140 (2115 reservoir elevation) | 3,516 | 1,711 | 5,227 | 6,264 |

TABLE B.24: COMBINED WATANA AND DEVIL CANYON OPERATION

· . .

. . .

ſ

| <u>Watana Project</u> | alone | (prior | to ye | ear 2002) |) |
|-----------------------------|-------|-----------|-------------------|-------------------|---|
| Crest Elevation (ft MSL) | | Ave Er | erage | Annual (GWh) | |
| 2240 2190 2140 | | | 3,9 3,3 3,0 | 542 522 071 | |

* Estimated costs in January 1982 dollars, based on preliminary conceptual designs, including relict channel drainage blanket and 20 percent contingencies.

TABLE B.25: PRESENT WORTH OF PRODUCTION COSTS

| Watana Dam Crest Elevation <u>_(ft MSL)</u> | of | Present Wor Production _(\$ x 10 ⁶ | th Costs |
|---|----|---|--------------|
| 2240 (reservoir elevation 2215) | | 7,123 | a alaa ah |
| 2190 (reservoir elevation 2165) | • | 7,052 | |
| 2140 (reservoir elevation 2115) | | 7,084 | |

* LTPW in January 1982 dollars.

TABLE B.26: DESIGN DATA AND DESIGN CRITERIA FOR FINAL REVIEW OF LAYOUTS

σ

River Flows

Average flow (over 30 years of record): Probable maximum flood (routed): Maximum inflow with return period of 1:10,000 years: Maximum 1:10,000-year routed discharge: Maximum flood with return period of 1:500 years: Maximum flood with return period of 1:50 years: Reservoir normal maximum operating level: Reservoir minimum operating level:

Dam

Type:

Crest elevation at point of maximum super elevation: Height: Cutoff and foundation treatment:

Upstream slope: Downstream slope: Crest width:

Diversion

Cofferdam type: Cutoff and foundation: Upstream cofferdam crest elevation: Downstream cofferdam crest elevation: Maximum pool level during construction: Tunnels Final closure: Releases during impounding:

Spillway

4

•

Design floods:

Main spillway - Capacity:

- Control structure:

Emergency spillway - Capacity: - Type:

Power Intake

Type: Number of intakes: Draw-off requirements:

Drawdown:

| 7 | ,860 | cfs |
|-----|------|-----|
| 326 | 000 | cfs |
| 156 | ,000 | cfs |
| 115 | 000 | cfs |
| 116 | ,000 | cfs |
| 87 | ,000 | cfs |
| 221 | 5 ft | |
| 203 | 0 ft | |

Rockfill 2240 ft 890 ft above foundation Core founded on rock; grout curtain and downstream drains 2.4H:1V 2H:1V 50 ft

Rockfill Slurry trench to bedrock 1585 ft 1475 ft 1580 ft Concrete lined, Mass concrete plugs 6,000 cfs maximum via bypass to outlet structure

Passes PMF, preserving integrity of dam with no loss of life Passes routed 1:10,000-year flood with no damage to structures Routed 1:10,000-year flood with 5 ft surcharge Gated ogge crests

PMF minus 1:10,000 year flood Fuse plug

Reinforced concrete 6 Multi-level corresponding to temperature strata 185 feet

TABLE B.26: (Cont'd)

Penstocks

Type:

Number of penstocks:

Powerhouse

Type: Transformer area: Control room and administration: Access - Vehicle: - Personnel:

Power Plant

Type of turbines: Number and rating: Rated net head: Design flow: Normal maximum gross head: Type of generator: Rated output: Power factor: Frequency: Transformers:

Tailrace

5

Water passages: Surge: Average tailwater elevation (full generation): Concrete-lined tunnels with downstream steel liners 6

Underground Separate gallery Surface Rock tunnel Elevator from surface

Francis 6 x 170 MW 690 ft 3,500 cfs per unit 745 ft Vertical synchronous 190 MVA 0.9 60 HZ 13.8-345 kV, 3-phase

2 concrete-lined tunnels Separate surge chambers 1458 ft

. . .

1.12

TABLE B.27: EVALUATION CRITIERA

PRELIMINARY REVIEW

م

Technical feasibility

Compatibility of layout with known geological and topographical site features

Ease of construction

Physical dimensions of component structures in certain locations

Obvious cost differences of comparable structures

Environmental acceptability

Operating characteristics

INTERMEDIATE REVIEW

Technical feasibility

Compatibility of layout with known geological and topographical site features

Ease of construction

Overall cost

Environmental acceptability

Operating characteristics

Impact on construction schedule

FINAL REVIEW

Technical feasibility

Compatibility of layout with known geological and topographical site features

Ease of construction

Overall cost

Environmental impact

Mode of operation of spillways

Impact on construction schedule

Design and operating limitations for key structures

| INTERM | EDIATE REVIEW ((January | DF ALTERNATIVE ARR 1982 \$ x 10°) | ANGEMENTS | |
|---|-----------------------------|--------------------------------------|-----------|--------|
| | WP1 | WP2 | WP3 | WP4 |
| Diversion | 101.4 | 112.6 | 101.4 🔹 | 103.1 |
| Service Spillway | 128.2 | 208.3 | 122.4 | 267.2 |
| Emergency Spillway | | 46.9 | 46.9 | - |
| Tailrace Tunnel | 13.1 | 13.1 | 13.1 | 8.0 |
| Credit for Use of Rock in Dam | (11.7) | (31.2) | (18.8) | (72.4) |
| Total Non-Common Items | 231.0 | 349.7 | 265.0 | 305.9 |
| Common Items | 1643.0 | 1643.0 | 1643.0 | 1643.0 |
| Subtotal | 1874.0 | 1992.7 | 1908.0 | 1948.9 |
| Camp & Support Costs (16%) | 299.8 | 318.8 | 305.3 | 311.8 |
| Subtotal | 2173.8 | 2311.5 | 2213.3 | 2260.7 |
| Contingency (20%) | 434.8 | 462.3 | 442.7 | 452.1 |
| Subtotal | 2608.6 | 1773.8 | -2656.0 | 2712.8 |
| Engineering and Administration (12.5%) | 326.1 | 346.7 | 332.0 | 339.1 |
| TOTAL | 2934.7 | 3120.5 | 2988.0 | 3051.9 |

TABLE 8-28: SUMMARY OF COMPARATIVE COST ESTIMATES

.

TABLE B.29: DESIGN DATA AND DESIGN CRITERIA FOR REVIEW OF ALTERNATIVE LAYOUTS

River Flows

Average flow (over 30 years of record): Probable maximum flood: Max. flood with return period of 1:10,000 years:

Maximum flood with return period of 1:500 years: Maximum flood with return period of 1:50 years:

Reservoir

Normal maximum operating level: Reservoir minimum operating level: Area of reservoir at maximum operating level: Reservoir live storage: Reservoir full storage:

Dan

Type: Crest elevation: Crest length: Maximum height above foundation: Crest width:

Diversion

Cofferdam types: Upstream cofferdam crest elevation: Downstream cofferdam crest elevation: Maximum pool level during construction: Tunnels: Outlet structures:

Final closure:

Releases during impounding:

Spillway

•

Design floods:

Service spillway - capacity: - control structure: - energy dissipation:

Secondary spillway - capacity:

- control structure: - energy dissipation:

Emergency spillway - capacity:

- type:

8,960 cfs 270,000 cfs 135,000 cfs (after routing through Watana

42,000 cfs (after routing through Watana

1455 feet 1430 feet 21,000 acres 180,000 acre feet 1,100,000 acre feet

Concrete arch 1455 feet

635 feet 20 feet

Rockfill 960 feet 900 feet 955 feet Concrete lined Low-level structure with slide closure gate Mass concrete plugs in line with dam grout curtain 2,000 cfs min. via fixed-cone valves

Passes PMF, preserving integrity of dam with no loss of life

Passes routed 1:10,000-year flood with no damage to structures

45,000 cfs Fixed-cone valves Five 108-inch diameter fixed-cone valves

90,000 cfs Gated, ogee crests Stilling basin

pmf minus routed 1:10,000-year flood Fuse plug

TABLE B.29: (Cont'd)

Power Intake

•

P. 1

Type: Transformer area: Access Type of turbines: Number and rating: Rated net head: Maximum gross head: Type of generator: Rated output: Power factor:

Underground Separate gallery Rock Tunnel Francis 4 x 140 MW 550 feet 565 feet approx. Vertical synchronous 155 MVA 0.9

TABLE B.30: SUMMARY OF COMPARATIVE COST ESTIMATES

| en a se a | | | | | | | |
|---|---------|-----|----------|-------|-------|--|-----|
| PREI TMTNARY | DEVIEW | OC | AL TO | - | | | |
| 1 11 m m 41 (1 1 1 1 1 1 1 | VEATCH | UF | ALIE | RNAIL | VE | ARRANGEME | VIS |
| | Jonuona | 100 | 37 6 | v #06 | <hr/> | the state of the s | 110 |
| | and ary | 120 | JZ (Þ. 1 | X 10" |) | | |

| Item | DC1 | DC2 | DC3 | DC4 |
|--|-----------------|-----------------|------------------------|---------------------------------|
| Land Acquisition | 22.1 | 22.1 | 22.1 | 22.1 |
| Reservoir | 10.5 | 10.5 | 10.5 | 10.5 |
| Main Dam | 468.7 | 468.7 | 468.7 | 468.7 |
| Emergency Spillway | 25.2 | 25.2 | 25.2 | 25.2 |
| Power Facilities | 211.7 | 211.7 | 211.7 | 211.7 |
| Switchyard | 7.1 | 7.1 | 7.1 | 7.1 |
| Miscellaneous Structures | 9.5 | 9.5 | 9.5 | 9.5 |
| Access Roads & Site Facilities | 28.4 | <u>28.4</u> | 28.4 | <u>28.4</u> |
| Common Items - Subtotal | 783.2 | 783.2 | 763.2 | 783.2 |
| Diversion | 32.1 | 32.1 | 32.1 | 34.9 |
| Service Spillway | 46.8 | 53.3 | 50.1 | 85.2 |
| Saddle Dam | 19.9 | <u>18.6</u> | <u>18.6</u> | 19.9 |
| Non-Common/Items Subtotal | 98.8 | 104.0 | 100.8 | 140.0 |
| Total | 882.0 | 887.2 | 884.0 | 923.2 |
| Camp & Support Costs (16%) | 141.1 | 141.9 | 141.4 | 147.7 |
| Subtotal | 1023.1 | 1029.1 | 1025.4 | 1070.9 |
| Contingency (20%) | 204.6 | 205.8 | 205.1 | 214.2 |
| Subtotal | 1227.7 | 1234.9 | 1230.5 | 1285.1 |
| Engineering & Administration (12.5%) Total | 153.5 1381.2 | 154.3 1389.2 | <u>153.8</u> 1384.3 | <u>160.6</u> 1445 . 7 |

| | ENERGY POTENTIAL GWH | | | | | | | | | | | | | |
|-------|----------------------|---------------------|------|-------|---------|------|----------------------|----------|------|------|---------|------|--|--|
| | | والمحرور والمحرادية | | | | | | | | | | | | |
| | | WATA | NA | UNLY | | WA | WATANA & DEVIL CANYI | | | | | | | |
| MONTH | F 1M | M ENERG | Y | AVE | RAGE EN | ERGY | FI | RM ENER | GY | AVER | AGE ENE | RGY | | |
| MUNIM | LASE A | L. | D | A | C | D | A | <u> </u> | D | A | C | D | | |
| OCT | 234 | 200 | 172 | 281 | 214 | 178 | 437 | 399 | 334 | 511 | 422 | 346 | | |
| NOV | 270 | 235 | 201 | 348 | 331 | 271 | 502 | 463 | 388 | 543 | 625 | 506 | | |
| DEC | 322 | 276 | 236 | 445 | 397 | 364 | 598 | 547 | 458 | 817 | 751 | 683 | | |
| JAN | 283 | 242 | 208 | 383 | 357 | 325 | 590 | 480 | 403 | 715 | 677 | 618 | | |
| FEB | 228 | 202 | 173 | 318 | 335 | 293 | 452 | 395 | 330 | 599 | 632 | 561 | | |
| MAR | 235 | 201 | 173 | . 276 | 330 | 277 | 470 | 398 | 335 | 532 | 629 | 536 | | |
| APR | 199 | 165 | 142 | 203 | 214 | 197 | 460 | 332 | 280 | 451 | 419 | 387 | | |
| MAY | 180 | 152 | 131 | 180 | 247 | 174 | 462 | 304 | 286 | 465 | 536 | 399 | | |
| JUN | 170 | 135 | 111 | 175 | 212 | 191 | 492 | 323 | 278 | 478 | 485 | 460 | | |
| JUL | 182 | 209 | 345 | 258 | 267 | 374 | 387 | 471 | 755 | 521 | 579 | 784 | | |
| AUG | . 170 | 311 | 531 | 344 | 327 | 545 | 321 | 659 | 1095 | 598 | 679 | 1095 | | |
| SEP | 158 | 151 | 155 | 249 | 158 | 166 | 293 | 326 | 390 | 463 | 346 | 395 | | |
| TOTAL | 2632 | 2479 | 2578 | 3459 | 3389 | 3354 | 5394 | 5099 | 5332 | 6793 | 6781 | 6768 | | |

TABLE B.31: ENERGY POTENTIAL OF WATANA - DEVIL CANYON DEVELOPMENTS FOR DIFFERENT RESERVOIR OPERATING RULES

NOTE: Cases B and C were similar and only Case C was analyzed in detail.

TABLE B.32: AVERAGE ANNUAL AND MONTHLY FLOW AT GAGE IN THE SUSITNA BASIN*

Ò

| Statistics of the local division of the loca | ومعرصت ويترجي مستوجد | JINI | TON (DODO U | erere | nce Number |) | - | |
|--|--|---|---|---|--|--|--|--|
| Sus at | itna River Gold Creek (2920) | Sus Nea | itna River r Cantwell (2915) | Sus Nea | itna River r Denali (2910) | Near Paxson (2912) | | |
| 36 | 6160 % Mean(cfs) | | 4140 % <u>Nean(cfs)</u> | | 950 Mean(cfs) | 280 % Mean(cfs | | |
| 1 | 1,453 | 1 | 824 | 1 | 244 | 1 | 96 | |
| 1 | 1,235 | 1 | 722 | 1 | 206 | 1 | 84 | |
| 1 | 1,114 | 1 | 692 | 1 | 188 | 1 | 76 | |
| 1 | 1,367 | 1 | 853 | 1 | 233 | 1 | 87 | |
| 12 | 13,317 | 10 | 7,701 | 6 | 2,036 | 7 | 803 | |
| 24 | 27,928 | 26 | 19,326 | 22 | 7,285 | 25 | 2,920 | |
| 21 | 23,853 | 23 | 16,892 | 28 | 9,350 | 27 | 3,181 | |
| 19 | 21,478 | 20 | 14,658 | 24 | 8,050 | 22 | 2,573 | |
| 12 | 13,171 | 10 | 7,800 | 10 | 3,350 | 10 | 1,149 | |
| 5 | 5,639 | 4 | 3,033 | 3 | 1,122 | 3 | 40 9 | |
| 2 | 2,467 | 2 | 1,449 | 2 | 490 | 1 | 177 | |
| 2 | 1,773 | 1 | 998 | 1 | 314 | 1 | 118 | |
| 100 | 9,566 | 100 | 6,246 | 100 | 2,739 | 100 | 973 | |
| | Sus at 1 1 1 1 1 1 2 4 21 19 12 5 2 2 2 100 | Susitna River at Gold Creek (2920) 6160 % Mean(cfs) 1 1,453 1 1,235 1 1,235 1 1,114 1 1,367 12 13,317 24 27,928 21 23,853 19 21,478 12 13,171 5 5,639 2 2,467 2 1,773 100 9,566 | Susitna River (2920) Sus (2920) 6160 % 1 1,453 1 1,453 1 1,235 1 1,235 1 1,235 1 1,235 1 1,367 1 1,317 12 13,317 12 13,317 12 13,317 19 21,478 20 12 12 13,171 10 5 5 5,639 4 2 2 1,773 100 9,566 | Susitna River at Gold Creek (2920) Susitna River Near Cantwell (2915) 6160 4140 % Mean(cfs) % Mean(cfs) 1 1,453 1 824 1 1,235 1 722 1 1,235 1 722 1 1,114 1 692 1 1,367 1 853 12 13,317 10 7,701 24 27,928 26 19,326 21 23,853 23 16,892 19 21,478 20 14,658 12 13,171 10 7,800 5 5,639 4 3,033 2 2,467 2 1,449 2 1,773 1 998 100 9,566 100 6,246 | Susitna River at Gold Creek (2920) Susitna River Near Cantwell (2915) Sus Near Near (2915) 6160 % Mean(cfs) 4140 % Mean(cfs) Near (2915) 1 1,453 1 824 1 1 1,453 1 824 1 1 1,235 1 722 1 1 1,235 1 722 1 1 1,367 1 853 1 12 13,317 10 7,701 6 24 27,928 26 19,326 22 21 23,853 23 16,892 28 19 21,478 20 14,658 24 12 13,171 10 7,800 10 5 5,639 4 3,033 3 2 2,467 2 1,449 2 2 1,773 1 998 1 100 9,566 100 6,246 100 | Susitna River at Gold Creek (2920) Susitna River Near Cantwell (2915) Susitna River Near Denali (2910) 6160 % Mean(cfs) 4140 % Mean(cfs) 950 % Mean(cfs) 1 1,453 1 824 1 244 1 1,235 1 722 1 206 1 1,1453 1 824 1 244 1 1,235 1 722 1 206 1 1,114 1 692 1 188 1 1,367 1 853 1 233 12 13,317 10 7,701 6 2,036 24 27,928 26 19,326 22 7,285 21 23,853 23 16,892 28 9,350 19 21,478 20 14,658 24 8,050 12 13,171 10 7,800 10 3,350 5 5,639 4 3,033 3 1,122 | Susitna River at Gold Creek (2920) Susitna River Near Cantwell (2915) Susitna River Near Denali (2910) Mac Near (2910) 6160 % Mean(cfs) 4140 % Mean(cfs) 950 % Mean(cfs) 950 % Mean(cfs) % 1 1,453 1 824 1 244 1 1 1,235 1 722 1 206 1 1 1,235 1 722 1 206 1 1 1,367 1 853 1 233 1 12 13,317 10 7,701 6 2,036 7 24 27,928 26 19,326 22 7,285 25 21 23,853 23 16,892 28 9,350 27 19 21,478 20 14,658 24 8,050 22 12 13,171 10 7,800 10 3,350 10 5 5,639 4 3,033 3 1,122 3 | |

 Period of Record
 Gold Creek
 1950-79

 Cantwell
 1961-72

 Denali
 1957-79

 Maclaren
 1957-79

* Ref. USGS Streamflow Data

TABLE B. 33: WATANA ESTIMATED NATURAL FLOWS

| YEAR | OCT | NO'V | DEC | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP . | AVE |
|--|---|--|---|---|--|--|--|--|---|--|--|--|---|
| 1950 1953 1953 1953 1954 1955 1955 1955 1958 1957 1958 1957 1960 1961 1962 1963 1964 1965 1966 1967 1968 1967 1976 1977 1977 1977 1977 1977 1978 1977 1978 1979 1980 | 4719.9^{4} 3299.1 4592.9 6285.7 4218.9 3402.3 4208.0 6034.9 3668.0 5165.5 6049.3 4637.6 5187.1 4759.4 5221.28 4019.0 3135.0 2403.1 3768.0 4979.1 43056.5 3088.8 55793.9 3773.9 3773.9 3759.0^{2} | 2083.6 1107.3 2170.1 2756.8 1599.6 2051.1 1588.1 2276.6 2935.9 1729.5 2327.8 2263.9 1729.5 2327.8 2263.9 1789.1 2368.3 1202.2 1934.9 1020.9 2496.4 2587.0 1977.9 1354.7 1474.4 1601.1 1926.7 2645.9 1944.9 3525.0 ³ 3297.0 ² | $\begin{array}{c} 1168.9\\ 906.2\\ 1501.0\\ 1281.2\\ 1183.8\\ 1549.5\\ 1038.6\\ 1707.0\\ 2258.5\\ 1115.1\\ 1672.3\\ 1973.2\\ 1760.9\\ 1197.3\\ 1203.6\\ 1121.6\\ 1704.2\\ 753.9\\ 1687.4\\ 1957.4\\ 1246.5\\ 931.6\\ 1276.2\\ 931.6\\ 1276.5\\ 1687.5\\ 1687.5\\ 1687.5\\ 1312.6\\ 3135.0^{4}\end{array}$ | 815.1 808.0 1274.5 818.9 1087.8 1388.3 816.9 1373.0 1480.6 1081.0 1400.4 1779.9 1608.9 1308.9 1308.9 852.0 863.0 1060.4 1102.2 1617.6 619.2 636.2 1097.1 1670.9 1031.5 786.4 1215.8 757.8 1348.7 1577.9 1136.8 1470.0 ³ | 641.7 673.0 841.0 611.7 803.1 1050.5 754.8 1189.0 1041.7 949.0 1138.9 1304.8 1257.4 1184.7 781.6 772.7 984.7 1031.3 1560.4 607.5 602.1 777.4 1491.4 1000.2 689.9 1110.3 743.2 1202.9 1267.7 1055.4 3 971.0 4 | 569.1 619.8 735.0 670.7 638.2 886.1 694.4 935.0 973.5 694.0 961.0 1376.8 577.3 887.5 889.4 577.3 887.5 694.5 1566.0 624.1 1366.0 624.1 1366.0 624.1 1366.0 627.3 1041.7 1101.2 1256.7 1107.0^3 887.0^4 | 680.1 1307.2 803.9 1382.0 942.6 940.8 718.3 945.1 1265.4 1265.4 1265.7 10457.6 609.2 1232.4 13849.7 1261.6 986.4 914.1 871.9 1203.4 1307.2 1408.4 1317.9 1404.0 103.0 4 | $\begin{array}{c} 8655.9\\ 11649.8\\ 4216.5\\ 15037.2\\ 11696.8\\ 6718.1\\ 12953.3\\ 10176.2\\ 9757.8\\ 10140.2\\ 13637.9\\ 113044.2\\ 13637.9\\ 11333.5\\ 15299.2\\ 3578.8\\ 10966.0\\ 7094.1\\ 12555.7\\ 3578.8\\ 10966.0\\ 7094.1\\ 12555.7\\ 9536.2\\ 15973.1\\ 7287.0\\ 12889.0\\ 12889.0\\ 12867.2\\ 8938.8\\ 8569.4\\ 112369.3\\ 10140.0\\ 10406.0\\ \end{array}$ | 16432.1 18517.9 25773.4 21469.8 19476.7 24881.4 27171.8 25275.0 22097.8 18329.6 13233.4 22784.1 36017.1 20663.4 42841.9 21213.0 25939.6 24711.9 25704.0 13962.1 14399.0 27429.3 23859.3 14780.6 27429.3 23859.3 14780.6 27429.3 23859.3 14780.6 27994.0 31352.8 17277.2 22904.8 17323.0 | 19193.4 19786.6 22110.9 17355.3 16983.6 23787.9 25831.3 19748.7 20493.1 19752.7 20493.1 19506.1 19839.8 23443.7 28767.4 20082.8 16153.5 21987.3 22082.8 14843.5 16351.9 16351.9 23430.4 15971.9 23430.4 15971.9 23430.4 15971.7 26740.0 27840.0 | 16913.6 16478.0 17356.3 16481.6 20420.6 23537.0 19153.7.0 19153.7.1 18843.4 23940.4 19323.1 19487.1 21011.4 17394.9 26104.5 14147.5 16263.6 17509.5 18016.7 13526.6 16807.3 13412.1 16800.0 31435.0 | 7320.4 17205.5 11571.0 11513.5 9145.5 13447.6 13194.4 14841.1 5978.7 12466.9 16085.6 10146.2 12746.2 16085.6 10146.2 12746.2 16080.0 7524.2 16225.6 9214.1 13672.9 .7163.6 4260.0 7224.1 12188.9 10955.7 8099.7 9786.2 13075.3 5711.5 10613.1 7132.6 9096.7 1000.0 12026.0 | 4577777780 5747777780 57480 57777780 57777780 57777780 57777780 57777780 57777780 57790 57905 57905 57905 54807 54807 57780 5777778 577905 57905 57905 54807 54807 57780 5777778 5777778 57905 57905 54807 54807 57780 5777778 5777778 57905 57905 54807 54807 57780 5777778 5777778 57905 57905 54807 54807 57780 5777778 5777778 5777778 5777778 5777778 5777778 5777778 5777778 5777778 5777778 5777778 5777778 5777778 5777778 5777778 5777778 5777778 577778 57777778 57777778 57777778 57777778 5777778 57777777777 |
| AVE | 4015.1 | 2052.4 | 1404.8 | 115/+3 | 978.9 | 878.3 | 1112+6 | 10397+6 | 22922.4 | 20778+0 | 18431.4 | 10670+4 | 7943.1 |

Notes: (1) Discharges based on Cantwell and Gold Creek flows unless specified (2) Watana observed flows (3) Flows based on Gold Creek (4) Watana long-term average flows assumed

0

TABLE B.34: DEVIL CANYON ESTIMATED NATURAL FLOWS

| YEAR | OCT | NOV | DEC | JAN | FEB | MAR | APR | MAY | NUL | JUL | AUG | SEF | AVE |
|--|---|--|--|---|---|---|--|---|--|---|--|--|--|
| 1950 1951 1952 19553 19554 19554 19556 19566 19566 19566 19566 19566 19566 19566 19566 19566 19566 19566 19576 195777 19577 19577 19577 19577 19577 19577 19577 19577 195777 19577 19577 19577 195777 195777 195777 195777 195777 195777 195777 195777 19577777 195777 195777 1957777777777 | 5758.2 3652.0 5221.7 7517.6 5109.3 4830.4 4647.9 5235.3 7434.5 4060.7 7170.9 5459.4 4060.7 5459.4 5307.7 57459.4 4060.7 5496.5 35744.0 4585.3 5744.0 4585.3 5537.0 4638.4 3506.3 3552.4 45900.0 7246.0 | 2404.7 1231.2 2539.0 3232.6 1921.3 2506.8 1788.6 2773.8 1999.8 2759.9 2544.1 1907.8 2696.0 2085.1 1907.8 2696.0 2085.1 1907.8 2085.1 1907.8 2085.1 1907.8 2085.1 1907.8 2085.1 1907.8 2085.1 1907.8 2085.1 1907.8 2085.1 1907.8 2085.1 1907.8 2085.1 1907.8 2085.1 1907.8 2085.1 1907.8 2085.1 1907.8 2085.1 1907.8 2085.1 1907.8 2085.1 1907.8 2085.1 1907.8 2085.1 2085.1 2085.1 2085.1 2085.1 2085.1 2085.1 2085.1 2085.1 2085.1 2085.1 2085.1 2085.1 2085.1 2085.1 2097.0 2085.1 2085.1 2097.0 2085.1 2097.0 2085.1 2097.0 2085.1 2097.0 2085.1 2085.1 2097.0 2085.1 2097.0 200.0 20 | 1342.5 1030.8 1757.5 1550.4 1387.1 1868.0 1206.6 1986.6 2904.9 1370.9 2011.5 2436.6 1978.7 1896.0 1387.1 1478.4 1929.7 636.3 2074.8 2312.6 1387.0 997.4 1387.0 1387.0 2312.6 1387.0 1549.0 1554.0 | 951.3 905.7 1483.7 999.6 1224.2 1649.1 921.7 1583.2 1792.0 1316.9 1686.2 2212.0 1796.0 978.0 978.0 978.0 1496.0 978.7 1357.9 1851.2 686.6 756.9 1318.8 2036.1 1139.8 842.7 1408.8 1657.4 1867.9 1304.1 1649.0 1287.0 | 735.7 767.5 943.2 745.6 929.7 1275.2 893.1 1388.9 1212.2 1379.1 1340.2 1593.6 1413.4 900.2 828.8 1187.4 900.2 828.8 1187.4 1268.3 1778.7 681.8 745.9 1342.2 876.2 1469.7 1525.0 1203.6 1383.0 1089.0 | 670.0 697.1 828.2 766.7 729.4 1023.6 852.3 1105.4 1085.7 877.9 1112.8 1638.9 1320.3 958.4 663.8 866.9 1187.4 1089.1 1778.7 769.6 866.8 1659.8 955.0 689.5 1271.9 825.2 1361.0 1480.6 1164.7 1321.0 | 802,2 1504.6 878.5 1531,8 1130.6 1107.4 867.3 1107.4 1107.4 1217.8 2405.4 1613.7 1217.8 2405.4 1613.7 1217.8 1613.7 1217.8 1613.7 1217.8 1613.7 1217.8 1619.1 1053.7 121.3 1046.6 986.2 1565.5 986.7 1261.2 1509.8 1597.1 1402.8 1597.1 1402.8 1575.0 1238.0 | 10490.7 13218.5 4989.5 17758.3 15286.0 8390.1 15979.0 12473.6 11849.2 13900.9 14802.9 14802.9 14802.9 14030.9 12141.2 17697.6 4046.9 12267.1 8734.0 14435.5 14982.4 10721.6 3427.9 19776.8 7896.4 15004.65 11305.3 11211.9 11673.0 11676.0 | 18468.6 19778.5 30014.2 25230.7 23188.1 28081.9 31137.1 28415.4 24413.5 21537.7 14709.8 40679.7 24094.1 47816.4 27069.3 40679.7 24094.1 47816.4 27796.4 14950.7 17118.9 31031.0 31929.6 16766.7 30302.6 16766.7 35606.7 18416.8 24052.0 19436.0 | 21383.4 21575.9 24861.7 19184.0 19154.1 26212.8 29212.0 22109.6 21763.1 23390.4 21739.3 22880.6 24990.6 32388.0 26195.7 18536.2 25081.2 21746.5 17571.8 17790.0 26188.0 18252.6 21740.5 20079.0 26188.6 21740.5 20079.0 26188.6 21740.5 20079.0 26188.6 21740.5 20079.0 26188.6 21740.5 20079.0 27462.8 30002.0 31236.0 | 18820.6 18530.0 19647.2 19207.0 24071.6 24959.6 22609.8 19389.2 21219.8 28594.4 22066.1 21164.8 22720.5 15585.8 19789.3 20244.6 30293.0 16090.5 8483.6 18652.8 30315.9 18654.1 19478.1 15257.0 17031.6 19297.7 18371.2 15326.5 19106.7 20196.0 35270.0 | 7950:8 19799:1 13441.1 13928.4 11579:1 13989:2 16495.8 18029.0 6988.8 15329.6 18929.9 12218.6 14767.2 11777.2 8840.0 18234.2 10844.3 15728.2 8225.9 4795.5 8443.5 13636.0 11884.2 8726.0 11370.1 15154.3 11916.1 8080.4 10172.4 13493.0 | 7481. 8574. 8574. 8897. 93097. 9655. 9655. 9705 |
| AVE | 5311.8 | 2382,9 | 1652.0 | 1351.9 | 1146.9 | 1041.8 | 1281.5 | 12230.2 | 25991.3 | 23100+9 | 20709.0 | 12299+2 | 9041.6 |

* Discharges based on Watana flows

8

-

•

TABLE B.35: PEAK FLOWS OF RECORD

| 0-1-4-0 | nank | Cantwe | a]] | Dena | li | Maclar | en |
|----------------|--------------|----------|-------------|---------|-----------|---------|-----------|
| <u>6010 C1</u> | Peak | Carrence | Peak | | Peak 3 | | Peak 3 |
| Date | <u>ft /s</u> | Date | ft /s | Date | ft /s | _Date_ | ft /s |
| 8/25/59 | 62,300 | 6/23/61 | 30,500 | 8/18/63 | 17,000 | 9/13/60 | 8,900 |
| 6/15/62 | 80,600 | 6/15/62 | 47,000 | 6/07/64 | 16,000 | 6/14/62 | 6,650 |
| 6/07/64 | 90,700 | 6/07/64 | 50,500 | 9/09/65 | 15,800 | 7/18/65 | 7,350 |
| 6/06/66 | 63,600 | 8/11/70 | 20,500 | 8/14/67 | 28,200 | 8/14/67 | 7,600 |
| 8/15/67 | 80,200 | 8/10/71 | 60,000 | 7/27/68 | 19,000 | 8/10/71 | 9,300 |
| 8/10/71 | 87,400 | 6/22/72 | 45,000 | 8/08/71 | 38,200 | 6/17/72 | 7,100 |

TABLE B.36: ESTIMATED FLOOD PEAKS IN SUSITNA RIVER

| Location | Peak Inf | low in Cfs | for Recurre | nce Interval | in Years |
|--|----------|------------|-------------|--------------|----------|
| | 1:2 | 1:50 | 1:100 | 1:10,000 | PMF |
| Gold Creek | 48,000 | 105,000 | 118,000 | 200,000 | 408,000 |
| Watana Damsite | 42,000 | 82,000 | 92,000 | 156,000 | 326,000 |
| Devil Canvon Damsite) | 12,600 | 43,000 | 61,000 | 165,000 | 346,000 |
| (Routed Peak Inflow) with Watana) | | | | | |

| | WAT | ANA | DEVIL | CANYON | Average | Month In Atom | |
|--|--|--|---|---|---|---|---|
| Month | Pan Evaporation (inches) | Reservoir Evaporation (inches) | Pan Evaporation (inches) | Reservoir Evaporation (inches) | Watana ¹ | Devil Canvon ² | ture (°C) |
| January February March April May June July August September October November December | 0.0 0.0 0.0 3.6 3.4 3.3 2.5 1.5 0.0 0.0 0.0 0.0 | $\begin{array}{c} 0.0\\ 0.0\\ 0.0\\ 0.0\\ 2.5\\ 2.4\\ 2.3\\ 1.8\\ 1.0\\ 0.0\\ 0.0\\ 0.0\\ 0.0\\ 0.0\\ 0.0\\ 0.0$ | 0.0 0.0 0.0 3.9 3.8 3.7 2.7 1.7 0.0 0.0 0.0 | 0.0 0.0 0.0 2.7 2.7 2.6 1.9 1.2 0.0 0.0 0.0 | - 2.5 - 7.3 - 1.8 - 1.8 8.7 10.0 13.7 12.5 N/A 0.2 - 5.1 -17.9 | - 4.5 - 5.0 - 4.3 - 2.5 6.1 9.2 11.9 N/A 4.8 - 1.8 - 7.2 -21.1 | -13.0 -9.3 -6.7 0.7 7.0 12.6 14.4 12.7 7.8 0.2 -7.8 -12.7 |
| Annual Evap. | 14.3 | 10.0 | 15.8 | 11 1 | | | |

TABLE B.37: ESTIMATED EVAPORATION LOSSES - WATANA AND DEVIL CANYON RESERVOIRS

1 Based on data - April 1980-June 1981 2 Based on data - July 1980-June 1981 3 Based on data - January 1941-December 1980

| Month A Band C Oct 1000 5500 Nov 900 1200 Dec 900 1200 Jan 900 1200 Feb 900 1200 Mar 900 1200 Apr 900 6000 | D 5500 |
|--|-----------|
| Oct 1000 5500 Nov 900 1200 Dec 900 1200 Jan 900 1200 Feb 900 1200 Mar 900 1200 Apr 900 1200 May 1000 6000 | 5500 |
| Nov 900 1200 Dec 900 1200 Jan 900 1200 Feb 900 1200 Mar 900 1200 Apr 900 1200 May 1000 6000 | |
| Dec 900 1200 Jan 900 1200 Feb 900 1200 Mar 900 1200 Apr 900 1200 May 1000 6000 | 1200 |
| Jan9001200Feb9001200Mar9001200Apr9001200May10006000 | 1200 |
| Feb 900 1200 Mar 900 1200 Apr 900 1200 May 1000 6000 | 1200 |
| Mar 900 1200 Apr 900 1200 May 1000 6000 | 1200 |
| Apr 900 1200 May 1000 6000 | 1200 |
| May 1000 6000 | 1200 |
| | 6000 |
| 2000 7000 | 7000 |
| Jul 2000 9500 70 | 00/1900(1 |
| Aug 2000 12000 | 19000 |
| Sep 1000 12000 | 12000 |

TABLE B.38: MONTHLY FLOW REQUIREMENT AT GOLD CREEK

1

(1) Split Month: 7000 cfs to 15th then 19000 cfs to month end.

TABLE 8.39: REQUIRED FLOW RELEASES AT WATANA

S

- U a

TABLE 8.40: REQUIRED FLOW RELEASES AT DEVIL CANYON

To be included after selection of operation schedule and scheme

| LOCATION* | ADDITIONAL NUMBER | ТҮРЕ | SOURCE (DEPTH) | AMOUNT | DAYS OF USE |
|-------------|--|--|---|---|--|
| CERTIFICATE | | | | | |
| T19N R5W | 45156 | Single-family dwelling general crops | well (?) same source | 650 gpd 0.5 ac-ft/yr | 365 91 |
| T25N R5W | 43981 | Single-family dwelling | well (90 ft) | 500 gpd | 365 |
| T26N R5W | 78895 200540 209233 | Single-family dwelling Grade school Fire station | well (20 ft) well (27 ft) well (34 ft) | 500 gpd 910 gpd 500 gpd | 365 334 365 |
| T27N R5W | 200180 200515 206633 206930 206931 | Single-family dwelling Lawn & garden irrigation Single-family dwelling Single-family dwelling Single-family dwelling Single-family dwelling | unnamed stream same source unnamed lake unnamed lake unnamed lake unnamed lake | 200 gpd 100 gpd 500 gpd 75 gpd 250 gpd 250 gpd | 365 153 365 365 365 365 |
| PERMIT | | | | | |
| | 206929 | General crops | unnamed creek | 1 ac-ft/yr | 153 |
| TJON RJW | 206735 | Single-family dwelling | unnamed stream | 250 gpd | 365 |
| PENDING | | | | | |
| | 209866 | Single-family dwelling Lawn & garden irrigation | Sherman Creek same source | 75 gpd 50 gpd | 365 183 |

TABLE B.41: WATER APPROPRIATIONS WITHIN ONE MILE OF THE SUSITNA RIVER

*All locations are within the Seward Meridian.

6

. ?

TABLE 8.42: TURBINE OPERATING CONDITIONS

| | Watana | Devil Canyon |
|--|-----------|--------------|
| Maximum net head | 728 fest | 597 feet |
| Minimum net head | 576 feet | 238 feet |
| Design head | 680 feet | 575 feet |
| Rated head | 680 feet | 575 feet |
| Turbine flow at rated head, cfs | 3550 cfs | 3800 cfs |
| Turbine efficiency at design head | 91% | 91% |
| Turbine-generating rating at rated head 18 | 31,500 kW | 164,000 kW |

| | | Apphonen and End |
|-------------|------|--|
| Period | U.S. | Anchorage and Fairbanks |
| 1940 - 1950 | 8.8% | 20.5% |
| 1950 - 1960 | 8.7% | 15.3% |
| 1960 - 1970 | 7.3% | 12.9% |
| 1970 - 1978 | 4.6% | 11.7% |
| 1970 - 1973 | 6.7% | 13.1% |
| 1973 - 1978 | 3.5% | 10.9% |
| 1940 - 1978 | 7.3% | 15.2% |
| | | and the second |

TABLE B.43: HISTORICAL ANNUAL GROWTH RATES OF ELECTRIC UTILITY SALES

.

- 1

| | | | | - | | |
|--|-------------|--|---|-----------------|--------------|-----------------|
| | Great | er Anchorage | Greater | : Fairbanks | | U.S. |
| | Customers | Consumption per | Customers (| Consumption per | Customers | Consumption per |
| | (Thousands) | Customer (MWh) | (Thousands) | Customer (MWh) | (Millions) | Customer (MWh) |
| en e | | | | | | |
| Posidontial | | | | | | |
| <u>Nesidentiai</u> | | | | | | |
| 1965 | 27 | 6.4 | 8.2 | 4.8 | 57.6 | 4.9 |
| | | | | | | |
| 1978 | 77 | 10.9 | 17.5 | 10.2 | 77.8 | 8.8 |
| Annual Crowth | | | and a second second Second second | | | |
| Rate (%) | 8.4 | 4.2 | 6.0 | 6.0 | 2.3 | 4.6 |
| Hace (M) | | | | 2.0 | | |
| | • | | | | | |
| Commercial | | | | | | |
| 1965 | Δ Π | and a second s | 1.3 | | 74 | |
| 1703 | 4.0 | | | | * • ¬ | |
| 1978 | 10.2 | - | 2.9 | - | 9.1 | |
| | | | | | | |
| Annual Growth | 7 2 | | 1 1 | | | |
| nace (%) | 1.7 | | 5.4 | | 1.0 | |
| | | | | | | |

TABLE B.44: ANNUAL GROWTH RATES IN UTILITY CUSTOMERS AND CONSUMPTION PER CUSTOMER

TABLE B.45: UTILITY SALES BY RAILBELT REGIONS

| | | Greater | Anchorage | (| Greater Fa | irbanks | • | G | lennalle | n-Valdez | Rai | lbelt Total |
|--|--|--------------------------|--|---|---------------------------|--|---|--|-------------------------|--|--|--|
| Year | <u>Sa</u> GWh | les Regional Share | 1 No. of Customers (Thousands) | <u>Sa</u> GWh | ales Regional Share | 1 No. of Customers (Thousands) | | Sa R GWh | les egional Share | 1 No. of Customers (Thousands) | <u>Sales</u> GWh | 1 No. of Customers (Thousends) |
| 1965 1966 1967 1968 1969 1970 1971 1972 1973 1974 1975 1976 1977 1978 | 369 415 461 519 587 684 797 906 1010 1086 1270 1463 1603 1767 | 78% 75% 75% | 31.0 32.2 34.4 39.2 42.8 46.9 49.5 54.1 56.1 61.8 66.1 71.2 81.1 87.2 | 98 108 66 141 170 213 251 262 290 322 413 423 447 | 21% 24% 24% | 9.5 9.6 NA 10.8 11.6 12.6 13.1 13.5 13.9 15.5 16.2 17.9 20.0 | | 6 NA NA NA 9 10 6 11 14 23 23 23 | 1% 1% 1% | .6 NA NA NA .8 .9 .4 1.0 1.3 1.9 2.2 2.1 2.0 | 473 523 527 661 758 907 1059 1174 1311 1422 1707 1920 2092 2217 | 41.1 41.8 34.4 30.0 54.4 60.3 63.5 68.0 71.0 78.6 84.2 91.3 103.2 109.6 |
| Annual Growth | 12.7% | 178 | 8.2% | 12. | 1% | 6.1% | | 13.9 | 2.73 | 9.7% | 12.6% | 7.9% |

NOTES:

(1) Includes residential and commercial users only, but not miscellaneous users.
 Source: Federal Energy Regulatory Commission, Power System Statement.
 NA: Not Available.

| | | Util | ity Sales to | All Consuming S | iectors | (GWh) | Military Net Generation (| GWh) | Self Industry Net | -Supplied Generation (GW | h) |
|--|--|--|--|---|---|--|--|--|--|--|--|
| Year | LES-GL ¹ Bound | LES-GM | MES-GM (Base Case) | MES-GM with Price Induced Shift | HES-GM | HES-GH ¹ Bound | MES-GM (Base Case) | LES-GM | MES-GM (Base Case) | MES-GM with Price Induced Shift | HES-GIM |
| 1980 1985 1990 1995 2000 2005 2010 | 2390 2798 3041 3640 4468 4912 5442 | 2390 2921 3236 3976 5101 5617 6179 | 2390 3171 3599 4601 5730 6742 7952 | 2390 3171 3599 4617 6525 8219 10142 | 2390 3561 4282 5789 7192 9177 11736 | 2390 3707 4443 6317 8010 10596 14009 | 334 334 334 334 334 334 334 334 | 414 414 414 414 414 414 414 414 | 414 571 571 571 571 571 571 571 | 414 571 571 571 571 571 571 571 | 414 847 981 981 981 981 981 981 |
| Average Ar Growth Rat | nual :e (%) | | | | | | | | | | |
| 1980-1990 1990-2000 2000-2010 1980-2010 | 2.44 3.92 1.99 2.78 | 3.08 4.66 1.94 3.22 | 4.18 4.76 3.33 4.09 | 4.18 6.13 4.51 4.94 | 6.00 5.32 5.02 5.45 | 6.40 6.07 5.75 6.07 | 0.0 0.0 0.0 0.0 | 0.0 0.0 0.0 0.0 | 3.27 0.0 0.0 1.08 | 3.27 0.0 0.0 1.08 | 9.0 0.0 0.0 2.92 |

TABLE B.46: SUMMARY OF ISER RAILBELT ELECTRICITY PROJECTIONS

NOTES:

Lower Bound = Estimates for LES-GL Upper Bound = Estimates for HES-GH

LES = Low Economic Growth MES = Medium Economic Growth

HES = High Economic Growth GL = Low Government Expenditure GM = Moderate Government Expenditure

GH = High Government Expenditure

(1) Results generated by Acres, all others by ISER.

| | ISER LOW (| LES-GM) ² | IS | ER Medium (ME | ISER High (HES-GM) | | |
|--|--|---|----|--|--|--|---|
| Year | Generation (GWh) | Peak Load (MW) | | Generation (GWh) | Peak Load (MW) | Generation (GWh) | Peak Load (MW) |
| 1978 1980 1985 1990 1995 2000 2005 2010 | 3323 3522 4141 4503 5331 6599 7188 7822 | 606 643 757 824 977 1210 1319 1435 | | 3323 3522 4429 4922 6050 7327 8471 9838 | 606 643 808 898 1105 1341 1551 1800 | 3323 4135 5528 6336 8013 9598 11843 14730 | 606 753 995 1146 1456 1750 2158 2683 |
| Percent Growth/Yr. 1978-2010 | 2.71 | 2.73 | | 3.45 | 3.46 | 4.76 | 4.76 |

TABLE B.47: FORECAST TOTAL GENERATION AND PEAK LOADS - TOTAL RAILBELT REGION¹

NOTES:

Ø

.,

(1) Includes net generation from military and self-supplied industry ources.

(2) All forecasts assume moderate government expenditure.

| | Low Plus Load Management and Conservation | | | Low | | | Medium | | | High | | |
|------|---|------|----------------|------|------|----------------|---|------|----------------|------|-------|----------------|
| Year | MW | GWh | Load Factor | MW | GWh | Load Factor | MW | GWh | Load Factor | MW | GWh | Load Factor |
| 1980 | 510 | 2790 | 62.5 | 510 | 2790 | 62.4 | 510 | 2790 | 62.4 | 510 | 2790 | 62.4 |
| 1985 | 560 | 3090 | 62.8 | 580 | 3160 | 62.4 | 650 | 3570 | 62.6 | 695 | 3860 | 63.4 |
| 1990 | 620 | 3430 | 63.2 | 640 | 3505 | 62.4 | 735 | 4030 | 62.6 | 920 | 5090 | 63.1 |
| 1995 | 685 | 3810 | 63.5 | 795 | 4350 | 62.3 | 945 | 5170 | 62.5 | 1295 | 7120 | 62.8 |
| 2000 | 755 | 4240 | 63.8 | 950 | 5210 | 62.3 | 1175 | 6430 | 62.4 | 1670 | 9170 | 62.6 |
| 2005 | 835 | 4690 | 64.1 | 1045 | 5700 | 62.2 | 1380 | 7530 | 62.3 | 2285 | 12540 | 62.6 |
| 2010 | 920 | 5200 | 64.4 | 1140 | 6220 | 62.2 | 1635 | 8940 | 62.4 | 2900 | 15930 | 62.7 |
| | | | | | | | 1. S. | | | | | |

 TABLE B.48:
 ISER 1980 RAILBELT REGION LOAD AND ENERGY FORECASTS USED FOR GENERATION PLANNING STUDIES FOR DEVELOPMENT SELECTION?

LOAD CASE

Notes:

~

LES-GL: Low economic growth/low government expenditure with load management and conservation.
 LES-GL: Low economic growth/low government expenditure.
 MES-GM: Medium economic growth/moderate government expenditure.
 HES-GH: High economic growth/high government expenditure.
 Excludes reserve requirements. Energy figures are for net generation.

| | | Madium | | <u>L 0</u> | <u>AD</u> | CASE | | | | |
|--|------|--------|--------|------------|-----------|--------|------|--------|----------------|--|
| | | reutum | Load | | LOW | | - | High | | |
| Year | MW | GWh | Factor | MW | GWh | Factor | MW | GWh | Load Factor | |
| 1981 | 574 | 2893 | 57.5 | 568 | 2853 | 57.3 | 598 | 3053 | 58.3 | |
| 1985 | 687 | 3431 | 57.8 | 642 | 3234 | 57.5 | 794 | 4231 | 60.8 | |
| 1990 | 892 | 4456 | 57.0 | 802 | 3999 | 56.9 | 1098 | 5703 | 59.3 | |
| 1995 | 983 | 4922 | 57.1 | 849 | 4240 | 57.0 | 1248 | 6464 | 59.1 | |
| 2000 | 1084 | 5469 | 57.4 | 921 | 4641 | 57.4 | 1439 | 7457 | 59.0 | |
| 2005 | 1270 | 6428 | 57.8 | 1066 | 5358 | 57.4 | 1769 | 9148 | 59.0 | |
| 2010 | 1537 | 7791 | 57.9 | 1245 | 6303 | 57.8 | 2165 | 11,435 | 60.3 | |
| Average Annual Growth Rate(%) | | | | | | | | | | |
| 1981–1990 | 5.0 | 4.9 | а 1 | 3.9 | 3.8 | | 7.0 | 7.2 | | |
| 1990-2000 | 2.0 | 2.1 | (د | 1.4 | . 1.5 | | 2.7 | 2.7 | | |
| 2001-2010 | 3.6 | 3.6 | | 3.1 | 3.1 | | 4.2 | 4.4 | | |
| 1981-2010 | 3.5 | 3.5 | | 2.7 | 2.8 | | 45 | 11 6 | | |

TABLE 8.49: DECEMBER 1981 BATTELLE PNL RAILBELT REGION LOAD AND ENERGY FORECASTS USED FOR GENERATION PLANNING STUDIES

ð

1

Note: Excludes reserve requirements. Energy figures are for net generation.





1

0.





.

PROFILE THROUGH ALTERNATIVE SITES

FIGURE B.4



MUTUALLY EXCLUSIVE DEVELOPMENT ALTERNATIVES

| n 1910 - Alexandria 1910 - Alexandria | | | | | | • | | | | | | |
|---|------------------------|---|---|---------------------------------------|--------------------------------------|----------------|---------------|----------------|---------------|--------|----------------|-------|
| | goìd Creek | OLSON | DEVIL CANYON | HIGH DEVIL CANYON | DEVIL CREEK | WATANA | SUSITNA III | VEE | MACLAREN | DENALI | BUTTE CREEK | TYONE |
| GOLD CREEK | | | | | | | | | | | | |
| OLS | OLSON 890 (30) | | | | | | | | | | | |
| DEV | DEVIL CANYON (160) | | | | | | | | | | | |
| | HIGH DEVIL CANYON | | | | | | | | | | | |
| | | DEVI | L CREEK | | | 1465 (405) | | | | | | |
| | | | W | ATANA | | | 181Q (355) | 1925 (470) | 1 | | | |
| | SUSITNA I | | | | | | | -1925 (125) | 2320 (520) | | | |
| COMP | ATIBLE ALTE | RNATIVES | | | | VEE | | | 2320 (405) | | | |
| | | | | | | MACLAREN | | | | | | |
| MUTU | | SIVE ALTERNA | ATIVES | | | JENALI | | | | | | |
| | | | | | | | BUTTE CREEK | | | | | |
| | DAI SUI 405) VAI | M IN COLUMN PPLY LEVEL (LUE IN BRACK | IS MUTUALLY OF DAM IN RO KET REFERS | EXCLUSIVE W EXCEEDS TO APPROXIN | IF FULL THIS VALUE MATE DAM HE | - FT. IGHT. | TYON | | | YONE | | |



T 1

 \cdot



.

÷., .

. £7-· ····



· • · •

24



1.

de la

- **P**


, °

.

· · · · · ·

1.95 . . .

-01

......

- ----

F-- \$

- 12

- · • •

.





- 📆

2









· . . .



5

¢





e,

.

ż



•















s.





<u>_____</u>





<u>...</u>







h

and a state of the second s Second second



방법 같은 것은 성장은 가슴을 얻는다.

فتستند







FIGURE 8.36

. . .







)



. .







/ _____

2



NOTE: PEAK MW DECEMBER 2000 AD = 1084 MW







NOTE: PEAK MW JULY 2000 AD = 658 MW

TYPICAL LOAD VARIATION IN ALASKA RAILBELT SYSTEM



IN YEAR 2000



Č.,



.

ويرجد بالطور المستع



Ĩ

. 7 5

.

ġ,

÷

AVERAGE ANNUAL FLOW DISTRIBUTION WITHIN THE SUSITNA RIVER BASIN










.

j

-6





FIGURE B.48



0.05 0.1 0.2

0.01



• • ¹ F





.



A second



c

8









.0.











يليد بججنين ت



\$ 24





C1

•





| | ACRES | ALASKA POWER AUTHORITY | | |
|--|-----------------------------------|-------------------------------|------------|--|
| | | SUSITNA HYDROELECTRIC PROJECT | | |
| | DEVIL CANYON HYDROLOGICAL DATA | | | |
| | | SHE | ET I | |
| | la | | MARCH 1982 | |



. . . .

1

.





o 2

.....









- - Å

\$* ~

.....



2.



WATANA-UNIT EFFICIENCY (AT RATED HEAD)



1



. . .

DEVIL CANYON-UNIT OUTPUT









ABIC

















