

MWH  
Watana Transmission Study  
Pre - Watana

---

## Appendix A – Detailed Reactive Support Analysis

---

**Table A.1 Detailed Reactive Support Analysis**

Config #	Healy - Douglas		Healy - Douglas		Lorraine - Douglas		Gold Creek		upgrade H - H - W GH		Healy - Doug Open End		No GVEA Import Reactor Size (MVAR)				Total Comp (MVAR)		SP #2 - 75 MW Import Reactor Size (MVAR)				WP #2 - 125 MW Import Reactor Size (MVAR)				Reactive Support Requirements (MVAR)									
	Lorr	Doug	Gold Crk	Healy	Lorr	Doug	Gold Crk	Healy	Lorr	Doug	Gold Crk	Healy	Lorr	Doug	Gold Crk	Healy	Lorraine Fix	Douglas Fix	Sold Crcl Fix	Crel Healy	Lorraine Fix	Douglas Fix	Sold Crcl Fix	Crel Healy	Lorraine Fix	Douglas Fix	Sold Crcl Fix	Crel Healy	Based on Summer Peak case	Based on Winter Peak case						
0	x			x					-	53	0	-	0	48	0	-	0	145	53	25	-	0	need voltage support	53	0	25	67	-	0	0	need voltage support					
1	x			x x					-	Doug	0	92	-	0	Doug	0	-	0	190	70	35	-	0	need voltage support	70	0	35	85	-	0	0	need voltage support				
2	x x			x x					-	Doug	76	0	-	0	Doug	70	0	-	5	218	76	55	-	5	need voltage support in GVEA at Wilson / Gold Hill	76	0	55	82	-	5	0	need voltage support in GVEA at Wilson / Gold Hill			
3	x x			x x x					-	Healy	0	137	-	0	Healy	0	-	0	103	76	-	27	0	need voltage support in GVEA at Wilson / Gold Hill	76	0	-	27	0	0	0	need voltage support in GVEA at Wilson / Gold Hill				
4	x x			x x			x x		-	Doug	81	0	-	0	Doug	70	0	-	27	245	81	50	-	27	60	10	-	27	81	0	50	87	-	27	0	60 21 10 127 - 27 0
5	x x			x x x			x x		-	Healy	0	137	-	0	Healy	75	-	4	0	108	81	-	27	0	60	-	10	0	81	0	-	27	0	0	0	60 21 - 10 17 0 0
6		x x	x x x						-	Doug	121	0	-	26	Doug	75	0	-	101	461	121	55	-	85	90	5	-	55	121	0	55	185	-	85	16	90 31 5 235 - 55 46
7		x x	x x x	x					-	Healy	0	240	-	0	Healy	107	-	39	0	190	107	-	83	0	90	-	83	0	107	0	-	83	0	0	0	90 17 - 83 0 0 0
8		x x	x x x		x x				-	Doug	115	0	-	45	Doug	75	0	-	131	490	115	60	-	100	110	5	-	100	115	0	60	184	-	100	31	110 5 5 239 - 100 31
9		x x	x x x		x x x				-	Healy	0	244	-	0	Healy	99	-	62	0	193	99	-	92	3	90	-	88	3	99	0	-	92	0	3	0	90 9 - 88 4 3 0

## Appendix B – Detailed Dynamic Results

**Table B.1 Summer Valley – Dispatch #2, HCCP offline**

Case	Upgrade	Healy Flows (MW)		Healy Gen Output (MW)	NPCC1 HEALY HCCP															
		Import	Export*		a0	a1	a2	a3	a4	a5	a6	b0	b1	b2	b3	u0	u1	u2	u3	g0
HCCP offline (g2)	0	30	71	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		35	76	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		40	81	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		45	86	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		50	91	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		55	96	47	x	x	x	x	x	x	x	x	x	x	x				x	x
	1	30	71	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		35	76	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		40	81	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		45	86	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		50	91	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		55	96	47	x	x	x	x	x	x	x	x	x	x	x				x	x
	3	30	71	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		35	76	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		40	81	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		45	86	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		50	91	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		55	96	47	x	x	x	x	x	x	x	x	x	x	x				x	x
	5	60	101	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		65	106	47	x	x	x	x	x	x	x	x	x	x	x				x	x
		30	71	47	x	x	x	x	x	x	x					x	x	x	x	x
		35	76	47	x	x	x	x	x	x	x					x	x	x	x	x
		40	81	47	x	x	x	x	x	x	x					x	x	x	x	x
		45	86	47	x	x	x	x	x	x	x					x	x	x	x	x
marginal		unstable		potential voltage problems														simulations ended		

MWH  
Watana Transmission Study  
Pre - Watana

**Table B.2 Summer Valley – Dispatch #3, Healy #1 at Min**

Case	Upgrade	Healy Flows (MW)		Healy Gen Output (MW)	MWH																
		Import	Export*		a0	a1	a2	a3	a4	a5	a6	b0	b1	b2	b3	u0	u1	u2	u3	g0	g3
Healy at Min (g3)	0	60	72	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		65	77	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		70	82	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		75	87	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		80	92	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		85	97	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
	1	60	72	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		65	77	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		70	82	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		75	87	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
	3	80	92	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		85	97	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		90	102	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		95	107	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		100	112	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		60	72	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		65	77	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		70	82	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		75	87	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		80	92	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
	5	85	97	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		90	102	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		95	107	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		100	112	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x

marginal

unstable

potential voltage problems

simulations ended

MWH  
Watana Transmission Study  
Pre - Watana

**Table B.4 Summer Peak – Dispatch #1, Healy Generation at Full Output**

Case	Upgrade Healy Flows (MW) Case #	Healy Gen Output (MW)	Wilson-Ft_WW@Wilson	North_Pole-Ft_WW@North_Pole	Douglas-Healy@Douglas	Douglas-Healy@Healy	Lorraine-West_Term@Lorraine	Lorraine-Douglas@Lorraine	Lorraine-Douglas@Douglas	Eva_Creek-Healy@Healy	Eva_Creek-Healy@Eva	Eva_Creek-Wilson@Eva	Gold_Hill-Healy@Healy	Eva_Creek-Healy@Healy	Eva_Creek-Healy@Eva	Eva_Creek-Wilson@Eva	Gold_Hill-Healy@Healy	NPCC1	HEALY	HCCP
			Import	Export*	a0	a1	a2	a3	a4	a5	b0	b1	b2	b3	u0	u1	u2	u3	g0	g3
Healy full output (g1)	0	50	145	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		55	150	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		60	155	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		65	160	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		70	165	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		75	170	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		80	175	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		85	180	103	x	x	x	x	x	x	x	x	x	x				x	x	x
	1	50	145	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		55	150	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		60	155	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		65	160	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		70	165	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		75	170	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		80	175	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		85	180	103	x	x	x	x	x	x	x	x	x	x				x	x	x
	3	50	145	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		55	150	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		60	155	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		65	160	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		70	165	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		75	170	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		80	175	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		85	180	103	x	x	x	x	x	x	x	x	x	x				x	x	x
	5	50	145	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		55	150	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		60	155	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		65	160	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		70	165	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		75	170	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		80	175	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		85	180	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		90	185	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		95	190	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		100	195	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		105	200	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		110	205	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		115	210	103	x	x	x	x	x	x	x	x	x	x				x	x	x
		120	214	102	x	x	x	x	x	x	x	x	x	x				x	x	x
		125	219	102	x	x	x	x	x	x	x	x	x	x				x	x	x

marginal      unstable      potential voltage problems      simulations ended

MWH  
Watana Transmission Study  
Pre - Watana

**Table B.5 Summer Peak – Dispatch #2, HCCP Offline**

Case	Upgrade Healy Flows (MW) Case #		Healy Gen Output (MW)	Wilson-Ft_WWW@Wilson	North_Pole-Ft_WWW@Nor	Douglas-Healy@Douglas	Douglas-Healy@Healy	Lorraine-West_Term@Lor	Lorraine-Douglas@Lorraine	Lorraine-Douglas@Douglas	Eva_Creek-Healy@Healy	Eva_Creek-Healy@Eva	Eva_Wilson@Eva	Gold_Hill-Healy@Healy	Eva_Creek-Healy@Healy	Eva_Creek-Healy@Eva	Eva_Wilson@Eva	Gold_Hill-Healy@Eva	NPCC1	HEALY	HCCP	
				Import	Export*	a0	a1	a2	a3	a4	a5	a6	b0	b1	b2	b3	u0	u1	u2	u3	g0	g3
HCCP offline (g2)	0	75	115	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		80	120	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		85	125	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		90	130	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		95	135	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
	1	75	115	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		80	120	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		85	125	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		90	130	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		95	135	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
	3	100	140	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		75	115	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		80	120	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		85	125	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		90	130	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		95	135	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		100	140	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		105	144	47	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		110	150	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		115	155	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
	5	120	159	47	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		125	165	48	x	x	x	x	x	x	x	x	x	x	x	x			x	x		
		75	115	48	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		80	120	48	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		85	125	48	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		90	130	48	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		95	135	48	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		100	140	48	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		105	144	47	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		110	150	48	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		115	155	48	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		120	159	47	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		125	165	48	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		130	169	47	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		135	175	48	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		140	179	47	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		145	184	47	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		150	189	47	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		155	195	48	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x

marginal      unstable      potential voltage problems      simulations ended

MWH  
Watana Transmission Study  
Pre - Watana

**Table B.6 Summer Peak – Dispatch #3, Healy #1 at Min**

Case	Upgrade Healy Flows (MW) Case #		Healy Gen Output (MW)	Line Status																NPCC1	H	HEALY	C	HCCP							
				Import	Export*	W	Wilson-Ft_WW@Wilson	N	North_Pole-Ft_WW@North_Pole	D	Douglas-Healy@Douglas	L	Lorraine-West_Term@Lorraine	D	Lorraine-Douglas@Lorraine	E	Eva_Creek-Healy@Healy	E	Eva_Creek-Healy@Eva	E	Eva_Creek-Wilson@Eva	G	Gold_Hill-Healy@Healy	E	Eva_Creek-Healy@Eva	E	Eva_Creek-Wilson@Eva	G	Gold_Hill-Healy@Healy	N	NPCC1
Healy at Min (g3)	0	75	85	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		80	90	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		85	95	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		90	100	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		95	105	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
	1	75	85	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		80	90	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		85	95	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		90	100	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		95	105	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
	3	100	110	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		75	85	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		80	90	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		85	95	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		90	100	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		95	105	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		100	110	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		105	115	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		110	120	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		115	125	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		120	130	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		125	135	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		130	140	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		135	145	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		140	150	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		145	155	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
	5	75	85	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		80	90	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		85	95	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		90	100	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		95	105	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		100	110	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		105	115	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		110	120	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		115	125	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		120	130	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		125	135	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		130	140	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		135	145	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		140	150	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		145	155	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		150	160	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		155	165	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x

marginal      unstable      potential voltage problems      simulations ended

MWH  
Watana Transmission Study  
Pre - Watana

**Table B.7 Winter Peak – Dispatch #1, Healy Generation at Full Output**

Case	Upgrade	Healy Flows (MW)	Healy Gen Output (MW)	MWH																	
				Import	Export*	a0	a1	a2	a3	a4	a5	a6	b0	b1	b2	b3	u0	u1	u2	g0	g3
Healy full output (g1)	0	65	161	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		70	166	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		75	171	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		80	176	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		85	181	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		90	186	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		95	191	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		100	195	103	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
	1	65	161	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		70	166	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
	3	75	171	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		80	176	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		85	181	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		90	186	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		95	191	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		100	195	103	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		65	161	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		70	166	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
	5	75	171	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		80	176	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		85	181	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		90	186	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		95	191	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		100	195	103	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		105	201	104	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		110	205	103	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		115	210	103	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		120	215	103	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		125	220	103	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		130	225	103	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		135	230	103	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		140	235	103	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		145	239	102	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		150	244	102	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		155	249	102	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x

marginal      unstable      potential voltage problems      simulations ended

MWH  
Watana Transmission Study  
Pre - Watana

**Table B.8 Winter Peak – Dispatch #2, HCCP Offline**

Case	Upgrade	lealy	Flows (MW)	Healy Gen Output (MW)	MWH																			
					Wilson_Ft_WWW@Wilson	North_Pole-Ft_WWW@North_Pole	Douglas-Healy@Douglas	Douglas-Healy@Healy	Lorraine-West_Term@Lorraine	Lorraine-Douglas@Lorraine	Eva_Creek-Healy@Healy	Eva_Creek-Healy@Eva	Eva_Hill-Healy@Healy	Eva_Hill-Healy@Eva	Eva_Creek-Healy@Healy	Eva_Creek-Healy@Eva	Gold_Hill-Healy@Healy	Gold_Hill-Healy@Eva	NPCC1	HEALY	HCCP			
		Import	Export*		a0	a1	a2	a3	a4	a5	a6	b0	b1	b2	b3	u0	u1	u2	u3	g0	g3	g4		
0		75	117	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x		
		80	122	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x		
		85	127	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x		
		90	132	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x		
		95	136	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x		
		100	142	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x		
1		105	147	50																			x	x
		75	117	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		80	122	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		85	127	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		90	132	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		95	136	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
HCCP offline (g2)		100	142	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		105	147	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		75	117	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		80	122	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		85	127	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		90	132	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		95	136	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		100	142	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		105	147	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		110	151	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		115	157	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		120	161	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		125	166	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		130	171	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		135	176	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		140	181	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
5		75	117	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		80	122	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		85	127	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		90	132	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		95	136	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		100	142	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		105	147	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		110	151	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		115	157	50	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		120	161	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		125	166	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		130	171	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		135	176	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		140	181	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		145	186	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		150	191	49	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	
		155	195	48	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	

marginal      unstable      potential voltage problems      simulations ended

MWH  
Watana Transmission Study  
Pre - Watana

**Table B.9 Winter Peak – Dispatch #3, Healy #1 at Min**

Case	Upgrade Case #	Healy Flows (MW)		Healy Gen Output (MW)	MWH																		
		Import	Export*		a0	a1	a2	a3	a4	a5	a6	b0	b1	b2	b3	u0	u1	u2	u3	g0	g3	g4	HEALY
Healy at Min (g3)	0	75	85	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		80	90	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		85	95	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		90	100	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		95	105	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
	1	75	85	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		80	90	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		85	95	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		90	100	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		95	105	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		100	110	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
	3	75	85	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		80	90	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		85	95	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		90	100	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		95	105	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		100	110	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		105	115	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		110	120	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		115	125	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		120	130	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		125	135	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		130	140	18	x	x	x	x	M	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		135	145	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		140	150	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
	5	75	85	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		80	90	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		85	95	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		90	100	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		95	105	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		100	110	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		105	115	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		110	120	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		115	125	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		120	130	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		125	135	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		130	140	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		135	145	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		140	150	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		145	155	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		150	160	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
		155	165	18	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x

marginal

unstable

potential voltage problems

simulations ended

MWH  
Watana Transmission Study  
Pre - Watana

## Appendix C – Detailed Power Flow Results

**Table C.1 Power Flow Results – Summer Valley**

Case	Trans. Config	Healy Flows (MW)			Healy Gen	Outage			Volt (kV)	Overload			Volt (kV)	Rating (MVA)	% Rating
		Import	Export*	ID		From Bus	To Bus	ID		From Bus	To Bus	ID			
HCCP offline (g2)	3	65	106	47	Ft. WW	N. Pole	1	138	Ft. WW Sub	FTWP Tap	1	69	46	105	
Healy at Min (g3)	3	100	112	18	Ft. WW	N. Pole	1	138	Ft. WP Tap	Badger Tap	1	69	46	105	

**Table C.2 Power Flow Results – Summer Peak**

Case	Trans. Config	Healy Flows			Healy Gen	Outage			Volt (kV)	Overload			Volt (kV)	Rating (MVA)	% Rating
		Import	Export*	ID		From Bus	To Bus	ID		From Bus	To Bus	ID			
base case															
Healy full output (g1)	3	75	165	103	Eva Creek	Wilson	1	138	Hamilton	FTWW	1	69	46	105	
					Nenana bus voltage = 0.9225 pu										
					Wilson	Ft. WW	1	138	Gold Hill	XFMR	1	138/69	112	143	
					Gold Hill	Aurora	1	69	68						
					Aurora	Zehnder	1	69	68						
					FTWW	XFMR	1	138/69	FTWW	XFMR	1	138/69	100	101	
					Hwy Park	Dawson	1	69	57						
					FTWW Sub	FTWP Tap	1	69	66						
					Gold Hill	XFMR	1	138/69	Gold Hill	XFMR	1	138/69	112	106	
					FTWW XFMR	1	138/69		FTWW XFMR	1	138/69	100	138		
					Gold Hill	XFMR	1	138/69	Hamilton	Ft WW	1	69	46	105	
Low 69 kV voltages between 0.95 and 0.946															
HCCP offline (g2)	3	110	150	48	base case			Hamilton	FTWW	1	69	46	105		
					Nenana bus voltage = 0.9322 pu										
					Wilson	Ft. WW	1	138	Gold Hill	XFMR	1	138/69	110	129	
					Gold Hill	Aurora	1	69	68						
					Aurora	Zehnder	1	69	68						
					Hwy Park	Dawson	1	69	57						
					FTWW Sub	FTWP Tap	1	69	66						
					Gold Hill	XFMR	1	138/69	Gold Hill	XFMR	1	138/69	112	105	
					FTWW XFMR	1	138/69		FTWW XFMR	1	138/69	100	137		
					Zehnder	Hamilton	1	69	68						
HCCP, Healy, and Eva Creek offline (g3)	3	130	140	18	base case			Hamilton	FTWW	1	69	46	107		
					Nenana bus voltage = 0.9322 pu										
					Wilson	Ft. WW	1	138	Gold Hill	XFMR	1	138/69	112	121	
					Gold Hill	Aurora	1	69	68						
					Hwy Park	Dawson	1	69	57						
					FTWW Sub	FTWP Tap	1	69	66						
					Gold Hill	XFMR	1	138/69	Gold Hill	XFMR	1	138/69	112	103	
					FTWW XFMR	1	138/69		FTWW XFMR	1	138/69	100	135		
					Hamilton	Ft WW	1	69	46						
					Low 69 kV voltages between 0.95 and 0.946										


MWH  
Watana Transmission Study  
Pre - Watana

**Table C.3 Power Flow Results – Winter Peak**

Case	Trans. Config	Healy Flows		Healy Gen	Outage			Volt (kV)	Overload		Volt (kV)	Rating (MVA)	% Rating	
		From Bus	To Bus		ID	From Bus	To Bus		ID	From Bus	To Bus			
Healy full output (g1)	3	65	161	104	base case			FTWW XFMR	1	138/69	100	103		
					Eva Creek	Wilson	1	138	Nenana bus voltage = 0.9126 pu					
					Healy	Nenana	1	138	Hamilton	Ft WW	1	69	66	106
					Nenana	Ester	1	138	Hamilton	Ft WW	1	69	66	106
					Ester	Gold Hill	1	138	Hamilton	Ft WW	1	69	66	105
					Wilson	Ft. WW	1	138	Gold Hill	XFMR	1	138/69	112	139
					N. Pole Ind	Carney	1	138	Carney	XFMR	1	138/69	30	138
					FT. WW XFMR		1	138/6	Hwy Park	Dawson	1	69	57	119
							9		Gold Hill	XFMR	1	138/69	112	131
					Low 69 kV voltages between 0.95 and 0.86									
					Gold Hill	XFMR	1	138/69	Hamilton	Ft WW	1	69	66	168
					Low 69 kV voltages between 0.95 and 0.92									
HCCP offline (g2)	3	100	142	50	base case			FTWW XFMR	1	138/69	100	101		
					Eva Creek	Wilson	1	138	Nenana bus voltage = 0.9409 pu					
					Healy	Nenana	1	138	Hamilton	Ft WW	1	69	66	105
					Nenana	Ester	1	138	Low 138 kV voltage at Eva Creek = 0.9376					
					Ester	Gold Hill	1	138	Hamilton	Ft WW	1	69	66	104
					Gold Hill	Wilson	1	138	Hamilton	Ft WW	1	69	66	102
					Wilson	Ft. WW	1	138	Gold Hill	XFMR	1	138/69	112	121
					N. Pole Ind	Carney	1	138	Hwy Park	Dawson	1	69	57	118
							9		Carney	XFMR	1	138/69	30	140
					Low 69 kV voltages between 0.95 and 0.94									
					FT. WW XFMR	1	138/6		Gold Hill	XFMR	1	138/69	112	127
							9		Low 69 kV voltages between 0.95 and 0.89					
HCCP, Healy, and Eva Creek offline (g3)	3	125	135	18	base case			FTWW XFMR	1	138/69	100	101		
					Healy	Eva Creek	1	138	Nenana bus voltage = 0.9450 pu					
					Eva Creek	Wilson	1	138	Nenana bus voltage = 0.9398 pu					
					Healy	Nenana	1	138	Hamilton	Ft WW	1	69	66	105
					Nenana	Ester	1	138	Low 138 kV voltage at Eva Creek = 0.9376					
					Ester	Gold Hill	1	138	Hamilton	Ft WW	1	69	66	104
					Gold Hill	Wilson	1	138	Hamilton	Ft WW	1	69	66	103
					Wilson	Ft. WW	1	138	Gold Hill	XFMR	1	138/69	112	114
					N. Pole Sub	N. Pole Ind	1	138	Hamilton	Ft WW	1	69	66	101
					N. Pole Ind	Carney	1	138	Hwy Park	Dawson	1	69	57	119
							9		Carney	XFMR	1	138/69	30	138
					Low 69 kV voltages between 0.95 and 0.94									
					FT. WW XFMR	1	138/6		Gold Hill	XFMR	1	138/69	112	125
							9		Low 69 kV voltages between 0.95 and 0.89					
					Gold Hill	XFMR	1	138/69	Hamilton	Ft WW	1	69	66	167
									Low 69 kV voltages between 0.95 and 0.92					

## Appendix D – Transmission Configuration Single Line Drawings

Table D.1 – Transmission Configuration #0



MWH  
Watana Transmission Study  
Pre - Watana

Table D.2 – Transmission Configuration #1





Table D.3 – Transmission Configuration #3



MWH  
Watana Transmission Study  
Pre - Watana

Table D.4 – Transmission Configuration #5

