

ALASKA POWER AUTHORITY

Anchorage - Fairbanks Transmission Intertie

Merged With
A.R.L.I.S.
ANCHORAGE ALASKA
Est. 1997



Economic Feasibility Study Report


December 1979



INTERNATIONAL ENGINEERING COMPANY, INC.



ROBERT W. RETHERFORD ASSOCIATES



ALASKA RESOURCES LIBRARY
U.S. Department of the Interior

ALASKA POWER AUTHORITY

TK
1425
S8
A23
no. 250

Anchorage - Fairbanks Transmission Intertie Economic Feasibility Study Report

December 1979

ARLIS

Alaska Resources
Library & Information Services
Anchorage, Alaska



INTERNATIONAL ENGINEERING COMPANY, INC.



ROBERT W. RETHERFORD ASSOCIATES

CONTENTS

| <u>Chapter</u> | | <u>Page</u> |
|----------------|---|-------------|
| | ABBREVIATIONS | x |
| 1 | INTRODUCTION | 1-1 |
| 2 | SUMMARY AND CONCLUSIONS | |
| | 2.1 Study Summary | 2-1 |
| | 2.2 Conclusions | 2-4 |
| 3 | LOAD FORECASTS FOR RAILBELT AREA | |
| | 3.1 Energy and Demand Forecasts Range | 3-1 |
| | 3.2 Demand Forecasts for Generation Planning | 3-8 |
| | 3.3 References | 3-10 |
| 4 | SELECTION OF INTERTIE ROUTE | |
| | 4.1 Review of Earlier Studies | 4-1 |
| | 4.2 Survey of Alternative Corridors | 4-1 |
| | 4.3 Preferred Route for Transmission Intertie | 4-1 |
| | 4.4 Field Investigations | 4-3 |
| | 4.5 Preliminary Environmental Assessment | 4-4 |
| | 4.6 References | 4-11 |
| 5 | TRANSMISSION LINE DESIGN | |
| | 5.1 Basic Design Requirements | 5-1 |
| | 5.2 Selection of Tower Type Used in the Study | 5-1 |
| | 5.3 Design Loading Assumptions | 5-2 |
| | 5.4 Tower Weight Estimation | 5-2 |

ARLIS

Alaska Resources
Library & Information Services
Anchorage, Alaska

CONTENTS

| <u>Chapter</u> | | <u>Page</u> |
|----------------|---|-------------|
| 5 | TRANSMISSION LINE DESIGN (Continued) | |
| | 5.5 Conductor Selection | 5-3 |
| | 5.6 Power Transfer Capabilities | 5-4 |
| | 5.7 HVDC Transmission System | 5-4 |
| | 5.8 References | 5-5 |
| 6 | SYSTEM EXPANSION PLANS | |
| | 6.1 Generation Planning Criteria | 6-1 |
| | 6.2 Multi-Area Reliability Study | 6-4 |
| | 6.3 System Expansion Plans | 6-10 |
| | 6.4 References | 6-12 |
| 7 | FACILITY COST ESTIMATES | |
| | 7.1 Transmission Line Costs | 7-1 |
| | 7.2 Substation Costs | 7-4 |
| | 7.3 Control and Communications System Costs | 7-5 |
| | 7.4 Transmission Intertie Facility Costs | 7-5 |
| | 7.5 Cost of Transmission Losses | 7-5 |
| | 7.6 Basis for Generating Plant Facility Costs | 7-6 |
| | 7.7 Generating Plant Fuel Costs | 7-7 |
| | 7.8 MEA Underlying System Costs | 7-8 |
| | 7.9 Construction Power Costs for the Upper Susitna Project | 7-8 |
| | 7.10 References | 7-9 |
| 8 | ECONOMIC FEASIBILITY ANALYSIS | |
| | 8.1 Methodology | 8-1 |
| | 8.2 Sensitivity Analysis | 8-2 |
| | 8.3 Economic Analysis | 8-3 |
| | 8.4 References | 8-8 |

CONTENTS

| <u>Chapter</u> | | <u>Page</u> |
|----------------|---|-------------|
| 9 | FINANCIAL PLANNING CONCEPTS | |
| | 9.1 Sources of Funds | 9-1 |
| | 9.2 Proportional Allocations Between Sources | 9-5 |
| | 9.3 Allocated Financial Responsibility for Participants | 9-7 |
| | 9.4 Costs for Reserve Sharing and Firm Transfer | 9-11 |
| | 9.5 Financial Plans for Future Staged Development | 9-12 |
| | 9.6 References | 9-13 |
| 10 | INSTITUTIONAL CONSIDERATIONS | |
| | 10.1 Present Institutions and Railbelt Utilities | 10-1 |
| | 10.2 Alaskan Interconnected Utilities | 10-3 |
| | 10.3 References | 10-5 |

APPENDIXES

| <u>Appendix</u> | | |
|-----------------|---|-----|
| A | NOTES ON FUTURE USE OF ENERGY IN ALASKA | A-1 |
| B | TRANSMISSION LINE COSTS ANALYSIS PROGRAM (TLCAP) | |
| | B.1 General Description | B-1 |
| | B.2 Computer Program Applications for Optimum Transmission Line Costs | B-2 |
| | B.3 TLCAP Sample Outputs | B-6 |
| C | MULTI-AREA RELIABILITY PROGRAM (MAREL) | C-1 |

CONTENTS

| <u>Appendix</u> | | <u>Page</u> |
|-----------------|---|-------------|
| D | DATA AND COST ESTIMATES FOR TRANSMISSION INTERTIE AND GENERATING PLANTS | D-1 |
| | D.1 Data and Cost Estimates for Trans- mission Intertie | D-1 |
| | D.2 Data and Cost Estimates for Gene- rating Plants | D-13 |
| | D.3 Data and Cost Estimates for Supply of Construction Power to Upper Susitna Project Sites | D-24 |
| | D.4 Alternative Generating Plant Fuel Costs | D-38 |
| E | TRANSMISSION LINE ECONOMIC ANALYSIS PROGRAM | E-1 |
| F | TRANSMISSION LINE FINANCIAL ANALYSIS | F-1 |

TABLES

| <u>Table</u> | | <u>Page</u> |
|--------------|---|-------------|
| 3-1 | Anchorage-Cook Inlet Area Utility Forecasts and Extrapolated Projections | 3-11 |
| 3-2 | Fairbanks-Tanana Valley Area Utility Forecasts and Extrapolated Pojections | 3-12 |
| 3-3 | Combined Utility Forecasts for Railbelt Area | 3-13 |
| 3-4 | Load Forecast for Upper Susitna Proj- ect by Alaska Power Administration | 3-14 |
| 3-5 | Load Demand Forecasts for Railbelt Area to Determine Statistical Average Forecast | 3-16 |
| 3-6 | Peak Load Demand Forecasts for Railbelt Area with Range Limits for Sensitivity Analysis | 3-17 |
| 5-1 | Conductor Size Selection Criteria | 5-6 |
| 6-1 | Existing Generation Sources, Anchorage- Cook Inlet Area | 6-14 |
| 6-2 | Existing Generation Sources, Fairbanks- Tanana Valley Area | 6-15 |
| 6-3 | Load Model Data, Anchorage Area, Probable Load Forecast Case | 6-16 |
| 6-4 | Load Model Data, Fairbanks Area, Probable Load Forecast Case | 6-17 |
| 6-5 | Load Model Data, Anchorage Area, Low Load Forecast Case | 6-18 |
| 6-6 | Load Model Data, Fairbanks Area, Low Load Forecast Case | 6-19 |
| 6-7 | Loss of Load Probability Index for Study Cases IA and ID, Probable Load Forecast Case | 6-20 |
| 6-8 | Loss of Load Probability Index for Study Case IB, Probable Load Forecast Case | 6-21 |

TABLES (Continued)

| <u>Table</u> | | <u>Page</u> |
|---------------|--|---------------|
| 6-9 | Loss of Load Probability Index for Study Case IIA, Probable Load Forecast Case | 6-22 |
| 6-10 | Loss of Load Probability Index for Study Case IA and ID, Low Load Forecast Case | 6-23 |
| 6-11 | Loss of Load Probability Index for Case IB, Low Load Forecast Case | 6-24 |
| 6-12 | Loss of Load Probability Index for Case IC, Probable Load Forecast Case | 6-25 |
| 7-1 | Cost Summary for Intertie Facilities | 7-10 |
| 7-2 | Present Worth of Intertie Line Losses, 1984-1997 Study Period | 7-11 |
| 7-3 | Cost Summary for Generating Facilities | 7-12 |
| 7-4 | Summary of Alternative Generating Plant Fuel Costs | 7-13 |
| 7-5 | Alternative Costs for Construction Power Supply to Watana and Devil Canyon Hydropower Sites during Construction of Upper Susitna Project | 7-14 |
| 8-1 to 8-6x | Differential Discounted Value of Base Year (1979) Costs | 8-9 to 8-21 |
| 9-1 | Alternative Disbursements of Capital Investment for Generation Expansion | 9-14 |
| 9-2 | Allocation of Total Project Costs Between Participants to Alaskan Intertie Agreement | 9-15 |
| 9-3A and 9-3B | Allocated Costs for Reserve Capacity Sharing and Firm Power Transfer | 9-16 and 9-17 |
| A-1 | MEA Statistical Summary - Past, Present and Future | A-4 |

FIGURES

| <u>Figure</u> | | <u>Page</u> |
|---------------|---|-------------|
| 3-1 | Comparative Net Energy Generation Forecast for Combined Utilities and Industrial Load - Railbelt Area | 3-18 |
| 3-2 | Projected Range of Net Energy Generation Forecast for Combined Utilities and Industrial Load, Railbelt Area | 3-19 |
| 3-3 | Projected Range of Net Energy Generation Forecasts for Combined Utilities and Industrial Load, Anchorage-Cook Inlet Area and Fairbanks-Tanana Valley Area | 3-20 |
| 3-4 | Comparative Annual Peak Demand Forecasts for Combined Utilities and Industrial Load, Railbelt Area | 3-21 |
| 3-5 | Projected Range of Annual Peak Demand Forecasts for Combined Utilities and Industrial Load, Railbelt Area | 3-22 |
| 3-6 | Annual Peak Demand Forecasts for Combined Utilities and Industrial Load, Anchorage-Cook Inlet Area and Fairbanks-Tanana Valley Area | 3-23 |
| 3-7 | Peak Load Demand Forecast with Range Limits for Sensitivity Analysis, Anchorage-Cook Inlet and Fairbanks-Tanana Valley Area Loads | 3-24 |
| 3-8 | Peak Load Demand Forecast with Range Limits for Sensitivity Analysis, Railbelt Area Loads | 3-25 |
| 4-1 | Nenana-Fairbanks-Tanana Transmission System | 4-12 |
| 4-2 | Anchorage-Matanuska-Susitna-Glenallen-Valdez Transmssion System | 4-13 |
| 4-3 | Cook Inlet-Kenai Peninsula Transmission System | 4-14 |
| 5-1 | 230 kV Tangent Tower | 5-7 |
| 5-2 | 345 kV Tangent Tower | 5-8 |

FIGURES (Continued)

| <u>Figure</u> | | <u>Page</u> |
|---------------|--|-------------|
| 6-1 | Non-Coincident 1975 Peak Demands, Anchorage and Fairbanks Areas | 6-26 |
| 6-2 | Independent System Expansion Plans, Anchorage and Fairbanks Areas, Probable Load Forecast Case | 6-27 |
| 6-3 | Interconnected System Expansion Plan, Anchorage-Fairbanks Area without Susitna Project, Probable Load Forecast Case, Case IA and ID | 6-28 |
| 6-4 | Interconnected System Expansion Plan, Anchorage-Fairbanks Area with Firm Power Transfer, Probable Load Forecast Case, Case IB | 6-29 |
| 6-5 | Interconnected System Expansion Plan, Anchorage-Fairbanks Area with Upper Susitna Project, Probable Load Expansion Case, Case II | 6-30 |
| 6-6 | Independent System Expansion Plan, Anchorage- Fairbanks Area, Low Load Forecast Case | 6-31 |
| 6-7 | Interconnected System Expansion Plan, Anchorage-Fairbanks Area, Low Load Forecast Case, Case IA and ID | 6-32 |
| 6-8 | Interconnected System Expansion Plan, Anchorage-Fairbanks Area, Low Load Forecast Case with Firm Power Transfer, Case IB | 6-33 |
| 6-9 | Case I - Alternative A and B | 6-34 |
| 6-10 | Case I - Alternative C | 6-35 |
| 6-11 | Case I - Alternative D | 6-36 |
| 6-12 | Case II | 6-37 |
| 7-1 | Construction Plan for Upper Susitna Project | 7-15 |

FIGURES (Continued)

| <u>Figure</u> | | <u>Page</u> |
|---------------|--|---------------|
| B-1 | Transmission Line Cost Analysis Program Methodology | B-4 |
| D-1 and D-2 | Nomogram Calculates Economy of Scale in Power Plants | D-45 and D-46 |
| D-3 | Estimates of Future National Gas Prices | D-47 |
| D-4 | Estimates of Future Coal Prices | D-48 |

ABREVIATIONS

| | | | |
|--------|---|-------|--|
| ac | alternating current | LNG | liquid nitrate gas |
| ACF | annual cost of fuel | LOLP | loss of load probability |
| ACSR | aluminium conductor, steel reinforced | MAREL | Multi-Area Reliability, a computer program developed by PTI |
| AIA | Alaskan Intertie Agreement | MBTU | Million British thermal unit |
| AML&P | Anchorage Municipal Light and Power Company | MEA | Matanuska Electrical Association, Inc. |
| APA | Alaska Power Authority | MVA | megavolt-amperes |
| A.R.R. | Alaska Railroad | MW | megawatts |
| AVF | average value factor | NESC | National Electrical Safety Committee |
| bpd | barrels per day | NOx | nitrous oxide |
| BTU | British thermal units | O&M | operations and maintenance |
| CEA | Chugach Electric Association, Inc. | ORV | off-road vehicle |
| CFC | Cooperative Finance Corporation | PCF | Plant capacity factor |
| dc | direct current | P.I. | point of intersection |
| DOE | U.S. Department of Energy | PRS | power requirements studies |
| EEI | Edison Electric Institute | PTI | Power Technology, Inc. |
| FFB | Federal Finance Bank | REA | Rural Electrification Administration |
| FGD | flue gas desulphurization | RI | radio interference |
| FOH | forced outage hours | RWRA | Robert W. Retherford Associates, Inc. |
| FMUS | Fairbanks Municipal Utility System | S/C | single circuit |
| ft | feet | SCGT | simple cycle combustion turbine |
| gal | gallon | SIL | surge impedance loading |
| GVEA | Golden Valley Electric Association, Inc. | TLCAP | Transmission Line Cost Analysis Program, a computer program developed by IECO |
| GWh | gigawatt-hours (million kilowatt-hours) | TLEAP | Transmission Line Economic Analysis Program, a computer program developed by IECO |
| HEA | Homer Electric Association, Inc. | TLFAP | Transmission Line Financial Analysis Program, a computer program developed by IECO |
| HVDC | high voltage, direct current | tpy | tons per year |
| IAEAT | Interior Alaska Energy Analysis Team | TVI | television interference |
| IECO | International Engineering Company, Inc. | USA | United States of America |
| IEEE | Institute of Electrical and Electronics Engineers | USGS | United States Geological Survey |
| ISER | Institute for Social and Economic Research | VAR | volt-amperes reactive |
| kcml | thousand circular mils | | |
| kV | kilovolts | | |
| kVa | kilovolt-amperes | | |
| kW | kilowatts | | |
| kWh | kilowatt-hours | | |

CHAPTER 1 INTRODUCTION

This report presents a determination of the economic feasibility for a transmission line interconnection between the utility systems of the Anchorage and Fairbanks areas. It includes an objective evaluation of the specific conditions under which the intertie is economically feasible. An interconnection between the two previously independent power systems will reduce total installed generation reserve capacity, provide means for the interchange of energy, reduce spinning reserve requirements, and provide the means for optimum economic dispatch of generating plants on the interconnected system basis. The later integration of the Upper Susitna Hydropower Project into the interconnected Anchorage-Fairbanks power system would serve to increase the benefits already available from early operation of the intertie. The work described in this report was performed under the authority of the 26 October 1978 contract between the Alaska Power Authority and the joint-venture of International Engineering Company, Inc. (IECO) and Robert W. Retherford Associates (RWRA).

Alternative system expansion plans were developed and analyzed during this study for each of the following areas:

- Independent Anchorage area
- Independent Fairbanks area
- Interconnected Anchorage-Fairbanks area
(generation reserve sharing option)
- Interconnected Anchorage-Fairbanks area
(generation reserve sharing and firm power transfer option)
- Interconnected Anchorage-Fairbanks area (with inclusion of
the Upper Susitna Hydropower Project)

This study confirms the economic feasibility of the Anchorage-Fairbanks transmission line interconnection as well as the possibility of an early implementation date for the project, prior to longer-range development of the Upper Susitna Hydropower Project. This study also establishes additional intertie benefits from the supply of construction power to the sites of the Upper Susitna Hydropower Project. It also evaluated potential benefits from firm power supply to Matanuska Electric Association's system at the intermediate Palmer substation of the intertie. Preliminary financial and management plans for the implementation of the project were developed and are presented in the last two chapters of this report.

An Intertie Advisory Committee, composed of managers of Railbelt area utilities with the chairmanship of the Executive Director of the Alaska Power Authority, was formed. During the performance of this study three Intertie Advisory Committee meetings were held (4 December 1978, 8 January 1979, 14 February 1979, and 18 May 1979) to review factors related to the intertie and to discuss preliminary findings of this study. The following Railbelt utilities were represented on the Intertie Advisory Committee:

- Anchorage Municipal Light & Power (AML&P)
- Copper Valley Electric Association (CVEA)
- Chugach Electric Association (CEA)
- Fairbanks Municipal Utility System (FMUS)
- Golden Valley Electric Association (GVEA)
- Homer Electric Association (HEA)
- Matanuska Electric Association (MEA)

The Consultants wish to acknowledge the valuable information, comments, and support received from the managers and engineers of the Railbelt utilities, and the Alaska Power Administration during the performance of this economic feasibility study.

CHAPTER 2
SUMMARY AND CONCLUSIONS

The purpose of this economic feasibility study is to determine the conditions under which a transmission interconnection between the utility systems of Anchorage and Fairbanks would be economically feasible. Following are the important aspects of work performed and the conclusions of this study.

2.1 STUDY SUMMARY

A. Load Forecasts for Railbelt Area

Load forecast is the basis for system expansion planning. The most recent load forecasts for the utility service areas in the Railbelt area were examined to establish the basis for projection of future trends.

The sum of the most recent forecasts made by the individual utilities in the area has been selected as the upper growth limit to the forecast ranges for the Railbelt area. The median forecast prepared by the Alaska Power Administration, as a revision to the Susitna Project Market Study, was selected as the lower limit. The statistical average of these two forecasts was calculated and used in this study as the "probable" forecast.

The long-range "probable" load demand projections in MW for the load areas are:

| | <u>Anchorage</u> | <u>Fairbanks</u> | <u>Combined Area</u> |
|------|------------------|------------------|----------------------|
| 1980 | 573 | 153 | 749 |
| 1985 | 977 | 231 | 1194 |
| 1990 | 1581 | 338 | 1896 |
| 1995 | 2402 | 477 | 2842 |
| 2000 | 3446 | 663 | 4054 |

B. Selection of Intertie Route

Alternative transmission corridors considered in previous studies were analyzed as to accessibility, cost of right-of-way, transmission line design, and environmental and aesthetic considerations. The preferred corridor described in the Susitna Report, along the Parks Highway from Anchorage to Fairbanks, was selected for the intertie route. It was selected because of its favorable length, accessibility, and environmental considerations. This corridor was further defined by preparing preliminary layouts. Field trips to important sites along this 323-mile line route were made to confirm the suitability at this corridor for the intertie.

C. Transmission Line Design

To provide a basis for intertie cost estimation, conceptual designs for 230-kV and 345-kV transmission lines and substations were made. The transmission Line Cost Analysis Program (TLCAP), a computer program developed by IECO, was used to select optimum designs. The results favored relatively long spans (1300 feet) and high-strength conductors. Tubular steel, guyed towers and pile-type foundations were selected for both the 230-kV and 345-kV lines as being well suited for Alaska conditions.

D. System Expansion Plans

To determine the intertie's economic feasibility, alternative system expansion plans were prepared with and without the Anchorage-Fairbanks intertie. System expansion plans were developed to meet both the "probable" and "low" load demand projections.

To assume a nearly constant level of power generation reliability (LOLP Index) for all system expansion plans, a multi-area reliability (MAREL) computer study was performed. Annual load models for both areas were developed. The load models indicate that there is little diversity between the loads in the Anchorage and Fairbanks areas.

The 1984-1997 study period was selected to best suit system requirements. The earliest year when the intertie can be operational is 1984. Based on optimistic assumptions, the last generating unit of Upper Susitna Hydro-power Project will be on-line in January 1997.

E. Facility Cost Estimates

Cost estimates were developed for alternative system facilities to allow for economic comparisons. All costs were adjusted to January 1979 levels. Transmission line costs were calculated by using the TLCAP program. The same computer program calculated the line losses.

To provide a means for optimum economic dispatch of generating units on an interconnected system basis, costs for control and communication systems were included in the intertie cost estimates. Cost estimates for new generating plant facilities (gas-turbine units and coal-fired steam plants) were based on cost information in the Power Supply Study - 1978 report to GVEA, prepared by Stanley Consultants. Appropriate Alaskan construction cost location adjustment factors were applied to derive specific site cost estimates.

Construction power costs for the proposed Susitna Project were calculated. The results indicate a clear advantage for utilizing the intertie as a source of construction power.

F. Economic Feasibility Analysis

The economic feasibility analysis of the intertie was performed by discounting two cash flows (independent and interconnected systems) to a common year and then measuring the project benefits by the net present worth value. Facility costs for those new generating plants not affected by the introduction of the intertie were excluded from the analysis. The Transmission Line Economic Analysis Program (TLEAP), a computer program, was used to analyze the sensitivity of different escalation and discount rates on the capital costs of various alternatives. For principal investigations to establish definite feasibility analysis a 10% rate was used to discount cash flow in constant 1979 dollars.

G. Financial and Institutional Planning

A preliminary financial plan for implementation of the transmission intertie on a progressive basis was developed. The probable composition of institutions and participating utilities for ownership, management, and operating responsibilities is reviewed in this report, and present arrangements and possible future requirements are discussed.

2.2 CONCLUSIONS

The study shows that:

- The 230-kV single circuit intertie, having a 130-MW line loading capability (Case IA), is economically feasible in 1984, based only on benefits due to reduction of generation reserve plant capacity (reserve sharing). The net present-worth or the benefits are \$12,475,000. The benefits become marginal (\$945,000) if intertie costs are increased by 25 percent. In the case of "low" load forecast scenario the benefits are \$2,704,000.

- An increase in benefits is obtained if the 230-kV single circuit intertie (double circuit after 1992), in addition to generation reserve sharing, includes firm power transfer capability (Case IB). The benefits are \$24,054,000 or an increase of 93 percent over Case IA. Additional benefits due to supply of construction power to the Upper Susitna Project sites are \$5,579,000.
- The 345-kV single circuit intertie (Case IC) is not economically feasible in 1984 based on the two scenarios developed in this study: generation reserve sharing only and reserve sharing plus firm power transfer capability. In the second scenario the results are negative (\$-426,000). Further studies are recommended to pursue the economic feasibility of the 345-kV intertie because from technical point of view the 345-kV voltage is more appropriate for the transmission distance between Anchorage and Fairbanks.
- The 230-kV single circuit intertie with intermediate substations at Palmer and Healy (Case ID) is economically feasible in 1984. The benefits are \$20,344,000 including the power supplies to MEA system to Palmer and the proposed Upper Susitna Hydropower Project sites. If intertie costs are increased by 25 percent the benefits become \$11,656,000.
- The fully integrated interconnected system operation generates additional benefits which are not quantified in this study. These benefits could be due to:
 - Decrease in spinning reserve requirements by reducing the on-line plant capacity for the combined system.
 - Coordination of maintenance scheduling which would improve combined system security and provide cost savings.
 - Economies from optimum dispatch of generating units on the interconnected system basis. It is definitely recommended that a multi-area production costing simulation study be performed to establish these additional benefits.

- Expansion plans for the interconnected system with the proposed Upper Susitna Project were developed to determine the effect of this project on the interconnected system expansion plans, the displacement of thermal generating units, and intertie transmission requirements with Susitna Project.
- If an early 230-kV transmission intertie is constructed in 1984, due considerations should be given for constructing the Anchorage-Susitna portion of this intertie for 345-kV and operating it temporarily at 230-kV.
- The average value of energy transfer cost (1984-2015) thru the 230-kV intertie is 8 Mills/kWh at 55 percent load factor when financed by 40/60% REA/FFB loan package and municipal bonds issued by Anchorage and Fairbanks.
- This Intertie Feasibility Study is only a part of the over- all power system expansion plans for the Railbelt area. Further studies will be required to establish definitive characteristics for this transmission intertie. These studies should be closely coordinated with the future expansion plans of all utilities in the Railbelt area.

CHAPTER 3
LOAD FORECASTS FOR RAILBELT AREA

3.1 ENERGY AND DEMAND FORECAST RANGE

The basis for establishing a range of future load projections for the Anchorage - Cook Inlet and Fairbanks - Tanana Valley areas, together with a combined forecast for an interconnected system service area in the Railbelt, was obtained from an examination of previous forecasts^{1/} compared in the Battelle Report of March 1978 (Ref. 1). These were examined in relation to a combination of the most recent utility forecasts prepared for the REA and an August 1978 revision of previous forecasts for the Upper Susitna Project, issued by the Alaska Power Administration in December 1975 (Ref. 2).

A. Range of Energy Consumption Resulting from Battelle Study

The Battelle study provides a compendium of previous forecasts and an analysis of assumptions intrinsic to their projections. It attempts to eliminate low probability scenarios and select a range of utility and industrial loads for the intertied Railbelt system. The following summary of annual energy consumption, excluding national defense and non-interconnected users, represents the definitive results of the Battelle study:

| | <u>1974</u> | <u>1980</u> | <u>1990</u> | <u>2000</u> |
|------------------------|-------------|-------------|-------------|-------------|
| Annual Consumption-GWh | | | | |
| Upper Range Limit | 1,600 | 3,400 | 10,800 | 22,500 |
| Interval Growth Rate | 13.4% | 15.3% | 10.2% | |
| Lower Range Limit | 1,600 | 2,600 | 8,500 | 16,000 |
| Interval Growth Rate | 8.4% | 9.6% | 4.0% | |

^{1/} See Section 3.3 for references used in this chapter.

Battelle selected this energy consumption range after carefully evaluating the methodology used in several previous forecasts and relevant assumptions pertaining to economic factors. Two load studies were deemed most appropriate to future load projections for the Railbelt. They are, in order of preference, the Upper Susitna Project Power Market Study by the Alaska Power Administration, and the report Electric Power in Alaska, 1976-1995 (Ref 3.) by the Institute for Social and Economic Research (ISER) of the University of Alaska.

1. Forecasts for Anchorage - Cook Inlet Area - From the several load forecasts corresponding to various growth scenarios of the ISER study, Battelle selected Forecasts 2 and 4 as most appropriate for the Anchorage and Cook Inlet area. These forecasts assume limited petroleum development, which was considered to be the most likely prospect. The assumptions underlying the scenario for limited petroleum development are:

- Petroleum Production will be 2 million bpd in 1980, and 3.6 million in 1990.
- A natural gas pipeline will be constructed from Prudhoe Bay through Canada.
- An LNG plant for natural gas from the Gulf of Alaska will be constructed.

The assumptions regarding electrical energy consumption are:

| Sector | Case 2 | Case 4 |
|-------------------------|--------------------------|----------------------------|
| • Residential | Moderate Electrification | No Growth |
| • Commercial/Industrial | Growth as Usual | Minimum Electrification |

The ISER study did not include new industrial consumption in forecasts, other than expansion of existing loads served by utilities. However, it did relate utility forecasts to economic scenarios, in which future energy consumption was quantitatively projected according to specified assumptions of petroleum development, population, aggregate income, saturation levels, and average usage per customer.

In 1975 the Alaska Power Administration prepared forecasts for the potential power market of the Upper Susitna Project. The forecasts contained projections of industrial load for existing and possible future installations. Battelle modified these projections to include the following assumptions:

- In addition to gradual expansion of existing refinery capacity, a new 150,000-bpd refinery will be built by 1983.
- An aluminum smelter with a capacity of 300,000 tpy will be constructed, to be on-line by 1985.
- A nuclear fuel enrichment plant, included in previous load projections, was deleted from future industrial load.
- Industrial development in the interior region was assumed to be excluded from the load area of an intertied Railbelt system.

A summary of industrial facilities included in the Battelle forecast for the Anchorage and Cook Inlet area is as follows:

| <u>Existing Facilities</u> | <u>New Facilities</u> |
|----------------------------|--------------------------------------|
| Chemical Plant | Aluminum Smelter |
| LNG Plant | LNG Plant |
| Refinery | Refinery |
| Timber Mills | Timber Mills |
| | Coal Gasification Plant |
| | Mining and Mineral Processing Plants |
| | New City |

2. Forecasts for Fairbanks - Tanana Valley Area - A similar evaluation by Battelle defined the most probable forecasts for the Fairbanks and Tanana Valley area. It assumed that industrial development in the interior region will consist largely of self-supplied mining operations in remote areas. Thus, load growth will be attributable only to utility customers in the service areas of the Fairbanks Municipal Utilities System (FMUS) and the Golden Valley Electric Association, Inc. (GVEA).

In the judgment of Battelle, the most likely consumption range for the Fairbanks area is bounded by the mid-range projections of the Upper Susitna Market Study, with mid-range forecasts prepared by the Interior Alaska Energy Analysis Team (IAEAT) (Ref. 4) as the upper bound and the ISER Case 4 as the lower bound.

3. Combined Forecasts for the Railbelt - The Battelle energy and demand forecast range for the combined utility and industrial load of the Railbelt, encompassing the Anchorage - Cook Inlet and Fairbanks - Tanana Valley areas, is shown graphically on Figures 3-1 and 3-4, respectively. These are intended to serve as background comparisons with combined utility forecasts and the revised projections of the Alaska Power Administration for the potential market of the Upper Susitna Project.

B. Forecasts by Utilities and the Alaska Power Administration

The most recent Power Requirements Studies (PRS) of the REA utilities (Ref. 5) in the Anchorage and Fairbanks areas were obtained, together with the most probable load forecasts, as projected for the Anchorage Municipal Light and Power Company (AML&P) and the Fairbanks Municipal Utilities System (FMUS).

Tables 3-1 and 3-2 provide tabulations of utility forecasts and extrapolated projections to the horizon year 2000, for the Anchorage - Cook Inlet area and the Fairbanks - Tanana Valley area, respectively. The Valdez - Copper Valley area is not included in the forecasts for the

Railbelt, as these load areas are assumed not to be interconnected with the intertied Railbelt system until after the completion of the Upper Susitna Project. As the PRS provided load projections for a base year and at two 5-year intervals, interpolations were made on the basis of assumed compound growth between reported values. On the further assumption that growth rates will decline progressively to the horizon year, extrapolations were made of net energy generation with growth rates declining from reported values at 5-year intervals to 2000. These growth rates were applied on the assumption that there will be no abrupt transition to low growth rates. Rather, growth will diminish in gradual steps as markets are saturated and the effects of conservation and price elasticity reflect in future energy consumption levels. Reported load factors were interpolated for intermediate years and the trend extrapolated to the horizon year to obtain projections of annual peak demand.

The utility forecasts were combined for the Anchorage - Cook Inlet area, the Fairbanks - Tanana Valley area, and the total Railbelt. Table 3-3 provides tabulations of net energy generation, load factor, and annual peak diversified demand. It is obtained by the application of coincidence factors to the sum of individual utility peak demands. These load forecasts are shown on Figures 3-1 through 3-6, in comparison with load projections prepared in August 1978 by the Alaska Power Administration for the Upper Susitna Project, as revisions to previous power market forecasts evaluated as part of the Battelle study. A summary of the Alaska Power Administration load forecasts is given in Table 3-4. These forecasts include only utility and industrial load projections on the assumption that national defense installations will not be supplied as part of the interconnected system load. Since the Battelle forecasts also excluded load forecasts for national defense installations, direct comparisons can be made. The range of Alaska Power Administration load forecasts for peak demand and annual energy was as follows:

| | | 1980 | 1985 | 1990 | 1995 | 2000 |
|--------------------------------|------|------|------|------|------|------|
| % Differential from median: | High | + 8 | + 21 | + 31 | + 41 | + 54 |
| | Low | - 8 | - 18 | - 27 | - 33 | - 38 |

The range of load forecasts exhibited this diverging spread from the 1977 base-year load level. The industrial load projected by Battelle was included in the Alaska Power Administration forecast range on a selective basis. The differential between the "high" and "extra high" forecasts is an additional 280 MW of load, representing an aluminum smelter. The "low" forecast excludes the load projected for the New City.

C. Comparison and Selection of Forecast Range

The forecasts of net energy generation for the Railbelt are shown on Figure 3-1. Curve 1 represents the combination of the most recent forecasts for municipal and REA utilities, as presented in Tables 3-1, 3-2, and 3-3. The forecast aligns closely up to 1990 with the upper bound of the Battelle forecast range. Beyond 1990 the divergence arises from the different assumptions made in regard to growth rates in the 1990-2000 period. The upper bound of the Battelle range exhibits an abrupt change of growth rate, from 15.3% to 10.2%, applied to total energy in the Railbelt, while the combined utilities forecast exhibits a more gradual transition to lower growth rates. Although many economic factors will contribute to lower overall growth rates in energy consumption, a reasonable approach to establishing an upper limit has been taken, in that individual utility forecasts were assumed to decline without abrupt change. This assumption is based on the fairly constant percentage expenditure from disposable income for energy needs, as determined by the study of future consumption patterns in Alaskan service areas (Ref. 6), the results of which are given in an extract from the RWRA report (Ref. 7) presented in Appendix A.

Accordingly, the combined utilities forecast has been selected as the upper limit to the possible range of total energy forecasts for the Railbelt. The median forecast prepared by the Alaska Power Administration, as a revision to the Susitna Project Market Study, has been selected as the lower limit to the forecast range for the Railbelt. This recently prepared forecast exhibits lower growth than the 1975

forecast for the Susitna Project, and represents a prudent choice for a conservative growth scenario.

Figures 3-2 and 3-3 show the relationship between the combined utilities forecast and the range of forecasts prepared by the Alaska Power Administration. The effect of the aluminum smelter load can be observed as the differential between curves 2C and 3C on Figure 3-2, and curves 2A and 3A on Figure 3-3. The median forecast also excludes the aluminum smelter load but provides for a reasonable realization of the industrial potential in the Anchorage area. In setting the lower limit of the forecast range in the context of the considerable industrial growth potential of this area of Alaska, it is thought that the selected forecast range will provide a good test of the economic feasibility of establishing an interconnection in the Railbelt.

A similar comparison of forecast demand can be made by reference to Figures 3-4, 3-5, and 3-6. The combined utilities demand forecast is below the upper bound of the Battelle range until after 1985 and aligns in fairly close proximity until 1990. Beyond 1990 divergence occurs based upon the assumption discussed previously in relation to energy growth. The median demand forecast for the Susitna Project, prepared by the Alaska Power Administration, exhibits a growth characteristic that roughly parallels the lower bound of the Battelle range between 1985 and 2000. As the low growth limit to the range of demand beyond 1981 selected for the interconnection study, it represents a moderately conservative view of overall growth potential.

Prior to 1981, the short-range combined utilities demand forecast is below the median forecast for the Susitna Project, approximately at Battelle mid-range. The demand forecasts for the Susitna Project may be observed in relation to the combined utilities demand forecasts of Figures 3-5 and 3-6. The selected range of demand forecasts represents a moderate to high expectation of a continued growth of the Railbelt economy through the end of the century, this being accentuated by the interconnection of utility systems in the area.

3.2 DEMAND FORECASTS FOR GENERATION PLANNING

The range exhibited by load forecasts for the Railbelt Area is considerable. Therefore, it remains to select definitive demand forecasts for generation expansion planning that are a reasonable representation of anticipated load growth under projected economic conditions.

A. Selection of Peak Load Demand Forecasts

The combined utilities forecast is appropriate to a high growth scenario that may not be possible under future economic constraints and prevailing trends towards greater conservation. The median forecast by the Alaska Power Administration does not include the entire industrial load potential that could be realized by a steady commitment towards economic growth in the State. It also specifically excludes the possibility of development of the aluminum smelter in the Anchorage area.

The selection of the statistical average forecasts, given in Table 3-5, for peak load demand is consistent with the moderate to high expectation of continued growth in the Railbelt economy. The natural resources of Alaska, particularly oil and gas, will largely determine the extent of future growth possible within the State. A steady pressure for additional domestic oil and gas supplies for the lower forty-eight will be engendered by the continuing energy crisis within the United States. The impact of additional exploitation of the North Slope on the State economy will be reflected in continued growth within the Railbelt. Thus, the conditions are present to ensure the realization of optimistic expectations for moderate to high growth of load demand.

B. Forecast Range for Sensitivity Analysis

In order to determine the effect of load growth on the economic feasibility of the Anchorage-Fairbanks Intertie, a suitable range of load growth must be established for sensitivity analysis.

The uncertainty associated with a load forecast increases with time, so the range of demand should also increase with time. The values given in Table 3-6 correspond to a range of load demand that steadily increases through time from a bandwidth of $\pm 1\%$ in 1979 to $\pm 21\%$ in 2000.

The long-range load projections for the Anchorage-Cook Inlet and Fairbanks-Tanana Valley areas are shown on Figure 3-7, with their corresponding range limits. The diversified demand for the combined areas of the Rail-belt is given on Figure 3-8, the peak load rising to approximately 4000 MW in the year 2000.

3.3 REFERENCES

1. Battelle Pacific Northwest Laboratories, Alaska Electric Power: An Analysis of Future Requirements and Supply Alternatives for the Railbelt Region, March 1978.
2. U.S. Department of the Interior, Alaska Power Administration, Upper Susitna River Hydroelectric Studies, Report on Markets for Project Power, December 1975.
3. University of Alaska, Institute for Social and Economic Research, Electric Power in Alaska, 1976-1995, August 1976.
4. Interior Alaska Energy Analysis Team, Report of Findings and Recommendations, June 1977.
5. Rural Electrification Association, Power Requirements Study for:
Alaska 2 - Matanuska Electric Association, Inc., May 1978
Alaska 5 - Kenai-Homer Electric Association, Inc., May 1978
Alaska 6 - Golden Valley Electric Association, Inc., May 1976
Alaska 8 - Chugach Electric Association, Inc., May 1976
Alaska 18 - Copper Valley Electric Association, Inc., May 1977.
6. E. O. Bracken, Alaska Department of Commerce and Economic Development, Power Demand Estimators, Summary and Assumptions for the Alaska Situation, June 1977.
7. Robert W. Retherford Associates, System Planning Report, Matanuska Electric Association, Inc., January 1979.
8. U.S. Department of the Interior, Alaska Power Administration, A Report of the Technical Advisory Committee on Economic Analysis and Load Projections, 1974.
9. Federal Power Commission, The 1976 Alaska Power Survey, Vol. 1, 1976.
10. U.S. Army Corps of Engineers, South-central Railbelt Area, Alaska, Upper Susitna River Basin Interim Feasibility Report, December 1975.
11. U.S. Department of the Interior, Alaska Power Administration, Bradley Lake Project Power Market Analyses, August 1977.
12. Tippet and Gee, Consulting Engineers, 1976 Power System Study, Chugach Electric Association, Inc., Anchorage, Alaska, March 1976.

TABLE 3-1

ANCHORAGE - COOK INLET AREA
UTILITY FORECASTS AND EXTRAPOLATED PROJECTIONS

| Year | Anchorage Municipal Light and Power Company | | | Alaska 2 - Matanuska Electric Association, Inc. | | | Alaska 5 - Kenai | | | | | | Alaska 8 - Chugach Electric Association, Inc. | | |
|------|--|---------------|----------------|--|---------------|----------------|------------------|---------------|----------------|-----------------|---------------|----------------|--|---------------|----------------|
| | Net | Load | Peak | Net | Load | Peak | Net | Load | Peak | Net | Load | Peak | Net | Load | Peak |
| | Energy (GWh) | Factor (%) | Demand (MW) | Energy (GWh) | Factor (%) | Demand (MW) | Energy (GWh) | Factor (%) | Demand (MW) | Energy (GWh) | Factor (%) | Demand (MW) | Energy (GWh) | Factor (%) | Demand (MW) |
| 1979 | 633.6 | 58.1 | 124.4 | 280.4 | 47.5 | 67.4 | 275.2 | 55.0 | 57.1 | 34.4 | 56.0 | 7.0 | 1,108.9 | 53.0 | 238.8 |
| 1980 | 699.4 | 58.1 | 137.5 | 332.8 | 47.0 | 80.8 | 336.6 | 55.0 | 69.9 | 37.5 | 56.0 | 7.6 | 1,283.0 | 54.0 | 271.2 |
| 1981 | 770.6 | 57.9 | 151.8 | 395.1 | 46.5 | 97.0 | 411.6 | 55.0 | 85.4 | 40.8 | 56.0 | 8.3 | 1,467.8 | 54.0 | 310.3 |
| 1982 | 847.3 | 57.8 | 167.3 | 468.0 | 56.0 | 116.1 | 502.0 | 55.0 | 104.2 | 44.4 | 56.0 | 9.1 | 1,679.1 | 54.0 | 355.0 |
| 1983 | 929.6 | 57.7 | 183.9 | 559.3 | 45.0 | 141.9 | 572.3 | 55.0 | 118.8 | 48.1 | 56.0 | 9.8 | 1,920.9 | 54.0 | 406.1 |
| 1984 | 1,017.5 | 57.6 | 201.8 | 668.3 | 44.5 | 171.4 | 652.4 | 55.0 | 135.4 | 52.1 | 56.0 | 10.6 | 2,197.5 | 54.0 | 464.5 |
| 1985 | 1,110.8 | 57.4 | 220.8 | 798.6 | 44.0 | 207.2 | 743.7 | 55.0 | 154.4 | 56.4 | 56.0 | 11.5 | 2,509.0 | 54.0 | 530.4 |
| 1986 | 1,209.5 | 57.3 | 241.1 | 954.4 | 43.5 | 250.5 | 847.9 | 55.0 | 176.0 | 61.1 | 56.0 | 12.5 | 2,810.1 | 54.0 | 594.1 |
| 1987 | 1,313.2 | 57.1 | 262.5 | 1,140.0 | 43.0 | 302.6 | 967.0 | 55.0 | 201.0 | 66.3 | 56.0 | 13.5 | 3,147.3 | 54.0 | 665.3 |
| 1988 | 1,421.6 | 56.9 | 285.0 | 1,322.4 | 44.0 | 343.1 | 1,083.0 | 55.0 | 224.8 | 71.5 | 56.0 | 14.6 | 3,525.0 | 54.0 | 745.2 |
| 1989 | 1,534.2 | 56.8 | 308.5 | 1,534.0 | 45.0 | 389.1 | 1,213.0 | 55.0 | 251.8 | 77.0 | 56.0 | 15.7 | 3,948.0 | 54.0 | 834.6 |
| 1990 | 1,650.5 | 56.6 | 333.0 | 1,779.4 | 46.0 | 441.6 | 1,358.6 | 55.0 | 282.0 | 83.1 | 56.0 | 16.9 | 4,421.7 | 55.0 | 934.7 |
| 1991 | 1,769.8 | 56.4 | 358.2 | 2,064.1 | 47.0 | 501.3 | 1,521.6 | 55.0 | 315.8 | 89.5 | 56.0 | 18.2 | 4,863.9 | 55.0 | 1,028.2 |
| 1992 | 1,891.3 | 56.2 | 384.1 | 2,394.4 | 48.0 | 569.4 | 1,704.2 | 55.0 | 353.7 | 96.5 | 56.0 | 19.7 | 5,350.3 | 55.0 | 1,131.0 |
| 1993 | 2,014.4 | 56.0 | 410.5 | 2,705.7 | 49.0 | 630.3 | 1,874.6 | 55.0 | 389.1 | 103.5 | 56.0 | 21.1 | 5,885.3 | 55.0 | 1,244.1 |
| 1994 | 2,138.0 | 55.8 | 437.2 | 3,057.4 | 50.0 | 698.0 | 2,062.1 | 55.0 | 428.0 | 111.1 | 56.0 | 22.6 | 6,473.9 | 55.0 | 1,368.6 |
| 1995 | 2,244.9 | 55.6 | 460.9 | 3,454.9 | 51.0 | 773.3 | 2,268.3 | 55.0 | 470.8 | 119.2 | 56.0 | 24.3 | 7,121.2 | 55.0 | 1,505.4 |
| 1996 | 2,357.1 | 55.4 | 485.7 | 3,904.0 | 52.0 | 857.0 | 2,495.1 | 55.0 | 517.9 | 127.9 | 56.0 | 26.1 | 7,690.9 | 55.0 | 1,625.8 |
| 1997 | 2,475.0 | 55.2 | 511.8 | 4,411.5 | 53.0 | 950.2 | 2,744.6 | 55.0 | 559.7 | 137.3 | 56.0 | 28.0 | 8,306.2 | 55.0 | 1,755.9 |
| 1998 | 2,598.8 | 55.0 | 539.4 | 4,852.7 | 54.0 | 1,025.9 | 2,964.2 | 55.0 | 615.2 | 146.9 | 56.0 | 29.9 | 8,970.7 | 55.0 | 1,900.6 |
| 1999 | 2,728.7 | 54.8 | 568.4 | 5,337.9 | 55.0 | 1,107.9 | 3,201.3 | 55.0 | 664.4 | 157.2 | 56.0 | 32.0 | 9,688.3 | 55.0 | 2,048.1 |
| 2000 | 2,865.0 | 54.6 | 599.0 | 5,871.7 | 56.0 | 1,196.9 | 3,457.4 | 55.0 | 717.6 | 168.2 | 56.0 | 34.3 | 10,463.4 | 55.0 | 2,211.9 |

Growth Rates:

| Reported | Logistic Curve 3 | 18.7% (1977-1982) | 22.3% (1977-1982) | 8.8% (1977-1982) | 15.7% (1977-1982) |
|-----------|------------------|-------------------|-------------------|------------------|-------------------|
| | | 19.5% (1983-1987) | 14.0% (1983-1987) | 8.3% (1983-1987) | 14.4% (1983-1987) |
| Projected | 5.0% (1995-2000) | 16.0% (1988-1992) | 12.0% (1988-1992) | 7.8% (1988-1992) | 12.0% (1988-1992) |
| | | 13.0% (1993-1997) | 10.0% (1993-1997) | 7.3% (1993-1997) | 10.0% (1993-1997) |
| | | 10.0% (1998-2000) | 8.0% (1998-2000) | 7.0% (1998-2000) | 8.0% (1998-2000) |

TABLE 3-2
FAIRBANKS - TANANA VALLEY AREA
UTILITY FORECASTS AND EXTRAPOLATED PROJECTIONS

| Year | Fairbanks Municipal Utilities System | | | Alaska 6 - Golden Valley Electric Association, Inc. | | |
|------|---|-----------------------|------------------------|--|-----------------------|------------------------|
| | Net Energy (GWh) | Load Factor (%) | Peak Demand (MW) | Net Energy (GWh) | Load Factor (%) | Peak Demand (MW) |
| 1979 | 144.3 | 50.0 | 32.9 | 450.0 | 46.3 | 111.0 |
| 1980 | 153.0 | 50.0 | 34.9 | 501.8 | 46.6 | 122.9 |
| 1981 | 162.2 | 50.0 | 37.0 | 559.5 | 46.9 | 136.2 |
| 1982 | 171.9 | 50.0 | 39.2 | 624.6 | 47.2 | 150.9 |
| 1983 | 182.2 | 50.0 | 41.6 | 692.6 | 47.3 | 167.1 |
| 1984 | 193.2 | 50.0 | 44.1 | 768.8 | 47.3 | 185.5 |
| 1985 | 204.7 | 50.0 | 46.7 | 853.4 | 47.4 | 205.5 |
| 1986 | 217.0 | 50.0 | 49.5 | 947.3 | 47.4 | 228.1 |
| 1987 | 230.0 | 50.0 | 52.5 | 1,050.0 | 47.5 | 252.3 |
| 1988 | 243.9 | 50.0 | 55.7 | 1,155.0 | 47.5 | 277.6 |
| 1989 | 258.5 | 50.0 | 59.0 | 1,270.5 | 47.6 | 304.7 |
| 1990 | 274.0 | 50.0 | 62.6 | 1,397.6 | 47.6 | 335.2 |
| 1991 | 287.7 | 50.0 | 65.7 | 1,537.3 | 47.7 | 367.9 |
| 1992 | 302.1 | 50.0 | 69.0 | 1,691.0 | 47.7 | 404.7 |
| 1993 | 317.2 | 50.0 | 72.4 | 1,843.2 | 47.8 | 440.2 |
| 1994 | 333.0 | 50.0 | 76.0 | 2,009.1 | 47.8 | 479.8 |
| 1995 | 349.7 | 50.0 | 79.8 | 2,189.9 | 47.9 | 521.0 |
| 1996 | 367.2 | 50.0 | 83.8 | 2,387.0 | 47.9 | 568.9 |
| 1997 | 385.5 | 50.0 | 88.0 | 2,601.8 | 48.0 | 618.8 |
| 1998 | 404.8 | 50.0 | 92.4 | 2,809.9 | 48.0 | 668.3 |
| 1999 | 425.1 | 50.0 | 97.1 | 3,034.7 | 48.0 | 721.7 |
| 2000 | 446.3 | 50.0 | 101.9 | 3,277.5 | 48.0 | 779.5 |

Growth Rates:

| | | |
|-----------|------------------|-------------------|
| Reported | 6.0% (1978-1990) | 11.5% (1977-1982) |
| | | 11.0% (1983-1987) |
| <hr/> | | |
| Projected | 5.0% (1991-2000) | 10.0% (1988-1992) |
| | | 9.0% (1993-1997) |
| | | 8.0% (1998-2000) |

TABLE 3-3

COMBINED UTILITY FORECASTS FOR RAILBELT AREA

| Year | Anchorage Cook - Inlet | | | Fairbanks - Tanana Valley | | | Combined Load Areas | | |
|------|------------------------|-----------------------|--------------------------------------|---------------------------|-----------------------|--------------------------------------|------------------------|-----------------------|--------------------------------------|
| | Net Energy (GWh) | Load Factor (%) | Peak ^{1/} Demand (MW) | Net Energy (GWh) | Load Factor (%) | Peak ^{2/} Demand (MW) | Net Energy (GWh) | Load Factor (%) | Peak ^{3/} Demand (MW) |
| 1979 | 2,332.5 | 56.1 | 475 | 594.3 | 47.6 | 142 | 2,926.8 | 55.3 | 605 |
| 1980 | 2,689.3 | 56.4 | 544 | 654.8 | 47.9 | 156 | 3,344.1 | 55.6 | 686 |
| 1981 | 3,085.9 | 56.2 | 627 | 721.7 | 48.0 | 171 | 3,807.6 | 55.6 | 782 |
| 1982 | 3,540.8 | 56.0 | 722 | 795.9 | 48.3 | 188 | 4,336.7 | 55.5 | 892 |
| 1983 | 4,030.2 | 55.7 | 826 | 874.8 | 48.3 | 207 | 4,905.0 | 55.3 | 1,012 |
| 1984 | 4,587.8 | 55.5 | 944 | 962.0 | 48.3 | 227 | 5,549.8 | 55.2 | 1,148 |
| 1985 | 5,218.5 | 55.2 | 1,079 | 1,058.1 | 48.4 | 250 | 6,276.6 | 55.0 | 1,302 |
| 1986 | 5,883.0 | 54.9 | 1,223 | 1,164.3 | 48.4 | 275 | 7,047.3 | 54.8 | 1,468 |
| 1987 | 6,633.8 | 54.6 | 1,387 | 1,280.0 | 48.4 | 302 | 7,913.8 | 54.6 | 1,655 |
| 1988 | 7,423.5 | 54.7 | 1,548 | 1,398.9 | 48.4 | 330 | 8,822.4 | 54.7 | 1,840 |
| 1989 | 8,306.2 | 54.9 | 1,728 | 1,529.0 | 48.5 | 360 | 9,835.2 | 54.9 | 2,046 |
| 1990 | 9,293.3 | 55.0 | 1,928 | 1,671.6 | 48.5 | 394 | 10,964.9 | 55.0 | 2,276 |
| 1991 | 10,308.9 | 55.2 | 2,133 | 1,825.0 | 48.5 | 429 | 12,133.9 | 55.2 | 2,511 |
| 1992 | 11,436.7 | 55.3 | 2,360 | 1,993.1 | 48.5 | 469 | 13,429.8 | 55.3 | 2,772 |
| 1993 | 12,583.5 | 55.5 | 2,587 | 2,160.4 | 48.6 | 507 | 14,743.9 | 55.5 | 3,032 |
| 1994 | 13,842.5 | 55.7 | 2,836 | 2,342.1 | 48.6 | 550 | 16,184.6 | 55.7 | 3,318 |
| 1995 | 15,208.5 | 55.9 | 3,105 | 2,539.6 | 48.6 | 596 | 17,748.1 | 55.9 | 3,627 |
| 1996 | 16,575.0 | 56.1 | 3,372 | 2,754.2 | 48.7 | 646 | 19,329.2 | 56.0 | 3,938 |
| 1997 | 18,074.6 | 56.3 | 3,663 | 2,987.3 | 48.7 | 700 | 21,061.9 | 56.2 | 4,276 |
| 1998 | 19,533.3 | 56.5 | 3,947 | 3,214.7 | 48.7 | 753 | 22,748.0 | 56.4 | 4,606 |
| 1999 | 21,113.4 | 56.8 | 4,244 | 3,459.8 | 48.7 | 811 | 24,573.2 | 56.6 | 4,954 |
| 2000 | 22,825.7 | 57.0 | 4,569 | 3,723.8 | 48.7 | 873 | 265,49.5 | 56.8 | 5,333 |

Diversified Demand
for Coincidence Factor:

1/ 0.96

2/ 0.99

3/ 0.98

TABLE 3-4
Sheet 1 of 2

LOAD FORECAST FOR UPPER SUSITNA PROJECT
BY
ALASKA POWER ADMINISTRATION

| | <u>1977</u> | <u>1980</u> | <u>1985</u> | <u>1990</u> | <u>1995</u> | <u>2000</u> |
|---|-------------|-------------|-------------|-------------|-------------|-------------|
| 1. <u>ANCHORAGE-COOK INLET AREA POWER DEMAND AND ENERGY REQUIREMENTS</u> | | | | | | |
| (Excluding National Defense) | | | | | | |
| <u>Peak Demand (MW)</u> | | | | | | |
| Utility Loads | | | | | | |
| High | | 620 | 1,000 | 2,150 | 3,180 | 7,240 |
| Median | 424 | 570 | 810 | 1,500 | 2,045 | 3,370 |
| Low | | 525 | 650 | 1,040 | 1,320 | 1,520 |
| Industrial Loads | | | | | | |
| Extra high | | 32 | 344 | 399 | 541 | 683 |
| High | | 32 | 64 | 119 | 261 | 403 |
| Median | 25 | 32 | 64 | 119 | 199 | 278 |
| Low | | 27 | 59 | 70 | 87 | 104 |
| Total | | | | | | |
| Extra high | | 652 | 1,344 | 1,914 | 2,691 | 3,863 |
| High | | 652 | 1,064 | 1,634 | 2,411 | 3,583 |
| Median | 449 | 602 | 874 | 1,234 | 1,699 | 2,323 |
| Low | | 552 | 709 | 890 | 1,127 | 1,424 |
| <u>Annual Energy (GWh)</u> | | | | | | |
| Utility Loads | | | | | | |
| High | | 2,720 | 4,390 | 6,630 | 9,430 | 13,920 |
| Median | 1,790 | 2,500 | 3,530 | 4,880 | 6,570 | 8,960 |
| Low | | 2,300 | 2,840 | 3,590 | 4,560 | 5,770 |
| Industrial Loads | | | | | | |
| Extra high | | 170 | 1,810 | 2,100 | 2,840 | 3,590 |
| High | | 170 | 340 | 625 | 1,370 | 2,120 |
| Median | 70 | 170 | 340 | 630 | 1,050 | 1,460 |
| Low | | 141 | 312 | 370 | 460 | 550 |
| Total | | | | | | |
| Extra high | | 2,890 | 6,200 | 8,730 | 12,270 | 17,510 |
| High | | 2,890 | 4,730 | 7,255 | 10,800 | 16,040 |
| Median | 1,860 | 2,670 | 3,870 | 5,510 | 7,620 | 10,420 |
| Low | | 2,441 | 3,152 | 3,960 | 5,020 | 6,320 |

TABLE 3-4
Sheet 2 of 2

LOAD FORECAST FOR UPPER SUSITNA PROJECT
BY
ALASKA POWER ADMINISTRATION

| | <u>1977</u> | <u>1980</u> | <u>1985</u> | <u>1990</u> | <u>1995</u> | <u>2000</u> |
|---|-------------|-------------|-------------|-------------|-------------|-------------|
| 2. <u>FAIRBANKS-TANANA VALLEY AREA POWER DEMAND AND ENERGY REQUIREMENTS</u> (Excluding National Defense) | | | | | | |
| <u>Peak Demand (MW)</u> | | | | | | |
| Utility Loads | | | | | | |
| High | | 158 | 244 | 358 | 495 | 685 |
| Median | 119 | 150 | 211 | 281 | 358 | 452 |
| Low | | 142 | 180 | 219 | 258 | 297 |
| <u>Annual Energy (GWh)</u> | | | | | | |
| Utility Loads | | | | | | |
| High | | 690 | 1,070 | 1,570 | 2,170 | 3,000 |
| Median | 483 | 655 | 925 | 1,230 | 1,570 | 1,980 |
| Low | | 620 | 790 | 960 | 1,130 | 1,300 |
| 3. <u>COMBINED ANCHORAGE-COOK INLET AND FAIRBANKS-TANANA VALLEY AREAS</u> | | | | | | |
| <u>Peak Demand (MW)</u> | | | | | | |
| Extra high | | 810 | 1,588 | 2,272 | 3,186 | 4,548 |
| High | | 810 | 1,308 | 1,992 | 2,906 | 4,268 |
| Median | 568 | 752 | 1,085 | 1,515 | 2,057 | 2,775 |
| Low | | 694 | 889 | 1,109 | 1,385 | 1,721 |
| <u>Annual Energy (GWh)</u> | | | | | | |
| Extra high | | 3,580 | 7,270 | 10,300 | 14,440 | 20,510 |
| High | | 3,580 | 5,800 | 8,825 | 12,970 | 19,040 |
| Median | 2,343 | 3,325 | 4,795 | 6,740 | 9,190 | 12,400 |
| Low | | 3,061 | 3,942 | 4,920 | 6,150 | 7,620 |

TABLE 3 - 5

LOAD DEMAND FORECASTS FOR RAILBELT AREA
TO
DETERMINE STATISTICAL AVERAGE FORECAST

| Year | Anchorage - Cook Inlet | | | Fairbanks - Tanana Valley | | | Combined Load Areas | | |
|------|---|---|--|---|---|--|---|---|--|
| | Combined Utilities Forecast (MW) | Alaska Power Administration Median Forecast (MW) | Statistical Average Forecast (MW) | Combined Utilities Forecast (MW) | Alaska Power Administration Median Forecast (MW) | Statistical Average Forecast (MW) | Combined Utilities Forecast (MW) | Alaska Power Administration Median Forecast (MW) | Statistical Average Forecast (MW) |
| 1979 | 475 | 546 | 511 | 142 | 139 | 141 | 605 | 685 | 645 |
| 1980 | 544 | 602 | 573 | 156 | 150 | 153 | 686 | 752 | 719 |
| 1981 | 627 | 648 | 638 | 171 | 161 | 166 | 782 | 809 | 796 |
| 1982 | 722 | 698 | 710 | 188 | 172 | 180 | 892 | 870 | 881 |
| 1983 | 826 | 752 | 789 | 207 | 184 | 196 | 1012 | 936 | 974 |
| 1984 | 944 | 810 | 877 | 227 | 197 | 212 | 1148 | 1007 | 1078 |
| 1985 | 1079 | 874 | 977 | 250 | 211 | 231 | 1302 | 1085 | 1194 |
| 1986 | 1223 | 937 | 1080 | 275 | 223 | 249 | 1468 | 1160 | 1314 |
| 1987 | 1387 | 1004 | 1196 | 302 | 237 | 270 | 1655 | 1241 | 1448 |
| 1988 | 1548 | 1077 | 1313 | 330 | 251 | 291 | 1840 | 1328 | 1584 |
| 1989 | 1728 | 1154 | 1441 | 360 | 265 | 313 | 2046 | 1419 | 1733 |
| 1990 | 1928 | 1234 | 1581 | 394 | 281 | 338 | 2276 | 1515 | 1896 |
| 1991 | 2133 | 1315 | 1724 | 429 | 295 | 362 | 2511 | 1610 | 2061 |
| 1992 | 2360 | 1402 | 1881 | 469 | 310 | 390 | 2772 | 1712 | 2242 |
| 1993 | 2587 | 1495 | 2041 | 507 | 325 | 416 | 3032 | 1820 | 2426 |
| 1994 | 2834 | 1593 | 2215 | 550 | 342 | 446 | 3318 | 1935 | 2627 |
| 1995 | 3105 | 1699 | 2402 | 596 | 358 | 477 | 3627 | 2057 | 2842 |
| 1996 | 3372 | 1809 | 2591 | 646 | 375 | 511 | 3938 | 2184 | 3061 |
| 1997 | 3663 | 1925 | 2794 | 700 | 393 | 547 | 4276 | 2318 | 3297 |
| 1998 | 3947 | 2049 | 2998 | 753 | 412 | 583 | 4606 | 2461 | 3534 |
| 1999 | 4244 | 2182 | 3213 | 811 | 432 | 622 | 4954 | 2614 | 3794 |
| 2000 | 4569 | 2323 | 3446 | 873 | 452 | 663 | 5333 | 2755 | 4054 |

TABLE 3-6
PEAK LOAD DEMAND FORECASTS FOR RAILBELT AREA
WITH
RANGE LIMITS FOR SENSITIVITY ANALYSIS

| Year | Anchorage - Cook Inlet | | | Fairbanks - Tanana Valley | | | Combined Load Areas | | |
|------|----------------------------------|---|---------------------------------|----------------------------------|---|---------------------------------|----------------------------------|---|---------------------------------|
| | Lower Range Limit* (MW) | Peak Load Demand Forecast** (MW) | Upper Range Limit (MW) | Lower Range Limit* (MW) | Peak Load Demand Forecast** (MW) | Upper Range Limit (MW) | Lower Range Limit* (MW) | Peak Load Demand Forecast** (MW) | Upper Range Limit (MW) |
| 1979 | 508 | 511 | 514 | 140 | 141 | 142 | 641 | 645 | 649 |
| 1980 | 570 | 573 | 576 | 151 | 153 | 155 | 744 | 749 | 754 |
| 1981 | 635 | 638 | 641 | 163 | 166 | 169 | 790 | 795 | 802 |
| 1982 | 702 | 710 | 718 | 175 | 180 | 185 | 874 | 881 | 888 |
| 1983 | 765 | 789 | 813 | 188 | 196 | 204 | 949 | 974 | 999 |
| 1984 | 832 | 877 | 922 | 202 | 212 | 222 | 1031 | 1078 | 1125 |
| 1985 | 908 | 977 | 1046 | 218 | 231 | 244 | 1121 | 1194 | 1267 |
| 1986 | 985 | 1020 | 1175 | 232 | 249 | 266 | 1212 | 1314 | 1416 |
| 1987 | 1068 | 1196 | 1324 | 248 | 270 | 292 | 1310 | 1448 | 1586 |
| 1988 | 1156 | 1313 | 1470 | 264 | 291 | 318 | 1413 | 1584 | 1755 |
| 1989 | 1250 | 1441 | 1632 | 281 | 313 | 345 | 1523 | 1733 | 1943 |
| 1990 | 1350 | 1581 | 1812 | 300 | 338 | 376 | 1642 | 1895 | 2150 |
| 1991 | 1451 | 1724 | 1997 | 317 | 362 | 407 | 1760 | 2051 | 2362 |
| 1992 | 1562 | 1881 | 2200 | 337 | 390 | 443 | 1888 | 2242 | 2596 |
| 1993 | 1677 | 2041 | 2405 | 355 | 416 | 477 | 2021 | 2426 | 2831 |
| 1994 | 1800 | 2215 | 2630 | 377 | 446 | 515 | 2167 | 2627 | 3087 |
| 1995 | 1933 | 2402 | 2871 | 398 | 477 | 556 | 2319 | 2842 | 3365 |
| 1996 | 2070 | 2591 | 3112 | 420 | 511 | 602 | 2476 | 3051 | 3646 |
| 1997 | 2215 | 2794 | 3373 | 444 | 547 | 650 | 2644 | 3297 | 3950 |
| 1998 | 2365 | 2998 | 3631 | 469 | 583 | 697 | 2820 | 3534 | 4248 |
| 1999 | 2526 | 3213 | 3900 | 495 | 622 | 749 | 3004 | 3724 | 4564 |
| 2000 | 2697 | 3446 | 4195 | 522 | 663 | 804 | 3203 | 4054 | 4905 |

* Low load forecast case in this study.

** Probable load forecast case in this study..




FIGURE 3-1




FIGURE 3-2




FIGURE 3-3




FIGURE 3-4




FIGURE 3-5





FIGURE 3-6

FIGURE 3-7






FIGURE 3-8

CHAPTER 4
SELECTION OF INTERTIE ROUTE

CHAPTER 4

SELECTION OF INTERTIE ROUTE

4.1 REVIEW OF EARLIER STUDIES

A number of studies have considered the electrical interconnection of the Fairbanks, South Central, and Anchorage areas (Refs. 1-8). The Susitna Hydroelectric Project Interim Feasibility Report (Ref. 2), hereafter called Susitna Report, reviewed a number of alternative transmission corridors in considerable depth. None of the studies included a specific route for a transmission line. The Susitna Report provides an excellent inventory of topography, geology, soils, vegetation, wildlife, climate, existing development, land ownership status, existing rights-of-way, and scenic quality and recreation values by corridor segments of about 5-mile widths.

4.2 SURVEY OF ALTERNATIVE CORRIDORS

Alternative corridors reviewed for this report were those along or near the Railbelt region between the Anchorage and Fairbanks areas. A reconnaissance (by USGS Quad's and local knowledge) of routes connecting the Railbelt area to Glennallen was also made to provide a basis for estimating the cost of such a connection at a later date.

4.3 PREFERRED ROUTE FOR TRANSMISSION INTERTIE

The preferred corridor described in the Susitna Report was further defined by making an actual preliminary layout of a definitive route (with some alternatives) using engineering techniques. This preliminary routing provides a basis for refining cost estimates, displaying a definitive location for use in studying potential environmental impacts, and providing a specific engineering recommendation for use in right-of-way negotiations.

The preliminary line routing is shown on the accompanying maps, Figures 4-1, 4-2, and 4-3, these being spatially related to the key map on the inside of the front cover of this report. These routes come from a working strip map of 1" = 1 mile (USGS Quad's.) on which these preliminary routes are drawn. The route was plotted by an engineer with nearly 30 years of experience with Alaskan transmission systems. It was also visually inspected throughout much of its length over the Parks Highway from Anchorage to Fairbanks.

The definitive line route was established within the preferred corridor, with due regard to the following restraints, insofar as they could be identified in this preliminary review:

- Avoidance of highway rights-of-way, which are better locations for distribution lines that will be required to serve homes and enterprises served by the highway.
- Avoidance of telephone lines, because of electrical interference problems. (An open-wire telephone circuit exists on the entire length of the Alaska Railroad right-of-way.)
- Avoidance of aircraft landing and takeoff corridors, including all lakes of sufficient size to accommodate small floatplanes. Where lines may cross landing patterns, at least 1/2 mile is allowed from the end of runways or lakes, so that special designs are not required.
- Avoidance of highly subdivided land areas and dwellings.
- Avoidance of crossings over developed agricultural lands.
- Selection of routings that provide for minimum visibility from highways and homes.

- Avoidance of heavily timbered lands.
- Selection of routes that provide for minimum changes in grade as the terrain will allow.
- Parallel alignments with property lines are favored, if not precluded by other considerations.
- Avoidance of sensitive wildlife areas, if practicable, and cooperation in regard to construction and operating restraints where lines pass through such areas.
- Alignments located in reasonable proximity to transportation corridors (roads, railroads, navigable waterways) so that construction, operation, and maintenance routines are not inordinately difficult.

4.4 FIELD INVESTIGATIONS

Principal engineers of the IECO-RWRA team made field trips by helicopter and surface transportation to important sites and typical structures of existing transmission lines in both the Anchorage and Fairbanks areas. Particular attention was given to lines using designs developed especially for Alaskan conditions of muskeg swamp, permafrost, and flood plain. These designs have had more than ten years of successful service, and are the basis for more recent tubular steel structure designs now being installed on Alaska projects.

Actual field records of Resident Engineers and Inspectors on Alaska transmission line construction projects were analyzed along with contractor bids for these projects to provide authoritative basic data on the actual man-hours, materials use, and dollar costs of completed transmission lines.

4.5 PRELIMINARY ENVIRONMENTAL ASSESSMENT

A. Description of the Environment

1. Point MacKenzie to Talkeetna - The corridor travels north along the east flank of the Susitna River Valley, an extremely wide and poorly drained plain. Heavy forests of bottomland spruce and poplar, interspersed with muskeg and black spruce, are typical. The soils vary from deep, very poorly drained peat to well-drained gravels and loams, with the well-drained soils being more abundant. Although permafrost is almost absent in this lower part of the Susitna Valley, the poorly drained areas are subject to freezing and heaving in the winter.

A sizeable concentration of moose inhabits the lower Susitna River Valley. This valley also supports black and brown bear and a moderate density of water fowl.

The proposed transmission line route generally follows a "tractor trail" (USGS designation) to three miles northeast of Middle Lake. Here, at the approach to the Nancy Lake area, an alternate route (A) may be used to avoid this area. The proposed route (B) is located in marshes and wetlands, between Papoose Twins and Finger Lakes, across the Little Susitna River. The corridor then travels northward along the east side of Lynx Lake, Rainbow Lake, and Long Lake where it crosses the Willow River. Here alternate routes (A) and (B) rejoin and intersect an existing 115-kV MEA transmission corridor at the Little Willow Junction and a proposed corridor to Anchorage on the east side of Knik Arm. Travelling north, the corridor crosses several major tributaries of the Susitna River including Sheep Creek and the Kashwitna River. In this area the terrain becomes more rolling, and the relative proportion of well-drained soils supporting thick poplar-spruce forests is considerably greater than to the south. The corridor then travels some five miles east of Talkeetna to the Bartlett Hills P.I. (point of intersection).

2. Talkeetna to Gold Creek - From Bartlett Hills P.I. the corridor crosses the Talkeetna River near the confluence of the Talkeetna and Chulitna Rivers, where it follows the west bank of the Chulitna River at a mean elevation of 600 feet. Where the Chulitna River curves eastward, the corridor travels northward, along the Susitna River Valley, through forested uplands, gradually rising to an elevation of 1000 feet. The uplands above the valley support sparser forests, and increasing amounts of permafrost soils are encountered. At the 1000-foot elevation, one to three miles east of the Susitna River, the corridor crosses Lane Creek, MacKenzie Creek, Portage Creek, Deadhorse Creek, and numerous other small tributaries of the Susitna River. It then crosses Gold Creek and the Susitna River, 1-1/2 miles east of A.R.R. Mile 265, to the Susitna Junction, one mile east of A.R.R. Mile 266. At the Susitna Junction, the proposed Devil Canyon-Watana-Glennallen line meets the corridor.

3. Gold Creek to Glennallen - The corridor parallels the Susitna River to the proposed Devil Canyon damsite and then travels east to the proposed Watana damsite. The vegetation in the canyons varies from upland spruce-hardwood to alpine tundra. Soils vary from poorly drained river bottoms to unstable talus. Permafrost occurs in this portion of the corridor. Some localized moose populations are crossed. The corridor passes through low lake areas west of Lake Louise until it intersects the Richardson Highway at Tazlina. From Tazlina the route follows the Richardson Highway into Glennallen.

4. Gold Creek to Cantwell - The transmission corridor travels north some 1 to 3 miles east of the Alaska Railroad between elevation 1500 and 2000 feet. The timber density becomes successively less in this area. This portion of the corridor is a good bear and moose habitat. Shallow permafrost occurs in this portion. The corridor crosses several major and minor tributaries to the Chulitna River including Honolulu Creek, Antimony Creek, Hardage Creek, the East Fork of the Chulitna River, and the Middle Fork of the Chulitna River. The corridor area is of medium scenic quality and is not readily accessible, except at the Denali Highway Crossing.

5. Cantwell to Healy - The corridor rises to the 3200 foot level along the west side of Reindeer Hills and then descends into the Nenana River Valley. It follows the east flank of the Nenana River northward at the 2200 foot level, through sparsely timbered country. This is an area of high scenic quality especially in the canyons. The terrain varies from rolling hills and valleys to high passes and sharp ridges. Habitats of moose, bear, and Dall sheep are traversed. Bedrock is exposed in the canyons. The corridor crosses several tributaries to the Nenana River including Slime Creek, Carlo Creek, Yanert Fork, and Montana Creek, and the Nenana River itself. It also crosses the Alaska Railroad at the Moody Tunnel, near A.R.R. Mile 354 and the Healy River. The boundary of Mt. McKinley National Park is on the west flank of the Nenana River.

6. Healy to Ester - The corridor leaves Healy and crosses the Parks Highway near Dry Creek. It then roughly parallels the west side of the highway at elevation 1500 feet, crossing several tributaries to the Nenana River. It crosses the GVEA line 1-1/2 miles north of Bear Creek, the Alaska Railroad and the Nenana River at A.R.R. Mile 383, and the Parks Highway. The route then parallels the GVEA line. The corridor crosses the Tanana River at the Tanana P.I. and follows the Tanana River flood plain for several miles until the route again crosses the highway where it travels on the west side of the Bonanza Creek Experimental Forest. The route parallels the GVEA right-of-way the rest of the way to Ester. The Healy to Ester portion of the route passes through some private lands (mining claims, homesteads, etc.), as well as near the towns of Healy, Lignite, and Nenana. An archeological site exists near Dry Creek. Portions of the corridor are heavily forested and provide habitat for moose, caribou, and bear. Poorly drained areas in this corridor are subject to potential permafrost degradation and frost heaving.

B. Environmental Impacts

Construction and maintenance of other Alaskan transmission systems has shown that most negative environmental impacts caused by a transmission system can be minimized. Golden Valley Electric Association, Matanuska Electric Association, and Chugach Electric Association have constructed and are operating several lines on poor soils and under harsh climatic conditions. Except for anticipated slight visual impacts, most environmental impacts caused by a transmission system would be far less than those of many transportation and communication systems. Specific areas to be impacted are discussed below.

1. Ecosystems - The major positive impact will be on human environment, while adverse effects to the other ecosystems will be minimal. The route has been selected to avoid adverse impacts on these ecosystems wherever possible. The human environment will be benefited by the provision of energy, vital to the growing state of Alaska. The development of many potential renewable energy resources will be made feasible by the Anchorage-Fairbanks intertie. The project will contribute to the reduction in costs of electrical energy, improvement in reliability of electrical service, and enhancement of opportunities for renewable energy resources (such as hydro and wind) to displace non-renewable energy resources (such as gas and oil) for the generation of electricity.

Alteration of vegetation patterns will affect wildlife. This corridor traverses many areas of moose concentrations, and moose should benefit from the introduction of brush resulting from regrowth on the clearing. Since the clearing must be maintained, this brush area will last for the lifetime of the project. Animals such as squirrels will suffer loss and displacement. However, their faster reproductive rates will allow their populations to adjust rapidly.

Construction itself will affect wildlife. Larger mammals may temporarily leave the area to return after the construction activity. Smaller animals will suffer individual losses, but should recuperate rapidly once construction is completed. The density of forest in portions of the corridor will allow animals to move only a short distance to avoid contact with construction activities.

Vegetation suppression, by whatever method, will periodically remove cover from along the right-of-way. However, due to the surrounding cover of the uncleared forests, this impact will be insignificant.

2. Recreation - The corridor will approach several recreational and wayside areas in the lower Susitna Valley. The largest of these is the Nancy Lake Recreational Area. The corridor will also approach the Denali State Park, but will be separated from the Park by the Susitna River.

This corridor will provide access to areas previously difficult to reach. The largest such area is that south of Nancy Lake to Point MacKenzie. Dense forest and muskeg limit travel.

Further north the corridor parallels the east border of Mt. McKinley National Park, being separated by the Parks Highway, the Nenana River, and the Alaska Railroad.

3. Cultural Resources - The National Register of Historical and Archaeological Sites lists the following sites which will be approached by the transmission corridor: Knik Village, Dry Creek, and the Tangle Lake Archaeological District. The line will be routed to bypass these areas.

During construction and preconstruction surveys, other archaeological sites may be discovered which may be eligible for nomination to the National Register. This is a positive benefit of the corridor, as archaeological and other cultural resources are often difficult to find in the great Alaska wilderness.

4. Scenic Resources - The southern portion of the corridor does not traverse any areas of good or high quality scenic values. The northern portion is, however, more scenic than the southern portion. In the northern portion the fairly continuous, moderately dense forest will provide ample screening from transportation routes. Further south, the forests are more intermingled with open muskeg. Glimpses of the transmission line will be seen from the highway or railroad through these muskeg areas. South of Nancy Lake the transmission corridor and the transportation corridors diverge, and although cover becomes more sporadic, the line will no longer be visible from the transportation routes. The transmission line will not be visible from most of the Nancy Lake Recreation Area.

As the Alaska Railroad and the transmission corridor approach Gold Creek, the valley becomes more confined, and screening becomes more difficult. However, it appears that the line can be concealed through most of this portion.

The corridor passes through an area recognized as being of good to high scenic quality from Devil Canyon to Healy. The possibility of screening throughout this area varies from moderate in the southern portion around Chulitna, to minimal in the Broad Pass and the upper and lower canyons of the Nenana River. Scenic quality will be impacted, the impact being a function of existing scenic quality and the opportunity for screening. The proposed line design will incorporate weathering tubular steel towers which blend well into the environment. Non-specular conductors might be used where light reflection from the line would cause unacceptable adverse visual impact. Impact in the Nenana Canyon will be high; impact on Broad Pass will be moderate to high; impact elsewhere will be moderate. Two favorable factors mitigate the impact somewhat: 1) the corridor is not visually intact as the Alaska Railroad and the Anchorage-Fairbanks Highway have already reduced scenic quality somewhat; and 2) the major views south of the canyons are to the west, toward the Mt. McKinley massif, whereas the transmission line corridor lies to the east of the transportation routes.

5. Social - Some economic impact can be expected, as flying services, motels, restaurants, and entertainment facilities receive business, not only from the transmission line workers, but from related personnel. Due to the high cost of a low-load tap on a high voltage line, the likelihood of use of the energy by small communities along the corridor is remote. However, in places where the demand could justify such a tap, it would provide a reliable source of electrical energy for growing communities.

C. Special Impact Mitigation Efforts During Construction

Right-of-way clearing will be accomplished by approved methods such as the hydro axe, and chips will be spread along the right-of-way. The line will be screened wherever possible. The towers will be designed to blend into the environment, thereby reducing visual impact.

Movement of men and equipment during construction will be scheduled to avoid excessive damage to the ground cover. This is generally accomplished by winter construction. The tower design will allow movement of men and equipment along the right-of-way centerline, thereby eliminating the need for an access road in addition to the transmission line clearing.

Major river crossings will be required over the Talkeetna River, Tanana River, Healy Creek, and the Susitna River. Minor stream crossings may be made either by fording or ice crossings. Special efforts will be made to avoid siltation of fish streams. Oil will be carefully handled to avoid spillage. Where larger quantities of oil are to be stockpiled, dikes will be constructed to protect against spills.


Since most of the construction will occur far from communities, noise is not anticipated to be a problem. Suitable muffling devices will be used to protect men and wildlife from excessive noise.

Prior to and during construction, special efforts will be made to consult with State historical and archaeological authorities, the Soil Conservation Service, the Bureau of Land Management, the Alaska Department of Fish and Game, and the U.S. Forest and Wildlife Service, and any other agencies having jurisdiction over the construction area, in an effort to ensure sound environmental practices.

4.6 REFERENCES

1. Robert W. Retherford Associates, North Slope Natural Gas Transport Systems and Their Potential Impact on Electric Power Supply and Uses in Alaska, March 1977.
2. U.S. Army Corps of Engineers, Southcentral Railbelt Area, Alaska, Upper Susitna River Basin Interim Feasibility Report, (Appendix I, Part II (G) Marketability Analysis, (H) Transmission System, (I) Environmental Assessment for Transmission Systems, December 1975.
3. Kozak, Edwin, under the direction of J. R. Eaton, Performance Characteristics of a 350-Mile Electric Power Transmission Line (Fairbanks to Anchorage), A project in EE 494, Department of Electrical Engineering, University of Alaska, June 1973.
4. Ch2M-Hill, Electric Generation and Transmission Intertie System for Interior and Southcentral Alaska, 1972.
5. Federal Power Commission, Alaska Power Survey, 1969.
6. Alaska Power Administration, Alaska Railbelt Transmission System, working paper, December 1967.
7. The Ralph M. Parsons Company, Central Alaska Power Study, undated.
8. The Ralph M. Parsons Company, Alaska Power Feasibility Study, 1962.





INTERNATIONAL ENGINEERING COMPANY, INC.
A MORRISON - KNUDSEN COMPANY



ROBERT W. RETHERFORD ASSOCIATES
CONSULTING ENGINEERS
A DIVISION OF ARKANSAS GLASS CONTAINER CORP.





FIGURE 4-2




INTERNATIONAL ENGINEERING COMPANY, INC.
A MORRISON-KNUDSEN COMPANY



ROBERT W. RETHERFORD ASSOCIATES
CONSULTING ENGINEERS
A DIVISION OF ARKANSAS GLASS CONTAINER CORP.

ANCHORAGE-MATANUSKA-SUSITNA-GLENALLEN-VALDEZ TRANSMISSION SYSTEM



The map displays the Hinchinbrook Island area in the Northwest Territories, Canada. It shows Prince William Sound to the north, Hinchinbrook Island to the east, and the Montague Strait to the south. The map includes a legend for transmission lines and submarine cables, and a scale of 1:1,000,000.

LEGEND

- EXISTING TRANSMISSION LINES
- INTERTIE ROUTE
- ALTERNATE INTERTIE ROUTE
- NEW LINE SCHEDULED FOR CONSTRUCTION
- FUTURE LINE
- SUBMARINE CABLES
- UTILITY SERVICE AREA

SCALE 1:1,000,000 / ELEVATION IN METERS



A MORRISON - KNUDSEN COMPANY



A DIVISION OF ARKANSAS GLASS CONTAINER CORP.

COOK INLET – KENAI PENINSULA TRANSMISSION SYSTEM

CHAPTER 5
TRANSMISSION LINE DESIGN

CHAPTER 5

TRANSMISSION LINE DESIGN

5.1 BASIC DESIGN REQUIREMENTS

Experience in Alaska with both wood-pole H-frame, aluminum lattice guyed-X towers, and tubular steel guyed-X towers with high-strength conductors (such as Drake 795 kcmil ACSR) has demonstrated the excellent performance of lines designed with relatively long spans and flexible structures. This general philosophy has been followed in establishing the input parameters for the Transmission Line Cost Analysis Program (TLCAP) used to optimize line designs for the Anchorage-Fairbanks Intertie study. Sample outputs of TLCAP and descriptions of the program methodology are found in Appendix B.

The results of this computer analysis for 230-kV lines favor relatively long spans (1300 ft) and high-strength conductors (such as Cardinal 954 kcmil ACSR). This confirms the previous Alaskan experience and contributes substantially to a more economical design, as Chapter 7 will illustrate.

5.2 SELECTION OF TOWER TYPE USED IN THE STUDY

Due to rather unique soil conditions in Alaska, with extensive regions of muskeg and permafrost, conventional self-supporting or rigid towers will not provide a satisfactory performance or solution for the proposed intertie. Permafrost and seasonal changes in the soil are known to cause large earth movements at some locations, requiring towers with a high degree of flexibility and capability for handling relatively large foundation movements without appreciable loss of structural integrity.

The guyed tower is exceptionally well suited for these type of conditions. Therefore, the final choice of tower for this study was the hinged-guyed X-type design, which has been considered for both the 230-kV and 345-kV

alternatives. These towers are essentially identical in design to towers presently used on some lines in Alaska, which have proven themselves during more than ten years of service. The design features include hinged connections between the leg members and the foundations which, together with the longitudinal guy system, provides for large flexibility combined with excellent stability in the direction of the line. Transverse stability is provided by the wide leg base which also accounts for relatively small and manageable footing reactions.

The foundations are pile-type, consisting of heavy H-pile beams driven to an expected depth of 20 to 30 feet depending upon the soil conditions.

Tower outlines with general dimensions for the two voltage levels are shown on Figures 5-1 and 5-2.

5.3 DESIGN LOADING ASSUMPTIONS

According to available information and experience on existing lines, heavy icing is not a serious problem in most parts of Alaska. NESC Heavy Loading is presently used for all line designs throughout the Rail-belt region. However, there are locations where Light Loading probably could be used. Some line failures have occurred due to exceptionally heavy wind combined with very little or no ice. Such locations should be identified and carefully investigated prior to the final line design.

In this study, NESC Heavy Loading or heavy wind on bare conductor (corresponding to NESC Light Loading) was used, whichever is more severe.

5.4 TOWER WEIGHT ESTIMATION

In order to arrive at realistic tower weights and material costs for the study, actual tower designs for both the 230-kV and the 345-kV

alternatives were obtained from Meyer Industries of Red Wing, Minnesota (Ref. 1). This company has designed similar towers for other lines in Alaska.

Based on these reference designs and additional manual calculations, tower weight formulas were developed to account for variations in tower weight due to changes in tower height and load as a function of the type of conductor used.

5.5 CONDUCTOR SELECTION

Conductor size (see Table 5-1) was selected by the use of the Transmission Line Cost Analysis Program (TLCAP) which was specially developed by IECO for this type of study. Given an appropriate range of conductor types and sizes, span lengths, and other pertinent data, TLCAP determines the most economical conductor-span combination.

The program includes a sag-tension routine which calculates the conductor sag and tension for a given set of criteria. Using this information, the tower height and loads are then determined for each discrete span length. These values are then applied to the tower weight formula with the pertinent overload factors included.

In the process of this analysis, the program also evaluated the effect of the cost of the power losses over a specified number of years. The power losses were minimized by varying the sending and receiving end voltages by $\pm 10\%$ and by providing required shunt compensation at both line terminals. Applicable material and labor costs, together with projected escalation rates, were included to enable the program to calculate the total installed cost of the line. A discount rate of 7% per annum was used for the determination of the present worth of transmission line losses.

For this particular study, material and labor costs were obtained from "as built" cost information realized on recently completed (138-kV and 230-kV) lines in Alaska.

5.6 POWER TRANSFER CAPABILITIES

Preliminary transmission line capabilities, based on surge impedance loading (SIL) criteria, were obtained from the National Power Survey Report (Ref. 2). Additional investigations indicate that for the 230-kV alternatives (Cases IA, IB, and ID), the calculated intertie power angle is near 30 degrees. To improve the 230-kV intertie's steady state and transient transmission capability, series capacitors will be necessary. Interconnected power system studies should be performed to determine the final series and shunt compensation requirements. Such studies are outside the scope of this work.

5.7 HVDC TRANSMISSION SYSTEM

Because of its asynchronous nature, the interconnection of two isolated alternating current (ac) systems by a point-to-point HVDC transmission link provides the desired power exchange without being prone to inherent stability problems. Furthermore, HVDC transmission can provide stabilizing power, and be very effective in damping system oscillations. While the state-of-the-art in HVDC technology is advancing, the resulting developments are keeping pace with inflation.

Preliminary investigations have shown that HVDC transmission, using 180-kV mono-polar transmission and ground return, is competitive with single-circuit 230-kV ac transmission in the transfer 130 MW of power over 323 miles. However, if the point-to-point transmission link is required to supply intermediate locations with power (either initially or in the future) then it is unlikely that dc transmission can be competitive with an ac alternative.

5.8 REFERENCES

1. Letter from ITT Meyer Industries to Robert W. Retherford Associates, Anchorage, Alaska, January 15, 1979.
2. FPC Advisory Committee Report No. 6, National Power Survey, Vol. II, p. IV2-12, 1964.

TABLE 5-1

CONDUCTOR SIZE SELECTION CRITERIA

| <u>Case and Alternative^{1/}</u> | <u>Interconnection</u> | <u>Voltage (kV + 10%)</u> | <u>Line Length (miles)</u> | <u>Optimum ACSR Conductor (kcmil)</u> | <u>Load^{2/} Per Circuit (MW)</u> |
|--|---------------------------------|-------------------------------|--------------------------------|---|---|
| I A & B | Anchorage-Ester | 230 s/c | 323 | 1/c - 954 | 130 |
| I C | Anchorage-Ester | 345 s/c | 323 | 2/c - 795 | 380 |
| I D | Anchorage-Palmer Healy-Ester | 230 s/c | 323 | 2/c - 954 | 130 |
| II A | Anchorage-Devil Canyon | 345 s/c ^{3/} | 155 | 2/c - 954 | 600 |
| | Devil Canyon-Ester | 230 s/c ^{3/} | 189 | 1/c - 1510 | 185 |
| | Watana-Devil Canyon | 230 s/c ^{3/} | 27 | 1/c - 2156 | 488 |


^{1/} Case I Alternatives exclude the proposed Susitna Project; Case II Alternative A includes the Susitna Project.

^{2/} 100% voltage support at both ends.

^{3/} Two single-circuit lines on the same right-of-way.


Note: s/c = single circuit; 1/c = single conductor; 2/c = two conductor bundle.

FIGURE 5-1



230KV TANGENT TOWER

FIGURE 5-2



345KV TANGENT TOWER

CHAPTER 6
SYSTEM EXPANSION PLANS

CHAPTER 6 SYSTEM EXPANSION PLANS

One benefit of transmission interconnection between two independent power systems is the reduction in the installed generating capacity that is possible, while maintaining the same electric power supply (generation) reliability level for both the independent and interconnected power systems. To calculate this reduction in installed generating plant capacity (megawatts), generation expansion plans had to be developed for both the independent and the interconnected power systems.

This chapter describes the actual process used in the generation expansion planning for the independent power systems of the Anchorage and Fairbanks areas, and for an interconnected Anchorage - Fairbanks power system. Generation expansion planning is a rather complex process. A brief description of the somewhat simplified method used in this Economic Feasibility Study is described below.

6.1 GENERATION PLANNING CRITERIA

A. Generating Unit Data

Existing generating unit data were obtained from the Battelle (Ref. 1) and University of Alaska, August 1976 (Ref. 2) reports. These available data were reviewed and updated using new information obtained by IECO-RWRA engineers during interviews with the managers of the Railbelt utilities. The updated existing generation unit data is presented in Tables 6-1 and 6-2.

Preliminary information on near future (1979-1986) generation expansion planning, including probable generation capacity requirements, for the AML&P and CEA systems was obtained directly from the two utilities. More

detailed information on GVEA generation expansion plans was available in the review copy of the report Power Supply Study - 1978 (Ref. 3) and the Report on FMUS/GVEA Net Study (Ref. 4).

B. Installed Reserve Capacity

At the present time, there is apparently no uniform policy as to the required installed generation reserve margins for Alaskan electric power utilities. By definition, the installed generation reserve capacity includes spinning reserve, "hot" and "cold" standby reserves, and generating units on maintenance and overhaul work. No effort is made in this study to separate the installed reserve capacity into spinning and other types of reserves. Utilities in Alaska currently keep spinning reserves to the very minimum, mainly because of the no-load fuel cost incurred by the spinning reserves, and because most generating units in Alaska's Railbelt area are quick starting, combustion turbine-type units. This situation may change in the future when new larger, slow starting, thermal power plants are constructed, exceptions being hydro plant units which can be started rather rapidly.

To develop alternative generation expansion plans for this study, guidelines for installed reserve generation capacity had to be established. A minimum of 20% reserve margin or the largest single unit at the time of peak system load was decided on as the installed generation reserve guideline. In general, the 20% value is close to the actual installed reserve margin of most U.S.A. utilities. Recently, the Department of Energy's Economic Regulatory Administration reported the following for the 1978 winter peak load of the lower 48 states:

"According to the forecast, total available power resources for the lower 48 states will total nearly 500,000 MW. Peak demand is anticipated at 380,000 MW, for a reserve of nearly 120,000 MW or 31.5 percent. The lowest reserve - the 21.1 percent - will occur for the southeastern Electric Reliability Council, the DOE said, with the Mid-Atlantic Council experiencing the highest reserve margin at 45.1 percent" (Ref. 5).

C. Unit Retirement

Except for the Knik Arm Power Plant (CEA), no other generating units were reported for retirement by the Railbelt utilities during the 1980-1992 period. Later, to include the effect of the proposed Susitna Hydroelectric Project and to obtain a better economic analysis, this study period was extended through 1997. An assumption was made that the generating units available from 1980-1992 will also be available from 1993 through 1997. Many of them, however, will serve as system standby reserve units.

D. Generation Expansion Planning

To program the economic feasibility study and to establish transmission line interconnection benefits, generation expansion plans for the 1980-1997 period were developed for:

- Independent Anchorage area system.
- Independent Fairbanks area system.
- Interconnected Anchorage-Fairbanks system (intertie for reserve sharing only).
- Interconnected Anchorage-Fairbanks system (intertie for reserve sharing and power transfer).
- Interconnected Anchorage-Fairbanks system (with Susitna Hydroelectric Project).

Basically, generation planning includes three aspects: forecasting future loads (previously described in Chapter 3); developing generation reserve and reliability criteria (discussed later in this chapter); and determining when, how much, and what type of generation capacity is needed (which is discussed below).

Generation timing and capacity were determined by the most probable load forecasts for the Anchorage, Fairbanks, and combined Anchorage-Fairbanks areas, as described in Chapter 3.

Unit sizes for the alternative system expansion plans were determined by the ability of the power system to withstand the loss of a generating unit (or units) and still maintain reasonable system generation reliability. In determining unit sizes, due consideration was given to the valuable generation expansion planning data for the 1979-1986 period which was obtained by IECO-RWRA engineers from the Railbelt area utilities, and as the power system grows the economy of larger unit sizes.

IECO-RWRA engineers determined the type of generation mix for the expansion plans based on:

- Preliminary planning information obtained through interviews with Railbelt utilities.
- Information available in the Battelle Report and Alaska Power Administration's January 1979 report draft (Ref. 6).
- The judgment of IECO-RWRA power system planners.

Most of the planned generation additions are baseload-type thermal steam power plants burning coal, gas, or oil as fuel. They are mixed with a few additional peaking-type combustion turbine generating units using natural gas or oil as fuel. It is assumed that in the later years of this study many existing combustion turbine generating units, presently used as baseload or intermediate units, will become peaking or standby units.

6.2 MULTI-AREA RELIABILITY STUDY

A. Purpose

The PTI Multi-Area Reliability (MAREL) Computer Program is used for alternative generation expansion planning, mainly for its ability to maintain a nearly constant level of generation supply reliability in all cases. This approach provides a nearly equal reliability level as far as generation ability to meet the load is concerned. The MAREL program

gives reliability equivalence to both individual area and interconnected system generation planning alternatives. The MAREL program manual (Ref. 7) introduces this program with the following:

"The PTI Multi-Area Reliability Program MAREL determines the reliability of multi-area power systems. It has been written in FORTRAN IV for use on a PRIME 400 time-sharing computer. Reliability indices computed by the program include system loss of load probability (LOLP), LOLP values for the individual areas, probability of various failure conditions and probability that each transmission (intertie) link is limiting in the transfer of generation reserves from one area to another."

MAREL program results helped determine the effectiveness of a transmission line intertie between the Anchorage and Fairbanks areas, and established the amount of generating capacity needed to give the individual areas approximately the same LOLP as for the interconnected system. MAREL study results are also applicable to the alternative which includes the Upper Susitna Project. In this instance the study became a three area reliability study with the Susitna area having only net generation and no load.

B. Reliability Index

To perform individual and interconnected system reliability studies (MAREL), it was necessary to select a reference system generation reliability index. As described above, the MAREL program uses LOLP calculation techniques for each study case. For each load condition the program user adjusts input data, specifically generator unit sizes, generator types, location of generating plants, and intertie capacities, to obtain generation expansion plans of near equal reliability for various alternatives. The LOLP method is very much the adapted method used by U.S.A. utilities during the last 30 years. According to the IEEE/PES Working Group on

Performance Records for Optimizing System Design, Power System Engineering Committee (Ref. 8):

"This (LOLP reliability) index is defined as the long run average number of days in a period of time that load exceeds the available installed capacity. The index may be expressed in any time units for the period under consideration and, in general, can be considered as the expected number of days that the system experiences a generating capacity deficiency in the period. This index is commonly, but mistakenly, termed the "loss of load probability, (LOLP)". A year is generally used as the period of consideration. In this case, the LOLP index is the long-run number of days/year that the hourly integrated daily peak load exceeds the available installed capacity."

There is no standard value of LOLP which is used throughout the electric power industry. However, one day in ten years is a very much accepted value by the lower 48 utilities. Since to the authors' knowledge, LOLP index has not previously been used in Alaska, it was decided to use one day in ten years as reference LOLP index in this study. The use of this LOLP index may imply larger generation reserve margins than are presently used in Alaska, but an equal or even lower LOLP index is justifiable for Alaska for at least the following reasons:

- In very cold climatic zones the loss of electric power may be more critical than in more temperate climates.
- There is very little information on existing generation and transmission outage rates in Alaska. Therefore, there is more uncertainty about the study input data.
- At present, most of the power systems in Alaska are independently operated. In case of emergency, utilities cannot rely on help from neighboring utilities or power pools as can most of utilities

in the lower 48. Therefore, a lower LOLP reliability index is justifiable.

- Higher planned generation reserves may be needed to provide protection against possible unplanned delays in construction of new larger thermal units.

C. Program Methodology

A general description of the MAREL computer program methodology is contained in Appendix C. The particular program application to this study is "Planning of interconnections to achieve regional integration and more widespread sharing of generation reserves" (Ref. 7). Briefly, the program models each area as a one-bus system to which all generators and loads are connected. Transmission interties between areas are modeled as having limited power transfer capabilities and specified line outage rates. The method assumes that each area takes care of its own internal transmission needs.

D. Load Model

Annual load models were developed for the Anchorage and Fairbanks areas. Daily peak load data for 1975 were obtained from AML&P, CEA, FMUS, and GVEA. The Railbelt utility representatives agreed that 1975 was a typical year with normal weather conditions. The 1975 load models were converted into per unit system for the MAREL program. The computer program multiplied this 1975 load model (input) by the respective study year peak loads to obtain annual load models for each year of the study. Forecasted annual peak loads and the per unit annual load models for the Anchorage and Fairbanks areas are shown in Tables 6-3 through 6-6. Annual demand curves indicating biweekly non-coincident peaks are shown on Figure 6-1. Figure 6-1 also indicates that there is very little diversity between the loads of the Anchorage and Fairbanks areas.

E. Generating Unit Data

Information on existing generating unit data, as indicated in Tables 6-1 and 6-2, was used in the study. Unit base ratings were rounded off to the nearest megawatt in the study. Sizes for new generating units used in the expansion plans are indicated on Figures 6-2 through 6-8.

Generating unit outage rates, which are required for calculating LOLP indexes, were obtained from the most recent Edison Electric Institute (EEI) report on equipment availability (Ref. 9). The rates for combustion turbines were obtained from the actual operating experience of CEA and GVEA at the Beluga and Zehnder Power Plants. The EEI publication defines the forced outage rate as:

$$\text{Forced Outage Rate} = \text{FOH} / (\text{SH} + \text{FOH}) \times 100$$

Where FOH represents forced outage hours and SH represents service hours. Generating unit outage rates used in the MAREL study are indicated below:

| <u>Unit Designation</u> | <u>Forced Outage Rate (%)</u> |
|-----------------------------------|-----------------------------------|
| Combustion Turbine* | 5.5 |
| Hydroelectric Plant | 1.6 |
| Thermal Steam Plant (small units) | 5.9 |
| Thermal Steam Plant (100-200 MW) | 5.7 |
| Thermal Steam Plant (300 MW) | 7.9 |

* The Forced Outage Rate for combustion turbines was based on the following information:

- CEA experience at Beluga during 1977-1978 period, six units base loaded.

| | |
|-----------------------|-----------------|
| Unit availability | 87% of the time |
| Scheduled maintenance | 8% of the time |
| Forced outage | 5% of the time |

Therefore, the calculated Forced Outage Rate equals 5.4%.

- In 1975 GVEA experience at Zehnder Station, Units No. 1 and 2 provides calculated Forced Outage Rates of 4.2% and 4%, respectively; however, these units were basically standby units.

F. Generating Unit Maintenance

The MAREL program automatically schedules generating unit maintenance within the specified restrictions. For the purpose of this study, it was assumed that no unit maintenance will be scheduled during the November-March winter season.

G. Intertie Data

The MAREL program models the transmission intertie by limiting intertie transfer capabilities and considering intertie outage rates. No load loss sharing method was used. This means that one area will share its generating reserves only up to the limit of intertie transfer capability or available reserves in the other area, whichever is limiting. The forced outage rates (on a per year basis) used in the study for transmission and line terminal equipment are indicated below:

| <u>Line Voltage (kV)</u> | <u>Forced Outage Rate (per unit/100 miles)</u> |
|------------------------------|--|
| 230 | 0.00113 |
| 345 | 0.00225 |

Note: The following outage rate was used for both 230-kV and 345-kV line terminals: 36 hours/10 years.

6.3 SYSTEM EXPANSION PLANS

A. Planning Study Period

Based on generation planning criteria and the results of the MAREL reliability study (previously described in this chapter), alternative generation expansion plans were developed. The 1984-1997 period was selected for the alternative expansion plans for the following reasons:

- 1984 is the earliest year when the interconnected system can be operational.
- The 1992-1997 period includes the Upper Susitna Hydroelectric Project, based on the optimistic assumption that Watana Unit No. 1 will be on-line in January 1992.
- The study period is long enough for the present worth economic analysis method, and includes most of the costs and benefits obtainable by the introduction of an intertie in 1984.

To close the gap between the existing generation systems and the first study year (1984) of the intertie economic feasibility study, generation expansion plans for the independent Anchorage and Fairbanks areas for 1980 through 1983 were developed. Information on planned generation additions supplied by the generating utilities in the Railbelt area was used for this purpose.

B. Independent System Expansion Plans

Generation expansion plans for the independent Anchorage and Fairbanks systems were also needed to calculate economic benefits of the interconnection. The planned generation additions consist of thermal base load and peaking units. They do not include the Upper Susitna Project (Watana and Devil Canyon Hydro Plants), which are only included in the

interconnected system expansion plans. The independent Anchorage and Fairbanks generation expansion plans are indicated on Figure 6-2 for the probable load forecast case and Figure 6-6 for the low load forecast case.

C. Interconnected System Expansion Plans

Two cases of system interconnection were studied - Case I, direct interconnection between Anchorage and Fairbanks (Ester), and Case II, interconnection between Watana-Devil Canyon with Anchorage and Fairbanks systems. Under Case I the alternatives were developed as follows:

- Case IA includes a single-circuit 230-kV transmission line having 130-MW power transfer capability allocated for reserve sharing only. This plan is shown on Figures 6-3 and 6-9 for the probable load forecast case and on Figures 6-7 and 6-9 for the low load forecast case.
- Case IB includes one single-circuit 230-kV transmission line (1984-1991) and two single-circuit 230-kV transmission lines (1992-1997) having the following generation reserve sharing capabilities: 100 MW (1984-1987), 130 MW (1989-1991) and 190 MW (1992-1997). In addition, this alternative has a firm power transfer capability of 30 MW (1984-1987), supplying 14% of peak load in Fairbanks area in 1984, and 70 MW (1992-1997) supplying 18% of peak load in Fairbanks area in 1992. This plan is shown on Figures 6-4 and 6-9 for the probable load forecast case and on Figures 6-8 and 6-9 for the low load forecast case.
- Case IC includes one single-circuit 345-kV transmission line having a total of 380 MW power transfer capability allocated for generation reserve sharing and for firm power transfer. The case is similar to Case IB (230 kV) except that only one 345 kV line is required during the 1992-1997 period. This plan is shown on Figures 6-4 (similar) and 6-10.

- Case ID is the same as Case IA, except with intermediate switching stations at Palmer and Healy. This plan is shown on Figures 6-3 and 6-11 for the probable load forecast case and on Figures 6-7 and 6-11 for the low load forecast case.

Under Case II, only one solution was studied: two single-circuit 230-kV transmission lines from Watana to Devil Canyon; two single-circuit 230-kV lines from Devil Canyon to Ester (Fairbanks); and two single-circuit 345-kV lines from Devil Canyon to Anchorage.

D. Reliability Indexes

The results of the MAREL study show loss of load probability (LOLP) indexes for independent system expansion plans and plans for an interconnected system (with and without the Upper Susitna Project), and are indicated in Tables 6-7 through 6-12. As previously discussed in Subsection 6.2B, the LOLP index of one day in ten years (0.1 day/year) was used as a reference standard throughout the study for comparing different alternatives. During the performance of the MAREL study the LOLP index was kept as close to the standard as reasonably possible.

6.4 REFERENCES

1. Battelle Pacific Northwest Laboratories, Alaskan Electric Power, An Analysis of Future Requirements and Supply Alternatives for the Railbelt Region, Vol. I, March 1978.
2. University of Alaska, Institute for Social and Economic Research, Electric Power in Alaska, 1976 - 1995, August 1976.
3. Stanley Consultants, Power Supply Study - 1978 for Golden Valley Electric Association, Inc.
4. Alaska Resource Sciences Corporation, Report FMUS/GVEA Net Study, Vol. 1, May 1978.

5. Electric Light and Power, Capacity Can Meet Winter Peaks - DOE, November 1978.
6. Alaska Power Administration, Upper Susitna River Project, POWER MARKET ANALYSES, Draft, January 1979.
7. Power Technologies, Inc. PTI Multi-Area Reliability Program (MAREL), Computer Program Manual, September 1978.
8. "Reliability Indices for Use in Bulk Power Supply Adequacy Evaluation", IEEE Transactions on Power Apparatus and Systems, Vol. PAS-97, No. 4, July/August 1978.
9. Edison Electric Institute, Report on Equipment Availability for the Ten-Year Period 1967-1976, December 1977.

TABLE 6-1

EXISTING GENERATION SOURCES

ANCHORAGE - COOK INLET AREA

| Name/Location | Unit Reference | Year of Installation | Type | Unit Rating | | Dependable Capacity (kw) | Remarks |
|--|-----------------------|----------------------|--------|-------------|-----------|--------------------------|------------------------------|
| | | | | Base (kw) | Peak (kw) | | |
| <u>ANCHORAGE MUNICIPAL LIGHT AND POWER (AML&P)</u> | | | | | | | |
| Anchorage | | | Diesel | 2,200 | | | Black start unit |
| Anchorage | Unit 1 | | SCGT | 15,130 | 18,000 | | |
| Anchorage | Unit 2 | | SCGT | 15,130 | 18,000 | | |
| Anchorage | Unit 3 | 1968 | SCGT | 18,650 | 21,000 | | |
| Anchorage | Unit 4 | 1972 | SCGT | 31,700 | 35,000 | | |
| Anchorage | Unit 5 | 1975 | SCGT | 36,800 | 40,000 | } | Combined cycle installation |
| Anchorage | Unit 6 | 1979 | HRST | 12,000 | | | |
| <u>CHUGACH ELECTRIC ASSOCIATION (CEA)</u> | | | | | | | |
| Beluga | Unit 1 | | SCGT | 15,150 | 18,700 | | |
| Beluga | Unit 2 | | SCGT | 15,150 | 18,700 | | |
| Beluga | Unit 3 | | RCGT | 53,500 | 67,000 | | |
| Beluga | Unit 4 | | SCGT | 9,300 | 10,000 | | |
| Beluga | Unit 5 | | RCGT | 53,500 | 67,000 | | |
| Beluga | Unit 6 | | SCGT | 67,810 | 72,900 | | |
| Beluga | Unit 7 | 1978 | SCGT | 67,810 | 72,900 | | |
| Bernice Lake | Unit 1 | | SCGT | 8,200 | 16,500 | | |
| Bernice Lake | Unit 2 | | SCGT | 19,600 | 20,500 | | |
| Bernice Lake | Unit 3 | 1978 | SCGT | 24,000 | | | |
| International | Unit 1 | | SCGT | 14,530 | 16,500 | | |
| International | Unit 2 | | SCGT | 14,530 | 16,500 | | |
| International | Unit 3 | | SCGT | 18,600 | 21,500 | | |
| Cooper Lake | Unit 1 | | Hydro | 7,500 | 9,600 | | |
| Cooper Lake | Unit 2 | | Hydro | 7,500 | 9,600 | 16,500 | |
| Knik Arm | Several (1,2,3,4 & 5) | | ST | 14,500 | 17,700 | | To be retired in 1985 |
| <u>MATANUSKA ELECTRIC ASSOCIATION (MEA)</u> | | | | | | | |
| Talkeetna | | | Diesel | 600 | | | Standby |
| <u>HOMER ELECTRIC ASSOCIATION (HEA)</u> | | | | | | | |
| English Bay | | | Diesel | 100 | | | |
| Homer-Kenai | | | Diesel | 300 | | | |
| Homer (2 x 3500) | | | SCGT | 7,000 | | | Leased to CEA |
| Port Graham | | | Diesel | 200 | | | Leased from GVEA (1977-1979) |
| Seldovia | | | Diesel | 1,648 | | 1,500 | |
| <u>SEWARD ELECTRIC SYSTEM (SES)</u> | | | | | | | |
| Seward | Unit 1 | | Diesel | 1,500 | | } 5,500 | Standby |
| | Unit 2 | | Diesel | 1,500 | 1,500 | | |
| | Unit 3 | | Diesel | 2,500 | 3,000 | | |
| <u>ALASKA POWER ADMINISTRATION (APA)</u> | | | | | | | |
| Eklutna | Unit 1 & 2 | | Hydro | 30,000 | 35,000 | 30,000 | Two 15,000 kW units |

TABLE 6-2
EXISTING GENERATION SOURCES
FAIRBANKS - TANANA VALLEY AREA

| Name/Location | Unit Reference | Year of Installation | Type | Unit Rating | | Dependable Capacity (kW) | Remarks |
|--|----------------|----------------------|--------|-------------|-----------|--------------------------|------------------------------|
| | | | | Base (kW) | Peak (kW) | | |
| <u>FAIRBANKS MUNICIPAL UTILITIES SYSTEM (FMUS)</u> | | | | | | | |
| Fairbanks | Chena 1 | 1954 | ST | 5,000 | | | |
| Fairbanks | Chena 2 | 1952 | ST | 2,000 | | | |
| Fairbanks | Chena 3 | 1952 | ST | 1,500 | | | |
| Fairbanks | Chena 4 | 1963 | ST | 20,000 | | | |
| Fairbanks | Chena 5 | 1970 | SCGT | 5,350 | 7,000 | | |
| Fairbanks | Chena 6 | 1976 | SCGT | 23,500 | | | |
| Fairbanks | Diesel 1 | 1967 | Diesel | 2,665 | | | |
| Fairbanks | Diesel 2 | 1968 | Diesel | 2,665 | | | |
| Fairbanks | Diesel 3 | 1968 | Diesel | 2,665 | | | |
| <u>GOLDEN VALLEY ELECTRIC ASSOCIATION (GVEA)</u> | | | | | | | |
| Zehnder Sub. | Unit 1 | 1971 | SCGT | 17,553 | 20,000 | 17,400 | Peaking Service |
| Zehnder Sub. | Unit 2 | 1972 | SCGT | 17,553 | 20,000 | 17,400 | |
| Zehnder Sub. | Unit 3 | 1975 | SCGT | | | 3,500 | Leased to HEA (1977-1979) |
| Zehnder Sub. | Unit 4 | 1975 | SCGT | | | 3,500 | |
| Zehnder Sub. | Units 1-7 | 1970 | Diesel | | | 12,900 | |
| Healy | Unit-1 | 1967 | ST | | | 26,200 | |
| Healy | | | Diesel | 2,500 | | | |
| Northpole | Unit 1 | 1976 | SCGT | 64,800 | 70,000 | | |
| Northpole | Unit 2 | 1977 | SCGT | 64,800 | 70,000 | | |
| U. of Alaska | Units 7&8 | | Diesel | | | 5,100 | |
| Delta | | | Diesel | | | 500 | Mobile Unit |

TABLE 6-3

LOAD MODEL DATA
ANCHORAGE AREA
PROBABLE LOAD FORECAST CASE

ANNUAL PEAK LOAD IN MW
(1983 - 1997)

789. 877. 977. 1080. 1196. 1313. 1441. 1581. 1724. 1881.
2041. 2215. 2402. 2591. 2794.

INTERVAL PEAK LOADS IN P.U. OF ANNUAL PEAK LOAD
(26 INTERVALS / YEAR)

.8333 .6667 .7404 .7500 .6571 .6346 .6122 .5865 .5481 .5353 .5224 .5160 .5064
.4904 .5032 .4968 .5160 .5737 .5769 .6154 .6827 .8429 .8526 .9135 1.0000 .8301

DAILY PEAK LOADS IN P.U. OF INTERVAL PEAK LOAD
(260 WEEK DAYS / YEAR)

| | | | | | | | | | |
|--------|--------|-------|-------|-------|-------|-------|-------|-------|-------|
| 1.0000 | .9769 | .9731 | .9538 | .9500 | .9462 | .8962 | .8731 | .8577 | .8423 |
| 1.0000 | .9808 | .9663 | .9663 | .9615 | .9615 | .9519 | .9519 | .9423 | .9375 |
| 1.0000 | .9913 | .9784 | .9827 | .9697 | .9654 | .9437 | .9307 | .9221 | .8918 |
| 1.0000 | .9829 | .9487 | .9359 | .9017 | .8889 | .8889 | .8846 | .8333 | .8034 |
| 1.0000 | .9512 | .9317 | .9171 | .9171 | .9073 | .9073 | .9024 | .9024 | .8976 |
| 1.0000 | .9848 | .9798 | .9747 | .9646 | .9495 | .9444 | .9343 | .9293 | .9141 |
| 1.0000 | .9686 | .9634 | .9529 | .9529 | .9476 | .9424 | .9372 | .9058 | .9058 |
| 1.0000 | .9781 | .9727 | .9617 | .9563 | .9563 | .9344 | .9344 | .9071 | .9071 |
| 1.0000 | .9883 | .9883 | .9825 | .9825 | .9708 | .9708 | .9649 | .9591 | .9415 |
| 1.0000 | .9940 | .9820 | .9701 | .9581 | .9461 | .9401 | .9341 | .9281 | .9162 |
| 1.0000 | .9939 | .9877 | .9571 | .9571 | .9509 | .9509 | .9448 | .9202 | .8589 |
| 1.0000 | .9938 | .9814 | .9689 | .9565 | .9379 | .9379 | .9379 | .9255 | .9255 |
| 1.0000 | .9810 | .9684 | .9620 | .9494 | .9494 | .9430 | .9367 | .9304 | .9177 |
| 1.0000 | .9804 | .9739 | .9739 | .9673 | .9608 | .9542 | .9542 | .9477 | .8824 |
| 1.0000 | .9873 | .9745 | .9554 | .9490 | .9490 | .9427 | .9427 | .9299 | .9299 |
| 1.0000 | 1.0000 | .9935 | .9871 | .9806 | .9742 | .9677 | .9613 | .9548 | .9484 |
| 1.0000 | .9938 | .9814 | .9689 | .9627 | .9565 | .9565 | .9441 | .9441 | .9379 |
| 1.0000 | .9777 | .9609 | .9441 | .9274 | .9106 | .8883 | .8715 | .8715 | .8045 |
| 1.0000 | .9944 | .9944 | .9722 | .9722 | .9722 | .9611 | .9278 | .9222 | .9222 |
| 1.0000 | .9948 | .9896 | .9896 | .9687 | .9583 | .9531 | .9375 | .9323 | .8802 |
| 1.0000 | .9859 | .9484 | .9437 | .9390 | .9296 | .9249 | .9202 | .9155 | .9014 |
| 1.0000 | .9962 | .9658 | .9468 | .9468 | .9087 | .7985 | .7757 | .7719 | .8555 |
| 1.0000 | 1.0000 | .9887 | .9662 | .9549 | .9511 | .9474 | .9398 | .9361 | .9323 |
| 1.0000 | .9754 | .8632 | .8596 | .8421 | .8386 | .8386 | .8386 | .8386 | .8175 |
| 1.0000 | .9840 | .9679 | .9519 | .9359 | .9327 | .9327 | .9135 | .8654 | .8045 |
| 1.0000 | .9730 | .9730 | .9614 | .9614 | .9575 | .9575 | .9537 | .9421 | .8340 |

TABLE 6-4

LOAD MODEL DATA
FAIRBANKS AREA
PROBABLE LOAD FORECAST CASE

ANNUAL PEAK LOAD IN MW
(1983 - 1997)

196. 212. 231. 249. 270. 291. 313. 338. 362. 390.
416. 446. 477. 511. 547.

INTERVAL PEAK LOADS IN P.U. OF ANNUAL PEAK LOAD
(26 INTERVALS / YEAR)

0.87590.69900.73710.76040.57490.59710.56630.51110.43240.41150.38330.37470.3587
0.35380.38080.41770.42010.43730.46190.53190.57490.89190.93370.93491.00000.7690

DAILY PEAK LOADS IN P.U. OF INTERVAL PEAK LOAD
(260 WEEK DAYS / YEAR)

1.00000.97480.94670.94670.94530.93130.89480.86540.84290.8177
1.00000.93670.92790.92790.90510.89980.88050.85940.82790.7891
1.00000.99330.96670.94830.94000.92330.90330.88000.86670.8267
1.00000.97580.96120.94510.86910.83200.82390.81100.79000.6769
1.00000.98500.98290.95940.95300.94660.91880.90810.90170.8825
1.00000.99790.99590.98770.97940.95880.93620.90530.89300.8827
1.00000.98480.95010.93710.91970.89370.88070.87200.86120.8091
1.00000.96870.96150.95190.93510.91590.88700.88220.87980.8558
1.00000.99150.99150.99150.97160.96870.93180.89200.88920.8693
1.00001.00000.96120.93130.92840.92840.92240.90750.90450.8955
1.00000.99040.99040.94550.92310.91990.91670.91350.87820.8558
1.00000.96720.95410.92790.92460.90490.89840.89510.87870.8721
1.00000.96920.96920.95890.95890.94520.94520.93150.92120.9041
1.00000.98960.97220.96870.95830.94790.93400.92360.92010.8507
1.00000.96770.93870.93230.91290.90320.90320.90320.87100.8677
1.00000.87350.87060.86760.86460.85880.84710.84410.83820.8059
1.00000.94440.90640.90640.89470.82750.82750.82460.81870.8012
1.00000.99720.97750.96350.96350.94940.93820.93820.91010.8904
1.00000.99470.96810.93090.92820.90960.90690.90160.88830.8856
1.00000.98850.93300.91450.90990.89610.88910.88450.86370.8568
1.00000.99150.98080.97650.94020.92950.92740.91880.91450.9017
1.00000.96690.91180.89260.88840.79890.73970.64460.61020.6088
1.00300.97710.91050.90790.90790.89340.88950.88550.86320.8434
1.00000.97110.86330.83050.81870.79630.79240.74510.73320.7201
1.00000.99510.98160.97300.97170.95580.91650.88450.82430.6818
1.00000.99840.93930.92010.89940.88980.88500.84820.81310.7971

TABLE 6-5

LOAD MODEL DATA
ANCHORAGE AREA
LOW LOAD FORECAST CASE

ANNUAL PEAK LOAD IN MW
(1983 - 1997)

765. 832. 908. 985. 1068. 1156. 1250. 1350. 1451. 1562.
1677. 1800. 1933. 2070. 2215.

INTERVAL PEAK LOADS IN P.U. OF ANNUAL PEAK LOAD
(26 INTERVALS / YEAR)

.8333 .6667 .7404 .7500 .6571 .6346 .6122 .5865 .5481 .5353 .5224 .5160 .5064
.4904 .5032 .4968 .5160 .5737 .5769 .6154 .6827 .8429 .8526 .9135 1.0000 .8301

DAILY PEAK LOADS IN P.U. OF INTERVAL PEAK LOAD
(260 WEEK DAYS / YEAR)

| | | | | | | | | | |
|--------|--------|-------|-------|-------|-------|-------|-------|-------|-------|
| 1.0000 | .9769 | .9731 | .9538 | .9500 | .9462 | .8962 | .8731 | .8577 | .8423 |
| 1.0000 | .9808 | .9663 | .9663 | .9615 | .9615 | .9519 | .9519 | .9423 | .9375 |
| 1.0000 | .9913 | .9784 | .9827 | .9697 | .9654 | .9437 | .9307 | .9221 | .8918 |
| 1.0000 | .9829 | .9487 | .9359 | .9017 | .8889 | .8889 | .8846 | .8333 | .8034 |
| 1.0000 | .9512 | .9317 | .9171 | .9171 | .9073 | .9073 | .9024 | .9024 | .8976 |
| 1.0000 | .9848 | .9798 | .9747 | .9646 | .9495 | .9444 | .9343 | .9293 | .9141 |
| 1.0000 | .9686 | .9634 | .9529 | .9529 | .9476 | .9424 | .9372 | .9058 | .9058 |
| 1.0000 | .9781 | .9727 | .9617 | .9563 | .9563 | .9344 | .9344 | .9071 | .9071 |
| 1.0000 | .9883 | .9883 | .9825 | .9825 | .9708 | .9708 | .9649 | .9591 | .9415 |
| 1.0000 | .9940 | .9820 | .9701 | .9581 | .9461 | .9401 | .9341 | .9281 | .9162 |
| 1.0000 | .9939 | .9877 | .9571 | .9571 | .9509 | .9509 | .9448 | .9202 | .8589 |
| 1.0000 | .9938 | .9814 | .9689 | .9565 | .9379 | .9379 | .9379 | .9255 | .9255 |
| 1.0000 | .9810 | .9684 | .9620 | .9494 | .9494 | .9430 | .9367 | .9304 | .9177 |
| 1.0000 | .9804 | .9739 | .9739 | .9673 | .9608 | .9542 | .9542 | .9477 | .8824 |
| 1.0000 | .9873 | .9745 | .9554 | .9490 | .9490 | .9427 | .9427 | .9299 | .9299 |
| 1.0000 | 1.0000 | .9935 | .9871 | .9806 | .9742 | .9677 | .9613 | .9548 | .9484 |
| 1.0000 | .9938 | .9814 | .9689 | .9627 | .9565 | .9565 | .9441 | .9441 | .9379 |
| 1.0000 | .9777 | .9609 | .9441 | .9274 | .9106 | .8883 | .8715 | .8715 | .8045 |
| 1.0000 | .9944 | .9944 | .9722 | .9722 | .9722 | .9611 | .9278 | .9222 | .9222 |
| 1.0000 | .9948 | .9896 | .9896 | .9687 | .9583 | .9531 | .9375 | .9323 | .8802 |
| 1.0000 | .9859 | .9484 | .9437 | .9390 | .9296 | .9249 | .9202 | .9155 | .9014 |
| 1.0000 | .9962 | .9658 | .9468 | .9468 | .9087 | .7985 | .7757 | .7719 | .8555 |
| 1.0000 | 1.0000 | .9887 | .9662 | .9549 | .9511 | .9474 | .9398 | .9361 | .9323 |
| 1.0000 | .9734 | .8632 | .8596 | .8421 | .8386 | .8386 | .8386 | .8386 | .8175 |
| 1.0000 | .9840 | .9679 | .9519 | .9359 | .9327 | .9327 | .9135 | .8654 | .8045 |
| 1.0000 | .9730 | .9730 | .9614 | .9614 | .9575 | .9575 | .9537 | .9421 | .8340 |

TABLE 6-6

LOAD MODEL DATA
FAIRBANKS AREA
LOW LOAD FORECAST CASE

ANNUAL PEAK LOAD IN MW
(1983 - 1997)

188. 202. 218. 232. 248. 264. 281. 300. 317. 337.
355. 377. 398. 420. 444.

INTERVAL PEAK LOADS IN P.U. OF ANNUAL PEAK LOAD
(26 INTERVALS / YEAR)

0.87590.69900.73710.76040.57490.59710.56630.51110.43240.41150.38330.37470.3587
0.35380.38080.41770.42010.43730.46190.53190.57490.89190.93370.93491.00000.7690

DAILY PEAK LOADS IN P.U. OF INTERVAL PEAK LOAD
(260 WEEK DAYS / YEAR)

1.00000.97480.94670.94670.94530.93130.89480.86540.84290.8177
1.00000.93670.92790.92790.90510.89980.88050.85940.82790.7891
1.00000.99330.96670.94830.94000.92330.90330.88000.86670.8267
1.00000.97580.96120.94510.86910.83200.82390.81100.79000.6769
1.00000.98500.98290.95940.95300.94660.91880.90810.90170.8825
1.00000.99790.99590.98770.97940.95880.93620.90530.89300.8827
1.00000.98480.95010.93710.91970.89370.88070.87200.86120.8091
1.00000.96870.96150.95190.93510.91590.88700.88220.87980.8558
1.00000.99150.99150.99150.97160.96870.93180.89200.88920.8693
1.00001.00000.96120.93130.92840.92840.92240.90750.90450.8955
1.00000.99040.99040.94550.92310.91990.91670.91350.87820.8558
1.00000.96720.95410.92790.92460.90490.89840.89510.87870.8721
1.00000.96920.96920.95890.95890.94520.94520.93150.92120.9041
1.00000.98960.97220.96870.95830.94790.93400.92360.92010.8507
1.00000.96770.93870.93230.91290.90320.90320.90320.87100.8677
1.00000.87350.87060.86760.86460.85880.84710.84410.83820.8059
1.00000.94440.90640.90640.89470.82750.82750.82460.81870.8012
1.00000.99720.97750.96350.96350.94940.93820.93820.91010.8904
1.00000.99470.96810.93090.92820.90960.90690.90160.88830.8856
1.00000.98850.93300.91450.90990.89610.88910.88450.86370.8568
1.00000.99150.98080.97650.94020.92950.92740.91880.91450.9017
1.00000.96690.91180.89260.88840.79890.73970.64460.61020.6088
1.00000.97710.91050.90790.90790.89340.88950.88550.86320.8434
1.00000.97110.86330.83050.81870.79630.79240.74510.73320.7201
1.00000.99510.98160.97300.97170.95530.91650.88450.82430.6818
1.00000.99840.93930.92010.89940.88980.88500.84820.81310.7971

TABLE 6-7

LOSS OF LOAD PROBABILITY INDEX (LOLP)^{1/}

FOR

STUDY CASES IA & ID^{2/}

PROBABLE LOAD FORECAST CASE

| Study Year | Anchorage | | Fairbanks | |
|--------------------|--|---|--|---|
| | Independent Expansion ^{3/} | Interconnected Expansion ^{4/} | Independent Expansion ^{3/} | Interconnected Expansion ^{4/} |
| 1984 | 0.0262 | 0.0063 | 0.8193 | 0.0066 |
| 1985 | 0.0123 | 0.0275 | 0.1446 | 0.0242 |
| 1986 ^{5/} | 0.0199 | 0.0113 | 0.2868 | 0.0236 |
| 1987 | 0.0247 | 0.0208 | 0.6795 | 0.0546 |
| 1988 | 0.0408 | 0.0698 | 0.1140 | 0.0278 |
| 1989 | 0.0290 | 0.0613 | 0.2318 | 0.0376 |
| 1990 | 0.0242 | 0.0625 | 0.0593 | 0.0652 |
| 1991 | 0.0184 | 0.0595 | 0.1550 | 0.1276 |
| 1992 | 0.0168 | 0.0259 | 0.0276 | 0.0269 |
| 1993 | 0.0539 | 0.0297 | 0.0586 | 0.0598 |
| 1994 | 0.0393 | 0.0296 | 0.1583 | 0.1358 |
| 1995 | 0.0307 | 0.0622 | 0.0373 | 0.0426 |
| 1996 | 0.0901 | 0.0568 | 0.0899 | 0.1014 |
| 1997 | 0.0676 | 0.0367 | 0.0441 | 0.0419 |

^{1/} LOLP in days per year.^{2/} 230 kV s/c, 130 MW reserve sharing only.^{3/} See Figure 6-2.^{4/} See Figure 6-3.^{5/} Starting in 1986 includes Bradley Lake Hydro Project.

TABLE 6-8

LOSS OF LOAD PROBABILITY INDEX (LOLP)^{1/}

FOR

CASE IB^{2/}

PROBABLE LOAD FORECAST CASE

| Study Year | Anchorage | | Fairbanks | |
|---------------|--|---|--|---|
| | Independent Expansion ^{3/} | Interconnected Expansion ^{4/} | Independent Expansion ^{3/} | Interconnected Expansion ^{4/} |
| 1984 | 0.0262 | 0.0077 | 0.8193 | 0.0018 |
| 1985 | 0.0123 | 0.0329 | 0.1446 | 0.0096 |
| 1986 | 0.0293 | 0.0220 | 0.2868 | 0.0152 |
| 1987 | 0.0288 | 0.0306 | 0.6766 | 0.0299 |
| 1988 | 0.0482 | 0.0799 | 0.1140 | 0.0300 |
| 1989 | 0.0330 | 0.0677 | 0.2318 | 0.0394 |
| 1990 | 0.0265 | 0.0680 | 0.0593 | 0.0670 |
| 1991 | 0.0193 | 0.0633 | 0.1550 | 0.0130 |
| 1992 | 0.0189 | 0.0644 | 0.0276 | 0.0227 |
| 1993 | 0.0546 | 0.0703 | 0.0586 | 0.0354 |
| 1994 | 0.0427 | 0.0550 | 0.1583 | 0.0654 |
| 1995 | 0.0326 | 0.0991 | 0.0373 | 0.0369 |
| 1996 | 0.0931 | 0.0838 | 0.0899 | 0.0506 |
| 1997 | 0.0676 | 0.0520 | 0.0441 | 0.0244 |

^{1/} LOLP in days per year.

^{2/} 230-kV transmission system with reserve sharing and firm power transfer capability.

^{3/} See Figure 6-2.

^{4/} See Figure 6-4.

TABLE 6-9

LOSS OF LOAD PROBABILITY INDEX (LOLP)^{1/}

FOR

CASE IIA^{2/}

PROBABLE LOAD FORECAST CASE

| Study Year | Anchorage | | Fairbanks | |
|---------------|--|---|--|---|
| | Independent Expansion ^{4/} | Interconnected Expansion ^{3/} | Independent Expansion ^{4/} | Interconnected Expansion ^{3/} |
| 1992 | 0.0189 | 0.0476 | 0.0276 | 0.0972 |
| 1993 | 0.0546 | 0.0418 | 0.0586 | 0.0299 |
| 1994 | 0.0427 | 0.0235 | 0.1583 | 0.0244 |
| 1995 | 0.0326 | 0.0070 | 0.0373 | 0.0089 |
| 1996 | 0.0931 | 0.0226 | 0.0899 | 0.0207 |
| 1997 | 0.0676 | 0.1240 | 0.0441 | 0.0461 |

^{1/} LOLP in days per year.^{2/} Includes interconnections between Devil Canyon-Anchorage (345 kV), Devil Canyon-Watana (230 kV), and Devil Canyon-Ester (230 kV).^{3/} Interconnected expansion for three area system: Anchorage, Fairbanks, and Upper Susitna (generation only). See also Figure 6-5.^{4/} See Figure 6-2.

TABLE 6-10
LOSS OF LOAD PROBABILITY INDEX (LOLP)^{1/}
FOR
STUDY CASES IA & ID^{2/}
LOW LOAD FORECAST CASE

| Study Year | Anchorage | | Fairbanks | |
|--------------------|--|---|--|---|
| | Independent Expansion ^{3/} | Interconnected Expansion ^{4/} | Independent Expansion ^{3/} | Interconnected Expansion ^{4/} |
| 1984 | 0.0262 | 0.0063 | 0.8193 | 0.0066 |
| 1985 | 0.0123 | 0.0275 | 0.1446 | 0.0242 |
| 1986 | 0.0199 | 0.0113 | 0.2868 | 0.0236 |
| 1987 ^{5/} | 0.0134 | 0.0527 | 0.2697 | 0.0501 |
| 1988 | 0.0095 | 0.0068 | 0.0329 | 0.0035 |
| 1989 | 0.0724 | 0.0701 | 0.0741 | 0.0222 |
| 1990 | 0.0309 | 0.0376 | 0.1511 | 0.0207 |
| 1991 | 0.0350 | 0.0533 | 0.0061 | 0.0387 |
| 1992 | 0.0182 | 0.0334 | 0.0591 | 0.0502 |
| 1993 | 0.0359 | 0.0351 | 0.1207 | 0.0173 |
| 1994 | 0.0190 | 0.0264 | 0.2499 | 0.0264 |
| 1995 | 0.0129 | 0.0211 | 0.0340 | 0.0463 |
| 1996 | 0.0075 | 0.0601 | 0.0711 | 0.0152 |
| 1997 | 0.0393 | 0.0393 | 0.0207 | 0.0225 |

^{1/} LOLP in days per year.

^{2/} 230 kV s/c, 130 MW reserve sharing only.

^{3/} See Figure 6-6.

^{4/} See Figure 6-7.

^{5/} From 1987, figures include Bradley Lake Hydro Project.

TABLE 6-11

LOSS OF LOAD PROBABILITY INDEX (LOLP)^{1/}

FOR

CASE IB^{2/}

LOW LOAD FORECAST CASE

| Study Year | Anchorage | | Fairbanks | |
|---------------|--|---|--|---|
| | Independent Expansion ^{3/} | Interconnected Expansion ^{4/} | Independent Expansion ^{3/} | Interconnected Expansion ^{4/} |
| 1984 | 0.0064 | 0.0012 | 0.4650 | 0.0006 |
| 1985 | 0.0105 | 0.0225 | 0.0807 | 0.0044 |
| 1986 | 0.0232 | 0.0745 | 0.1515 | 0.0176 |
| 1987 | 0.0217 | 0.0918 | 0.2697 | 0.0393 |
| 1988 | 0.0121 | 0.0090 | 0.0329 | 0.0037 |
| 1989 | 0.0869 | 0.0822 | 0.0740 | 0.0238 |
| 1990 | 0.0344 | 0.0428 | 0.1511 | 0.0219 |
| 1991 | 0.0393 | 0.0602 | 0.2557 | 0.0413 |
| 1992 | 0.0189 | 0.0366 | 0.0591 | 0.0515 |
| 1993 | 0.0366 | 0.0393 | 0.1207 | 0.0180 |
| 1994 | 0.0209 | 0.0288 | 0.2499 | 0.0271 |
| 1995 | 0.0133 | 0.0207 | 0.0340 | 0.0024 |
| 1996 | 0.0078 | 0.0126 | 0.0711 | 0.0195 |
| 1997 | 0.0427 | 0.0692 | 0.0207 | 0.0029 |

^{1/} LOLP in days per year.^{2/} 230-kV transmission system with reserve sharing and firm power transfer capability.^{3/} See Figure 6-6.^{4/} See Figure 6-8.

TABLE 6-12

LOSS OF LOAD PROBABILITY INDEX (LOLP)^{1/}
 FOR
 CASE IC^{2/}
 PROBABLE LOAD FORECAST CASE

| Study Year | Anchorage | | Fairbanks | |
|--------------------|--|---|--|---|
| | Independent Expansion ^{3/} | Interconnected Expansion ^{4/} | Independent Expansion ^{3/} | Interconnected Expansion ^{4/} |
| 1984 | 0.0262 | 0.0063 | 0.8193 | 0.0066 |
| 1985 | 0.0123 | 0.0275 | 0.1446 | 0.0242 |
| 1986 ^{5/} | 0.0199 | 0.0113 | 0.2868 | 0.0236 |
| 1987 | 0.0247 | 0.0208 | 0.6795 | 0.0546 |
| 1988 | 0.0408 | 0.0698 | 0.1140 | 0.0278 |
| 1989 | 0.0290 | 0.0613 | 0.2318 | 0.0376 |
| 1990 | 0.0242 | 0.0625 | 0.0593 | 0.0652 |
| 1991 | 0.0184 | 0.0595 | 0.1550 | 0.1276 |
| 1992 | 0.0168 | 0.0616 | 0.0276 | 0.0388 |
| 1993 | 0.0539 | 0.0666 | 0.0586 | 0.0620 |
| 1994 | 0.0393 | 0.0511 | 0.1583 | 0.1198 |
| 1995 | 0.0307 | 0.0971 | 0.0373 | 0.0486 |
| 1996 | 0.0901 | 0.0830 | 0.0899 | 0.0699 |
| 1997 | 0.0676 | 0.0516 | 0.0441 | 0.0354 |

^{1/} LOLP in days per year.

^{2/} 345-kV transmission system with reserve sharing and firm power transfer capability.

^{3/} See Figure 6-2.

^{4/} See Figure 6-4. The 345 kV (Case IC) is similar to 230 kV (Case IB) except that only one 345-kV line is required during the 1992-1997 period, instead of two 230-kV lines.

^{5/} Starting in 1986 includes Bradley Lake Hydro Project.

FIGURE 6-1

NON-COINCIDENT 1975 PEAK DEMANDS
ANCHORAGE AND FAIRBANKS AREAS





FIGURE 6-2



INDEPENDENT SYSTEM EXPANSION PLANS
ANCHORAGE AND FAIRBANKS AREAS
PROBABLE LOAD FORECAST CASE 8/79






FIGURE 6-3
CASE 1A & 1D

INTERCONNECTED SYSTEM EXPANSION PLAN
ANCHORAGE - FAIRBANKS AREA
WITHOUT SUSITNA PROJECT
PROBABLE LOAD FORECAST CASE

8/79




INTERCONNECTED SYSTEM EXPANSION PLAN
ANCHORAGE - FAIRBANKS AREA
WITH FIRM POWER TRANSFER
PROBABLE LOAD FORECAST CASE 6/79



INTERCONNECTED SYSTEM EXPANSION PLAN
ANCHORAGE-FAIRBANKS AREA
WITH UPPER SUSITNA PROJECT
PROBABLE LOAD FORECAST CASE 8/79

FIGURE 6-6



INDEPENDENT SYSTEM EXPANSION PLAN
ANCHORAGE - FAIRBANKS AREA
LOW LOAD FORECAST CASE

FIGURE 6-6

FIGURE 6-7




FIGURE 6-7
CASE 1A & 1D

FIGURE 6-8




INTERCONNECTED SYSTEM EXPANSION PLAN
ANCHORAGE-FAIRBANKS AREA
LOW LOAD FORECAST CASE
WITH FIRM POWER TRANSFER

FIGURE 6-8
CASE 1B



CASE I
Alternatives A & B



CASE I
Alternative C

FIGURE 6-10




FIGURE 6-11




FIGURE 6-12

CHAPTER 7
FACILITY COST ESTIMATES

CHAPTER 7 FACILITY COST ESTIMATES

7.1 TRANSMISSION LINE COSTS

The transmission line costs were obtained from past and current experience of the Consultants with the design and construction of transmission lines in Alaska. Cost data was escalated to 1979 levels and a factor of 1.46 (AVF = Average Value Factor) was applied to total costs to give an average value for construction in the area. The AVF includes a 10% addition for anticipated difficulty with the constraints associated with the selected line route.

A. Alaskan Experience

Facility cost estimates for alternative transmission intertie designs are based on an in-depth analysis of pertinent Alaskan transmission lines that have been built and are now in successful operation. Analyses were made based on actual experience to develop material and man-hour costs, together with specific installation requirements for structures, conductors, and footing assemblies. In addition, typical right-of-way clearing costs and other costs associated with the solicitation and obtainment of right-of-way easements, permits, and environmental reviews were gathered to provide representative costs for estimating component items for the Anchorage-Fairbanks Intertie.

The first Alaskan transmission line capable of operating at voltages as high as 230 kV was the Beluga Line. It was constructed for Chugach Electric Association (CEA) in 1967 by City Electric, Inc. of Anchorage. This line traverses about 42.5 miles of undeveloped land, of which about 65% was muskeg swamp. No roads existed to connect the line right-of-way to any highway or railroad, requiring that access be by water (Cook Inlet - Susitna River), by air (helicopter), or by ORV (off-road vehicle). One major river crossing was required along the transmission line route.

The Beluga Line was constructed of aluminum lattice, X-shape, hinged-guyed towers and Drake (795 kcmil ACSR) conductor by the Contractor. Using one tower assembly yard at Anchorage, the Contractor made extensive use of helicopter delivery of men and materials with ORV equipment during winter weather to construct the line. This project was completed at a cost of about \$50,000 per mile, including right-of-way clearing.

The hinged-guyed, X-shaped tower proved successful and has since been used for the following lines described below.

1. Knik Arm Transmission Line - 230 kV (Aluminum Lattice Towers, 795 kcmil Drake ACSR Conductor), 1975. This line was built using Owner-furnished material by force account and contract methods. The Owner (CEA) installed the piling and anchors, and contracted for the right-of-way clearing, tower erection, and wire stringing. Piling and anchors were installed using ORV equipment to carry the power tool for installing anchors and the Del Mag-5 diesel hammer and welding equipment for the piling work. City Electric, Inc. accomplished the tower erection and wire stringing using helicopter and ORV equipment.

| <u>Summary of Actual Costs:</u> | <u>\$/Mile</u> |
|---------------------------------|----------------|
| Construction Cost | 87,294 |
| Right-of-way Clearing Cost | 19,049 |
| Right-of-way Solicitation Cost | <u>7,706</u> |
| TOTAL (w/o Engineering) | 114,049 |

2. Willow Transmission Line - 115 kV (Tubular Steel Towers, 556.5 kcmil Dove ACSR Conductor), 1978. This line was built by contract using Owner-furnished material. Right-of-way clearing was accomplished by one contractor and line construction by another (Rogers Electric - an experienced Alaska contractor). This line contractor used a vibratory driver to install the 8" H-pile with great success. (This driver has since been used to drive 10" H-pile for another line. In one case, the tool drove a 14" H-pile for a sign support. The contractors are preparing

to drive more 14" piles for a new CEA line.) The introduction of the vibratory pole-driving technique, together with the application of the tubular steel, hinged-guyed, X-tower is expected to realize substantial cost savings on future transmission line projects.

| <u>Summary of Actual Costs:</u> | <u>\$/Mile</u> |
|---------------------------------|----------------|
| Construction Cost | 73,863 |
| Right-of-way Clearing Cost | 10,312 |
| Right-of-way Solicitation Cost | <u>4,909</u> |
| TOTAL (w/o Engineering) | 89,084 |

B. Material Costs

The estimated cost for the tower steel, as well as the physical characteristics were obtained from ITT Meyer Industries (Ref. 1). The cost of steel, therefore, has 1979 as the reference year.

The cost of foundation steel was taken to be \$0.31 per lb for WG Beam. This value is somewhat conservative, as the current market price is \$0.22 per lb.

Prices for insulators and conductors have a reference year of 1977; thereafter, the price was escalated at 7 percent per year through 1979. The cost of right-of-way was based on actual average values paid by utilities in the same area as the proposed lines. Other factors used, that provide good indication of projected costs for the transmission line are:

- Terrain Factor - This factor is used to correct the number of calculated towers per mile to actual towers per mile.
- Line Angle Factor - This factor is used to increase the effective transversal load on the tower, and accounts for the 3⁰ design-angle for the towers.

- Tower Weight Factor - This factor is used to increase the total estimated tower weight, to account for heavy angle and dead-end towers.

C. Labor Costs

Labor costs were obtained from actual construction experience, obtained by the Consultants' construction records for transmission lines built in Alaska. This information included the cost of labor and a detailed breakdown of the man-hours required for every specific task included in the construction program. A multiplier of 1.33 was applied to the estimated cost of labor for this period, which then was multiplied by 1.1 as explained in 7.1 above to obtain the 1.46 AVF indicated above.

D. Transportation Costs

An estimated unit cost of \$100 per ton was taken to represent the transportation and shipping costs from the Pacific Northwest to the line route staging depot, including loading and unloading (Ref. 2).

7.2 SUBSTATIONS COSTS

For this report, the facility costs for substations were obtained from the U.S. Department of Energy 1978 version of the previous FPC publication "Hydroelectric Power Evaluation" (Ref. 3). As the values included in the publication are list prices, with 1977 as reference year, they were adjusted to 1979 values by using the U.S. Bureau of Reclamation Index (Ref. 4). The cost of the substations includes the shunt compensation, required at both ends, for operation from no-load to full-load. No reactive power (VAR) compensation support from the source generators was considered in this study.

7.3 CONTROL AND COMMUNICATIONS SYSTEM COSTS

Control and communications systems costs are included in the intertie cost estimates. The system is necessary to provide effective control of power system operations, and economic energy dispatch throughout the inter-connected Anchorage-Fairbanks area. The cost estimates include a power line carrier type communications system, a digital supervisory control and data acquisition (SCADA) system, and automatic generation control equipment.

7.4 TRANSMISSION INTERTIE FACILITY COSTS

As previously discussed in Chapter 5, transmission line costs were calculated using TLCAP. Computer printout sheets indicating input data and the calculated results for all five intertie alternatives are shown in Appendix B. Costs for substation facilities and the control and communications system were added to the transmission line costs, thus obtaining the investment cost for the total intertie facilities. A cost summary for each of the five alternatives studied is presented in Table 7-1. Detailed cost estimates and supporting data are included in Appendix D.

7.5 COST OF TRANSMISSION LOSSES

The Transmission Line Optimization Program (TLCAP) for the selection of the optimum span-conductor combination, includes the cost of demand and energy losses for long transmission lines. The loss components are optimized by varying the voltages at the receiving and sending ends. The program assumes 100 percent volt support at both ends. Table 7-2 presents the present worth (1979) costs of calculated transmission line energy and demand losses.

7.6 BASIS FOR GENERATING PLANT FACILITY COSTS

Cost estimates were prepared for all new generating plants (five gas-turbine units and five coal-fired steam plants), and associated substation and transmission facilities which will be affected by the transmission interconnection. The costs for the facilities are summarized in Table 7-3.

The most recent cost data and estimates available for both gas-turbine and coal-fired steam plants planned for the Railbelt area was used as a basis for the generating plant estimates. The three principal sources of cost data and information are included in the references at the end of this chapter. The Battelle study report (Ref. 2) provided background information and specific factors to determine applicable Alaskan construction cost location adjustment factors. The Stanley Consultants report to GVEA (Ref. 5) provided detailed cost estimates for both the 104-MW coal-fired plant at Healy and combustion turbines at the Northpole substation in Fairbanks. These estimates were then used to derive reference costs for other gas-turbine and coal-fired units of different capacity at other Railbelt sites. The nomogram developed by Arkansas Power & Light Company (Ref. 6) was used to determine the 100-MW reference cost estimate from reported costs relevant to the 104-MW coal-fired plant at Healy. The same nomogram was then used to determine plant costs for unit ratings of 200 and 300 MW, taking into consideration economies of scale. Subsequently, the Alaskan construction cost location adjustment factors were applied to derive site specific cost estimates.

Cost estimates for the associated transmission facilities were obtained from cost data developed during this study for the transmission intertie, the Stanley Consultants report (Ref. 5), and typical costs experienced in recent Alaskan transmission projects.

The cost estimates and supporting data are contained in Appendix D.

7.7 GENERATING PLANT FUEL COSTS

Benefits in addition to those resulting from generation reserve capacity sharing will result from the supply of firm power over the intertie. An analysis was made of the relative generation costs for both independent and interconnected system expansions to determine the comparative economic advantage of firm power interchange. The fuel cost component of operating expenses is the salient factor which affects the economic comparison of alternative system expansions. Therefore, a year-by-year analysis of alternative modes of generation was completed for each period during which firm power transfer over the intertie is possible, as follows:

| <u>From</u> | <u>To</u> | <u>Duration</u> | <u>Transmission Intertie Firm Power Transfer</u> | | | |
|-------------|-----------|-----------------|--|----------------------------------|----------------------------|-----------------------------------|
| | | | <u>Capacity</u> | <u>% Power Loss^{1/}</u> | <u>Energy^{2/}</u> | <u>% Energy Loss^{1/}</u> |
| 1984 | 1987 | 4 yrs. | 30 MW | 6.9 | 145 GWh | 1.05 |
| 1992 | 1996 | 5 yrs. | 70 MW | 6.9 | 337 GWh | 1.05 |

^{1/} Case IB.

^{2/} Annual Transmission Capacity Factor of 0.55 assumed for analysis.

Fuel costs were estimated utilizing the trend curves from the Battelle report for future natural gas and coal prices in the Railbelt area. The energy loss component of firm power transfer over the intertie was considered, in estimating the total cost of fuel required to generate sufficient energy in one area to displace a block of energy otherwise generated by a local plant in an independently supplied area.

A year-by-year analysis of the comparative cost of generation is given in Appendix D. Table 7-4 summarizes these costs. Although this analysis is germane to the confirmation of salient considerations regarding the economic feasibility of the intertie, this level of study of fuel costs is in no way a definitive substitution for a detailed year-by-year analysis of production costing for the multi-area interconnection.

7.8 MEA UNDERLYING SYSTEM COSTS

The construction of transmission intertie with the intermediate substation at Palmer (Case ID) provides an opportunity for Matanuska Electric Association (MEA) to purchase power at the intermediate substation at Palmer. Information in the System Planning Report (Ref. 8) indicates the following MEA system expansion investment cost for transmission lines and substation facilities with and without the intertie:

| | |
|-----------------------|--------------------|
| Interconnected System | \$1,356,000 (1987) |
| Independent System | \$6,646,000 (1987) |
| Independent System | \$2,004,000 (1992) |

The above costs are in 1979 dollars, values were escalated by 10% from 1978 to 1979 level. These values were used in an economic analysis to obtain additional benefits for Case ID.

7.9 CONSTRUCTION POWER COSTS FOR THE UPPER SUSITNA PROJECT

Completion of the transmission interconnection, prior to the development of the Watana and Devil Canyon sites of the Upper Susitna Project will enable the supply of electrical energy for construction power. A temporary wood-pole line to the sites will be supplied from a transmission tap along the intertie route, near the junction of the site access road with the main highway between Anchorage and Fairbanks. Generally, isolated diesel generation is used at such remote hydropower plant sites.

A comparison was made of the relative costs of isolated diesel generation and energy supply to the sites via the tap-line. Table 7-5 shows alternative cost streams through the construction period corresponding to the introduction of the Watana and Devil Canyon units to the interconnected Railbelt generation expansion, shown on Figure 6-5. The construction schedule, as outlined on page 94 of the Interim Feasibility Report (Ref. 7),

was followed to establish the time frame for economic comparison of alternative modes of construction power supply. Results of the economic comparison indicate a clear advantage for utilizing the intertie as a source of construction power.

7.10 REFERENCES

1. Letter from ITT Meyer Industries to R. W. Retherford Associates, Anchorage, Alaska, January 15, 1979.
2. Battelle Pacific Northwest Laboratories, Alaska Electric Power: An Analysis of Future Requirements and Supply Alternatives for the Railbelt Region, March 1978.
3. DOE, Federal Energy Regulatory Commission, Hydroelectric Power Evaluation (Final Draft), August 1978.
4. U.S. Bureau of Reclamation, "BuRec Construction Costs", Engineering News Record, 22 March 1979.
5. Stanley Consultants, Power Supply Study - 1978, Review Copy of Report to Golden Valley Electric Association, Inc.
6. Power Engineering, "Nomogram calculates economy of scale in power plants", Volume 83, February 1979.
7. U.S. Army Corps of Engineers, South-Central Railbelt Area, Alaska, Upper Susitna River Basin Interim Feasibility Report, December 1975.
8. Robert W. Retherford Associates, System Planning Report, Matanuska Electric Association, Inc., January 1979.

TABLE 7-1

COST SUMMARY FOR INTERTIE FACILITIES^{1/}

| | | Total Cost at 1979 Levels (\$1000) | | | | |
|----|------------------------------------|------------------------------------|---------------|---------------|---------------|----------------|
| | | Case IA | Case IB | Case IC | Case ID | Case II |
| 1. | <u>Transmission Line:</u> | | | | | |
| | Eng'g. & Constr. Supv. | 3,012 | 3,012 | 7,988 | 3,012 | 15,442 |
| | Right-of-Way | 8,837 | 8,837 | 7,573 | 8,837 | 12,994 |
| | Foundations | 8,445 | 8,445 | 12,160 | 8,445 | 22,966 |
| | Towers | 21,615 | 21,615 | 33,990 | 21,615 | 64,974 |
| | Hardware | 477 | 477 | 477 | 477 | 1,096 |
| | Insulators | 503 | 503 | 755 | 503 | 1,396 |
| | Conductor | <u>10,761</u> | <u>10,761</u> | <u>17,663</u> | <u>10,761</u> | <u>36,946</u> |
| | Subtotal | 53,650 | 53,650 | 80,606 | 53,650 | 155,814 |
| 2. | <u>Substations:</u> | | | | | |
| | Eng'g. & Constr. Supv. | 1,352 | 1,352 | 1,855 | 2,816 | 6,902 |
| | Land | 57 | 57 | 46 | 81 | 185 |
| | Transformers | 1,703 | 1,703 | 3,291 | 1,703 | 11,917 |
| | Circuit Breakers | 1,093 | 1,093 | 1,323 | 1,953 | 6,410 |
| | Station Equipment | 1,223 | 1,223 | 1,933 | 1,345 | 4,375 |
| | Structures & Accessories | <u>3,628</u> | <u>3,628</u> | <u>3,978</u> | <u>4,026</u> | <u>16,411</u> |
| | Subtotal | 9,056 | 9,056 | 12,426 | 11,924 | 46,200 |
| 3. | <u>Control and Communications:</u> | | | | | |
| | Eng'g. & Constr. Supv. | 125 | 125 | 125 | 165 | 200 |
| | Equipment | <u>2,375</u> | <u>2,375</u> | <u>2,375</u> | <u>3,135</u> | <u>3,600</u> |
| | Subtotal | <u>2,500</u> | <u>2,500</u> | <u>2,500</u> | <u>3,300</u> | <u>3,800</u> |
| | Total Baseline 1979 Costs | <u>65,206</u> | <u>65,206</u> | <u>95,532</u> | <u>68,874</u> | <u>205,814</u> |

^{1/} The interest and escalation during the construction and other financial charges are excluded from the costs in this summary. These costs are not relevant for the economic analysis and they appear only in the financial analysis (See Chapter 9 for Case ID).

TABLE 7-2

PRESENT WORTH OF INTERTIE LINE LOSSES
1984-1997 STUDY PERIOD^{1/}

| <u>Case</u> | <u>\$ x 1000 (1979)</u> |
|--------------------------|-------------------------|
| IA & ID (230 kV) | 5,410 |
| IB (230 kV) | 7,071 |
| IC (345 kV) | 6,429 |
| II A (230 & 345 kV) | |
| Anchorage - Devil Canyon | 11,476 |
| Devil Canyon - Ester | 7,076 |
| Watana - Devil Canyon | <u>2,708</u> |

^{1/} Cost of losses, energy, and demand, escalated at 3% per year.

TABLE 7-3

COST SUMMARY FOR GENERATING FACILITIES^{5/}
(Costs at 1979 Levels^{1/})

| Unit Name | Code ^{2/} | Type ^{3/} | MW | Installed Cost | | Total Cost ^{4/} | |
|---------------|--------------------|--------------------|-----|----------------|-------|--------------------------|-------|
| | | | | Thousand \$ | \$/kW | Thousand \$ | \$/kW |
| Northpole #3 | NORT 3 | SCGT | 69 | 24,385 | 353 | 27,934 | 405 |
| Beluga #9 | BELU 9 | SCGT | 71 | 33,548 | 473 | 42,498 | 598 |
| Northpole #4 | NORT 4 | SCGT | 69 | 24,385 | 353 | 25,185 | 365 |
| Anchorage | PEAK A2 | SCGT | 78 | 22,620 | 290 | 23,400 | 300 |
| Northpole #5 | NORT 5 | SCGT | 69 | 24,385 | 353 | 25,185 | 365 |
| Anchorage #11 | ANCH 11 | Coal | 104 | 99,084 | 953 | 105,636 | 1016 |
| Unit F2 | COAL F2 | Coal | 100 | 130,000 | 1300 | 151,980 | 1520 |
| Unit No. 5 | COAL 5 | Coal | 200 | 200,000 | 1000 | 212,245 | 1061 |
| Unit No. 6 | COAL 6 | Coal | 300 | 274,000 | 913 | 292,250 | 974 |
| Unit No. 1 | GEN 1 | Coal | 300 | 274,000 | 913 | 292,250 | 974 |
| Unit No. 2 | GEN 2 | Coal | 300 | 274,000 | 913 | 292,250 | 974 |

^{1/} Investment costs adjusted to January 1979 levels, excluding IDC.

^{2/} Code name used in MAREL study.

^{3/} SCGT - Simple cycle combustion turbine, includes NO_x removal equipment.
COAL - Steam turbine, coal-fired with FGD equipment.^x

^{4/} Total cost includes substation and transmission costs.

^{5/} The interest and escalation during the construction and other financial charges are excluded from the costs in this summary. These costs are not relevant for the economic analysis and they appear only in the financial analysis.

TABLE 7-4

SUMMARY
OF
ALTERNATIVE GENERATING PLANT FUEL COSTS

| <u>Year</u> | <u>\$ 1000 (Escalated)</u> | |
|-------------|---|--|
| | <u>Independent System Operation</u> | <u>Interconnected System Operation</u> |
| 1984 | - | - |
| 1985 | 8,468 | 7,648 |
| 1986 | 9,324 | 8,498 |
| 1987 | 10,267 | 9,029 |
| 1992 | 6,851 | 8,324 |
| 1993 | 7,212 | 8,654 |
| 1994 | 7,933 | 8,016 |
| 1995 | 8,654 | 8,745 |
| 1996 | 9,015 | 9,109 |


TABLE 7-5

ALTERNATIVE COSTS FOR CONSTRUCTION POWER SUPPLY
TO
WATANA AND DEVIL CANYON HYDROPOWER SITES
DURING
CONSTRUCTION OF UPPER SUSITNA PROJECT

| <u>Year</u> | <u>1979 Baseline Costs - \$1000</u> | |
|-------------|---|---|
| | <u>Isolated Diesel Generation at Site</u> | <u>Tapline Supply From Intertie</u> |
| 1985 | 2,835 | 267 |
| 1986 | 695 | 483 |
| 1987 | 697 | 481 |
| 1988 | 696 | 478 |
| 1989 | 3,055 | 752 |
| 1990 | 1,324 | 902 |
| 1991 | 187 | 734 |
| 1992 | 623 | 430 |
| 1993 | 623 | 419 |
| 1994 | -500 ^{1/} | 304 |

^{1/} Negative sign indicates that resale value of generating plant exceeds cost of generation in final year.

FIGURE 7-1



CONSTRUCTION PLAN FOR UPPER SUSITNA PROJECT:

Ref. Interim Feasibility Report - P.94, US Army Corps of Engineers, 12 Dec. 1975

Construction Period for Selected Projects:

Watana Dam - 6 Years
Devil Canyon Dam - 5 Years
Total Period - 10 Years (1 Year Overlap)

SUGGESTED REVISED SCHEDULE:

Ref. Chapter 6, Figure 6-5

First Unit On-Line at Watana - Beginning Year 1992
Last Unit On-Line at Devil Canyon - End of Year 1996
Period of Overlap in Construction - 2 Years
Due to Introduction of First Unit at Devil Canyon in 1994

CHAPTER 8
ECONOMIC FEASIBILITY ANALYSIS

CHAPTER 8

ECONOMIC FEASIBILITY ANALYSIS

An economic feasibility analysis was performed to determine which system expansion plan provides the best use of available resources for supplying electrical power to the Railbelt area. Alternative system expansion plans and facility cost estimates were developed in Chapters 6 and 7. In this chapter, the results of the economic feasibility analysis are presented.

8.1 METHODOLOGY

This economic analysis uses the conventional present-worth model. Annual capital disbursement tables, on a year-by-year basis, were prepared for independent and interconnected system expansion plans. To evaluate these plans on an equal basis all capital disbursements were discounted to the 1979 base year and then totalized for each plan to obtain a single 1979 present-worth value for each plan. The difference between the two present worth values is the net present worth or project benefits. This approach does not include additional capital disbursements after 1997. Such disbursements will be required later to replace retired facilities. However, the extension of the present-worth model over the whole life of the proposed intertie will not significantly affect the results of this feasibility study. The year 1997 was chosen as the final year of the study period to include the last unit of Upper Susitna Hydropower Project (Devil Canyon Unit No. 4).

Figures 6-2 thru 6-8 in Chapter 6 show that many plant additions for both independent and interconnected system expansion plans do not vary. Therefore, in this economic analysis, facility costs for the new generating plants not affected by the introduction of the intertie are not considered. Also excluded from the analysis are plant fixed operation and maintenance costs. The exclusion of these O&M costs will somewhat favor the independent system expansion alternatives.

Only capital costs are used to evaluate generation reserve capacity sharing benefits. This simplification is based on the assumption that an average operating cost of generation for reserve sharing is approximately the same in the Anchorage and Fairbanks areas. To account for generating plant operating costs with reasonable accuracy, a multi-area production cost study would be needed. The multi-area production cost model simulates an economic dispatching of generating units in the system and computes expected fuel and variable O&M costs based on the energy (MWh) output for each unit, taking into consideration intertie transfer limits. Since such a study is outside the scope of the present work, a somewhat simplified method was used in this feasibility study. It is definitely recommended that a multi-area production cost study be performed as the next step to finalize this Intertie Economic Feasibility Study.

8.2 SENSITIVITY ANALYSIS

A computer program was developed by IECO to analyze the sensitivity of different escalation and discount rates on the capital costs of various alternatives. This program, the Transmission Line Economic Analysis Program (TLEAP), provides the following outputs:

- Tables indicating independent minus interconnected system costs, discounted to the base year 1979.
- Separate tables indicating the discounted value of base year (1979) costs for the independent and interconnected systems.
- Cost disbursement tables for alternative system expansion plans. These tables also include intertie line losses.

Computer printout sheets indicating input data and calculated results for all alternatives included in this economic feasibility analysis are found in Appendix E.

8.3 ECONOMIC ANALYSIS

Tables included in this chapter and in Appendix E indicate economic analyses for a range of annual escalation rates of 0% to 12%, and a range of discount rates from 8% to 12%. For principal investigations below, a 10% discount rate is used and cash flow for facilities under consideration is expressed in constant 1979 dollars, only the fuel related energy costs are escalated. The 10% is regarded as the appropriate discount value for Opportunity Cost of Capital and is now required by the Office of Management and Budget (Ref. 1) for economic analyses to determine benefits for all federal projects.

For the purposes of the economic analysis, it is the discount rate corresponding to the opportunity cost of capital which is used to calculate all present values of costs and benefits; the particular cost of interest actually paid on bonds or other obligations is irrelevant since it bears no relationship whatsoever to the project's internal rate of return. It is only a financial (or budgeting) parameter. Therefore, the interest during construction and other financial charges are excluded from the economic analysis. These charges appear only in the financial analysis.

A. Benefits Due to Generation Reserve Capacity Sharing (Case IA)

Three cases were investigated to determine intertie benefits due to generation reserve capacity sharing alone; the 230-kV single circuit intertie between Anchorage and Fairbanks. In all cases 130 MW of power transfer capacity was allocated for generation reserve capacity sharing purposes. The economic analysis results indicate the following benefits due to intertie (differential of present worth):

| <u>Load Forecast</u> | <u>Intertie Cost (Percent)</u> | <u>Reference Table</u> | <u>Benefits (\$ x 1000) (PW 1979)</u> |
|----------------------|--------------------------------|------------------------|---------------------------------------|
| Probable | 100 | 8-1 | 12,475 |
| Probable | 125 | 8-1x | 945 |
| Low | 100 | 8-1-LL | 2,704 |

The above results indicate that the 230-kV intertie is economically feasible based on generation reserve capacity sharing alone.

Sensitivity of the results to variations in escalation and discount rates are indicated in Tables 8-1, 8-1x and 8-1-LL. Computer printouts indicating details are included in Appendix E.

B. Benefits Due to Generation Reserve Capacity Sharing and Firm Power Transfer (Case 1B)

Six cases were investigated to determine combined 230-kV intertie benefits due to both firm power transfer and generation reserve capacity sharing. These study cases have one 230-kV single circuit line during the 1984-1991 period and two single circuit 230-kV lines during the 1992-1997 period except for low load forecast case (Table 8-3LL) when the second 230-kV circuit is added in 1995. The economic analysis results indicate the following intertie benefits (differential of present worth):

| <u>Load Forecast</u> | <u>Intertie Cost (Percent)</u> | <u>Reference Table</u> | <u>Benefits (\$ x 1000) (PW 1979)</u> |
|----------------------|--------------------------------|------------------------|---------------------------------------|
| Probable | 100 | 8-3 | 24,054 |
| Probable | 125 | 8-3x | 12,533 |
| Low | 100 | 8-3-LL | -2,626 |

If the above intertie benefits are combined with the additional benefits due to supply of construction power to the Upper Susitna Hydropower Project site (see Section 7.9), the economic analysis results indicate the following benefits (differential of present worth):

| <u>Load Forecast</u> | <u>Intertie Cost (Percent)</u> | <u>Reference Table</u> | <u>Benefits (\$ x 1000) (PW 1979)</u> |
|--------------------------|------------------------------------|----------------------------|---|
| Probable | 100 | 8-4 | 29,633 |
| Probable | 125 | 8-4x | 18,112 |

Sensitivity of the results to variations in escalation and discount rates are indicated in Tables 8-3, 8-3x, 8-3-LL, 8-4 and 8-4x. Computer printouts indicating details are included in Appendix E.

C. Benefits Due to Generation Reserve Sharing and Firm Power Transfer (Case IC)

Two cases were investigated to determine 345 kV intertie benefits due to both: generation reserve sharing only (first line) and generation reserve sharing combined with firm power transfer (second line). These study cases consider one 345 kV single circuit line between Anchorage and Fairbanks. The economic study results indicate the following intertie benefits (differential of present worth):

| <u>Load Forecast</u> | <u>Intertie Cost (Percent)</u> | <u>Reference Table</u> | <u>Benefits (\$ x 1000) (PW 1979)</u> |
|--------------------------|------------------------------------|----------------------------|---|
| Probable | 100 | 8-2 | -3,556 |
| Probable | 100 | 8-7 | - 426 |

The above results indicate that the 345 kV intertie is not economically feasible based on the conditions specified in this study. Additional studies, including interconnected system production costing, may prove the 345 kV intertie feasible.

Sensitivity of the results to variations in escalation and discount rates are indicated in Tables 8-2 and 8-7. Computer printouts indicating details are included in Appendix E.

D. 230-kV Intertie with Intermediate Substations (Case ID)

Four cases were investigated to determine additional benefits due to supply of power to the MEA System at Palmer substation, and construction power to the Upper Susitna Hydropower Project. These cases include a 230-kV single circuit line between Anchorage and Fairbanks (Ester), with intermediate substations at Palmer and Healy. The economic analysis results indicate the following intertie benefits:

| <u>Load Forecast</u> | <u>Intertie Cost (Percent)</u> | <u>Reference Table</u> | <u>Benefits (\$ x 1000) (PW 1979)</u> |
|----------------------|--------------------------------|------------------------|---------------------------------------|
| Probable | 100 | 8-5 | 17,814 |
| Probable | 125 | 8-5x | 9,125 |

If the above intertie benefits are combined with the additional benefits due to supply of construction power to the Upper Susitna Hydropower Project sites (see Section 7.9), the economic analysis results indicated the following benefits (differential of present worth):

| <u>Load Forecast</u> | <u>Intertie Cost (Percent)</u> | <u>Reference Table</u> | <u>Benefits (\$ x 1000) (PW 1979)</u> |
|----------------------|--------------------------------|------------------------|---------------------------------------|
| Probable | 100 | 8-6 | 20,344 |
| Probable | 125 | 8-6x | 11,656 |

Sensitivity of the results to variations in escalation and discount rates are indicated in Tables 8-5, 8-5x, 8-6 and 8-6x. Computer printouts indicating details are included in Appendix E.

E. Intertie with Upper Susitna Hydropower Project

Only system reliability (MAREL) analyses and facility cost estimates were developed for this alternative system expansion plan (Case II, Chapter 6). The economic feasibility analysis was not performed for this alternative because:

- The methodology of this economic analysis is more appropriate for thermal generation systems. It is not applicable to a large mixed hydro/thermal generation systems. A multi-area production cost study, involving extensive analyses of optimum hydro operations in conjunction with thermal plants, would be required to obtain accurate results.
- A draft copy of the Upper Susitna project report prepared by the Alaska Power Administration (Ref. 2) was received by the Consultants in the course of this study. It includes revisions to unit ratings for the Upper Susitna Project used in the MAREL analyses (as described in Chapter 6). The new total installed capacity is 1573 MW, versus the 1392 MW installed capacity used in development of the expansion plans analyzed in this report.

A study should be performed to accommodate the above revisions to the Susitna power ratings and change to the production economics due to major hydro substitution for thermal energy. The study should examine in detail the economic feasibility of Susitna hydropower, due to the displacement of large increments of thermal power.

For reference, Figure 6-5 in Chapter 6 indicates the initial expansion plan developed for this study. This figure also indicates the thermal generating unit displacement by Upper Susitna Hydropower units.

MAREL study results indicate the following intertie requirements for maintaining the study criteria of equal reliability system expansion with introduction of Upper Susitna power:

| <u>Period</u> | <u>Requirement</u> |
|---------------|--|
| 1992 | One 345-kV S/C line to Anchorage One 230-kV S/C line to Fairbanks |
| 1993 | One 345-kV S/C line to Anchorage Two 230-kV S/C lines to Fairbanks |
| 1994-1997 | Two 345-kV S/C lines to Anchorage Two 230-kV S/C lines to Fairbanks |

8.4 REFERENCES

1. Business Week, Economics, Pages 96-97, February 19, 1979.
2. Alaska Power Administration, Upper Susitna River Project Market Analyses Report, March 1979.

ALASKA POWER AUTHORITY
 ANCHORAGE - FAIRBANKS INTERTIE
 ECONOMIC FEASIBILITY STUDY

TABLE 8-1

 CASE 1A, 230 kV GENERATION RESERVE SHARING ONLY
 PROBABLE LOAD FORECAST CASE

 DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS
 INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS
 (IN \$1000)

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|--------|--------|--------|---------|---------|---------|---------|---------|---------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 10,914 | 2,434 | -1,210 | -5,662 | -11,042 | -17,486 | -25,147 | -34,196 | -44,825 | -57,252 |
| 8.25 | 11,173 | 3,202 | -257 | -4,491 | -9,619 | -15,771 | -23,095 | -31,756 | -41,939 | -53,853 |
| 8.50 | 11,414 | 3,927 | 647 | -3,379 | -8,265 | -14,137 | -21,136 | -29,424 | -39,179 | -50,600 |
| 8.75 | 11,634 | 4,612 | 1,503 | -2,324 | -6,977 | -12,579 | -19,268 | -27,197 | -36,540 | -47,488 |
| 9.00 | 11,836 | 5,258 | 2,314 | -1,321 | -5,752 | -11,096 | -17,486 | -25,071 | -34,017 | -44,511 |
| 9.25 | 12,020 | 5,868 | 3,081 | -371 | -4,588 | -9,683 | -15,786 | -23,040 | -31,605 | -41,663 |
| 9.50 | 12,188 | 6,442 | 3,806 | 531 | -3,481 | -8,339 | -14,166 | -21,102 | -29,301 | -38,938 |
| 9.75 | 12,339 | 6,983 | 4,491 | 1,385 | -2,430 | -7,059 | -12,621 | -19,252 | -27,099 | -36,333 |
| 10.00 | 12,475 | 7,491 | 5,138 | 2,194 | -1,431 | -5,841 | -11,149 | -17,486 | -24,996 | -33,841 |
| 10.25 | 12,596 | 7,969 | 5,749 | 2,960 | -484 | -4,682 | -9,747 | -15,802 | -22,987 | -31,458 |
| 10.50 | 12,703 | 8,417 | 6,324 | 3,685 | 415 | -3,581 | -8,411 | -14,195 | -21,068 | -29,181 |
| 10.75 | 12,797 | 8,838 | 6,867 | 4,371 | 1,268 | -2,534 | -7,139 | -12,662 | -19,235 | -27,003 |
| 11.00 | 12,879 | 9,231 | 7,378 | 5,019 | 2,076 | -1,540 | -5,928 | -11,202 | -17,486 | -24,922 |
| 11.25 | 12,949 | 9,599 | 7,858 | 5,630 | 2,841 | -595 | -4,776 | -9,809 | -15,816 | -22,934 |
| 11.50 | 13,007 | 9,943 | 8,309 | 6,208 | 3,566 | 301 | -3,680 | -8,482 | -14,223 | -21,034 |
| 11.75 | 13,055 | 10,264 | 8,732 | 6,752 | 4,252 | 1,152 | -2,637 | -7,218 | -12,703 | -19,219 |
| 12.00 | 13,093 | 10,562 | 9,129 | 7,265 | 4,900 | 1,959 | -1,647 | -6,014 | -11,253 | -17,486 |

Note:

In early years of the expansion plan capital requirements are higher for the independent system plan, but in the later years capital requirements are higher for the interconnected system plan. As the discount rate increases, the sum of present worth decreases more for the interconnected system plan than for the independent system plan, therefore, the differential of the sums of the discounted values increases with the increase in the discount rate.

Due to larger capital requirements in the later years of the expansion plan, the increase in the escalation rate causes a greater increase in capital costs for the interconnected system. As a consequence, the differential of the discounted values (benefits) decrease.

Refer to APPENDIX E for capital disbursement tables and tables of discounted values.

TABLE 8-1

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERTIE
ECONOMIC FEASIBILITY STUDY

TABLE 8-1X

CASE 1A, GENERATION RESERVE SHARING ONLY
TRANSMISSION LINE COSTS INCREASED BY 25%
PROBABLE LOAD FORECAST CASE

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS
INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS
(IN \$1000)

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | -1,410 | -11,778 | -15,927 | -20,897 | -26,809 | -33,798 | -42,019 | -51,642 | -62,860 | -75,889 |
| 8.25 | -1,046 | -10,891 | -14,850 | -19,598 | -25,253 | -31,946 | -39,824 | -49,054 | -59,821 | -72,333 |
| 8.50 | -704 | -10,048 | -13,824 | -18,360 | -23,768 | -30,175 | -37,725 | -46,577 | -56,910 | -68,924 |
| 8.75 | -383 | -9,247 | -12,847 | -17,178 | -22,350 | -28,484 | -35,718 | -44,206 | -54,122 | -65,658 |
| 9.00 | -81 | -8,485 | -11,917 | -16,052 | -20,997 | -26,868 | -33,798 | -41,937 | -51,451 | -62,528 |
| 9.25 | 201 | -7,761 | -11,032 | -14,979 | -19,705 | -25,323 | -31,962 | -39,766 | -48,894 | -59,529 |
| 9.50 | 466 | -7,074 | -10,190 | -13,957 | -18,473 | -23,848 | -30,207 | -37,688 | -46,446 | -56,656 |
| 9.75 | 714 | -6,422 | -9,389 | -12,982 | -17,297 | -22,440 | -28,529 | -35,700 | -44,102 | -53,903 |
| 10.00 | 945 | -5,803 | -8,627 | -12,054 | -16,176 | -21,095 | -26,926 | -33,798 | -41,857 | -51,265 |
| 10.25 | 1,161 | -5,216 | -7,903 | -11,171 | -15,107 | -19,810 | -25,393 | -31,979 | -39,708 | -48,738 |
| 10.50 | 1,361 | -4,659 | -7,215 | -10,330 | -14,088 | -18,585 | -23,928 | -30,238 | -37,651 | -46,318 |
| 10.75 | 1,548 | -4,132 | -6,562 | -9,529 | -13,116 | -17,415 | -22,528 | -28,574 | -35,682 | -43,999 |
| 11.00 | 1,721 | -3,632 | -5,941 | -8,768 | -12,190 | -16,298 | -21,191 | -26,983 | -33,798 | -41,779 |
| 11.25 | 1,881 | -3,159 | -5,353 | -8,044 | -11,308 | -15,233 | -19,914 | -25,461 | -31,995 | -39,652 |
| 11.50 | 2,030 | -2,712 | -4,794 | -7,355 | -10,468 | -14,217 | -18,695 | -24,006 | -30,269 | -37,615 |
| 11.75 | 2,166 | -2,289 | -4,265 | -6,701 | -9,668 | -13,248 | -17,530 | -22,616 | -28,618 | -35,665 |
| 12.00 | 2,291 | -1,889 | -3,763 | -6,079 | -8,907 | -12,325 | -16,418 | -21,287 | -27,039 | -33,798 |

Note:

This case is similar to the case presented in Table 8-I, except for the increase in intertie costs by 25 percent which caused an increase in capital requirements for the interconnected system expansion plan. For case analysis refer to note in Table 8-I.

TABLE 8-1X

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERTIE
ECONOMIC FEASIBILITY STUDY

TABLE 8-1-LL

CASE IA, 230 kV, GENERATION RESERVE SHARING ONLY
LOW LOAD FORECAST CASE

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS
INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS
(IN \$1000)

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|-------|-------|-------|-------|-------|-------|-------|-------|--------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 4,292 | 6,955 | 7,203 | 7,166 | 6,765 | 5,904 | 4,475 | 2,351 | -619 | -4,605 |
| 8.25 | 4,095 | 6,860 | 7,167 | 7,206 | 6,903 | 6,167 | 4,895 | 2,964 | 232 | -3,466 |
| 8.50 | 3,897 | 6,754 | 7,114 | 7,225 | 7,014 | 6,396 | 5,272 | 3,523 | 1,016 | -2,409 |
| 8.75 | 3,698 | 6,638 | 7,048 | 7,225 | 7,100 | 6,593 | 5,607 | 4,031 | 1,736 | -1,430 |
| 9.00 | 3,499 | 6,513 | 6,968 | 7,207 | 7,163 | 6,759 | 5,904 | 4,491 | 2,397 | -524 |
| 9.25 | 3,300 | 6,379 | 6,876 | 7,172 | 7,203 | 6,897 | 6,165 | 4,906 | 3,001 | 312 |
| 9.50 | 3,101 | 6,237 | 6,773 | 7,122 | 7,224 | 7,008 | 6,392 | 5,278 | 3,552 | 1,083 |
| 9.75 | 2,902 | 6,088 | 6,660 | 7,058 | 7,225 | 7,095 | 6,588 | 5,610 | 4,053 | 1,791 |
| 10.00 | 2,704 | 5,933 | 6,537 | 6,981 | 7,209 | 7,159 | 6,753 | 5,904 | 4,507 | 2,442 |
| 10.25 | 2,507 | 5,772 | 6,406 | 6,892 | 7,177 | 7,201 | 6,891 | 6,163 | 4,917 | 3,037 |
| 10.50 | 2,311 | 5,606 | 6,267 | 6,791 | 7,129 | 7,223 | 7,003 | 6,388 | 5,284 | 3,580 |
| 10.75 | 2,116 | 5,435 | 6,121 | 6,681 | 7,068 | 7,226 | 7,090 | 6,583 | 5,613 | 4,074 |
| 11.00 | 1,923 | 5,261 | 5,969 | 6,561 | 6,993 | 7,212 | 7,155 | 6,748 | 5,904 | 4,522 |
| 11.25 | 1,731 | 5,083 | 5,811 | 6,433 | 6,907 | 7,182 | 7,198 | 6,885 | 6,161 | 4,927 |
| 11.50 | 1,541 | 4,902 | 5,647 | 6,296 | 6,809 | 7,136 | 7,222 | 6,997 | 6,385 | 5,290 |
| 11.75 | 1,353 | 4,718 | 5,479 | 6,153 | 6,701 | 7,077 | 7,227 | 7,085 | 6,578 | 5,615 |
| 12.00 | 1,166 | 4,532 | 5,308 | 6,004 | 6,584 | 7,005 | 7,214 | 7,151 | 6,742 | 5,904 |

Note:

In the early years of the expansion plan capital requirements are somewhat lower for the independent system expansion plan (less new generating capacity is required). In the later years capital requirements are lower for the interconnected system plan. As the discount rate increases, the sum of the present worth decreases more for the independent system plan, therefore, the differential of the sums of the discounted values decrease with the increase in the discount rate.

The above analysis is applicable at the lower escalation rates. Due to marginal differences between capital requirements for both independent and interconnected expansion plans, at higher escalation rates the situation reverses, the differential discounted values (benefits) increase with the increase in the discount rate and decrease with the increase in the escalation rate.

Refer to APPENDIX E for capital disbursement tables and tables of discounted values.

TABLE 8-1-LL

23 AUGUST 79

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INERTIE
ECONOMIC FEASIBILITY STUDY

TABLE 8-2

CASE IC, 345 kV GENERATION RESERVE SHARING ONLY
PROBABLE LOAD FORECAST

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS
INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS
(IN \$1000)

| DISCOUNT RATE | ----- ESCALATION RATES ----- | | | | | | | | | |
|------------------|------------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | -4,886 | -10,269 | -13,279 | -16,167 | -19,601 | -23,658 | -28,421 | -33,984 | -40,450 | -47,934 |
| 8.25 | -4,679 | -10,354 | -12,653 | -15,412 | -18,698 | -22,583 | -27,150 | -32,489 | -38,700 | -45,893 |
| 8.50 | -4,484 | -9,865 | -12,057 | -14,692 | -17,835 | -21,556 | -25,935 | -31,058 | -37,023 | -43,936 |
| 8.75 | -4,302 | -9,401 | -11,489 | -14,006 | -17,011 | -20,574 | -24,771 | -29,687 | -35,415 | -42,059 |
| 9.00 | -4,132 | -8,959 | -10,950 | -13,351 | -16,225 | -19,636 | -23,658 | -28,574 | -33,874 | -40,259 |
| 9.25 | -3,973 | -8,540 | -10,436 | -12,728 | -15,474 | -18,739 | -22,593 | -27,117 | -32,397 | -38,532 |
| 9.50 | -3,824 | -8,143 | -9,947 | -12,154 | -14,758 | -17,882 | -21,575 | -25,913 | -30,982 | -36,876 |
| 9.75 | -3,685 | -7,766 | -9,483 | -11,568 | -14,075 | -17,063 | -20,601 | -24,761 | -29,626 | -35,289 |
| 10.00 | -3,556 | -7,408 | -9,042 | -11,029 | -13,423 | -16,282 | -19,669 | -23,658 | -28,328 | -33,766 |
| 10.25 | -3,436 | -7,070 | -8,622 | -10,517 | -12,802 | -15,535 | -18,779 | -22,603 | -27,083 | -32,307 |
| 10.50 | -3,325 | -6,749 | -8,224 | -10,029 | -12,210 | -14,823 | -17,928 | -21,593 | -25,892 | -30,908 |
| 10.75 | -3,222 | -6,445 | -7,847 | -9,565 | -11,646 | -14,143 | -17,115 | -20,627 | -24,751 | -29,567 |
| 11.00 | -3,127 | -6,158 | -7,488 | -9,123 | -11,108 | -13,494 | -16,338 | -19,702 | -23,658 | -28,282 |
| 11.25 | -3,040 | -5,885 | -7,149 | -8,704 | -10,596 | -12,875 | -15,596 | -18,819 | -22,612 | -27,051 |
| 11.50 | -2,959 | -5,630 | -6,827 | -8,305 | -10,109 | -12,285 | -14,887 | -17,973 | -21,611 | -25,871 |
| 11.75 | -2,886 | -5,388 | -6,522 | -7,927 | -9,645 | -11,722 | -14,210 | -17,165 | -20,652 | -24,741 |
| 12.00 | -2,819 | -5,159 | -6,233 | -7,568 | -9,204 | -11,186 | -13,564 | -16,393 | -19,735 | -23,658 |

23 AUGUST 79

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERTIE
ECONOMIC FEASIBILITY STUDY

TABLE 8-3

CASE IB, 230 kV, GENERATION RESERVE SHARING
PLUS FIRM POWER TRANSFER
PROBABLE LOAD FORECAST CASE

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS
INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS
(IN \$1000)

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 6.00 | 24,726 | 23,316 | 22,034 | 20,252 | 17,893 | 14,872 | 11,092 | 6,448 | 821 | -5,918 |
| 6.25 | 24,678 | 23,265 | 22,035 | 20,745 | 18,541 | 15,700 | 12,128 | 7,723 | 2,372 | -4,053 |
| 6.50 | 24,619 | 23,288 | 22,726 | 21,203 | 19,147 | 16,478 | 13,106 | 8,932 | 3,844 | -2,278 |
| 6.75 | 24,549 | 23,987 | 23,028 | 21,627 | 19,713 | 17,209 | 14,028 | 10,075 | 5,242 | -589 |
| 7.00 | 24,468 | 24,163 | 23,503 | 22,017 | 20,240 | 17,894 | 14,898 | 11,157 | 6,566 | 1,016 |
| 7.25 | 24,378 | 24,317 | 23,551 | 22,377 | 20,729 | 18,536 | 15,716 | 12,179 | 7,825 | 2,543 |
| 7.50 | 24,279 | 24,450 | 23,774 | 22,700 | 21,184 | 19,136 | 16,486 | 13,144 | 9,016 | 3,993 |
| 7.75 | 24,171 | 24,563 | 23,973 | 23,007 | 21,604 | 19,697 | 17,209 | 14,056 | 10,144 | 5,569 |
| 8.00 | 24,054 | 24,658 | 24,149 | 23,281 | 21,993 | 20,219 | 17,887 | 14,915 | 11,211 | 6,676 |
| 8.25 | 23,931 | 24,734 | 24,304 | 23,529 | 22,350 | 20,705 | 18,523 | 15,724 | 12,220 | 7,916 |
| 8.50 | 23,800 | 24,793 | 24,438 | 23,752 | 22,678 | 21,157 | 19,118 | 16,485 | 13,174 | 9,091 |
| 8.75 | 23,662 | 24,835 | 24,552 | 23,951 | 22,978 | 21,575 | 19,674 | 17,201 | 14,075 | 10,204 |
| 9.00 | 23,518 | 24,863 | 24,648 | 24,128 | 23,252 | 21,961 | 20,192 | 17,873 | 14,924 | 11,258 |
| 9.25 | 23,369 | 24,876 | 24,720 | 24,284 | 23,499 | 22,317 | 20,675 | 18,503 | 15,725 | 12,255 |
| 9.50 | 23,214 | 24,874 | 24,787 | 24,419 | 23,723 | 22,644 | 21,123 | 19,093 | 16,478 | 13,197 |
| 9.75 | 23,053 | 24,860 | 24,831 | 24,535 | 23,923 | 22,944 | 21,539 | 19,644 | 17,187 | 14,087 |
| 10.00 | 22,888 | 24,833 | 24,861 | 24,632 | 24,100 | 23,217 | 21,924 | 20,159 | 17,853 | 14,928 |

AUGUST 79

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERLINE
ECONOMIC FEASIBILITY STUDY

TABLE 8-3X

CASE 1B, 230 kV, GENERATION RESERVE SHARING
PLUS FIRM POWER TRANSFER
TRANSMISSION LINE COSTS INCREASED BY 25%
PROBABLE LOAD FORECAST CASE

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS
INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS
(IN \$1000)

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|--------|--------|--------|--------|--------|--------|---------|---------|---------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 12,411 | 9,113 | 7,326 | 5,026 | 2,136 | -1,430 | -5,769 | -10,987 | -17,202 | -24,544 |
| 8.25 | 12,467 | 9,481 | 7,811 | 5,648 | 2,917 | -465 | -4,591 | -9,564 | -15,499 | -22,522 |
| 8.50 | 12,509 | 9,822 | 8,264 | 6,233 | 3,654 | 449 | -3,473 | -8,211 | -13,876 | -20,591 |
| 8.75 | 12,540 | 10,138 | 8,687 | 6,781 | 4,350 | 1,315 | -2,411 | -6,924 | -12,330 | -18,748 |
| 9.00 | 12,559 | 10,429 | 9,081 | 7,296 | 5,005 | 2,133 | -1,404 | -5,700 | -10,857 | -16,990 |
| 9.25 | 12,567 | 10,697 | 9,448 | 7,778 | 5,621 | 2,906 | -450 | -4,537 | -9,454 | -15,314 |
| 9.50 | 12,565 | 10,943 | 9,788 | 8,228 | 6,201 | 3,636 | 454 | -3,432 | -8,119 | -13,715 |
| 9.75 | 12,554 | 11,168 | 10,103 | 8,649 | 6,740 | 4,325 | 1,310 | -2,383 | -6,848 | -12,190 |
| 10.00 | 12,533 | 11,373 | 10,394 | 9,042 | 7,257 | 4,975 | 2,121 | -1,387 | -5,640 | -10,738 |
| 10.25 | 12,504 | 11,558 | 10,661 | 9,407 | 7,736 | 5,587 | 2,887 | -443 | -4,491 | -9,354 |
| 10.50 | 12,466 | 11,725 | 10,907 | 9,746 | 8,185 | 6,163 | 3,610 | 451 | -3,399 | -8,036 |
| 10.75 | 12,421 | 11,875 | 11,133 | 10,060 | 8,604 | 6,704 | 4,294 | 1,299 | -2,362 | -6,782 |
| 11.00 | 12,369 | 12,008 | 11,338 | 10,351 | 8,995 | 7,212 | 4,938 | 2,102 | -1,378 | -5,588 |
| 11.25 | 12,309 | 12,125 | 11,524 | 10,619 | 9,359 | 7,689 | 5,546 | 2,861 | -444 | -4,453 |
| 11.50 | 12,244 | 12,228 | 11,642 | 10,865 | 9,697 | 8,135 | 6,118 | 3,578 | 442 | -3,374 |
| 11.75 | 12,172 | 12,316 | 11,844 | 11,091 | 10,011 | 8,552 | 6,656 | 4,256 | 1,282 | -2,348 |
| 12.00 | 12,095 | 12,391 | 11,978 | 11,297 | 10,302 | 8,942 | 7,161 | 4,896 | 2,077 | -1,374 |

28 AUGUST 79

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERTIE
ECONOMIC FEASIBILITY STUDY

TABLE 8-3-LL

CASE IB, 230 kV, GENERATION RESERVE SHARING
PLUS FIRM POWER TRANSFER
LOW LOAD FORECAST CASE

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS
INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS
(IN \$1000)

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|-------|-------|-------|--------|--------|--------|--------|--------|--------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | -729 | 4,879 | 6,790 | 8,952 | 11,395 | 14,152 | 17,258 | 20,755 | 24,689 | 29,111 |
| 8.25 | -996 | 4,430 | 6,279 | 8,373 | 10,739 | 13,408 | 16,416 | 19,802 | 23,611 | 27,892 |
| 8.50 | -1,254 | 3,995 | 5,786 | 7,813 | 10,104 | 12,688 | 15,601 | 18,881 | 22,569 | 26,714 |
| 8.75 | -1,503 | 3,575 | 5,309 | 7,271 | 9,490 | 11,993 | 14,814 | 17,990 | 21,562 | 25,576 |
| 9.00 | -1,743 | 3,169 | 4,847 | 6,748 | 8,896 | 11,321 | 14,053 | 17,129 | 20,589 | 24,476 |
| 9.25 | -1,976 | 2,776 | 4,401 | 6,242 | 8,322 | 10,671 | 13,318 | 16,297 | 19,648 | 23,413 |
| 9.50 | -2,200 | 2,396 | 3,969 | 5,752 | 7,767 | 10,042 | 12,606 | 15,493 | 18,738 | 22,385 |
| 9.75 | -2,417 | 2,029 | 3,552 | 5,279 | 7,231 | 9,434 | 11,918 | 14,714 | 17,859 | 21,391 |
| 10.00 | -2,626 | 1,674 | 3,149 | 4,821 | 6,711 | 8,846 | 11,253 | 13,962 | 17,008 | 20,431 |
| 10.25 | -2,828 | 1,331 | 2,759 | 4,378 | 6,209 | 8,278 | 10,609 | 13,234 | 16,186 | 19,502 |
| 10.50 | -3,023 | 999 | 2,381 | 3,949 | 5,724 | 7,727 | 9,987 | 12,530 | 15,390 | 18,603 |
| 10.75 | -3,212 | 678 | 2,016 | 3,535 | 5,254 | 7,195 | 9,384 | 11,849 | 14,621 | 17,734 |
| 11.00 | -3,394 | 368 | 1,664 | 3,134 | 4,799 | 6,680 | 8,802 | 11,190 | 13,876 | 16,894 |
| 11.25 | -3,569 | 67 | 1,322 | 2,747 | 4,360 | 6,182 | 8,238 | 10,553 | 13,156 | 16,081 |
| 11.50 | -3,739 | -223 | 992 | 2,372 | 3,934 | 5,700 | 7,693 | 9,936 | 12,460 | 15,294 |
| 11.75 | -3,902 | -503 | 673 | 2,009 | 3,523 | 5,234 | 7,165 | 9,339 | 11,785 | 14,533 |
| 12.00 | -4,060 | -775 | 364 | 1,658 | 3,124 | 4,783 | 6,654 | 8,762 | 11,133 | 13,797 |

23 AUGUST 79

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERTIE
ECONOMIC FEASIBILITY STUDY

TABLE 8-4

CASE IB: , 230 kV, GENERATION RESERVE SHARING PLUS
FIRM POWER TRANSFER & SUSITNA PROJECT CONSTRUCTION POWER
PROBABLE LOAD FORECAST CASE

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS
INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS
(IN \$1000)

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 31,206 | 32,272 | 31,731 | 30,748 | 29,249 | 27,151 | 24,364 | 20,785 | 16,303 | 10,791 |
| 8.25 | 31,057 | 32,350 | 31,908 | 31,041 | 29,679 | 27,742 | 25,143 | 21,783 | 17,552 | 12,330 |
| 8.50 | 30,859 | 32,407 | 32,058 | 31,502 | 30,072 | 28,289 | 25,870 | 22,719 | 18,730 | 13,787 |
| 8.75 | 30,672 | 32,443 | 32,183 | 31,534 | 30,429 | 28,794 | 26,547 | 23,597 | 19,840 | 15,164 |
| 9.00 | 30,478 | 32,460 | 32,285 | 31,736 | 30,751 | 29,258 | 27,177 | 24,418 | 20,884 | 16,465 |
| 9.25 | 30,276 | 32,458 | 32,463 | 31,912 | 31,042 | 29,684 | 27,761 | 25,187 | 21,866 | 17,694 |
| 9.50 | 30,068 | 32,438 | 32,421 | 32,062 | 31,301 | 30,072 | 28,301 | 25,904 | 22,789 | 18,852 |
| 9.75 | 29,853 | 32,402 | 32,458 | 32,187 | 31,531 | 30,426 | 28,800 | 26,572 | 23,653 | 19,945 |
| 10.00 | 29,633 | 32,351 | 32,476 | 32,288 | 31,733 | 30,746 | 29,259 | 27,194 | 24,464 | 20,973 |
| 10.25 | 29,407 | 32,284 | 32,476 | 32,368 | 31,908 | 31,034 | 29,680 | 27,770 | 25,222 | 21,940 |
| 10.50 | 29,176 | 32,204 | 32,458 | 32,426 | 32,057 | 31,292 | 30,065 | 28,305 | 25,929 | 22,849 |
| 10.75 | 28,941 | 32,110 | 32,424 | 32,465 | 32,182 | 31,520 | 30,416 | 28,798 | 26,589 | 23,702 |
| 11.00 | 28,702 | 32,003 | 32,374 | 32,484 | 32,285 | 31,721 | 30,733 | 29,253 | 27,203 | 24,501 |
| 11.25 | 28,458 | 31,885 | 32,310 | 32,486 | 32,365 | 31,896 | 31,020 | 29,670 | 27,773 | 25,249 |
| 11.50 | 28,211 | 31,756 | 32,232 | 32,470 | 32,425 | 32,046 | 31,276 | 30,052 | 28,302 | 25,948 |
| 11.75 | 27,961 | 31,616 | 32,140 | 32,438 | 32,465 | 32,172 | 31,504 | 30,399 | 28,790 | 26,600 |
| 12.00 | 27,709 | 31,466 | 32,037 | 32,391 | 32,486 | 32,275 | 31,704 | 30,715 | 29,240 | 27,207 |

23 AUGUST 79

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERIE
ECONOMIC FEASIBILITY STUDY

TABLE 8-4X

CASE IB, 230 kV, GENERATION RESERVE SHARING PLUS
FIRM POWER TRANSFER & SUSITNA CONSTRUCTION POWER
TRANSMISSION LINE COSTS INCREASED BY 25%
PROBABLE LOAD FORECAST CASE

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS
INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS
(IN \$1000)

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 18,891 | 18,069 | 17,024 | 15,523 | 13,492 | 10,849 | 7,502 | 3,350 | -1,721 | -7,835 |
| 8.25 | 18,825 | 18,266 | 17,324 | 15,944 | 14,055 | 11,578 | 8,424 | 4,495 | -319 | -6,139 |
| 8.50 | 18,749 | 18,441 | 17,596 | 16,332 | 14,579 | 12,260 | 9,291 | 5,576 | 1,009 | -4,527 |
| 8.75 | 18,663 | 18,594 | 17,842 | 16,688 | 15,065 | 12,899 | 10,108 | 6,598 | 2,268 | -2,995 |
| 9.00 | 18,569 | 18,726 | 18,063 | 17,015 | 15,516 | 13,496 | 10,875 | 7,562 | 3,460 | -1,542 |
| 9.25 | 18,466 | 18,838 | 18,260 | 17,313 | 15,934 | 14,053 | 11,595 | 8,471 | 4,588 | -163 |
| 9.50 | 18,355 | 18,931 | 18,435 | 17,584 | 16,319 | 14,572 | 12,270 | 9,328 | 5,654 | 1,145 |
| 9.75 | 18,237 | 19,007 | 18,588 | 17,829 | 16,673 | 15,054 | 12,902 | 10,134 | 6,661 | 2,385 |
| 10.00 | 18,112 | 19,066 | 18,720 | 18,049 | 16,997 | 15,502 | 13,492 | 10,892 | 7,613 | 3,559 |
| 10.25 | 17,980 | 19,109 | 18,833 | 18,246 | 17,294 | 15,916 | 14,044 | 11,603 | 8,510 | 4,671 |
| 10.50 | 17,843 | 19,136 | 18,927 | 18,421 | 17,564 | 16,298 | 14,558 | 12,271 | 9,356 | 5,722 |
| 10.75 | 17,700 | 19,149 | 19,004 | 18,574 | 17,808 | 16,650 | 15,036 | 12,896 | 10,152 | 6,716 |
| 11.00 | 17,552 | 19,149 | 19,064 | 18,707 | 18,028 | 16,972 | 15,480 | 13,481 | 10,901 | 7,655 |
| 11.25 | 17,399 | 19,135 | 19,108 | 18,821 | 18,225 | 17,268 | 15,691 | 14,028 | 11,605 | 8,541 |
| 11.50 | 17,242 | 19,109 | 19,138 | 18,916 | 18,400 | 17,537 | 16,271 | 14,537 | 12,266 | 9,377 |
| 11.75 | 17,080 | 19,072 | 19,153 | 18,994 | 18,553 | 17,781 | 16,621 | 15,012 | 12,885 | 10,164 |
| 12.00 | 16,915 | 19,024 | 19,154 | 19,056 | 18,687 | 18,001 | 16,942 | 15,452 | 13,464 | 10,905 |

8-17

TABLE 8-4X

23 AUGUST 79

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERTIE
ECONOMIC FEASIBILITY STUDY

TABLE 8-5

CASE ID, 230 KV, GENERATION RESERVE SHARING
WITH INTERMEDIATE SUBSTATIONS
PROBABLE LOAD FORECAST CASE

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS
INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS
(IN \$1000)

| DISCOUNT RATE | ----- ESCALATION RATES ----- | | | | | | | | | |
|------------------|------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| | ===== | ===== | ===== | ===== | ===== | ===== | ===== | ===== | ===== | ===== |
| 8.00 | 18,460 | 17,550 | 16,592 | 15,239 | 13,431 | 11,100 | 8,168 | 4,552 | 157 | -5,122 |
| 8.25 | 18,406 | 17,728 | 16,858 | 15,610 | 13,924 | 11,735 | 8,967 | 5,541 | 1,363 | -3,665 |
| 8.50 | 18,343 | 17,886 | 17,101 | 15,955 | 14,384 | 12,330 | 9,721 | 6,476 | 2,508 | -2,280 |
| 8.75 | 18,272 | 18,026 | 17,322 | 16,269 | 14,812 | 12,889 | 10,431 | 7,362 | 3,595 | -963 |
| 9.00 | 18,194 | 18,148 | 17,521 | 16,560 | 15,210 | 13,413 | 11,100 | 8,198 | 4,625 | 289 |
| 9.25 | 18,108 | 18,253 | 17,700 | 16,827 | 15,580 | 13,902 | 11,729 | 8,989 | 5,601 | 1,478 |
| 9.50 | 18,016 | 18,343 | 17,860 | 17,070 | 15,922 | 14,359 | 12,520 | 9,734 | 6,525 | 2,608 |
| 9.75 | 17,918 | 18,417 | 18,002 | 17,292 | 16,238 | 14,785 | 12,874 | 10,438 | 7,400 | 3,680 |
| 10.00 | 17,814 | 18,476 | 18,126 | 17,492 | 16,528 | 15,182 | 13,594 | 11,100 | 8,228 | 4,696 |
| 10.25 | 17,704 | 18,522 | 18,234 | 17,673 | 16,795 | 15,550 | 13,880 | 11,723 | 9,009 | 5,660 |
| 10.50 | 17,589 | 18,555 | 18,325 | 17,835 | 17,040 | 15,891 | 14,335 | 12,309 | 9,747 | 6,574 |
| 10.75 | 17,470 | 18,576 | 18,402 | 17,978 | 17,262 | 16,207 | 14,759 | 12,860 | 10,444 | 7,438 |
| 11.00 | 17,346 | 18,585 | 18,464 | 18,104 | 17,464 | 16,497 | 15,154 | 13,376 | 11,100 | 8,256 |
| 11.25 | 17,217 | 18,582 | 18,513 | 18,214 | 17,646 | 16,765 | 15,521 | 13,859 | 11,718 | 9,030 |
| 11.50 | 17,085 | 18,569 | 18,548 | 18,307 | 17,809 | 17,009 | 15,861 | 14,311 | 12,299 | 9,760 |
| 11.75 | 16,949 | 18,547 | 18,572 | 18,386 | 17,954 | 17,232 | 16,176 | 14,733 | 12,845 | 10,450 |
| 12.00 | 16,810 | 18,514 | 18,583 | 18,451 | 18,082 | 17,435 | 16,467 | 15,126 | 13,358 | 11,100 |

23 AUGUST 79

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERTIE
ECONOMIC FEASIBILITY STUDY

TABLE 8-5X

CASE ID, GENERATION RESERVE SHARING PLUS
INTERMEDIATE SUBSTATIONS
TRANSMISSION LINE COSTS INCREASED BY 25%
PROBABLE LOAD FORECAST CASE

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS
INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS
(IN \$1000)

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|-------|-------|-------|-------|--------|--------|--------|---------|---------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| | ===== | ===== | ===== | ===== | ===== | ===== | ===== | ===== | ===== | ===== |
| 8.00 | 9,155 | 6,772 | 5,420 | 5,663 | 1,439 | -1,319 | -4,689 | -8,755 | -13,611 | -19,363 |
| 8.25 | 9,181 | 7,043 | 5,783 | 4,133 | 2,036 | -577 | -3,778 | -7,651 | -12,285 | -17,783 |
| 8.50 | 9,197 | 7,294 | 6,121 | 4,575 | 2,598 | 125 | -2,915 | -6,601 | -11,022 | -16,276 |
| 8.75 | 9,205 | 7,524 | 6,436 | 4,989 | 3,128 | 789 | -2,095 | -5,603 | -9,819 | -14,838 |
| 9.00 | 9,204 | 7,736 | 6,729 | 5,377 | 3,626 | 1,417 | -1,319 | -4,655 | -8,673 | -13,466 |
| 9.25 | 9,195 | 7,931 | 7,001 | 5,740 | 4,095 | 2,009 | -584 | -3,754 | -7,583 | -12,159 |
| 9.50 | 9,179 | 8,108 | 7,252 | 6,078 | 4,535 | 2,568 | 113 | -2,899 | -6,546 | -10,912 |
| 9.75 | 9,155 | 8,269 | 7,484 | 6,393 | 4,948 | 3,094 | 771 | -2,088 | -5,559 | -9,725 |
| 10.00 | 9,125 | 8,415 | 7,697 | 6,686 | 5,335 | 3,590 | 1,394 | -1,319 | -4,621 | -8,594 |
| 10.25 | 9,089 | 8,546 | 7,893 | 6,959 | 5,697 | 4,057 | 1,982 | -590 | -3,730 | -7,517 |
| 10.50 | 9,047 | 8,663 | 8,072 | 7,211 | 6,035 | 4,495 | 2,538 | 100 | -2,884 | -6,492 |
| 10.75 | 8,999 | 8,767 | 8,235 | 7,444 | 6,350 | 4,907 | 3,061 | 754 | -2,081 | -5,516 |
| 11.00 | 8,946 | 8,858 | 8,383 | 7,658 | 6,644 | 5,293 | 3,555 | 1,372 | -1,319 | -4,589 |
| 11.25 | 8,888 | 8,938 | 8,516 | 7,856 | 6,917 | 5,654 | 4,020 | 1,956 | -596 | -3,707 |
| 11.50 | 8,825 | 9,006 | 8,636 | 8,036 | 7,170 | 5,992 | 4,456 | 2,508 | 88 | -2,870 |
| 11.75 | 8,758 | 9,063 | 8,742 | 8,201 | 7,404 | 6,308 | 4,867 | 3,029 | 737 | -2,074 |
| 12.00 | 8,687 | 9,109 | 8,835 | 8,351 | 7,620 | 6,602 | 5,252 | 3,520 | 1,350 | -1,319 |

23 AUGUST 79

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERLIF
ECONOMIC FEASIBILITY STUDY

TABLE 8-6

CASE ID, 230 kV, GENERATION RESERVE SHARING
WITH INTERMEDIATE SUBSTATIONS & SUSITNA CONSTRUCTION POWER
PROBABLE LOAD FORECAST CASE

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS
INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS
(IN \$1000)

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 21,345 | 21,367 | 20,677 | 19,609 | 18,101 | 16,085 | 13,486 | 10,219 | 6,190 | 1,296 |
| 8.25 | 21,244 | 21,483 | 20,877 | 19,909 | 18,518 | 16,639 | 14,200 | 11,117 | 7,301 | 2,651 |
| 8.50 | 21,134 | 21,580 | 21,055 | 20,182 | 18,903 | 17,156 | 14,869 | 11,964 | 8,352 | 3,937 |
| 8.75 | 21,018 | 21,660 | 21,212 | 20,430 | 19,259 | 17,637 | 15,497 | 12,762 | 9,346 | 5,156 |
| 9.00 | 20,895 | 21,723 | 21,348 | 20,653 | 19,585 | 18,085 | 16,085 | 13,513 | 10,285 | 6,312 |
| 9.25 | 20,766 | 21,770 | 21,465 | 20,854 | 19,884 | 18,499 | 16,634 | 14,218 | 11,172 | 7,407 |
| 9.50 | 20,630 | 21,803 | 21,565 | 21,033 | 20,157 | 18,883 | 17,147 | 14,881 | 12,008 | 8,443 |
| 9.75 | 20,490 | 21,821 | 21,647 | 21,191 | 20,405 | 19,237 | 17,625 | 15,503 | 12,797 | 9,423 |
| 10.00 | 20,344 | 21,826 | 21,712 | 21,329 | 20,629 | 19,562 | 18,069 | 16,085 | 13,539 | 10,350 |
| 10.25 | 20,194 | 21,818 | 21,762 | 21,448 | 20,831 | 19,860 | 18,481 | 16,630 | 14,237 | 11,226 |
| 10.50 | 20,039 | 21,798 | 21,797 | 21,549 | 21,011 | 20,133 | 18,862 | 17,138 | 14,893 | 12,052 |
| 10.75 | 19,880 | 21,766 | 21,818 | 21,633 | 21,170 | 20,381 | 19,215 | 17,612 | 15,508 | 12,831 |
| 11.00 | 19,717 | 21,724 | 21,826 | 21,701 | 21,309 | 20,606 | 19,539 | 18,053 | 16,085 | 13,564 |
| 11.25 | 19,551 | 21,672 | 21,821 | 21,753 | 21,430 | 20,808 | 19,837 | 18,463 | 16,625 | 14,255 |
| 11.50 | 19,382 | 21,610 | 21,804 | 21,791 | 21,533 | 20,988 | 20,109 | 18,842 | 17,129 | 14,904 |
| 11.75 | 19,209 | 21,539 | 21,776 | 21,815 | 21,619 | 21,149 | 20,357 | 19,193 | 17,600 | 15,514 |
| 12.00 | 19,034 | 21,459 | 21,737 | 21,825 | 21,689 | 21,290 | 20,582 | 19,516 | 18,038 | 16,085 |

8 - 20

TABLE 8-6

23 AUGUST 79

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERTIE
ECONOMIC FEASIBILITY STUDY

TABLE 8-6X

CASE ID, 230 KV, GENERATION RESERVE SHARING
WITH INTERMEDIATE SUBSTATIONS & SUSITNA CONSTRUCTION POWER
TRANSMISSION LINE COST INCREASED BY 25%
PROBABLE LOAD FORECAST CASE

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS
INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS
(IN \$1000)

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|--------|--------|--------|--------|--------|-------|--------|--------|---------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 6.00 | 12,040 | 10,589 | 9,506 | 8,032 | 6,108 | 3,666 | 629 | -3,088 | -7,578 | -12,946 |
| 8.25 | 12,018 | 10,798 | 9,802 | 8,432 | 6,629 | 4,328 | 1,454 | -2,074 | -6,348 | -11,467 |
| 8.50 | 11,968 | 10,987 | 10,075 | 8,804 | 7,117 | 4,951 | 2,234 | -1,113 | -5,179 | -10,059 |
| 8.75 | 11,951 | 11,158 | 10,326 | 9,150 | 7,574 | 5,537 | 2,971 | -203 | -4,068 | -8,719 |
| 9.00 | 11,905 | 11,311 | 10,556 | 9,470 | 8,001 | 6,089 | 3,666 | 660 | -3,013 | -7,443 |
| 9.25 | 11,852 | 11,147 | 10,766 | 9,767 | 8,400 | 6,606 | 4,322 | 1,476 | -2,012 | -6,230 |
| 9.50 | 11,793 | 11,568 | 10,956 | 10,040 | 8,771 | 7,091 | 4,940 | 2,248 | -1,063 | -5,077 |
| 9.75 | 11,727 | 11,673 | 11,128 | 10,292 | 9,116 | 7,546 | 5,522 | 2,977 | -163 | -3,981 |
| 10.00 | 11,656 | 11,764 | 11,283 | 10,523 | 9,436 | 7,971 | 6,069 | 3,666 | 690 | -2,940 |
| 10.25 | 11,579 | 11,842 | 11,421 | 10,733 | 9,732 | 8,367 | 6,583 | 4,316 | 1,497 | -1,952 |
| 10.50 | 11,496 | 11,906 | 11,544 | 10,925 | 10,006 | 8,737 | 7,065 | 4,929 | 2,261 | -1,014 |
| 10.75 | 11,409 | 11,958 | 11,651 | 11,099 | 10,258 | 9,082 | 7,517 | 5,506 | 2,983 | -124 |
| 11.00 | 11,318 | 11,998 | 11,745 | 11,255 | 10,489 | 9,401 | 7,940 | 6,050 | 3,666 | 719 |
| 11.25 | 11,222 | 12,027 | 11,824 | 11,395 | 10,701 | 9,698 | 8,336 | 6,560 | 4,310 | 1,518 |
| 11.50 | 11,122 | 12,046 | 11,891 | 11,520 | 10,894 | 9,972 | 8,704 | 7,040 | 4,918 | 2,274 |
| 11.75 | 11,018 | 12,055 | 11,946 | 11,629 | 11,069 | 10,224 | 9,048 | 7,489 | 5,491 | 2,990 |
| 12.00 | 10,911 | 12,054 | 11,989 | 11,725 | 11,227 | 10,456 | 9,367 | 7,911 | 6,031 | 3,666 |

23 AUGUST 79

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERTIE
ECONOMIC FEASIBILITY STUDY

TABLE 8-7

CASE IC , 345 kV, GENERATION RESERVE SHARING PLUS
FIRM POWER TRANSFER & SUSITNA PROJECT CONSTRUCTION POWER
PROBABLE LOAD FORECAST

DIFFERENTIAL DISCOUNTED VALUE OF BASE YEAR (1979) COSTS
INDEPENDENT SYSTEM COSTS MINUS INTERCONNECTED SYSTEM COSTS
(IN \$1000)

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|--------|--------|---------|---------|---------|---------|---------|---------|---------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| | ===== | ===== | ===== | ===== | ===== | ===== | ===== | ===== | ===== | ===== |
| 8.00 | -1,444 | -6,495 | -8,036 | -11,240 | -14,375 | -18,110 | -22,547 | -27,760 | -33,860 | -40,959 |
| 8.25 | -1,277 | -6,035 | -8,069 | -10,549 | -13,540 | -17,115 | -21,354 | -26,349 | -32,198 | -39,013 |
| 8.50 | -1,122 | -5,601 | -7,532 | -9,892 | -12,745 | -16,159 | -20,215 | -24,999 | -30,608 | -37,148 |
| 8.75 | -979 | -5,190 | -7,023 | -9,268 | -11,987 | -15,249 | -19,128 | -23,709 | -29,087 | -35,363 |
| 9.00 | -848 | -4,802 | -6,540 | -8,675 | -11,267 | -14,381 | -18,090 | -22,477 | -27,631 | -33,653 |
| 9.25 | -728 | -4,430 | -6,083 | -8,113 | -10,582 | -13,554 | -17,100 | -21,299 | -26,239 | -32,016 |
| 9.50 | -618 | -4,091 | -5,651 | -7,579 | -9,930 | -12,760 | -16,155 | -20,174 | -24,907 | -30,449 |
| 9.75 | -517 | -3,760 | -5,242 | -7,073 | -9,311 | -12,010 | -15,254 | -19,099 | -23,634 | -28,949 |
| 10.00 | -420 | -3,459 | -4,856 | -6,544 | -8,723 | -11,302 | -14,395 | -18,073 | -22,417 | -27,513 |
| 10.25 | -344 | -3,171 | -4,492 | -6,139 | -8,164 | -10,622 | -13,570 | -17,094 | -21,253 | -26,139 |
| 10.50 | -270 | -2,901 | -4,147 | -5,709 | -7,634 | -9,976 | -12,795 | -16,159 | -20,141 | -24,825 |
| 10.75 | -205 | -2,647 | -3,823 | -5,302 | -7,131 | -9,361 | -12,052 | -15,267 | -19,079 | -23,567 |
| 11.00 | -146 | -2,409 | -3,517 | -4,917 | -6,654 | -8,777 | -11,343 | -14,416 | -18,064 | -22,365 |
| 11.25 | -95 | -2,180 | -3,230 | -4,554 | -6,201 | -8,222 | -10,669 | -13,604 | -17,094 | -21,215 |
| 11.50 | -51 | -1,978 | -2,959 | -4,210 | -5,773 | -7,694 | -10,027 | -12,830 | -16,169 | -20,115 |
| 11.75 | -13 | -1,783 | -2,705 | -3,880 | -5,307 | -7,194 | -9,417 | -12,093 | -15,285 | -19,065 |
| 12.00 | 18 | -1,602 | -2,467 | -3,581 | -4,984 | -6,719 | -8,830 | -11,390 | -14,442 | -18,060 |

CHAPTER 9
FINANCIAL PLANNING CONCEPTS

CHAPTER 9

FINANCIAL PLANNING CONCEPTS

The approach taken towards the financial planning for the intertie facilities represents an initial effort to structure the financial package required to implement the Railbelt interconnection. The concepts included in this chapter are intended to be representative of the conditions under which funding would proceed but are in no way definitive recommendations. Rather, they are anticipated to stimulate discussion amongst the participants and increase the understanding of projected financial obligations.

The proportionate allocation of total project costs between participants has been determined in relation to the tangible cost savings derived from the interconnection and represent an equitable division of the total financial burden. The acceptance of these allocations by participants to an Alaska Intertie Agreement (AIA) will require individual utility financial positions to be evaluated. Provision has been made for projected debt service to be analyzed for each participant, to facilitate the evaluation of financial impact on individual utility operations. What follows is an initial exploration of possible financial arrangements, which will serve as a starting point for successive evaluations by each potential participant as more definitive financial plans are evolved.

9.1 SOURCES OF FUNDS

An initial appraisal of possible sources of funds has been made, to determine a combination which will be both financially advantageous and appropriate to the principal division of cost savings between REA and municipal utilities.

The following sources were examined:

- State of Alaska revenue bonds floated by APA
- REA loans negotiated by APA and participants
- FFB loans negotiated as part of REA loan package
- CFC loans negotiated in conjunction with REA loans
- Municipal bond issues by Anchorage and Fairbanks

A. State of Alaska Revenue Bonds

As State of Alaska revenue bonds would be legally secured by project revenues, a complex formula for revenue generation would be required to arrive at an acceptable level of cash flow to repay the bonds. The formulation could be based on wheeling charges for power flow over the intertie but the number of participants and the differences between their operational requirements could prove an insuperable obstacle to the realization of a final agreement. It is thought that the issue of State bonds should be deferred from present consideration, until such time as a combined generation and transmission project is ready for funding. Within the confines of the Railbelt development, this would be appropriate when consideration is given to the financing of the first hydropower development of the Upper Susitna Project, together with its associated transmission facilities.

Although APA bonds have been retained in the Transmission Line Financial Analysis Program (TLFAP), for analytical purposes, consideration has been given only to the remaining sources in these initial financial plans for implementation of the intertie. The transmission intertie facilities represent what may be regarded as the first stage development of the ultimate transmission system that will be required for the Watana and Devil Canyon hydropower plants of the Upper Susitna Project.

The financial sources discussed in the following sections were considered for composite funding of the Anchorage-Fairbanks Interconnection.

B. Rural Electrification Administration (REA)

The prospective participants, with the exception of the Anchorage and Fairbanks municipal systems, are all REA utilities of the Alaska District. Therefore, a combination of REA insured and guaranteed loans is assumed for the maximum amount of total project financial requirements allowed by federal regulations. REA loans are normally limited to 70 percent of total project costs; however, as OMB restrictions are expected to affect future REA commitments for project funding, this 70 percent limitation was taken to be the magnitude of a loan package comprising both REA and FFB loans. The percentage division between the two sources varies, recent past experience and future projections indicating a range of possibilities, with the FFB portion considerably larger than that of REA.

In the present study, a range of between 20/80 and 40/60 for the combination of REA/FFB loan funds has been assumed for analytical purposes, these percentages being applied to the 70 percent limit for the total loan package, as a proportion of total project costs.

REA loans carry a 5 percent interest rate and have a repayment period of 35 years, the first three years of which require interest only.

C. Federal Financing Bank (FFB)

REA makes guaranteed loans through FFB as a source of supplementary funding for REA utilities. Interest rates for FFB vary but are generally within the range of 9 to 9-1/2 percent. An average of 9-1/4 percent has been used in the financial analysis for this study. A similar 35 year repayment period to that for REA insured loans is normal, with the first three years of interest only also applicable.

The combination REA/FFB loan package offers a means of financing 70 percent of project costs with a minimum of negotiation, as precedents have

been set for this type of financial arrangement. The goal of negotiation would be to maximize the REA loan portion and secure the best interest rate applicable to the FFB loan.

D. National Rural Utilities Cooperative Finance Corporation (CFC)

CFC makes loans to REA utilities to supplement REA funds, although these loans are generally used for distribution type facilities. It is possible that a CFC loan could be obtained for a transmission project such as the Intertie but for purposes of this analysis it has been assumed that CFC funding will not be required. If at the time of negotiation there is a definite advantage to be gained by inclusion of a CFC loan portion with sufficiently attractive terms, the resultant impact on the financial plan can be determined.

E. Municipal Bonds

Anchorage and Fairbanks municipalities both have the authority to arrange financing for a portion of the project by the issuance of tax-exempt, general obligation bonds. As separate bond issues would possibly be made, the bonding rate pertaining to Anchorage could differ from that of Fairbanks. A recent bond issue by the Anchorage Municipal Bond Bank to cover G & T expansion on the AML & P system realized a bond rate of 6.48 percent, with 20 year maturity bonds. A rate of 6.5 percent has been used in this study for the projected Anchorage bonds, with a somewhat more conservative level of 7 percent assumed for the Fairbanks bonding. Both sets of bonds were assumed to be of 20 year maturity.

9.2 PROPORTIONAL ALLOCATIONS BETWEEN SOURCES

In the ultimate financial package for the Transmission Intertie, the final negotiated amounts for debt financing and bonding will be agreed to by APA and AIA participants. To arrive at the final allocation of total project costs between possible sources will require a concerted effort on the part of APA and AIA participants, in the successive negotiations with REA and other federal funding agencies such as FFB, together with the officials responsible for decisions relating to issuance of municipal bonds.

To assist with an evaluation of financial positions in relation to possible agreement on questions pertaining to proportional allocations between sources, the Consultants offer the following approach for further consideration.

- A combination of REA and FFB funds would be used to finance a total of 70 percent of project costs. In order to examine the relative improvement of composite financial terms by changes to the percentage allocation between the two sources over a range of combinations, the following allocations were evaluated:

| | <u>Combination REA/FFB - %</u> | |
|-----------------------------------|--------------------------------|-------|
| Allocation within loan package | 20/80 | 40/60 |
| Allocation of total project costs | 14/56 | 28/42 |

- The balance of funding, 30 percent of project costs, would be obtained from the following bond issues:

| | <u>General Obligation Bonds</u> | |
|---------------------------------------|---------------------------------|-----------|
| | Anchorage | Fairbanks |
| Percentage allocation by municipality | 18 | 12 |

In preparing a financial plan to follow this approach the following analysis was completed using computer programs TLFAP and COMPARE. The results of this analysis are contained in Appendix F, Sheets F-1 thru F-29.

1. An initial run of TLFAP was made with the following allocations and assumptions for funding terms and conditions:

| <u>Project Funding</u> | <u>Source</u> | <u>Interest Rate</u> |
|------------------------|---------------|----------------------|
| 14% | REA | 5% |
| 56% | FFB | 9.25% |

Above loans have 35 year repayment period with interest only for first three years, during construction period.

| | | |
|-----|-----|------|
| 18% | AMU | 6.5% |
| 12% | FMU | 7.0% |

Above bond issues have 20 year maturity.

2. On the assumption that the overall financial terms can be improved by changing the proportions of the combination REA/FFB loan package, a second run of TLFAP was made with the following adjustments:

| <u>Project Funding</u> | <u>Source</u> | <u>Interest Rate</u> |
|------------------------|---------------|----------------------|
| 28% | REA | 5% |
| 42% | FFB | 9.25% |

All other components of project funding remained the same.

It is of interest to compare the composite interest rate for project funding to determine the overall improvement in financial terms. The net effect was a decrease from 8.9 to 8.3 percent for the entire project funding, including all financial sources.

3. To translate this improvement into a present value for purposes of comparison of the respective loan packages, two runs were made using program COMPARE to determine the differential present value of future debt service associated with the two REA/FFB combinations. A net reduction of \$1,472,000 in total financial costs was realized. These computations are shown on Sheets F-27 thru F-29.

9.3 ALLOCATED FINANCIAL RESPONSIBILITY FOR PARTICIPANTS

A. Basis for Assumption of Financial Obligation

The approach followed to determine the allocated responsibility for financial participation and debt service matched the proportions of total project costs to allocated cost savings derived from interconnection. The cost savings to be realized from implementation of the transmission intertie are several, these being derived from:

1. Reserve capacity sharing, resulting in cancellation or postponement of in-service dates for certain generating units that would be required with independent system expansion. This in turn results in a reduction of total capital investment.
2. Improvement in overall economics of system operation, within the limits of potential power transfers over the intertie.
3. Reduction in capital expenditures for transmission expansion that would be required if the intertie were not built. A definite saving of this type would be realized by Matanuska Electric Association (MEA) if their system could be supplied from the Palmer bus.
4. Reduction in the cost of construction power for the Susitna Project, by use of a transmission tap-line.

Of the above cost savings, the first and third have been fully quantified in this study, the second would require a detailed computer analysis of the operational costs using a multi-area production costing program. In estimating the cost advantages of power transfer, a simplified analysis was made of the potential economies to be obtained from substitution of selected generation blocks on the basis of fuel cost only. This demonstrates adequately the potential for cost saving but is no substitute for a comprehensive analysis of system operation. This would provide a breakdown

by year of the production cost for each unit on the system, whether independent or interconnected, and would include both fuel and O & M components. The simulation of economic dispatch for units on alternative systems is essential for a definitive apportionment of the operational savings between utility participants.

Accordingly, the allocation of cost savings has been determined on the basis of reduction in capital investment by reserve sharing and the elimination of certain expenditures by MEA for transmission expansion. The cost savings to the Susitna Project is not germane to the financial allocations between utilities and has been excluded from analysis.

The cost savings from reserve sharing have been determined by segregating capital disbursements for generating units affected by interconnection between the respective utilities owning and operating the particular units. Table 9-1 indicates the annual capital disbursements by generating utility for independent and interconnected system expansion, together with the cumulative present worth for each of the investment streams.

Cost savings for each participating utility are given by the differential present worth between independent and interconnected investment streams. To these are added the cost savings to MEA for elimination of alternative transmission supply facilities by establishment of the Palmer bus. The cost savings are derived as follows:

| <u>Participating Utility</u> | <u>Present Worth of Future Investment - \$1000</u> | | |
|----------------------------------|--|-----------------------|---------------------|
| | <u>Independent</u> | <u>Interconnected</u> | <u>Cost Savings</u> |
| AML&P | 103,647 | 91,869 | 11,778 |
| CEA | 236,840 | 229,941 | 6,899 |
| MEA | | | 2,097* |
| GVEA | 43,203 | - | <u>43,203</u> |
| | | TOTAL | 63,977 |

* MEA Cost savings obtained from Section 8.3C on P.8-6.

The large magnitude of savings accruing to GVEA (68% of total) should be subdivided between GVEA and FMUS, as the municipal system will also benefit directly by association with GVEA and the continued purchase of power generated by GVEA will ultimately be reflected in the customer rates of the FMUS service area. To approximate the division of savings, a long-term average ratio between load forecasts for the two systems in the Fairbanks area was taken to be representative of relative magnitudes and resulted in the following apportionment:

| | GVEA | FMUS |
|---------------------------------------|------|------|
| Percentage Allocation of Cost Savings | 56 | 12 |

No further breakdown of allocated benefits was deemed appropriate at this stage; however, it may well be that other utilities such as Homer Electric Association (HEA) may decide to assume a minor share of the responsibility for debt service of the total investment in support of the project. In which case non-generating utilities can participate on an elective basis and future analysis can take into consideration minimum funding participation as a percentage of the total. The only utility which is not an immediate direct beneficiary of the intertie is CVEA. Although TLFAP contains a provision for later participation by this utility, it is not anticipated that CVEA will exercise this option prior to the connection of the Glennallen-Valdez system to the Railbelt system, following completion of the first stage development of the Upper Susitna Project.

The assumption of financial obligation was taken to be directly related to the proportionate division of allocated cost savings. The basis for financial apportionment of total project costs is as follows:

| <u>Participating Utility</u> | <u>Cost Savings \$ 1000</u> | <u>Percentage Participation</u> |
|----------------------------------|---------------------------------|-------------------------------------|
| AML&P | 11,778 | 18 |
| CEA | 6,899 | 11 |
| MEA | 2,097 | 3 |
| GVEA | 35,827 | 56 |
| FMUS | 7,677 | 12 |
| TOTAL | <u>63,977</u> | <u>100</u> |

These values of percentage participation were used for financial analysis.

B. Allocation of Total Project Costs

An attempt was made to relate the allocation of project costs between participants to physical facilities in sections of the intertie. Table 9-2 contains a division of total project costs on a percentage basis and a breakdown of percentage allocations between participants, to relate their percentage allocation of total project costs with projected potential ownership of physical facilities within their own service area.

The allocation of costs was aided by considering the logical division of the total facility into three sections:

| <u>Section</u> | <u>From</u> | <u>To</u> | <u>Distance (Miles)</u> | <u>% Total</u> |
|----------------|-------------|-----------|-------------------------|----------------|
| I | Anchorage | Palmer | 40 | 12 |
| II | Palmer | Healy | 191 | 59 |
| III | Healy | Ester | 92 | 29 |

The costs included in Table 9-2 pertain to Case ID transmission facilities for the probable load forecast expansion, consisting of a single-circuit 230 kV transmission line with intermediate switching at Palmer and Healy. This also allows the realization of investment participation by MEA in the AIA to the extent indicated in Table 9-2, which corresponds to the allocated percentage for MEA. These costs are assumed to be largely associated with the Palmer substation. Similarly, the costs allocated to FMUS are assumed to be related to the Healy-Ester line section, on a joint basis with GVEA.

C. Allocation of Debt Repayment and Sinking Fund Payments

The responsibility for loan servicing and payment of sinking fund installments is shared by utility participants, in direct proportion to the cost savings derived from the interconnection. A tabulation of the annual payments by each participating utility is given in Appendix F, Sheets F-13 through F-18. It should be noted that the annual payments do include the pro-rata share of payments to the municipal bond sinking funds tabulated on Sheets F-19 and F-20. The totals are given on Sheets F-21 through F-26.

9.4 COSTS FOR RESERVE SHARING AND FIRM POWER TRANSFER

An analysis was made of the relative costs of reserve capacity and firm power transfer for the two alternative financial plans. Tables 9-3A and B provide annual costs for reserve capacity and firm power transfer based upon the total debt service per year required for the two alternative financial plans, including REA/FFB loan packages in two proportionate combinations.

The division of costs between reserve capacity sharing and firm power transfer was made on the basis of the line capacity which was allocated to each specific purpose. The total transfer capacity of the 230 kV single-circuit line is 130 MW, this being divided into 100 MW for reserve capacity and 30 MW for firm power transfer. The annual costs for firm power transfer were converted into energy costs equivalent to wheeling charges for load factors of 40, 55 and 70 percent and energy transfer of 105, 145 and 184 GWh, respectively.

The cost streams progressively diminish according to the magnitude of total debt service for the transmission interconnection facilities. The following summary tabulation provides an indication of the average values over the 32 year loan repayment period, following the interest only three year construction period.

AVERAGE VALUES FOR RESERVE CAPACITY AND ENERGY TRANSFER

| Combination REA/FFB Loan Package | Reserve Capacity Cost (\$/kW/Yr) | Energy Transfer Cost Equivalent to Wheeling Charge Energy Cost - Mills/kWh | | |
|--|---|--|----------|----------|
| | | (40% LF) | (55% LF) | (70% LF) |
| 20/80 | 43 | 12 | 9 | 7 |
| 40/60 | 41 | 12 | 8 | 7 |

It may be observed that the average values correspond approximately to the actual values at the year 2003.

9.5 FINANCIAL PLANS FOR FUTURE STAGED DEVELOPMENT

The following is one possible way to plan for funding successive expansions and extensions of the projected interconnection of Railbelt utilities.

A. Interconnection Extension Between Systems

The implementation of the Anchorage-Fairbanks Transmission Intertie will cause Railbelt utilities to examine their system expansions in relation to those of other utilities, to determine mutual benefits of additional transmission facilities to firm ties between adjacent systems. The cost of associated facilities could be financed on a comprehensive basis, possibly on more advantageous terms than if attempted by individual utilities or municipalities. The cost of such additions to utility systems could be met from a revolving fund administered by APA, on behalf of the participants.

One possibility for application of major funds for system extension would be the interconnection of the CVEA system to the Anchorage end of the intertie. The participation of CVEA in the AIA would then be desirable, with possibly a small allocation for initial intertie facilities, prior to the determination of the timing and cost of the facilities to link the initial interconnection with the CVEA system at Glennallen. This could be implemented on a separate basis, or as part of an integrated plan for transmission of hydropower from the Susitna Project.

B. Expansion of a Susitna Transmission System

The implementation of the Susitna Hydropower Project would require that a comprehensive financial plan be followed for funding the generation project and associated transmission facilities. The large increments of power possible from the Susitna development would require the expansion of the initial intertie, to receive energy for transmission to Anchorage and Fairbanks.

As part of the comprehensive financial plan, the funding of transmission line and substation facility expansion through time could be arranged on the basis of total incremental funding, with partition of costs and financial obligations between APA and utility participants, on a similar basis to that used for this initial approach to first stage financing of the transmission system interconnection in the Railbelt.

9.6 REFERENCES

1. International Engineering Company, Inc.
Financial Planning Model
2. Moody's Bond Record
'Tax Exempt Bond Fields by Ratings'
'Tax Exempts Vs. Governments and Corporates'
January 1979

TABLE 9-1

ALTERNATIVE DISBURSEMENTS OF CAPITAL INVESTMENT FOR GENERATION EXPANSION

\$1000
(1979)

| Year | pw ¹ | Anchorage Municipal Light & Power System Expansion | | Chugach Electric Association System Expansion | | Golden Valley Electric Association System Expansion | |
|------|-----------------|---|-----------------------|--|-----------------------|--|-----------------------|
| | | <u>Independent</u> | <u>Interconnected</u> | <u>Independent</u> | <u>Interconnected</u> | <u>Independent</u> | <u>Interconnected</u> |
| 1979 | 1.0000 | | | | | | |
| 1982 | 0.9151 | 2,009 | | | | | |
| 1983 | 0.8885 | 8,037 | | 10,959 | | 7,670 | - |
| 1984 | 0.8626 | 30,139 | | 31,539 | 10,959 | 20,264 | - |
| 1985 | 0.8375 | 37,172 | | | 31,539 | | |
| 1986 | 0.8131 | 21,127 | | | | | |
| 1987 | 0.7894 | 7,152 | 2,009 | | | | |
| 1988 | 0.7664 | | 8,037 | | | 7,555 | - |
| 1989 | 0.7441 | | 30,139 | 5,480 | | 17,630 | - |
| 1990 | 0.7224 | | 37,172 | 21,920 | 5,480 | | |
| 1991 | 0.7014 | | 21,127 | 82,200 | 21,920 | | |
| 1992 | 0.6810 | | 7,152 | 101,380 | 82,200 | | |
| 1993 | 0.6611 | | 7,020 | 58,450 | 101,380 | | |
| 1994 | 0.6419 | 7,020 | 16,380 | 22,820 | 58,450 | | |
| 1995 | 0.6232 | 16,380 | | | 22,820 | | |
| | TOTAL pw | 103,647 | 91,869 | 236,840 | 229,941 | 43,203 | - |

NOTE: Present worth obtained using 3% discount rate, equivalent to 7% cost escalation and 10% discount rate.

TABLE 9-2

ALLOCATION OF TOTAL PROJECT COSTS BETWEEN PARTICIPANTS
TO
ALASKAN INTERTIE AGREEMENT
A I A

SECTIONAL INTERCONNECTION DIVISIONS

| Anchorage | Palmer | Healy | Ester |
|-----------|------------|-------------|-------|
| Section I | Section II | Section III | |
| 40 M | 191 M | 92 M | |

INTERTIE COMPONENTSPROJECT COSTS - 1979 \$1000 (%)TOTAL FACILITY

| | | | | |
|--------------------------|-------------|-----------------|-----------------|--------------|
| Transmission Line | 6644 (10) | 31,726 (46) | 15,282 (22) | 53,652 (78) |
| Substations: | | | | |
| Anchorage | 3976 (6) | | | 3,976 (6) |
| Palmer | | 717 (1) 717 (1) | | 1,434 (2) |
| Healy | | | 717 (1) 717 (1) | 1,434 (2) |
| Ester | | | 5,080 (7%) | 5,080 (7) |
| Control & Communications | 1,450 (2) | 400 (1) | 1,450 (2) | 3,300 (5) |
| TOTAL | 12,787 (19) | 33,560 (49) | 22,529 (32) | 68,876 (100) |

AIA PARTICIPANTSALLOCATIONS OF TOTAL PROJECT COSTS (%)

| | | | |
|-------|-----|------|------|
| AM&LP | (8) | (10) | (18) |
| CEA | (8) | (3) | (11) |
| MEA | (3) | | (3) |
| GVEA | | (36) | (56) |
| FMUS | | | (12) |

TABLE 9.3A
 ALLOCATED COSTS FOR RESERVE CAPACITY SHARING AND FIRM POWER TRANSFER
 WITH
 FINANCIAL PLAN ALT. 1 - 20/80% COMBINATION REA/FFB LOAN PACKAGE
 AND
 MUNICIPAL BONDS

| Year | Total Debt Service (1979/\$1000) | Cost of Reserve Capacity Sharing and Firm Power Transfer Based on Capacity Allocation | | | | | |
|------|--|--|-------------------------|--|----------|----------|----------|
| | | 100 MW Reserve (Annual Cost of Reserve Capacity) | Annual Cost (\$1000) | 30 MW Firm Power Transfer (Energy Charge - Mills/kWh) | | | |
| | | (\$1000) | | (\$/kW/Yr.) | (40% LF) | (55% LF) | (70% LF) |
| | | | | | | | |
| 1984 | 8,670 | 6,669 | 67 | 2,001 | 19 | 14 | 11 |
| 1985 | 8,523 | 6,556 | 66 | 1,967 | 19 | 14 | 11 |
| 1986 | 8,376 | 6,443 | 64 | 1,933 | 19 | 13 | 10 |
| 1987 | 8,229 | 6,330 | 63 | 1,899 | 18 | 13 | 10 |
| 1988 | 8,082 | 6,217 | 62 | 1,865 | 18 | 13 | 10 |
| 1989 | 7,934 | 6,103 | 61 | 1,831 | 18 | 13 | 10 |
| 1990 | 7,787 | 5,990 | 60 | 1,797 | 17 | 12 | 10 |
| 1991 | 7,640 | 5,877 | 59 | 1,763 | 17 | 12 | 10 |
| 1992 | 7,493 | 5,764 | 58 | 1,729 | 17 | 12 | 9 |
| 1993 | 7,346 | 5,651 | 57 | 1,695 | 16 | 12 | 9 |
| 1994 | 7,199 | 5,538 | 55 | 1,661 | 16 | 11 | 9 |
| 1995 | 7,052 | 5,425 | 54 | 1,627 | 16 | 11 | 9 |
| 1996 | 6,905 | 5,312 | 53 | 1,593 | 15 | 11 | 9 |
| 1997 | 6,758 | 5,198 | 52 | 1,560 | 15 | 11 | 8 |
| 1998 | 6,611 | 5,085 | 51 | 1,526 | 15 | 11 | 8 |
| 1999 | 6,464 | 4,972 | 50 | 1,492 | 14 | 10 | 8 |
| 2000 | 6,317 | 4,859 | 49 | 1,458 | 14 | 10 | 8 |
| 2001 | 6,170 | 4,746 | 47 | 1,424 | 14 | 10 | 8 |
| 2002 | 6,023 | 4,633 | 46 | 1,390 | 13 | 10 | 8 |
| 2003 | 5,876 | 4,520 | 45 | 1,356 | 13 | 9 | 7 |
| 2004 | 3,515 | 2,704 | 27 | 811 | 8 | 6 | 4 |
| 2005 | 3,368 | 2,591 | 26 | 777 | 7 | 5 | 4 |
| 2006 | 3,221 | 2,478 | 25 | 743 | 7 | 5 | 4 |
| 2007 | 3,074 | 2,365 | 24 | 709 | 7 | 5 | 4 |
| 2008 | 2,927 | 2,252 | 23 | 675 | 6 | 5 | 4 |
| 2009 | 2,780 | 2,138 | 21 | 642 | 6 | 4 | 3 |
| 2010 | 2,633 | 2,025 | 20 | 608 | 6 | 4 | 3 |
| 2011 | 2,486 | 1,912 | 19 | 574 | 6 | 4 | 3 |
| 2012 | 2,339 | 1,799 | 18 | 540 | 5 | 4 | 3 |
| 2013 | 2,192 | 1,686 | 17 | 506 | 5 | 3 | 3 |
| 2014 | 2,045 | 1,573 | 16 | 472 | 5 | 3 | 3 |
| 2015 | 1,898 | 1,460 | 15 | 438 | 4 | 3 | 2 |

TABLE 9.3B
 ALLOCATED COSTS FOR RESERVE CAPACITY SHARING AND FIRM POWER TRANSFER
 WITH
 FINANCIAL PLAN ALT. 2 - 40/60% COMBINATION REA/FFB LOAN PACKAGE
 AND
 MUNICIPAL BONDS

| Year | Total Debt Service (1979/\$1000) | Cost of Reserve Capacity Sharing and Firm Power Transfer Based on Capacity Allocation | | | | | |
|------|--|--|-------------|---------------------------|-----------------------------|----------|----------|
| | | 100 MW Reserve (Annual Cost of Reserve Capacity) | | 30 MW Firm Power Transfer | | | |
| | | (\$1000) | (\$/kW/Yr.) | Annual Cost (\$1000) | (Energy Charge - Mills/kWh) | | |
| | | | | | (40% LF) | (55% LF) | (70% LF) |
| 1984 | 8,194 | 6,303 | 63 | 1,891 | 18 | 13 | 10 |
| 1985 | 8,061 | 6,201 | 62 | 1,860 | 18 | 13 | 10 |
| 1986 | 7,929 | 6,099 | 61 | 1,830 | 18 | 13 | 10 |
| 1987 | 7,797 | 3,998 | 60 | 1,799 | 17 | 12 | 10 |
| 1988 | 7,665 | 5,896 | 59 | 1,769 | 17 | 12 | 10 |
| 1989 | 7,533 | 5,795 | 58 | 1,738 | 17 | 12 | 9 |
| 1990 | 7,401 | 5,693 | 57 | 1,708 | 16 | 12 | 9 |
| 1991 | 7,268 | 5,591 | 56 | 1,677 | 16 | 12 | 9 |
| 1992 | 7,136 | 5,489 | 55 | 1,647 | 16 | 11 | 9 |
| 1993 | 7,004 | 5,388 | 54 | 1,616 | 16 | 11 | 9 |
| 1994 | 6,872 | 5,286 | 53 | 1,586 | 15 | 11 | 9 |
| 1995 | 6,740 | 5,185 | 52 | 1,555 | 15 | 11 | 8 |
| 1996 | 6,608 | 5,083 | 51 | 1,525 | 15 | 11 | 8 |
| 1997 | 6,475 | 4,981 | 50 | 1,494 | 14 | 10 | 8 |
| 1998 | 6,343 | 4,879 | 49 | 1,464 | 14 | 10 | 8 |
| 1999 | 6,211 | 4,778 | 48 | 1,433 | 14 | 10 | 8 |
| 2000 | 6,079 | 4,676 | 47 | 1,403 | 13 | 10 | 8 |
| 2001 | 5,947 | 4,575 | 46 | 1,372 | 13 | 9 | 7 |
| 2002 | 5,815 | 4,473 | 45 | 1,342 | 13 | 9 | 7 |
| 2003 | 5,682 | 4,371 | 44 | 1,311 | 13 | 9 | 7 |
| 2004 | 3,337 | 2,567 | 26 | 770 | 7 | 5 | 4 |
| 2005 | 3,204 | 2,465 | 25 | 739 | 7 | 5 | 4 |
| 2006 | 3,072 | 2,363 | 24 | 709 | 7 | 5 | 4 |
| 2007 | 2,940 | 2,262 | 23 | 678 | 7 | 5 | 4 |
| 2008 | 2,808 | 2,160 | 22 | 648 | 6 | 4 | 4 |
| 2009 | 2,676 | 2,058 | 21 | 618 | 6 | 4 | 3 |
| 2010 | 2,544 | 1,957 | 20 | 587 | 6 | 4 | 3 |
| 2011 | 2,411 | 1,855 | 19 | 556 | 5 | 4 | 3 |
| 2012 | 2,279 | 1,753 | 18 | 526 | 5 | 4 | 3 |
| 2013 | 2,147 | 1,652 | 17 | 495 | 5 | 3 | 3 |
| 2014 | 2,015 | 1,550 | 16 | 465 | 4 | 3 | 3 |
| 2015 | 1,883 | 1,448 | 14 | 435 | 4 | 3 | 2 |

CHAPTER 10
INSTITUTIONAL CONSIDERATIONS

CHAPTER 10 INSTITUTIONAL CONSIDERATIONS

The Intertie Advisory Committee has proven itself most useful during this study. It has enabled initial discussions to be held between potential participants in the projected interconnection of Railbelt utilities via the Anchorage-Fairbanks Transmission Intertie. This committee represents a sure, first step towards the formation of a continuing, viable, cohesive entity, through which the intertie can be built and the resulting benefits realized by the continued expansion and operation of the interconnected utility systems in the Railbelt.

10.1 PRESENT INSTITUTIONS AND RAILBELT UTILITIES

The predominant pattern of ownership management and operating responsibility by public power organizations in Alaska is exemplified by the prospective participants to an Alaskan Intertie Agreement (AIA). In addition to REA and municipal utilities in the Railbelt, it is anticipated that both the Alaska Power Administration and the Alaska Power Authority would be parties to the AIA. The probable composition of institutions and participating utilities is anticipated to be:

- Alaska Power Authority
- Anchorage Municipal Light and Power
- Chugach Electric Association, Inc.
- Homer Electric Association, Inc.
- Matanuska Electric Association, Inc.
- Golden Valley Electric Association, Inc.
- Fairbanks Municipal Utility System
- Alaska Power Administration

The above group of utilities may be joined by Copper Valley Electric Association, Inc. at a later date, to extend the interconnected facilities to the Glennallen-Valdez system.

A. Statutes and Limitations

The enabling legislation for the Alaska Power Authority (APA) is contained in HB 442 for the Legislature of the State of Alaska. It provides for the establishment of power projects and the authorization to proceed with developments that will serve "to supply power at the lowest reasonable cost to the state's municipal electric, rural electric, cooperative electric, and private electric utilities, and regional electric authorities, and thereby to the consumers of the state, as well as to supply existing or future industrial needs".

APA would mainly act on behalf of the municipal and rural electric utilities as a party to the AIA. Therefore, it is not presently anticipated that the authorized "powers to construct, acquire, finance, and incur debt" would be required for the Intertie Project. Rather APA could integrate and coordinate the efforts of the other participants to the AIA, to ensure that an expeditious approach is maintained during the course of the project.

APA is in an excellent position to coordinate regional programs with its state-wide involvement. For example, such coordination may assist in the process of securing an abridgement of the two county rule for the transmission intertie. Left unresolved, such existing statutes may otherwise constitute a roadblock to the realization of the benefits to be achieved by interconnection of systems of participating utilities over the large geographical area encompassed.

B. Jurisdiction and Service Territories

The Alaska Power Authority exercises jurisdiction over power projects in Alaska as a State entity. It parallels the Alaska Power Administration, which has federal jurisdiction in Alaska for the United States Department of Energy in Washington, D.C.

Both State and Federal entities have statewide responsibility in Alaska.

The service territories of the municipal and rural electric utilities are shown on the maps of Figures 4-1, 4-2, and 4-3 in Chapter 4. The confines of the Railbelt result in elongated geographical service areas. Such areas are particularly appropriate in relation to the transmission corridor for the intertie and enable the delineation of easements along the route to be made relative to existing transmission and distribution facilities in the area.

10.2 ALASKAN INTERCONNECTED UTILITIES

To provide an identity for the utility participants to the AIA, it is suggested that the name Alaskan Interconnected Utilities (AIU) be adopted by the existing Railbelt utilities to be included in the institutional and management plan for the implementation and operation of the intertie.

A. Present Arrangements and Future Requirements

To a certain extent, the operating utilities in the Anchorage and Fairbanks areas have already evolved mutual interests. These interests now need to be augmented, to satisfy future operating requirements.

Prior to interconnection, there would be a need to coordinate revised planning for system expansion, the scheduled construction of facilities, and the separate building programs of each utility. A Planning Subcommittee of the Intertie Advisory Committee, composed of technical staff from AIU, would be desirable in the near future if this program is implemented. This planning subcommittee could be empowered to resolve joint planning problems affecting participating members.

Later on, an Operating Subcommittee would be required to determine operating procedures and coordinate system planning policy, working towards centralized economic dispatch for the interconnected system. The need for communications facilities will also need to be addressed, together with the mode of overall system control and data acquisition for interconnected facilities.

B. Evolution of Institutional Framework

In any approach toward projecting institutional requirements for the establishment of the necessary framework to support the Anchorage-Fairbanks Transmission Intertie, it is essential to preserve a sense of perspective towards the future and allow for the possibility of integrating the presently conceived plans and concepts within a larger and more comprehensive institutional structure. This is particularly appropriate to the task of system interconnection, when successive expansions are necessary to accommodate the incremental additions associated with major generating plants.

In the case of the Railbelt, the possible implementation of the major hydropower developments of the Upper Susitna Project, would require that the institutional structure required for the transmission intertie be compatible with future institutional needs of the Susitna developments. Thus, whatever institutional changes would be brought about by a program of hydropower development of the Susitna should represent only a transition between organizational requirements keyed to transmission system expansion without the facilities of the Susitna developments and with the addition of major hydropower sources, such as Watana and Devil Canyon.

The evolutionary approach to effecting this transition is preferable over an abrupt change of institutional structures and it is thought that, with the acceptance of a pattern of multiple participation in the planning, financing, implementation, and operation of the Intertie, a suitable mode of proportionate involvement can also be considered for applicability to other transmission facilities required for the Susitna Project. This division of fiscal and managerial responsibility can also be extended into the operation of the system.

In this way a maximum of local utility participation can be achieved, with a financially beneficial allocation of total project costs between funding sources to arrive at a least financial cost package to multiple borrowers having pre-arranged sharing of debt-service obligations.

10.3 REFERENCES

1. Battelle Pacific Northwest Laboratories, Alaska Electric Power: An Analysis of Future Requirements and Supply Alternatives for the Railbelt Region, March 1978.
2. University of Alaska, Institute for Social and Economic Research, Electric Power in Alaska 1976-1995, August 1976.
3. House Bill 442 in the Legislature of the State of Alaska, Finance Committee, Tenth Legislature - Second Session.

APPENDIX A
NOTES ON FUTURE USE OF ENERGY IN ALASKA

APPENDIX A

NOTES ON FUTURE USE OF ENERGY IN ALASKA

Power requirements studies analyzing historical data and forecasting future trends have been regularly accomplished for the REA-financed electric utilities in Alaska since they began operation. These studies and their forecasts over the years provide an interesting perspective as to the changes in use of electricity and the change in numbers of users, but do not fully account for the forces that produce these changes.

It is observed that electrical uses increase as the dreary, manual routines of everyday life are displaced by the equivalent electrically-powered devices. This allows the human effort to be directed elsewhere or eliminated. Electric lighting, water pumping (many Alaska homes have their own water systems) and heating, clothes washing, refrigerator, freezer, vacuum cleaner, dishwasher, cooking aids, radio and TV (education and recreation), lawn mower, chain saw, etc., all direct electrical energy toward improving the quality of life and making human effort more productive.

The typical Alaskan family is becoming more productive as a unit through an increasing percentage of the family partners entering the community group of wage earners. Increasing income allows the family to seek out new means of improving the quality of living.

There are on the horizon a number of technological triumphs that will undoubtedly find uses in those communities where the families can assign some of their resources to enhancing their lives. The home computer with its implications of many more "robots" to come and the electric car are just two of such items nearing the scene.

These considerations certainly support the trends of electrical energy use that are being forecast and could well result in the forecasts being

exceeded, if the rising standards of Alaskan life are maintained into the future.

The following paragraphs are a direct excerpt from a system planning report (see Ref. 7 in Section 3) completed in early 1979 for the Matanuska Electric Association, Inc. of Palmer, Alaska. This electric system is the oldest REA-financed system in Alaska and the statistics cited which relate the use of electrical energy to the average family earnings over a period of 35 years of actual history and a forecast of 15 to 25 years are interesting indeed.

*INTRODUCTION

The accomplishment of long-range planning requires that data be estimated for future conditions and that technical answers for those conditions be evaluated in a prudent manner. Technical answers to a defined set of conditions can be readily developed using state-of-the-art methods. An occasional set of conditions prompts innovation when conventional methods appear limited; but, it is demonstrably clear that the estimate of future conditions is the single most significant factor affecting the ultimate value of a long-range plan.

It will be noted in the following System Planning Report a great effort was made to provide accurate and detailed historical data. A better understanding of the nature of electrical consumers and their actual performance amidst the set of observed environmental restraints (political and natural) is bound to be enhanced by such data. It is believed that forecasts of future conditions will also benefit in sufficient measure to make the effort a bargain.

* Excerpted from MEA System Planning Report, January 1979 - see Chapter 3, Ref. 7.

The understanding of a long-range plan in the context of the whole growth of a community or region and in terms more useful to the consumer of electricity and his representatives is believed extra difficult today because of environmental concerns, high inflation and other cost aberrations.

To provide some perspective that is intended to illuminate the broad impact and position of the MEA electric supply system on its service area a tabular listing of significant MEA statistics is included herewith on the following page, Table A-1.

This table contains the 35-year history of MEA and a 20-year forecast based on the data in the Long-Range Plan. The numbers listed may surprise the reader at first inspection but this simple listing of historic factual data and related future estimates serves to demonstrate the powerful influence of electricity on the quality of life and the productivity of the MEA service area.

MEA STATISTICAL SUMMARY - PAST, PRESENT AND FORECAST

| Year | Ave. No. Served Average kWh/Mo. | Ave. No. (w/o LP) Average kWh/Mo. | Miles of Line Dist. Trans. | Const. Per Mile Dist. | Ave. Cost Purch. Power \$/kWh | Average Revenue Total Sales \$/kWh | Average Revenue (w/o LP) \$/kWh | Average Bill/Const. (w/o LP) \$/Mo. | Average Family Income \$/Mo. | Portion of Income Percent |
|--------------------------|--|--|-------------------------------------|--------------------------------|--|---|--|--|---------------------------------------|------------------------------------|
| (1) | (2) | (3) | (4) | (5) | (6) | (7) | (8) | (9) | (10) | (11) |
| 1942 | <u>210</u> 142 | <u>188</u> 47 | <u>90</u> 0 | 2.3 | 0.020 | 0.0628 | 0.1074 | 5.07 | 175 | 2.9 |
| 1954 | <u>1401</u> 533 | <u>1393</u> 335 | <u>313</u> 0 | 4.5 | 0.0196 | 0.0450 | 0.0531 | 17.82 | 590 | 3.02 |
| 1966 | <u>3134</u> 951 | <u>3113</u> 694 | <u>708</u> 63 | 4.4 | 0.0114 | 0.0348 | 0.0366 | 25.40 | 885 | 3.9 |
| 1977 | <u>9434</u> 1578 | <u>9352</u> 1318 | <u>1430</u> 97 | 6.6 | 0.0128 | 0.0359 | 0.0368 | 48.50 | 2248 | 2.4 |
| See Footnotes | | | | | | | | | | |
| Level I ('82-'85) | <u>16693</u> 2100 | <u>16510</u> 1785 | <u>2212</u> 241 | 7.5 | 0.0187 | 0.0546 | 0.0559 | 99.78 | 3303 | 3.02 |
| Level II ('87-'92) | <u>30510</u> 2799 | <u>30060</u> 2488 | <u>2705</u> 269 | 11.3 | 0.0348 | 0.0692 | 0.0705 | 175.30 | 4853 | 3.60 |
| Level III ('92-'99) | <u>55744</u> 3714 | <u>54956</u> 3494 | <u>3041</u> 293 | 18.3 | 0.0488 | 0.0829 | 0.0837 | 292.45 | 7131 | 4.10 |

The basic historical data was taken from the REA Form 7. Each column is explained as follows:

- (1) The year of operation - MEA first energized its system on January 19, 1942. Level I, II, and III refer to the Load Levels of the December 1978 Long Range Plan. The years in parenthesis are estimated dates when these levels might be reached.
- (2) The total average number of consumers with LPs and their average monthly energy (kWh) use.
- (3) The average number of consumers (w/o LPs) and their average monthly energy (kWh) use.
- (4) Miles of line at year end.
- (5) Average number of consumers served per mile of distribution line - Columns (2) divided by Column (4).
- (6) Cost of purchased power - at Levels I, II and III these are estimates developed by RWR from miscellaneous sources. These forecast are believed to be consistent with other elements of the forecast.
- (7), (8), and (9) For levels I, II and III the figures resulted from a generalized forecast of costs using the investments indicated by the Long Range Plan escalated at 7% per year, the operating costs per consumer escalated @ 7% per year and the purchased power costs of Column (6). It was also assumed that there would be 10% losses of energy and that MEA margins would be 10% of Gross Revenue.
- (10) The estimated average family income is developed from old payroll records, the "Statistical Abstract of the U.S." (Public by Bureau of the Census) 1977, and "The Alaska Economy, Year-End Performance Report 1977" (Published by Alaska Department of Commerce and Economic Development). Future income estimates made by escalating 1977 numbers at 1.08 per year which is the approximate average growth rate of income for the last 35 years.
- (11) Column (9) divided by Column (10) multiplied by 100.

APPENDIX B
TRANSMISSION LINE COST ANALYSIS
PROGRAM (TLCAP)

APPENDIX B

TRANSMISSION LINE COST ANALYSIS PROGRAM (TLCAP)

B.1 GENERAL DESCRIPTION

The Transmission Line Cost Analysis Program (TLCAP) calculates the installation, operation, and maintenance costs of a transmission line using a detailed unit cost model. It also automatically determines the "optimum" span and conductor size combination. Applications include the following:

- Voltage Selection - TLCAP examines the relative economics of various voltage levels.
- Span and Conductor Optimization - Span and conductor are optimized simultaneously to provide a matrix of present worth costs. Sensitivity of present worth costs to assumed discount rate is also automatically included.
- Tower Type Selection - TLCAP compares the cost impact of alternate tower types.

B.2 COMPUTER PROGRAM APPLICATIONS FOR OPTIMUM TRANSMISSION LINE COSTS

Choosing the most economical voltage level and other line parameters for any projected transmission line is a complex problem. It requires the simultaneous consideration of a multitude of interrelated factors, each of which will have a decided influence on line performance and the installed and operational costs of both the line and the overall system. The installed cost of a line increases rapidly with the voltage used. For typical single-circuit ac lines, the cost increase is approximately in direct proportion to the increase in voltage. On the other hand, the load carrying capacity of a line increases with the square of the voltage,

but this is partially offset by the increase in phase spacing and the resultant increase of line impedance.

Another factor affecting the load carrying capacity and line cost is the size of the conductor and the number of conductors per phase. Since the installed cost of the conductors may constitute as much as 28% of the total line cost, the selection of the conductor is an important decision in any line design.

For EHV lines, conductor size selection is first governed by two basic electrical requirements - the current carrying capacity and the corona performance in terms of corona loss radio interference (R.I.) and television interference (T.V.I.). As the line voltage increases, the corona performance becomes more and more the governing factor in selecting conductor size and bundle configuration.

If consideration is given to the electrical aspects alone, there is an optimum solution as to the size and number of conductors for each voltage level and load carrying requirement. However, the size of the conductor affects the loads on the structures supporting it, as well as the sag, tension, span length, and tower height and weight. All such factors influence the total cost and economics of the line. Hence, both the electrical and mechanical aspects must be considered together in order to arrive at a truly optimized overall line cost. Often a solution which is entirely satisfactory from the electrical viewpoint alone will be in conflict with the mechanical requirements. This is particularly true at locations where heavy ice loading is encountered. For example, a small conductor in a bundle of three may meet all the electrical requirements but may be entirely unsatisfactory mechanically due to excessive sag and overstress. This results in higher towers or shorter spans with more towers per unit length of line than would a larger conductor in a bundle of two. A large number of conductor and phase configurations must usually be tried before an optimum solution is found for a specific voltage level.

The voltage level for any given line should be chosen on the basis of its effect on the system to which it will be connected. This may require medium- or long-range estimation of load flow. For example, it may be more advantageous to build a single 750-kV line instead of two 400-kV lines. Each solution has its own impact on the system with respect to reliability, stability, switching over-voltages, transfer of power, and possibly the cost of future expansion. In other words, the line should be custom designed to meet present and future needs of the system within which it is to operate. It should also provide for the lowest overall cost in terms of investment and operation. Without proper attention to future needs, the "lowest initial cost solution" for a line between two given points may not necessarily be the most desirable or satisfactory one.


In addition to the variables mentioned above, there are numerous other line parameters that must be considered to properly evaluate and compare the various solutions. A few of the more important ones are:

- Conductor material, size, and stranding.
- Tower types, such as rigid or guyed, single or double-circuit, ac or dc, metal or wood.
- Foundation costs.
- Wind and ice load criteria, and their effect on tower cost through transverse, vertical, broken-wire, and/or construction loads.
- Number and strength of insulators.
- Insulator swing and air gap.
- Applicable material and labor costs.
- Investment charges, demand, and annual energy loss charges.

To accurately assess all the complexities and interrelationships, and to integrate them into a totally coordinated design that will produce a line of required performance at minimum cost, a carefully engineered computer program was developed by IECO. Program methodology of TLCAP is shown on Figure C-1. Briefly, program elements include:

TRANSMISSION LINE COST ANALYSIS PROGRAM (TLCAP)

METHODOLOGY



- Conductor Selection - A large variety of conductor sizes and strandings are on file for automatic use by the program. Depending upon line voltage and load, the program determines the minimum power and energy losses for each conductor studied.
- Insulation Selection - The program calculates the incremental cost differences caused by changes in the insulator length, which together with other studies of system performance indicates the best insulation for each voltage level. To ensure maximum transmission capacity, the minimum possible phase spacing is used with each type of tower, considering clearance to tower steel and insulator swing.
- Tower Selection and Span Optimization - The installed cost of towers represents a large portion of the total line cost. Therefore, this item is given special and careful consideration in the calculations. The installed cost of a tower is usually a function of the weight of the steel used. A considerable difference in weight between different tower configurations can be experienced, even in cases where the loads are identical. If to this variable, the variations in loads due to conductor size, bundling, and climatic criteria are added, it becomes evident that correct tower weights can only be determined by an actual tower design in which all the variables are properly considered. Therefore, the optimization program is complemented with a tower design program. Appropriate foundation and insulation costs are added to each tower solution to obtain the total installed cost per tower location. This information is then used by the optimization program to determine the optimum span length (the span that results in the lowest tower cost per unit length of line) for each conductor configuration being considered.

In processing these criteria, including a present worth evaluation of annual energy loss and other time-related charges, the optimization pro-

gram arrives at a long-range minimum cost solution for each voltage level investigated. However, as previously mentioned, the final evaluation of the adequacy of a line should be based upon its present and future effect on the system as a whole. Therefore, the lowest cost solution for a select number of conductor configurations, with their specific electrical characteristics, should be tried in a few additional system study runs to obtain a proper basis for a final decision.

B.3 TLCAP SAMPLE OUTPUTS

Sample outputs of the TLCAP computer program are shown on the following pages. The output cases are listed below:

- Anchorage - Fairbanks, 230 kV (Case IA).
- Anchorage - Fairbanks, 230 kV (Case IB).
- Anchorage - Fairbanks, 345 kV (Case IC).
- Anchorage - Devil Canyon, 345 kV (Case II-1).
- Devil Canyon - Ester, 230 kV (Case II-2A).
- Watana - Devil Canyon, 230 kV (Case II-3A).

INTERNATIONAL ENGINEERING CO. INC
SAN FRANCISCO CALIFORNIA

TRANSMISSION LINE COST ANALYSIS PROGRAM
VERSION 1: 23 FEB 1979,

ANCHORAGE-FAIRBANKS INTERTIE CASE 1A
230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
DATE: 12 APR 79 TIME: 9:29:47

* INPUT DATA *

| SYSTEM ECONOMIC FACTORS ----- | INPUT VALUE ----- | REFERENCE YEAR FOR INPUT ----- |
|----------------------------------|----------------------|-----------------------------------|
| STARTING YEAR OF STUDY | 1979 | |
| ENDING YEAR OF STUDY | 1996 | |
| BASE YEAR FOR ESCALATION | 1977 | |
| MAXIMUM CIRCUIT LOADING | 136.8 MVA | 1992 |
| AVERAGE CIRCUIT LOADING | 41.0 MVA | 1992 |
| DEMAND COST FACTOR | 73.0 \$/KW | 1979 |
| ENERGY COST FACTOR | 13.0 MILLS/KWH | 1979 |
| VAR COST FACTOR | 0.0 \$/KVAR | 1984 |
| CAPITAL COST/DISCOUNT RATE: | | |
| MINIMUM | 7.0 PERCENT | 1984 |
| MAXIMUM | 10.0 PERCENT | 1984 |
| NUMBER OF INTERVALS | 1 | |
| O&M COST FACTOR | 1.5 % CAP.COST | 1979 |
| RIGHT OF WAY COST FACTOR | 715.0 \$/ACRE | 1979 |
| RIGHT OF WAY CLEARING COST | 1430.0 \$/ACRE | 1979 |
| INTEREST DURING CONSTRUCTION | 0.00 % INST.CST | |
| ENGINEERING FEE | 11.00 % INST.CST | |

ANCHORAGE-FAIRBANKS INTERTIE CASE 1A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 12 APR 79 TIME: 9:29:47

 * INPUT DATA *

 CONDUCTOR DATA

NUMBER PER PHASE 1
 CONDUCTOR SPACING 0.0 IN
 VOLTAGE 230 KV
 VOLTAGE VARIATION 10.00 PCT
 LINE FREQUENCY 60 CPS
 FAIRWEATHER LOSSES 0.00 KW/MI
 LINE LENGTH 323.00 MILES
 POWER FACTOR 0.95

 GROUNDWIRE DATA

NUMBER PER TOWER 0
 DIAMETER 0.00 IN
 WEIGHT 0.0000 LBS/FT

 SPAN DATA

MINIMUM 1200. FT
 MAXIMUM 1600. FT
 INTERVAL 100.0 FT

 WEATHER DATA

MAXIMUM RAINFALL RATE 1.18 IN/HR
 MAXIMUM RAINFALL DURATION 1 HRS/YR
 AVERAGE RAINFALL RATE 0.03 IN/HR
 AVERAGE RAINFALL DURATION 636 HRS/YR
 MAXIMUM SNOWFALL RATE 1.87 IN/HR
 MAXIMUM SNOWFALL DURATION 1 HRS/YR
 AVERAGE SNOWFALL RATE 0.13 IN/HR
 AVERAGE SNOWFALL DURATION 264 HRS/YR
 RELATIVE AIR DENSITY 1.000

ANCHORAGE-FAIRBANKS INTERTIF CASE 1A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 12 APR 79 TIME: 9:29:47

 * INPUT DATA *

SAG/TENSION DESIGN FACTORS

| | | | |
|-----------------------------------|----------------|--------------------------------|-----------------|
| EVERYDAY STRESS TEMPERATURE | 40. DEGREES F | ICE AND WIND TENSION (PCT UTS) | 50. PERCENT |
| ICE AND WIND TEMPERATURE | 0. DEGREES F | HIGH WIND TENSION (PCT UTS) | 50. PERCENT |
| HIGH WIND TEMPERATURE | 40. DEGREES F | EXTREME ICE TENSION (PCT UTS) | 70. PERCENT |
| EXTREME ICE TEMPERATURE | 30. DEGREES F | ICE THICKNESS WITH WIND | 0.50 INCHES |
| MAX DESIGN TEMP FOR GND CLEARANCE | 120. DEGREES F | WIND PRESSURE WITH ICE | 4.00 LBS/SQ.FT. |
| EDS TENSION (PCT UTS) | 20. PERCENT | HIGH WIND | 9.0 LBS/SQ.FT. |
| NESC CONSTANT | 0.31 LBS/FT | EXTREME ICE | 0.50 INCHES |

TOWER DESIGN

| | | | |
|--------------------------------|-----------------|--------------------------|----------|
| TOTAL NUMBER OF PHASES | 3 | DISTANCE BETWEEN PHASES: | |
| PHASE SPACING | 20.0 FEET | D1 | 20.00 FT |
| CONDUCTOR CONFIGURATION FACTOR | 1.02 | D2 | 20.00 FT |
| GROUND CLEARANCE | 28.0 FEET | D3 | 40.00 FT |
| NO. OF INSULATORS PER TOWER | 48 | D4 | 0.00 FT |
| INSULATOR SAFETY FACTOR | 2.50 | D5 | 0.00 FT |
| STRING LENGTH | 6.5 FEET | D6 | 0.00 FT |
| I, VEE, OR COMBINATION | 3 | | |
| FOUNDATION TYPE | 4 | | |
| TERRAIN FACTOR | 1.06 PER UNIT | | |
| LINE ANGLE FACTOR | 0.0864 | | |
| TOWER GROUNDING | 0 | | |
| TRANSVERSE OVERLOAD FACTOR | 2.50 | | |
| VERTICAL OVERLOAD FACTOR | 1.50 | | |
| LONGITUDINAL LOAD | 1000. LBS | | |
| MISCELLANEOUS HARDWARE WEIGHT | 0.11 TONS/TOWER | | |
| TOWER WEIGHT FACTOR | 1.02 | | |

TOWER WEIGHT ESTIMATION ALGORITHM

TOWER TYPE 9: 230KV TOWER

$$TW = 0.00016 * TH ** 2 - 3.09797 * TH * 0.3333 - 0.08943 * EFFVDL + 0.27367 * EFFIDL + 0.00510 * TH * EFFTDL + 0.00160 * TH * EFFVDL + 18.37912 \text{ KIPS}$$

ANCHORAGE-FAIRBANKS INTERTIE CASE 1A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 12 APR 79 TIME: 9:29:47

 * INPUT DATA *

CONDUCTOR SUMMARY

| ID NUMBER | NAME | SIZE (KCM) | STRANDING (AL/ST) | UNIT WEIGHT (LBS/FT) | OUT. DIAM. (INCHES) | TOTAL AREA (SQ. IN.) | MODULUS (EF/E6 PSI) | TEMP. COEF. ALPHA * E-6 PER DEG F |
|-----------|-----------|------------|----------------------|-------------------------|------------------------|-------------------------|------------------------|---|
| 24 | GROSBREAK | 636.0 | 26/ 7 | 0.8750 | 0.9900 | 0.5809 | 11.00 | 10.3 |
| 25 | EGRET | 636.0 | 30/19 | 0.9880 | 1.0190 | 0.6134 | 11.30 | 9.7 |
| 26 | FLAMINGO | 666.0 | 24/ 7 | 0.8590 | 1.0000 | 0.5914 | 10.55 | 10.7 |
| 27 | GANNET | 666.0 | 26/ 7 | 0.9180 | 1.0140 | 0.6087 | 11.00 | 10.3 |
| 28 | STILT | 715.0 | 24/ 7 | 0.9210 | 1.0360 | 0.6348 | 10.55 | 10.7 |
| 29 | STARLING | 715.0 | 26/ 7 | 0.9850 | 1.0510 | 0.6535 | 11.00 | 10.3 |
| 30 | REDWING | 715.0 | 30/19 | 1.1110 | 1.0810 | 0.6901 | 11.30 | 9.7 |
| 31 | CUCKOO | 795.0 | 24/ 7 | 1.0240 | 1.0920 | 0.7053 | 10.55 | 10.7 |
| 32 | DRAKE | 795.0 | 26/ 7 | 1.0940 | 1.1080 | 0.7261 | 11.00 | 10.3 |
| 33 | TERN | 795.0 | 45/ 7 | 0.8960 | 1.0630 | 0.6676 | 9.40 | 11.5 |
| 34 | CONDOR | 795.0 | 54/ 7 | 1.0240 | 1.0930 | 0.7053 | 10.85 | 10.9 |
| 35 | MALLARD | 795.0 | 30/19 | 1.2350 | 1.1400 | 0.7668 | 11.30 | 9.7 |
| 36 | PUDDY | 900.0 | 45/ 7 | 1.0150 | 1.1310 | 0.7069 | 9.40 | 11.5 |
| 37 | CANARY | 900.0 | 54/ 7 | 1.1590 | 1.1620 | 0.7985 | 10.85 | 10.9 |
| 38 | RAIL | 954.0 | 45/ 7 | 1.0750 | 1.1650 | 0.8011 | 9.40 | 11.5 |
| 39 | CARDINAL | 954.0 | 54/ 7 | 1.2290 | 1.1960 | 0.8464 | 10.85 | 10.9 |

ANCHORAGE-FAIRBANKS INTERTIE CASE 1A
230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
DATE: 12 APR 79 TIME: 9:29:47

* INPUT DATA *

CONDUCTOR SUMMARY

| ID NUMBER | NAME | ULT.TENS. STRENGTH(LBS) | G.FOM.MEAN RADIUS(FT) | PRICE(\$/LB) | THERM.LIMIT (AMPERES) | AC RESIST. AT 25 DEG C (OHMS/MILE) | IND.REACT. (OHMS/MILE) | CAP.REACT. (MOHM-MILES) |
|-----------|----------|----------------------------|--------------------------|--------------|--------------------------|--|---------------------------|----------------------------|
| ----- | ---- | ----- | ----- | ----- | ----- | ----- | ----- | ----- |
| 24 | GROSBEAK | 25000.0 | 0.0335 | 0.628/1977 | 790. | 0.1452 | 0.4118 | 2.6347 |
| 25 | FGREY | 31500.0 | 0.0351 | 0.609/1977 | 870. | 0.1447 | 0.4060 | 2.6136 |
| 26 | FLAMINGO | 23700.0 | 0.0335 | 0.640/1977 | 810. | 0.1399 | 0.4118 | 2.6294 |
| 27 | GANNET | 26200.0 | 0.0343 | 0.609/1977 | 820. | 0.1373 | 0.4092 | 2.6347 |
| 28 | STILT | 25500.0 | 0.0347 | 0.627/1977 | 840. | 0.1320 | 0.4066 | 2.6400 |
| 29 | STARLING | 28100.0 | 0.0355 | 0.608/1977 | 850. | 0.1294 | 0.4050 | 2.6453 |
| 30 | REDWING | 34600.0 | 0.0372 | 0.612/1977 | 860. | 0.1288 | 0.3992 | 2.5661 |
| 31 | CUCKOO | 27100.0 | 0.0366 | 0.636/1977 | 900. | 0.1214 | 0.3992 | 2.5502 |
| 32 | DRAKE | 31200.0 | 0.0375 | 0.622/1977 | 910. | 0.1172 | 0.3992 | 2.5450 |
| 33 | TERN | 22900.0 | 0.0352 | 0.677/1977 | 890. | 0.1188 | 0.4060 | 2.5766 |
| 34 | CONDOR | 28500.0 | 0.0368 | 0.635/1977 | 900. | 0.1172 | 0.4002 | 2.5555 |
| 35 | MALLARD | 38400.0 | 0.0392 | 0.599/1977 | 910. | 0.1162 | 0.3928 | 2.5186 |
| 36 | RUDY | 25400.0 | 0.0374 | 0.676/1977 | 935. | 0.1082 | 0.3928 | 2.5080 |
| 37 | CANARY | 32300.0 | 0.0392 | 0.633/1977 | 950. | 0.1040 | 0.3928 | 2.5027 |
| 38 | RAIL | 26900.0 | 0.0385 | 0.671/1977 | 970. | 0.0998 | 0.3949 | 2.5027 |
| 39 | CARDINAL | 34200.0 | 0.0404 | 0.632/1977 | 990. | 0.0987 | 0.3902 | 2.4816 |

ANCHORAGE-FAIRBANKS INTERIF CASE 1A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 12 APR 79 TIME: 9:29:47

 * INPUT DATA *

| UNIT MATERIALS COSTS ----- | INPUT VALUE ----- | REFERENCE YEAR FOR INPUT ----- |
|------------------------------------|-------------------------|-----------------------------------|
| PRICE OF TOWER MATERIAL | 0.957 \$/LB | 1979 |
| PRICE OF CONCRETE | 0.00 \$/CU.YD. | 1977 |
| PRICE OF GROUND WIRE | 0.000 \$/LB | 1977 |
| INSTALLED COST OF GROUNDING SYSTEM | 0.00 \$/TOWER | 1977 |
| TOWER SETUP | 1751. \$ | 1979 |
| TOWER ASSEMBLY | 0.455 \$/LB | 1979 |
| FOUNDATION SETUP | 0. \$ | 1979 |
| FOUNDATION ASSEMBLY | 4140.00 \$/TON | 1979 |
| FOUNDATION EXCAVATION | 0.00 \$/CU.YD. | 1979 |
| PRICE OF MISCELLANEOUS HARDWARE | 290.00 \$/TOWER | 1977 |
| | | |
| UNIT LABOR COSTS ----- | | |
| REFERENCE YEAR LABOR COST | 24.00 \$/MANHOUR | 1979 |
| STRING GROUND WIRE | 0.0 \$/MILE | 1977 |
| STRING LABOR MARKUP | 4.2 PER UNIT | |
| | | |
| UNIT TRANSPORTATION COSTS ----- | | |
| TOWER | 100.0 \$/TON | |
| FOUNDATION CONCRETE | 100.0 \$/YD. | |
| FOUNDATION STEEL | 100.0 \$/TON | |
| CONDUCTOR | 100.0 \$/TON | |
| GROUND WIRE | 100.0 \$/TON | |
| INSULATOR | 100.0 \$/TON OR \$/M**3 | |
| HARDWARE | 100.0 \$/TON | |

ANCHORAGE-FAIRBANKS INTERTIE CASE 1A
230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
DATE: 12 APR 79 TIME: 9:29:47

*
* AUTOMATIC CONDUCTOR SELECTION *
* ALL QUANTITIES PER MILE *
*

CAPITAL COST/DISCOUNT RATE OF 7.00 PERCENT

| CONDUCTOR | | | INSTALLED COST | | | | | PRESENT WORTH | | |
|-----------|------|----------|----------------|----------------|--------------|---------|----------|-------------------------|----------------------|--------------------|
| NO. | KCM | SPAN(FT) | MATERIALS | TRANSPORTATION | INSTALLATION | ENG/IDC | SUBTOTAL | LINE LOSSES SUBTOTAL | O&M COST SUBTOTAL | LINE COST TOTAL |
| 39 | 954. | 1300. | 68147. | 3834. | 84796. | 9328. | 166104. | 32600. | 3284. | 201988. |
| 35 | 795. | 1300. | 64664. | 3721. | 82616. | 9088. | 160089. | 39120. | 3151. | 202354. |
| 35 | 795. | 1400. | 65375. | 3684. | 82031. | 9073. | 160113. | 39120. | 3161. | 202394. |
| 37 | 900. | 1300. | 67299. | 3772. | 84608. | 9307. | 164986. | 34543. | 3257. | 202784. |
| 39 | 954. | 1400. | 69552. | 3828. | 84673. | 9314. | 167367. | 32600. | 3322. | 203288. |
| 37 | 900. | 1400. | 68697. | 3766. | 84494. | 9294. | 166251. | 34543. | 3294. | 204088. |
| 35 | 795. | 1500. | 66879. | 3689. | 82176. | 9039. | 161784. | 39120. | 3206. | 204109. |
| 32 | 795. | 1300. | 65558. | 3685. | 83893. | 9228. | 162364. | 39523. | 3195. | 205082. |
| 30 | 715. | 1300. | 63510. | 3615. | 82301. | 9053. | 158478. | 44166. | 3112. | 205756. |
| 30 | 715. | 1400. | 64204. | 3576. | 81729. | 8990. | 158498. | 44166. | 3122. | 205787. |
| 34 | 795. | 1300. | 65807. | 3659. | 84359. | 9279. | 163104. | 39599. | 3209. | 205913. |
| 32 | 795. | 1400. | 66784. | 3669. | 83683. | 9205. | 163342. | 39523. | 3226. | 206091. |
| 39 | 954. | 1500. | 71843. | 3870. | 85337. | 9387. | 170437. | 32600. | 3397. | 206433. |
| 38 | 954. | 1300. | 70136. | 3831. | 86787. | 9547. | 170300. | 32997. | 3371. | 206667. |
| 32 | 954. | 1200. | 70386. | 4033. | 87082. | 9579. | 171080. | 32600. | 3385. | 207065. |
| 37 | 900. | 1500. | 70983. | 3807. | 85172. | 9369. | 169331. | 34543. | 3369. | 207242. |
| 34 | 795. | 1400. | 67235. | 3653. | 84298. | 9273. | 164459. | 39599. | 3248. | 207306. |
| 35 | 795. | 1600. | 69124. | 3735. | 82979. | 9128. | 164966. | 39120. | 3282. | 207367. |
| 30 | 715. | 1500. | 65702. | 3580. | 81896. | 9009. | 160187. | 44166. | 3167. | 207520. |
| 35 | 795. | 1200. | 66889. | 3916. | 85020. | 9352. | 165176. | 39120. | 3254. | 207549. |
| 37 | 900. | 1200. | 69631. | 3977. | 86926. | 9562. | 170096. | 34543. | 3361. | 207999. |
| 29 | 715. | 1300. | 64091. | 3593. | 83683. | 9205. | 160573. | 44804. | 3150. | 208527. |
| 24 | 636. | 1200. | 58648. | 3345. | 82481. | 9073. | 153548. | 52193. | 2975. | 208715. |
| 32 | 795. | 1500. | 68883. | 3701. | 84257. | 9268. | 166109. | 39523. | 3295. | 208926. |
| 36 | 900. | 1300. | 69499. | 3780. | 86682. | 9535. | 169496. | 36096. | 3351. | 208942. |

ANCHORAGE-FAIRBANKS INTERTIF CASE 1A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 12 APR 79 TIME: 9:29:47

 * COST OUTPUT PER MILE *
 * PRESENT VALUE RATE *
 * 7.00 PERCENT *
 *

CONDUCTOR NUMBER = 39
 954. KCMIL 1300. FT SPAN 87.7 FT TOWER

| INSTALLED COST BREAKDOWN | QUANTITY | MATERIAL COST(\$) | TONNAGE | TRANSPORTATION COST(\$) | INSTALLATION COST(\$) | TOTAL COST(\$) |
|-----------------------------|------------|----------------------|---------|----------------------------|--------------------------|-------------------|
| CONDUCTOR | 15840. FT | 14086. | 9.73 | 973. | 18257. | 33316. |
| GROUNDWIRE | 0. FT | 0. | 0.00 | 0. | 0. | 0. |
| INSULATORS | 207. UNITS | 1313. | 1.14 | 244. | | 1557. |
| HARDWARE | | 1429. | 0.47 | 47. | | 1477. |
| TOWERS | 4.3 UNITS | 38870. | 20.31 | 2031. | 26019. | 66921. |
| FOUNDATIONS | 4.3 UNITS | 3327. | | 538. | 22280. | 26145. |
| RIGHT OF WAY | 13. ACRES | 9120. | | | 18241. | 27361. |
| IDC/ENGINEERING | | 9328. | | | | 9328. |
| TOTALS | | 68147. | 31.65 | 3834. | 84796. | 166104. |

PRESENT VALUE (\$)

| LOSS ANALYSIS | DEMAND LOSSES | ENERGY LOSSES | TOTAL LOSSES |
|-------------------|---------------|---------------|--------------|
| RESISTANCE LOSSES | 24588. | 7992. | 32580. |
| CORONA LOSSES | 0. | 19. | 19. |
| TOTALS | 24588. | 8011. | 32600. |

INTERNATIONAL ENGINEERING CO. INC
SAN FRANCISCO CALIFORNIA

TRANSMISSION LINE COST ANALYSIS PROGRAM
VERSION 1: 23 FEB 1979,

ANCHORAGE-FAIRBANKS INTERTIE CASE IB
230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
DATE: 12 APR 79 TIME: 9:37:07

* INPUT DATA *

B-15

| SYSTEM ECONOMIC FACTORS ----- | INPUT VALUE ----- | REFERENCE YEAR FOR INPUT ----- |
|----------------------------------|----------------------|-----------------------------------|
| STARTING YEAR OF STUDY | 1979 | |
| ENDING YEAR OF STUDY | 1996 | |
| BASE YEAR FOR ESCALATION | 1977 | |
| MAXIMUM CIRCUIT LOADING | 136.8 MVA | 1992 |
| AVERAGE CIRCUIT LOADING | 49.2 MVA | 1992 |
| DEMAND COST FACTOR | 73.0 \$/KW | 1979 |
| ENERGY COST FACTOR | 13.0 MILLS/KWH | 1979 |
| VAR COST FACTOR | 0.0 \$/KVAR | 1984 |
| CAPITAL COST/DISCOUNT RATE: | | |
| MINIMUM | 7.0 PERCENT | 1984 |
| MAXIMUM | 10.0 PERCENT | 1984 |
| NUMBER OF INTERVALS | 1 | |
| O&M COST FACTOR | 1.5 % CAP.COST | 1979 |
| RIGHT OF WAY COST FACTOR | 715.0 \$/ACRE | 1979 |
| RIGHT OF WAY CLEARING COST | 1430.0 \$/ACRE | 1979 |
| INTEREST DURING CONSTRUCTION | 0.00 % INST.CST | |
| ENGINEERING FEE | 11.00 % INST.CST | |

ANCHORAGE-FAIRBANKS INTERTIE CASE 18
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 12 APR 79 TIME: 9:37:07

 * INPUT DATA *

 CONDUCTOR DATA

NUMBER PER PHASE 1
 CONDUCTOR SPACING 0.0 IN
 VOLTAGE 230 KV
 VOLTAGE VARIATION 10.00 PCT
 LINE FREQUENCY 60 CPS
 FAIRWEATHER LOSSES 0.00 KW/MI
 LINE LENGTH 323.00 MILES
 POWER FACTOR 0.95

 GROUNDWIRE DATA

NUMBER PER TOWER 0
 DIAMETER 0.00 IN
 WEIGHT 0.0000 LBS/FT

 SPAN DATA

MINIMUM 1200. FT
 MAXIMUM 1600. FT
 INTERVAL 100.0 FT

 WEATHER DATA

MAXIMUM RAINFALL RATE 1.18 IN/HR
 MAXIMUM RAINFALL DURATION 1 HRS/YR
 AVERAGE RAINFALL RATE 0.03 IN/HR
 AVERAGE RAINFALL DURATION 636 HRS/YR
 MAXIMUM SNOWFALL RATE 1.87 IN/HR
 MAXIMUM SNOWFALL DURATION 1 HRS/YR
 AVERAGE SNOWFALL RATE 0.13 IN/HR
 AVERAGE SNOWFALL DURATION 264 HRS/YR
 RELATIVE AIR DENSITY 1.000

ANCHORAGE-FAIRBANKS INTERTIE CASE 18
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 12 APR 79 TIME: 9:37:07

 * INPUT DATA *

SAG/TENSION DESIGN FACTORS

| | | | |
|-----------------------------------|----------------|--------------------------------|-----------------|
| EVERYDAY STRESS TEMPERATURE | 40. DEGREES F | ICE AND WIND TENSION (PCT UTS) | 50. PERCENT |
| ICF AND WIND TEMPERATURE | 0. DEGRFES F | HIGH WIND TENSION (PCT UTS) | 50. PERCENT |
| HIGH WIND TEMPERATURE | 40. DFGRFES F | EXTREME ICE TENSION (PCT UTS) | 70. PERCENT |
| EXTREME ICE TEMPERATURE | 30. DEGREES F | ICE THICKNESS WITH WIND | 0.50 INCHES |
| MAX DESIGN TEMP FOR GND CLEARANCE | 120. DEGRFES F | WIND PRESSURE WITH ICE | 4.00 LBS/SQ.FT. |
| EDS TENSION (PCT UTS) | 20. PERCENT | HIGH WIND | 9.0 LBS/SQ.FT. |
| NESC CONSTANT | 0.31 LBS/FT | | |
| | | EXTREME ICE | 0.50 INCHES |

B-17

TOWER DESIGN

| | | | |
|--------------------------------|-----------------|--------------------------|----------|
| TOTAL NUMBER OF PHASES | 3 | DISTANCE BETWEEN PHASES: | |
| PHASE SPACING | 20.0 FEET | D1 | 20.00 FT |
| CONDUCTOR CONFIGURATION FACTOR | 1.02 | D2 | 20.00 FT |
| GROUND CLEARANCE | 28.0 FEET | D3 | 40.00 FT |
| NO. OF INSULATORS PER TOWER | 48 | D4 | 0.00 FT |
| INSULATOR SAFETY FACTOR | 2.50 | D5 | 0.00 FT |
| STRING LENGTH | 6.5 FEET | D6 | 0.00 FT |
| I, VEE, OR COMBINATION | 3 | | |
| FOUNDATION TYPE | 4 | | |
| TERRAIN FACTOR | 1.06 PER UNIT | | |
| LINE ANGLE FACTOR | .0864 | | |
| TOWER GROUNDING | 0 | | |
| TRANSVERSE OVERLOAD FACTOR | 2.50 | | |
| VERTICAL OVERLOAD FACTOR | 1.50 | | |
| LONGITUDINAL LOAD | 1000. LBS | | |
| MISCELLANEOUS HARDWARE WEIGHT | 0.11 TONS/TOWER | | |
| TOWER WEIGHT FACTOR | 1.02 | | |

TOWER WEIGHT ESTIMATION ALGORITHM

TOWER TYPE 9: 230KV TOWER

$$TW = 0.00016 * TH * A^2 = 3.09797 * TH * 0.3333 = 0.08943 * EFFVDL =$$

$$0.27367 * EFFTDL + 0.00510 * TH * EFFTDL + 0.00160 * TH * EFFVDL +$$

$$18.57912 \text{ KIPS}$$

ANCHORAGE-FAIRBANKS INTERTIE CASE 18
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 12 APR 79 TIME: 9:37:07

 * INPUT DATA *

CONDUCTOR SUMMARY

| ID NUMBER | NAME | SIZE(KCM) | STRANDING (AL/ST) | UNIT WEIGHT (LBS/FT) | OUT.DIAM. (INCHES) | TOTAL AREA (SQ.IN.) | MODULUS (EF/E6 PSI) | TEMP.COEF. ALPHA*E-6 PER DEG F |
|-----------|-----------|-----------|----------------------|-------------------------|-----------------------|------------------------|------------------------|--------------------------------------|
| ----- | ---- | ----- | ----- | ----- | ----- | ----- | ----- | ----- |
| 24 | GROSBREAK | 636.0 | 26/ 7 | 0.8750 | 0.9900 | 0.5809 | 11.00 | 10.3 |
| 25 | EGRET | 636.0 | 30/19 | 0.9880 | 1.0190 | 0.6134 | 11.30 | 9.7 |
| 26 | FLAMINGO | 666.0 | 24/ 7 | 0.8590 | 1.0000 | 0.5914 | 10.55 | 10.7 |
| 27 | GANNET | 666.0 | 26/ 7 | 0.9180 | 1.0140 | 0.6087 | 11.00 | 10.3 |
| 28 | STILT | 715.0 | 24/ 7 | 0.9210 | 1.0360 | 0.6348 | 10.55 | 10.7 |
| 29 | STARLING | 715.0 | 26/ 7 | 0.9850 | 1.0510 | 0.6535 | 11.00 | 10.3 |
| 30 | REDWING | 715.0 | 30/19 | 1.1110 | 1.0810 | 0.6901 | 11.30 | 9.7 |
| 31 | CUCKOO | 795.0 | 24/ 7 | 1.0240 | 1.0920 | 0.7053 | 10.55 | 10.7 |
| 32 | DRAKE | 795.0 | 26/ 7 | 1.0940 | 1.1080 | 0.7261 | 11.00 | 10.3 |
| 33 | TERN | 795.0 | 45/ 7 | 0.8960 | 1.0630 | 0.6676 | 9.40 | 11.5 |
| 34 | CONDOR | 795.0 | 54/ 7 | 1.0240 | 1.0930 | 0.7053 | 10.85 | 10.9 |
| 35 | MALLARD | 795.0 | 30/19 | 1.2350 | 1.1400 | 0.7668 | 11.30 | 9.7 |
| 36 | RUDDY | 900.0 | 45/ 7 | 1.0150 | 1.1310 | 0.7069 | 9.40 | 11.5 |
| 37 | CANARY | 900.0 | 54/ 7 | 1.1590 | 1.1620 | 0.7985 | 10.85 | 10.9 |
| 38 | RAIL | 954.0 | 45/ 7 | 1.0750 | 1.1650 | 0.8011 | 9.40 | 11.5 |
| 39 | CARDINAL | 954.0 | 54/ 7 | 1.2290 | 1.1960 | 0.8464 | 10.85 | 10.9 |

ANCHORAGE-FAIRBANKS INTERTIE CASE 18
230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
DATE: 12 APR 79 TIME: 9:37:07

* INPUT DATA *

CONDUCTOR SUMMARY

| ID NUMBER | NAME | ULT.TENS. STRENGTH(LBS) | GEOM.MEAN RADIUS(FT) | PRICE(\$/LB) | THERM.LIMIT (AMPERES) | AC RESIST. AT 25 DEG C (OHMS/MILE) | IND.REACT. (OHMS/MILE) | CAP.REACT. (MOHM-MILES) |
|-----------|----------|----------------------------|-------------------------|--------------|--------------------------|--|---------------------------|----------------------------|
| 24 | GROSHAK | 25000.0 | 0.0335 | 0.628/1977 | 790. | 0.1452 | 0.4118 | 2.6347 |
| 25 | EGRET | 31500.0 | 0.0351 | 0.609/1977 | 870. | 0.1447 | 0.4060 | 2.6136 |
| 26 | FLAMINGO | 23700.0 | 0.0335 | 0.640/1977 | 810. | 0.1399 | 0.4118 | 2.6294 |
| 27 | GANNET | 26200.0 | 0.0343 | 0.609/1977 | 820. | 0.1373 | 0.4092 | 2.6347 |
| 28 | STILT | 25500.0 | 0.0347 | 0.627/1977 | 840. | 0.1320 | 0.4066 | 2.6400 |
| 29 | STARLING | 28100.0 | 0.0355 | 0.608/1977 | 850. | 0.1294 | 0.4050 | 2.6453 |
| 30 | REDWING | 34600.0 | 0.0372 | 0.612/1977 | 860. | 0.1288 | 0.3992 | 2.5661 |
| 31 | CUCKOO | 27100.0 | 0.0366 | 0.636/1977 | 900. | 0.1214 | 0.3992 | 2.5502 |
| 32 | DRAKE | 31200.0 | 0.0375 | 0.622/1977 | 910. | 0.1172 | 0.3992 | 2.5450 |
| 33 | TERN | 22900.0 | 0.0352 | 0.677/1977 | 890. | 0.1188 | 0.4060 | 2.5766 |
| 34 | CONDOR | 28500.0 | 0.0368 | 0.635/1977 | 900. | 0.1172 | 0.4002 | 2.5555 |
| 35 | MALLARD | 38400.0 | 0.0392 | 0.599/1977 | 910. | 0.1162 | 0.3928 | 2.5186 |
| 36 | RUDDY | 25400.0 | 0.0374 | 0.676/1977 | 935. | 0.1082 | 0.3928 | 2.5080 |
| 37 | CANARY | 32300.0 | 0.0392 | 0.633/1977 | 950. | 0.1040 | 0.3928 | 2.5027 |
| 38 | RAIL | 26900.0 | 0.0385 | 0.671/1977 | 970. | 0.0998 | 0.3949 | 2.5027 |
| 39 | CARDINAL | 34200.0 | 0.0404 | 0.632/1977 | 990. | 0.0987 | 0.3902 | 2.4816 |

ANCHORAGE-FAIRBANKS INTERTIE CASE 1B
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 12 APR 79 TIME: 9:37:07

 * INPUT DATA *

| UNIT MATERIALS COSTS ----- | INPUT VALUE ----- | REFERENCE YEAR FOR INPUT ----- |
|------------------------------------|-------------------------|-----------------------------------|
| PRICE OF TOWER MATERIAL | 0.957 \$/LB | 1979 |
| PRICE OF CONCRETE | 0.00 \$/CU.YD. | 1977 |
| PRICE OF GROUND WIRE | 0.000 \$/LB | 1977 |
| INSTALLED COST OF GROUNDING SYSTEM | 0.00 \$/TOWER | 1977 |
| TOWER SETUP | 1751. \$ | 1979 |
| TOWER ASSEMBLY | 0.455 \$/LB | 1979 |
| FOUNDATION SETUP | 0. \$ | 1979 |
| FOUNDATION ASSEMBLY | 4140.00 \$/TON | 1979 |
| FOUNDATION EXCAVATION | 0.00 \$/CU.YD. | 1979 |
| PRICE OF MISCELLANEOUS HARDWARE | 290.00 \$/TOWER | 1977 |
| UNIT LABOR COSTS ----- | | |
| REFERENCE YEAR LABOR COST | 24.00 \$/MANHOUR | 1979 |
| STRING GROUND WIRE | 0.0 \$/MILE | 1977 |
| STRING LABOR MARKUP | 4.2 PER UNIT | |
| UNIT TRANSPORTATION COSTS ----- | | |
| TOWER | 100.0 \$/TON | |
| FOUNDATION CONCRETE | 100.0 \$/YD | |
| FOUNDATION STEEL | 100.0 \$/TON | |
| CONDUCTOR | 100.0 \$/TON | |
| GROUND WIRE | 100.0 \$/TON | |
| INSULATOR | 100.0 \$/TON OR \$/M**3 | |
| HARDWARE | 100.0 \$/TON | |

ANCHORAGE-FAIRBANKS INTERTIE CASE 18
230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
DATE: 12 APR 79 TIME: 9:37:07

*
* AUTOMATIC CONDUCTOR SELECTION *
* ALL QUANTITIES PER MILE *
*

CAPITAL COST/DISCOUNT RATE OF 7.00 PERCENT

B-21

| CONDUCTOR | | | INSTALLED COST | | | | | PRESENT WORTH | | |
|-----------|------|----------|----------------|----------------|--------------|---------|----------|-------------------------|----------------------|--------------------|
| NO. | KCM | SPAN(FT) | MATERIALS | TRANSPORTATION | INSTALLATION | ENG/IDC | SUBTOTAL | LINE LOSSES SUBTOTAL | O&M COST SUBTOTAL | LINE COST TOTAL |
| 39 | 954. | 1300. | 68147. | 3834. | 84796. | 9328. | 166104. | 35856. | 3284. | 205244. |
| 37 | 900. | 1300. | 67299. | 3772. | 84608. | 9307. | 164986. | 37993. | 3257. | 206235. |
| 35 | 795. | 1300. | 64664. | 3721. | 82616. | 9088. | 160089. | 43028. | 3151. | 206267. |
| 35 | 795. | 1400. | 65375. | 3684. | 82031. | 9023. | 160113. | 43028. | 3161. | 206302. |
| 39 | 954. | 1400. | 69552. | 3828. | 84673. | 9314. | 167367. | 35856. | 3322. | 206545. |
| 37 | 900. | 1400. | 68697. | 3766. | 84494. | 9294. | 166251. | 37993. | 3294. | 207538. |
| 35 | 795. | 1500. | 66879. | 3689. | 82176. | 9039. | 161784. | 43028. | 3206. | 208017. |
| 32 | 795. | 1300. | 65558. | 3685. | 83893. | 9228. | 162364. | 43468. | 3195. | 209027. |
| 39 | 954. | 1500. | 71843. | 3870. | 85337. | 9387. | 170437. | 35856. | 3397. | 209689. |
| 34 | 795. | 1300. | 65807. | 3659. | 84359. | 9279. | 163104. | 43545. | 3209. | 209858. |
| 38 | 954. | 1300. | 70136. | 3831. | 86787. | 9547. | 170300. | 36293. | 3371. | 209963. |
| 32 | 795. | 1400. | 66784. | 3669. | 83683. | 9205. | 163342. | 43468. | 3226. | 210036. |
| 30 | 715. | 1300. | 63510. | 3615. | 82301. | 9053. | 158478. | 48561. | 3117. | 210151. |
| 30 | 715. | 1400. | 64204. | 3576. | 81729. | 8990. | 158498. | 48561. | 3122. | 210182. |
| 39 | 954. | 1200. | 70386. | 4033. | 87082. | 9579. | 171080. | 35856. | 3385. | 210321. |
| 37 | 900. | 1500. | 70983. | 3807. | 85172. | 9369. | 169331. | 37993. | 3369. | 210693. |
| 34 | 795. | 1400. | 67235. | 3653. | 84298. | 9273. | 164459. | 43545. | 3248. | 211251. |
| 35 | 795. | 1600. | 69124. | 3735. | 82979. | 9128. | 164966. | 43028. | 3282. | 211275. |
| 37 | 900. | 1200. | 69631. | 3977. | 86926. | 9562. | 170096. | 37993. | 3361. | 211450. |
| 35 | 795. | 1200. | 66889. | 3916. | 85020. | 9352. | 165176. | 43028. | 3254. | 211457. |
| 30 | 715. | 1500. | 65702. | 3580. | 81896. | 9009. | 160187. | 48561. | 3167. | 211915. |
| 36 | 900. | 1300. | 69499. | 3780. | 86682. | 9535. | 169496. | 39701. | 3351. | 212547. |
| 38 | 954. | 1400. | 72348. | 3861. | 87234. | 9596. | 173039. | 36293. | 3440. | 212771. |
| 32 | 795. | 1500. | 68883. | 3701. | 84257. | 9268. | 166109. | 43468. | 3295. | 212871. |
| 29 | 715. | 1300. | 64091. | 3593. | 83683. | 9205. | 160573. | 49222. | 3150. | 212944. |

ANCHORAGE-FAIRBANKS INTERTIE CASE IB
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 12 APR 79 TIME: 9:37:07

 *
 * COST OUTPUT PER MILE *
 * PRESENT VALUE RATE *
 * 7.00 PERCENT *
 *

CONDUCTOR NUMBER = 39
 954. KCMIL 1300. FT SPAN 87.7 FT TOWER

| INSTALLED COST BREAKDOWN | QUANTITY | MATERIAL COST(\$) | TONNAGE | TRANSPORTATION COST(\$) | INSTALLATION COST(\$) | TOTAL COST(\$) |
|-----------------------------|------------|----------------------|---------|----------------------------|--------------------------|-------------------|
| CONDUCTOR | 15840. FT | 14086. | 9.73 | 973. | 18257. | 33316. |
| GROUNDWIRE | 0. FT | 0. | 0.00 | 0. | 0. | 0. |
| INSULATORS | 207. UNITS | 1313. | 1.14 | 244. | | 1557. |
| HARDWARE | | 1429. | 0.47 | 47. | | 1477. |
| TOWERS | 4.3 UNITS | 38870. | 20.31 | 2031. | 26019. | 66921. |
| FOUNDATIONS | 4.3 UNITS | 3327. | | 538. | 22280. | 26145. |
| RIGHT OF WAY | 13. ACRES | 9120. | . | | 18241. | 27361. |
| IDC/ENGINEERING | | 9328. | | | | 9328. |
| TOTALS | | 68147. | 31.65 | 3834. | 84796. | 166104. |

PRESENT VALUE (\$)

| LOSS ANALYSIS | DEMAND LOSSES | ENERGY LOSSES | TOTAL LOSSES |
|-------------------|---------------|---------------|--------------|
| RESISTANCE LOSSES | 24588. | 11249. | 35837. |
| CORONA LOSSES | 0. | 19. | 19. |
| TOTALS | 24588. | 11268. | 35856. |

INTERNATIONAL ENGINEERING CO. INC
SAN FRANCISCO CALIFORNIA

TRANSMISSION LINE COST ANALYSIS PROGRAM
VERSION 2: 02 AUG 1979,

ANCHORAGE-FAIRBANKS INTERTIE CASE I-C
345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
DATE: 15 AUG 79 TIME: 14:06:42

* INPUT DATA *

| SYSTEM ECONOMIC FACTORS ----- | INPUT VALUE ----- | REFERENCE YEAR FOR INPUT ----- |
|----------------------------------|----------------------|-----------------------------------|
| BASE YEAR FOR PW ANALYSIS | 1979 | |
| ENDING YEAR OF STUDY | 1997 | |
| BASE YEAR FOR ESCALATION | 1977 | |
| MAXIMUM CIRCUIT LOADING | 168.4 MVA | 1984 |
| AVERAGE CIRCUIT LOADING | 58.9 MVA | 1984 |
| DEMAND COST FACTOR | 73.0 \$/KW | 1979 |
| ENERGY COST FACTOR | 13.0 MILLS/KWH | 1979 |
| VAR COST FACTOR | 0.0 \$/KVAR | 1984 |
| CAPITAL COST/DISCOUNT RATES: | | |
| | 7.0 PERCENT | 1984 |
| | 10.0 PERCENT | 1984 |
| O&M COST FACTOR | 1.5 % CAP.COST | 1984 |
| RIGHT OF WAY COST FACTOR | 715.0 \$/ACRE | 1979 |
| RIGHT OF WAY CLEARING COST | 1430.0 \$/ACRE | 1979 |
| INTEREST DURING CONSTRUCTION | 0.00 % INST.CST | |
| ENGINEERING FEF | 11.00 % INST.CST | |

ANCHORAGE-FAIRBANKS INTERTIE CASE I-C
 345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 14:06:42

 * INPUT DATA *

CONDUCTOR DATA

GROUNDWIRE DATA

SPAN DATA

| | | | | | |
|--------------------|--------------|------------------|---------------|----------|----------|
| NUMBER PER PHASE | 2 | NUMBER PER TOWER | 0 | MINIMUM | 1000. FT |
| CONDUCTOR SPACING | 18.0 IN | DIAMETER | 0.00 IN | MAXIMUM | 1600. FT |
| VOLTAGE | 345 KV | WEIGHT | 0.0000 LBS/FT | INTERVAL | 100.0 FT |
| VOLTAGE VARIATION | 10.00 PCT | | | | |
| LINE FREQUENCY | 60 CPS | | | | |
| FAIRWEATHER LOSSES | 1.70 KW/MI | | | | |
| LINE LENGTH | 323.00 MILES | | | | |
| POWER FACTOR | 0.95 | | | | |

B - 24

WEATHER DATA

| | |
|---------------------------|------------|
| MAXIMUM RAINFALL RATE | 1.18 IN/HR |
| MAXIMUM RAINFALL DURATION | 1 HRS/YR |
| AVERAGE RAINFALL RATE | 0.03 IN/HR |
| AVERAGE RAINFALL DURATION | 636 HRS/YR |
| MAXIMUM SNOWFALL RATE | 1.87 IN/HR |
| MAXIMUM SNOWFALL DURATION | 1 HRS/YR |
| AVERAGE SNOWFALL RATE | 0.13 IN/HR |
| AVERAGE SNOWFALL DURATION | 264 HRS/YR |
| RELATIVE AIR DENSITY | 1.000 |

ANCHORAGE-FAIRBANKS INTERTIE CASE I-C
 345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 14:06:42

 *
 * INPUT DATA *
 *

SAG/TENSION DESIGN FACTORS

| | | | |
|-----------------------------------|----------------|--------------------------------|-----------------|
| EVERYDAY STRESS TEMPERATURE | 40. DEGREES F | ICE AND WIND TENSION (PCT UTS) | 50. PERCENT |
| ICE AND WIND TEMPERATURE | 0. DEGREES F | HIGH WIND TENSION (PCT UTS) | 50. PERCENT |
| HIGH WIND TEMPERATURE | 40. DEGREES F | EXTREME ICE TENSION (PCT UTS) | 70. PERCENT |
| EXTREME ICE TEMPERATURE | 30. DEGREES F | ICE THICKNESS WITH WIND | 0.50 INCHES |
| MAX DESIGN TEMP FOR GND CLEARANCE | 120. DEGREES F | WIND PRESSURE WITH ICE | 4.00 LBS/SQ.FT. |
| EDS TENSION (PCT UTS) | 20. PERCENT | HIGH WIND | 9.0 LBS/SQ.FT. |
| NESC CONSTANT | 0.31 LBS/FT | EXTREME ICE | 0.50 INCHES |

TOWER DESIGN

| | | | |
|--------------------------------|-----------------|--------------------------|----------|
| TOTAL NUMBER OF PHASES | 3 | DISTANCE BETWEEN PHASES: | |
| PHASE SPACING | 27.0 FEET | D1 | 27.00 FT |
| CONDUCTOR CONFIGURATION FACTOR | 1.00 | D2 | 27.00 FT |
| GROUND CLEARANCE | 32.0 FEET | D3 | 54.00 FT |
| NO. OF INSULATORS PER TOWER | 72 | D4 | 0.00 FT |
| INSULATOR SAFETY FACTOR | 2.50 | D5 | 0.00 FT |
| STRING LENGTH | 9.5 FEET | D6 | 0.00 FT |
| I, VEE, OR COMBINATION | 3 | | |
| FOUNDATION TYPE | 4 | | |
| TERRAIN FACTOR | 1.06 PER UNIT | | |
| LINE ANGLE FACTOR | .0864 | | |
| TOWER GROUNDING | 0 | | |
| TRANSVERSE OVERLOAD FACTOR | 2.50 | | |
| VERTICAL OVERLOAD FACTOR | 1.50 | | |
| LONGITUDINAL LOAD | 1000. LBS | | |
| MISCELLANEOUS HARDWARE WEIGHT | 0.11 TONS/TOWER | | |
| TOWER WEIGHT FACTOR | 1.02 | | |

TOWER WEIGHT ESTIMATION ALGORITHM

TOWER TYPE 10: 345KV TOWER

$$TW = 0.00043*TH**2 + 0.992111*TH*0.6000 + 0.10371*EFFVDL + 0.27365*EFFTDL + 0.00503*TH*EFFTDL + 0.00181*TH*EFFVDL + 20.77701 \text{ KIPS}$$

ANCHORAGE-FAIRBANKS INTERTIE CASE I-C
 345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 14:06:42

 *
 * INPUT DATA *
 *

CONDUCTOR SUMMARY

| ID NUMBER | NAME | SIZE(KCM) | STRANDING (AL/ST) | UNIT WEIGHT (LBS/FT) | OUT.DIAM. (INCHES) | TOTAL AREA (SQ.IN.) | MODULUS (EF/E6 PSI) | TEMP.COEF. ALPHA*E-6 PER DEG F |
|-----------|----------|-----------|----------------------|-------------------------|-----------------------|------------------------|------------------------|--------------------------------------|
| 29 | STARLING | 715.0 | 26/ 7 | 0.9850 | 1.0510 | 0.6535 | 11.00 | 10.3 |
| 30 | REDWING | 715.0 | 30/19 | 1.1110 | 1.0810 | 0.6901 | 11.30 | 9.7 |
| 31 | CUCKOO | 795.0 | 24/ 7 | 1.0240 | 1.0920 | 0.7053 | 10.55 | 10.7 |
| 32 | DRAKE | 795.0 | 26/ 7 | 1.0940 | 1.1080 | 0.7261 | 11.00 | 10.3 |
| 33 | TERN | 795.0 | 45/ 7 | 0.8960 | 1.0630 | 0.6676 | 9.40 | 11.5 |
| 34 | CONDOR | 795.0 | 54/ 7 | 1.0240 | 1.0930 | 0.7053 | 10.85 | 10.9 |
| 35 | MAILLARD | 795.0 | 30/19 | 1.2350 | 1.1400 | 0.7668 | 11.30 | 9.7 |
| 36 | RUDDY | 900.0 | 45/ 7 | 1.0150 | 1.1310 | 0.7069 | 9.40 | 11.5 |
| 37 | CANARY | 900.0 | 54/ 7 | 1.1590 | 1.1620 | 0.7985 | 10.85 | 10.9 |
| 38 | RAJL | 954.0 | 45/ 7 | 1.0750 | 1.1650 | 0.8011 | 9.40 | 11.5 |
| 39 | CARDINAL | 954.0 | 54/ 7 | 1.2290 | 1.1960 | 0.8464 | 10.85 | 10.9 |
| 40 | ORTOLAN | 1033.0 | 45/ 7 | 1.1650 | 1.2130 | 0.8678 | 9.40 | 11.5 |

ANCHORAGE-FAIRBANKS INTERTIE CASE I-C
 345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 14:06:42

 * INPUT DATA *

CONDUCTOR SUMMARY

| ID NUMBER | NAME | ULT.TENS. STRENGTH(LBS) | GEOM.MEAN RADIUS(FT) | PRICE(\$/LB) | THERM.LIMIT (AMPERES) | AC RESIST. AT 25 DEG C (OHMS/MILE) | IND.REACT. (OHMS/MILE) | CAP.REACT. (MOHM-MILES) | |
|-----------|------|----------------------------|-------------------------|--------------|--------------------------|--|---------------------------|----------------------------|--------|
| B - 27 | 29 | STARLING | 28100.0 | 0.0355 | 0.608/1977 | 850. | 0.1294 | 0.4050 | 2.6453 |
| | 30 | REDWING | 34600.0 | 0.0372 | 0.612/1977 | 860. | 0.1288 | 0.3992 | 2.5661 |
| | 31 | CUCKOO | 27100.0 | 0.0366 | 0.636/1977 | 900. | 0.1214 | 0.3992 | 2.5502 |
| | 32 | DRAKE | 31200.0 | 0.0375 | 0.622/1977 | 910. | 0.1172 | 0.3992 | 2.5450 |
| | 33 | TERN | 22900.0 | 0.0352 | 0.677/1977 | 890. | 0.1188 | 0.4060 | 2.5766 |
| | 34 | CUNDR | 28500.0 | 0.0368 | 0.635/1977 | 900. | 0.1172 | 0.4002 | 2.5555 |
| | 35 | MALLARD | 38400.0 | 0.0392 | 0.599/1977 | 910. | 0.1162 | 0.3928 | 2.5186 |
| | 36 | RIDDY | 25400.0 | 0.0374 | 0.676/1977 | 935. | 0.1082 | 0.3928 | 2.5080 |
| | 37 | CANARY | 32300.0 | 0.0392 | 0.633/1977 | 950. | 0.1040 | 0.3928 | 2.5027 |
| | 38 | RAIL | 26900.0 | 0.0385 | 0.671/1977 | 970. | 0.0998 | 0.3949 | 2.5027 |
| | 39 | CARDINAL | 34200.0 | 0.0404 | 0.632/1977 | 990. | 0.0987 | 0.3902 | 2.4816 |
| | 40 | ORTULAN | 28900.0 | 0.0401 | 0.670/1977 | 1020. | 0.0924 | 0.3902 | 2.4658 |

ANCHORAGE-FAIRBANKS INTERTIE CASE I-C
 345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 14:06:42

 *
 * INPUT DATA *
 *

| UNIT MATERIALS COSTS | INPUT VALUE | REFERENCE YEAR FOR INPUT |
|------------------------------------|-----------------|--------------------------|
| PRICE OF TOWER MATERIAL | 0.957 \$/LB | 1979 |
| PRICE OF CONCRETE | 0.00 \$/CU.YD. | 1977 |
| PRICE OF GROUND WIRE | 0.000 \$/LB | 1977 |
| INSTALLED COST OF GROUNDING SYSTEM | 0.00 \$/TOWER | 1977 |
| TOWER SETUP | 1751. \$ | 1979 |
| TOWER ASSEMBLY | 0.455 \$/LB | 1979 |
| FOUNDATION SETUP | 0. \$ | 1979 |
| FOUNDATION ASSEMBLY | 4140.00 \$/TON | 1979 |
| FOUNDATION EXCAVATION | 0.00 \$/CU.YD. | 1979 |
| PRICE OF MISCELLANEOUS HARDWARE | 290.00 \$/TOWER | 1977 |

| UNIT LABOR COSTS | | |
|---------------------------|------------------|------|
| REFERENCE YEAR LABOR COST | 24.00 \$/MANHOUR | 1979 |
| STRING GROUND WIRE | 0.0 \$/MILE | 1977 |
| STRING LABOR MARKUP | 4.2 PER UNIT | |

| UNIT TRANSPORTATION COSTS | | |
|---------------------------|-------------------------|--|
| TOWER | 131.0 \$/TON | |
| FOUNDATION CONCRETE | 131.0 \$/YD | |
| FOUNDATION STEEL | 131.0 \$/TON | |
| CONDUCTOR | 131.0 \$/TON | |
| GROUND WIRE | 131.0 \$/TON | |
| INSULATOR | 131.0 \$/TON OR \$/M**3 | |
| HARDWARE | 131.0 \$/TON | |

ANCHORAGE-FAIRBANKS INTERTIE CASE I-C
345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
DATE: 15 AUG 79 TIME: 14:06:42

*
* AUTOMATIC CONDUCTOR SELECTION *
* ALL QUANTITIES PER MILE *
*

CAPITAL COST/DISCOUNT RATE OF 7.00 PERCENT

PRESENT WORTH (\$)

B - 29

| CONDUCTOR | | | INSTALLED COST | | | | | | LINE LOSSES | O&M COST | LINE COST |
|-----------|------|----------|----------------|---------|----------|-----------|-----|----------|-------------|----------|-----------|
| NO. | KCM | SPAN(FT) | MATERIALS | TRANSP. | INSTALL. | ENGINEER. | IDC | SUBTOTAL | SUBTOTAL | SUBTOTAL | TOTAL |
| 35 | 795. | 1300. | 108253. | 6482. | 110086. | 24730. | 0. | 249551. | 46122. | 3372. | 299046. |
| 35 | 795. | 1400. | 110039. | 6483. | 108849. | 24791. | 0. | 250162. | 46122. | 3381. | 299665. |
| 30 | 715. | 1300. | 105622. | 6257. | 109368. | 24337. | 0. | 245584. | 52150. | 3319. | 301053. |
| 35 | 795. | 1200. | 107799. | 6557. | 112490. | 24953. | 0. | 251799. | 46122. | 3403. | 301324. |
| 30 | 715. | 1400. | 107324. | 6253. | 108105. | 24385. | 0. | 246066. | 52150. | 3325. | 301541. |
| 37 | 900. | 1300. | 112812. | 6579. | 112648. | 25524. | 0. | 257563. | 41403. | 3481. | 302447. |
| 32 | 795. | 1300. | 109255. | 6395. | 111472. | 24983. | 0. | 252106. | 47191. | 3407. | 302703. |
| 35 | 795. | 1500. | 113021. | 6550. | 108617. | 25101. | 0. | 253289. | 46122. | 3423. | 302834. |
| 39 | 954. | 1300. | 114706. | 6710. | 113084. | 25795. | 0. | 260295. | 39129. | 3517. | 302941. |
| 37 | 900. | 1200. | 111385. | 6608. | 114494. | 25574. | 0. | 258061. | 41403. | 3487. | 302751. |
| 30 | 954. | 1200. | 113228. | 6736. | 114915. | 25837. | 0. | 260716. | 39129. | 3523. | 303367. |
| 30 | 715. | 1200. | 105232. | 6336. | 111787. | 24569. | 0. | 247924. | 52150. | 3350. | 303424. |
| 34 | 795. | 1300. | 109578. | 6337. | 111931. | 25041. | 0. | 252687. | 47590. | 3415. | 303691. |
| 32 | 795. | 1200. | 108121. | 6439. | 113468. | 25083. | 0. | 253111. | 47191. | 3420. | 303722. |
| 29 | 715. | 1300. | 105955. | 6199. | 110878. | 24534. | 0. | 247565. | 53308. | 3345. | 304219. |
| 34 | 795. | 1200. | 107941. | 6369. | 113774. | 25095. | 0. | 253229. | 47590. | 3422. | 304247. |
| 30 | 715. | 1500. | 110237. | 6316. | 107857. | 24685. | 0. | 249095. | 52150. | 3366. | 304611. |
| 32 | 795. | 1400. | 111805. | 6432. | 110688. | 25182. | 0. | 254106. | 47191. | 3434. | 304731. |
| 37 | 900. | 1400. | 115679. | 6631. | 112024. | 25777. | 0. | 260112. | 41403. | 3515. | 305029. |
| 29 | 715. | 1200. | 104868. | 6246. | 112878. | 24639. | 0. | 248632. | 53308. | 3360. | 305300. |
| 39 | 954. | 1400. | 117620. | 6765. | 112473. | 26054. | 0. | 262913. | 39129. | 3553. | 305594. |
| 29 | 715. | 1400. | 108480. | 6233. | 110103. | 24730. | 0. | 249545. | 53308. | 3372. | 306225. |
| 34 | 795. | 1400. | 112220. | 6386. | 111322. | 25292. | 0. | 255220. | 47590. | 3449. | 306259. |
| 35 | 795. | 1100. | 108831. | 6718. | 116263. | 25499. | 0. | 257312. | 46122. | 3477. | 306911. |
| 37 | 900. | 1100. | 111580. | 6730. | 117785. | 25970. | 0. | 262065. | 41403. | 3541. | 307009. |

ANCHORAGE-FAIRBANKS INTERTIE CASE I-C
 345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 14:06:42

 * COST OUTPUT PER MILE *
 * PRESENT VALUE RATE *
 * 7.00 PERCENT *
 *

CONDUCTOR NUMBER = 35
 795. KCMIL 1300. FT SPAN 89.3 FT TOWER

| INSTALLED COST BREAKDOWN | QUANTITY | MATERIAL COST(\$) | TONNAGE | TRANSPORTATION COST(\$) | INSTALLATION COST(\$) | TOTAL COST(\$) |
|-------------------------------------|------------|----------------------|---------|----------------------------|--------------------------|-------------------------|
| CONDUCTOR | 31680. FT | 35171. | 19.56 | 2563. | 33947. | 71681. |
| GROUNDWIRE | 0. FT | 0. | 0.00 | 0. | 0. | 0. |
| INSULATORS | 310. UNITS | 2582. | 1.70 | 480. | | 3062. |
| HARDWARE | | 1874. | 0.47 | 62. | | 1936. |
| TOWERS | 4.3 UNITS | 83824. - ? | 33.41 - | 4377. - | 49735. | 137936. |
| FOUNDATIONS | 4.3 UNITS | 6280. | | 1015. | 42054. | 49349. |
| RIGHT OF WAY (107FT) | 13. ACRES | 12167. | | | 18565. | 30732. |
| SUB-TOTALS | | 141897. | 55.15 | 8497. | 144301. | 294695. |
| IDC ENGINEERING | | | | | | 0. 32416. |
| | | | | | | TOTAL 327111. |
| PRESENT WORTH IDC ENGINEERING | | 108253. | | 6482. | 110086. | 224821. 0. 24730. |
| | | | | | | TOTAL 249551. |

PRESENT WORTH (\$)

| LOSS ANALYSIS | DEMAND LOSSES | ENERGY LOSSES | TOTAL LOSSES |
|---------------------------|---------------|---------------|--------------|
| RESISTANCE LOSSES | 25483. | 14441. | 39924. |
| CORONA LOSSES: INSULATORS | 1624. | 3145. | 4768. |
| CONDUCTOR | - | 1430. | 1430. |
| TOTALS | 27107. | 19015. | 46122. |

INTERNATIONAL ENGINEERING CO. INC
SAN FRANCISCO CALIFORNIA

TRANSMISSION LINE COST ANALYSIS PROGRAM
VERSION 2: 02 AUG 1979,

ANCHORAGE-DEVIL CANYON CASE II-1
345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
DATE: 15 AUG 79 TIME: 15:56:14

* INPUT DATA *
*

B - 31

| SYSTEM ECONOMIC FACTORS ----- | INPUT VALUE ----- | REFERENCE YEAR FOR INPUT ----- |
|----------------------------------|----------------------|-----------------------------------|
| BASE YEAR FOR PW ANALYSIS | 1979 | |
| ENDING YEAR OF STUDY | 1997 | |
| BASE YEAR FOR ESCALATION | 1977 | |
| MAXIMUM CIRCUIT LOADING | 631.6 MVA | 1992 |
| AVERAGE CIRCUIT LOADING | 347.4 MVA | 1992 |
| DEMAND COST FACTOR | 73.0 \$/KW | 1979 |
| ENERGY COST FACTOR | 13.0 MILLS/KWH | 1979 |
| VAR COST FACTOR | 0.0 \$/KVAR | 1984 |
| CAPITAL COST/DISCOUNT RATES: | | |
| | 7.0 PERCENT | 1984 |
| | 10.0 PERCENT | 1984 |
| OKM COST FACTOR | 1.5 % CAP.COST | 1984 |
| RIGHT OF WAY COST FACTOR | 715.0 \$/ACRE | 1979 |
| RIGHT OF WAY CLEARING COST | 1430.0 \$/ACRE | 1979 |
| INTEREST DURING CONSTRUCTION | 0.00 % INST.CST | |
| ENGINEERING FEE | 11.00 % INST.CST | |

ANCHORAGE-DEVIL CANYON CASE II-1
 345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 15:56:14

 * INPUT DATA *

CONDUCTOR DATA

NUMBER PER PHASE 2
 CONDUCTOR SPACING 18.0 IN
 VOLTAGE 345 KV
 VOLTAGE VARIATION 10.00 PCT
 LINE FREQUENCY 60 CPS
 FAIRWEATHER LOSSES 1.70 KW/MI
 LINE LENGTH 155.00 MILES
 POWER FACTOR 0.95

GROUNDWIRE DATA

NUMBER PER TOWER 0
 DIAMETER 0.00 IN
 WEIGHT 0.0000 LBS/FT

SPAN DATA

MINIMUM 1000. FT
 MAXIMUM 1600. FT
 INTERVAL 100.0 FT

WEATHER DATA

MAXIMUM RAINFALL RATE 1.18 IN/HR
 MAXIMUM RAINFALL DURATION 1 HRS/YR
 AVERAGE RAINFALL RATE 0.03 IN/HR
 AVERAGE RAINFALL DURATION 0.36 HRS/YR
 MAXIMUM SNOWFALL RATE 1.87 IN/HR
 MAXIMUM SNOWFALL DURATION 1 HRS/YR
 AVERAGE SNOWFALL RATE 0.13 IN/HR
 AVERAGE SNOWFALL DURATION 264 HRS/YR
 RELATIVE AIR DENSITY 1.000

ANCHORAGE-DEVIL CANYON CASE II-1
 345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 15:56:14

 * INPUT DATA *

SAG/TENSION DESIGN FACTORS

| | | | |
|-----------------------------------|----------------|--------------------------------|-----------------|
| EVERYDAY STRESS TEMPERATURE | 40. DEGREES F | ICE AND WIND TENSION (PCT UTS) | 50. PERCENT |
| ICE AND WIND TEMPERATURE | 0. DEGREES F | HIGH WIND TENSION (PCT UTS) | 50. PERCENT |
| HIGH WIND TEMPERATURE | 40. DEGREES F | EXTREME ICE TENSION (PCT UTS) | 70. PERCENT |
| EXTREME ICE TEMPERATURE | 30. DEGREES F | ICE THICKNESS WITH WIND | 0.50 INCHES |
| MAX DESIGN TEMP FOR GND CLEARANCE | 120. DEGREES F | WIND PRESSURE WITH ICE | 4.00 LBS/SQ.FT. |
| EDS TENSION (PCT UTS) | 20. PERCENT | HIGH WIND | 9.0 LBS/SQ.FT. |
| NESC CONSTANT | 0.31 LBS/FT | | |
| | | EXTREME ICE | 0.50 INCHES |

TOWER DESIGN

| | | | |
|--------------------------------|-----------------|--------------------------|----------|
| TOTAL NUMBER OF PHASES | 3 | DISTANCE BETWEEN PHASES: | |
| PHASE SPACING | 27.0 FEET | D1 | 27.00 FT |
| CONDUCTOR CONFIGURATION FACTOR | 1.02 | D2 | 27.00 FT |
| GROUND CLEARANCE | 32.0 FEET | D3 | 54.00 FT |
| NO. OF INSULATORS PER TOWER | 72 | D4 | 0.00 FT |
| INSULATOR SAFETY FACTOR | 2.50 | D5 | 0.00 FT |
| STRING LENGTH | 9.5 FEET | D6 | 0.00 FT |
| I, VEF, OR COMBINATION | 3 | | |
| FOUNDATION TYPE | 4 | | |
| TERRAIN FACTOR | 1.06 PER UNIT | | |
| LINE ANGLE FACTOR | .0864 | | |
| TOWER GROUNDING | 0 | | |
| TRANSVERSE OVERLOAD FACTOR | 2.50 | | |
| VERTICAL OVERLOAD FACTOR | 1.50 | | |
| LONGITUDINAL LOAD | 1000. LBS | | |
| MISCELLANEOUS HARDWARE WEIGHT | 0.11 TONS/TOWER | | |
| TOWER WEIGHT FACTOR | 1.02 | | |

TOWER WEIGHT ESTIMATION ALGORITHM

TOWER TYPE 10: 345KV TOWER

$$TW = 0.00043*TH**2 - 0.992111*TH*0.6000 - 0.10371*EFFVDL - 0.27365*EFFTDL + 0.00503*TH*EFFTDL + 0.00181*TH*EFFVDL + 20.77701 \text{ KIPS}$$

ANCHORAGE-DEVIL CANYON CASE II-1
 345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 15:56:14

 * INPUT DATA *

CONDUCTOR SUMMARY

B - 34

| ID NUMBER | NAME | SIZE(KCM) | STRANDING (AL/ST) | UNIT WEIGHT (LBS/FT) | OUT.DIAM. (INCHES) | TOTAL AREA (SQ.IN.) | MODULUS (EF/E6 PSI) | TEMP.COEF. ALPHA*E-6 PER DEG F |
|-----------|----------|-----------|----------------------|-------------------------|-----------------------|------------------------|------------------------|--------------------------------------|
| ----- | ---- | ----- | ----- | ----- | ----- | ----- | ----- | ----- |
| 29 | STARLING | 715.0 | 26/ 7 | 0.9850 | 1.0510 | 0.6535 | 11.00 | 10.3 |
| 30 | PEDWING | 715.0 | 30/19 | 1.1110 | 1.0810 | 0.6901 | 11.30 | 9.7 |
| 31 | CHUCKO | 795.0 | 24/ 7 | 1.0240 | 1.0920 | 0.7053 | 10.55 | 10.7 |
| 32 | DRAKE | 795.0 | 26/ 7 | 1.0940 | 1.1080 | 0.7261 | 11.00 | 10.3 |
| 33 | TERN | 795.0 | 45/ 7 | 0.8960 | 1.0630 | 0.6676 | 9.40 | 11.5 |
| 34 | CUNNOR | 795.0 | 54/ 7 | 1.0240 | 1.0930 | 0.7053 | 10.85 | 10.9 |
| 35 | MALLARD | 795.0 | 30/19 | 1.2350 | 1.1400 | 0.7668 | 11.30 | 9.7 |
| 36 | RUDDY | 900.0 | 45/ 7 | 1.0150 | 1.1310 | 0.7069 | 9.40 | 11.5 |
| 37 | CANARY | 900.0 | 54/ 7 | 1.1590 | 1.1620 | 0.7985 | 10.85 | 10.9 |
| 38 | RAIL | 954.0 | 45/ 7 | 1.0750 | 1.1650 | 0.8011 | 9.40 | 11.5 |
| 39 | CARDINAL | 954.0 | 54/ 7 | 1.2290 | 1.1960 | 0.8464 | 10.85 | 10.9 |
| 40 | ORTULAN | 1033.0 | 45/ 7 | 1.1650 | 1.2130 | 0.8678 | 9.40 | 11.5 |

ANCHORAGE-DEVIL CANYON CASE IT-1
 345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 15:56:14

 * INPUT DATA *

CONDUCTOR SUMMARY

| ID NUMBER | NAME | ULT.TENS. STRENGTH(LBS) | GEOM.MEAN RADIUS(FT) | PRICE(\$/LB) | THERM.LIMIT (AMPERES) | AC RESIST. AT 25 DEG C (OHMS/MILE) | IND.REACT. (OHMS/MILE) | CAP.REACT. (MOHM-MILES) |
|-----------|-------------|----------------------------|-------------------------|--------------|--------------------------|--|---------------------------|----------------------------|
| B - 35 | 29 STAPLING | 28100.0 | 0.0355 | 0.608/1977 | 850. | 0.1294 | 0.4050 | 2.6453 |
| | 30 REDWING | 34600.0 | 0.0372 | 0.612/1977 | 860. | 0.1288 | 0.3992 | 2.5661 |
| | 31 CUCKOO | 27100.0 | 0.0366 | 0.636/1977 | 900. | 0.1214 | 0.3992 | 2.5502 |
| | 32 DRAKE | 31200.0 | 0.0375 | 0.622/1977 | 910. | 0.1172 | 0.3992 | 2.5450 |
| | 33 TERN | 22900.0 | 0.0352 | 0.677/1977 | 890. | 0.1188 | 0.4060 | 2.5766 |
| | 34 CONDOR | 28500.0 | 0.0368 | 0.635/1977 | 900. | 0.1172 | 0.4002 | 2.5555 |
| | 35 MALLARD | 38400.0 | 0.0392 | 0.599/1977 | 910. | 0.1162 | 0.3928 | 2.5186 |
| | 36 RUDDY | 25400.0 | 0.0374 | 0.676/1977 | 935. | 0.1082 | 0.3928 | 2.5080 |
| | 37 CANARY | 32300.0 | 0.0392 | 0.633/1977 | 950. | 0.1040 | 0.3928 | 2.5027 |
| | 38 RAIL | 26900.0 | 0.0385 | 0.671/1977 | 970. | 0.0998 | 0.3949 | 2.5027 |
| | 39 CARDINAL | 34200.0 | 0.0404 | 0.632/1977 | 990. | 0.0987 | 0.3902 | 2.4816 |
| | 40 ORTULAN | 28900.0 | 0.0401 | 0.670/1977 | 1020. | 0.0924 | 0.3902 | 2.4658 |

ANCHORAGE-DEVIL CANYON CASE II-1
 345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 15:56:14

 * INPUT DATA *

| UNIT MATERIALS COSTS ----- | INPUT VALUE ----- | REFERENCE YEAR FOR INPUT ----- |
|------------------------------------|----------------------|-----------------------------------|
| PRICE OF TOWER MATERIAL | 0.957 \$/LB | 1979 |
| PRICE OF CONCPETE | 0.00 \$/CU.YD. | 1977 |
| PRICE OF GROUND WTRE | 0.000 \$/LB | 1977 |
| INSTALLED COST OF GROUNDING SYSTEM | 0.00 \$/TOWER | 1977 |
| TOWER SETUP | 1751. \$ | 1979 |
| TOWER ASSEMBLY | 0.455 \$/LB | 1979 |
| FOUNDATION SETUP | 0. \$ | 1979 |
| FOUNDATION ASSEMBLY | 4140.00 \$/TON | 1979 |
| FOUNDATION EXCAVATION | 0.00 \$/CU.YD. | 1979 |
| PRICE OF MISCELLANEOUS HARDWARE | 290.00 \$/TOWER | 1977 |

UNIT LABOR COSTS

| | | |
|---------------------------|------------------|------|
| REFERENCE YEAR LABOR COST | 24.00 \$/MANHOUR | 1979 |
| STRING GROUND WIRE | 0.0 \$/MILE | 1977 |
| STRING LABOR MARKUP | 4.2 PER UNIT | |

UNIT TRANSPORTATION COSTS

| | |
|---------------------|-------------------------|
| TOWER | 225.0 \$/TON |
| FOUNDATION CONCRETE | 225.0 \$/YD |
| FOUNDATION STEEL | 225.0 \$/TON |
| CONDUCTOR | 225.0 \$/TON |
| GROUND WIRE | 225.0 \$/TON |
| INSULATOR | 225.0 \$/TON OR \$/M**3 |
| HARDWARE | 225.0 \$/TON |

ANCHORAGE-DEVIL CANYON CASE II-1
 345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 15:56:14

 *
 * AUTOMATIC CONDUCTOR SELECTION *
 * ALL QUANTITIES PER MILE *
 *

CAPITAL COST/DISCOUNT RATE OF 7.00 PERCENT

PRESENT WORTH (\$)

| CONDUCTOR | | | INSTALLED COST | | | | | | LINE LOSSES | O&M COST | LINE COST |
|-----------|-------|----------|----------------|---------|----------|-----------|-----|----------|-------------|----------|-----------|
| NO. | KCM | SPAN(FT) | MATERIALS | TRANSP. | INSTALL. | ENGINEER. | TOC | SUBTOTAL | SUBTOTAL | SUBTOTAL | TOTAL |
| 39 | 954. | 1300. | 114706. | 6707. | 106803. | 25104. | 0. | 253320. | 103751. | 3423. | 360494. |
| 39 | 954. | 1200. | 113228. | 6733. | 109119. | 25199. | 0. | 254279. | 103751. | 3436. | 361466. |
| 40 | 1033. | 1200. | 117782. | 6833. | 111149. | 25934. | 0. | 261697. | 96912. | 3536. | 362145. |
| 39 | 954. | 1400. | 117620. | 6763. | 105670. | 25306. | 0. | 255358. | 103751. | 3451. | 362560. |
| 40 | 1033. | 1300. | 120420. | 6862. | 109426. | 26038. | 0. | 262747. | 96912. | 3551. | 363209. |
| 37 | 900. | 1300. | 112812. | 6577. | 106335. | 24830. | 0. | 250553. | 109695. | 3386. | 363634. |
| 37 | 900. | 1200. | 111385. | 6606. | 108671. | 24933. | 0. | 251594. | 109695. | 3400. | 364689. |
| 40 | 1033. | 1100. | 116899. | 6903. | 114340. | 26196. | 0. | 264337. | 96912. | 3572. | 364821. |
| 37 | 900. | 1400. | 115679. | 6629. | 105183. | 25024. | 0. | 252516. | 109695. | 3412. | 365623. |
| 39 | 954. | 1100. | 113373. | 6852. | 112838. | 25637. | 0. | 258700. | 103751. | 3496. | 365947. |
| 38 | 954. | 1200. | 114994. | 6655. | 110421. | 25528. | 0. | 257598. | 105138. | 3481. | 366218. |
| 38 | 954. | 1300. | 117510. | 6678. | 108644. | 25611. | 0. | 258442. | 105138. | 3492. | 367073. |
| 39 | 954. | 1500. | 121880. | 6892. | 105583. | 25779. | 0. | 260134. | 103751. | 3515. | 367400. |
| 40 | 1033. | 1400. | 124683. | 6982. | 108982. | 26471. | 0. | 267117. | 96912. | 3610. | 367639. |
| 38 | 954. | 1100. | 114231. | 6732. | 113666. | 25809. | 0. | 260438. | 105138. | 3519. | 369096. |
| 37 | 900. | 1100. | 111580. | 6728. | 112411. | 25379. | 0. | 256098. | 109695. | 3461. | 369253. |
| 35 | 795. | 1300. | 108253. | 6480. | 104166. | 24079. | 0. | 242978. | 123194. | 3283. | 369455. |
| 35 | 795. | 1400. | 110039. | 6480. | 102462. | 24088. | 0. | 243069. | 123194. | 3285. | 369548. |
| 37 | 900. | 1500. | 119895. | 6755. | 105080. | 25490. | 0. | 257220. | 109695. | 3476. | 370391. |
| 38 | 954. | 1400. | 121645. | 6790. | 108142. | 26023. | 0. | 262601. | 105138. | 3549. | 371288. |
| 35 | 795. | 1500. | 113021. | 6548. | 101728. | 24343. | 0. | 245640. | 123194. | 3319. | 372154. |
| 35 | 795. | 1200. | 107799. | 6555. | 107003. | 24349. | 0. | 245705. | 123194. | 3320. | 372220. |
| 32 | 795. | 1300. | 109255. | 6393. | 105210. | 24244. | 0. | 245153. | 124675. | 3313. | 373141. |
| 36 | 900. | 1200. | 113498. | 6546. | 110037. | 25309. | 0. | 255389. | 114545. | 3451. | 373385. |
| 34 | 795. | 1300. | 109378. | 6334. | 105529. | 24337. | 0. | 245578. | 124885. | 3319. | 373781. |

ANCHORAGE-DEVIL CANYON CASE II-1
 345 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 15:56:14

 * COST OUTPUT PER MILE *
 * PRESENT VALUE RATE *
 * 7.00 PERCENT *

CONDUCTOR NUMBER = 39
 954. KCMIL 1300. FT SPAN 94.7 FT TOWER

| INSTALLED COST BREAKDOWN | QUANTITY | MATERIAL COST(\$) | TONNAGE | TRANSPORTATION COST(\$) | INSTALLATION COST(\$) | TOTAL COST(\$) |
|-----------------------------|------------|----------------------|---------|----------------------------|--------------------------|-------------------|
| CONDUCTOR | 31680. FT | 63449. | 19.47 | 4380. | 58264. | 126094. |
| GROUNDWIRE | 0. FT | 0. | 0.00 | 0. | 0. | 0. |
| INSULATORS | 310. UNITS | 4436. | 1.70 | 824. | | 5260. |
| HARDWARE | | 3219. | 0.47 | 107. | | 3326. |
| TOWERS | 4.3 UNITS | 154265. | 35.79 | 8052. | 90323. | 252640. |
| FOUNDATIONS | 4.3 UNITS | 10790. | | 1744. | 72256. | 84790. |
| RIGHT OF WAY (113FT) | 14. ACRES | 22181. | | | 19697. | 41877. |
| SUB-TOTALS | | 258340. | 57.43 | 15107. | 240540. | 513987. |
| IDC | | | | | | 0. |
| ENGINEERING | | | | | | 56539. |
| | | | | | | TOTAL 570526. |
| PRESENT WORTH | | 114706. | | 6707. | 106803. | 228216. |
| IDC | | | | | | 0. |
| ENGINEERING | | | | | | 25104. |
| | | | | | | TOTAL 253320. |

| PRESENT WORTH (\$) | | |
|---------------------------|---------------|---------------|
| LOSS ANALYSIS | DEMAND LOSSES | ENERGY LOSSES |
| RESISTANCE LOSSES | 53177. | 48068. |
| CORONA LOSSES: INSULATORS | 696. | 1498. |
| CONDUCTOR | - | 313. |
| TOTALS | 53872. | 49879. |
| | | 103751. |

INTERNATIONAL ENGINEERING CO. INC
SAN FRANCISCO CALIFORNIA

TRANSMISSION LINE COST ANALYSIS PROGRAM
VERSION 2: 02 AUG 1979,

DEVIL CANYON-ESTER CASE II-2A
230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
DATE: 16 AUG 79 TIME: 13:14:31

* INPUT DATA *

B - 39

| SYSTEM ECONOMIC FACTORS | INPUT VALUE | REFERENCE YEAR FOR INPUT |
|------------------------------|------------------|--------------------------|
| BASE YEAR FOR PW ANALYSIS | 1979 | |
| ENDING YEAR OF STUDY | 1997 | |
| BASE YEAR FOR ESCALATION | 1977 | |
| MAXIMUM CIRCUIT LOADING | 194.7 MVA | 1992 |
| AVERAGE CIRCUIT LOADING | 107.1 MVA | 1992 |
| DEMAND COST FACTOR | 73.0 \$/KW | 1979 |
| ENERGY COST FACTOR | 13.0 MILLS/KWH | 1979 |
| VAR COST FACTOR | 0.0 \$/KVAR | 1984 |
| CAPITAL COST/DISCOUNT RATES: | | |
| | 7.0 PERCENT | 1984 |
| | 10.0 PERCENT | 1984 |
| O&M COST FACTOR | 1.5 % CAP.COST | 1984 |
| RIGHT OF WAY COST FACTOR | 715.0 \$/ACRE | 1979 |
| RIGHT OF WAY CLEARING COST | 1450.0 \$/ACRE | 1979 |
| INTEREST DURING CONSTRUCTION | 0.00 % INST.CST | |
| ENGINEERING FEE | 11.00 % INST.CST | |

DEVIL CANYON-ESTER CASE II-2A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 16 AUG 79 TIME: 13:14:31

 * INPUT DATA *

CONDUCTOR DATA

NUMBER PER PHASE 1
 CONDUCTOR SPACING 0.0 IN
 VOLTAGE 230 KV
 VOLTAGE VARIATION 10.00 PCT
 LINE FREQUENCY 60 CPS
 FAIRWEATHER LOSSES 0.00 KW/MI
 LINE LENGTH 189.00 MILES
 POWER FACTOR 0.95

GROUNDWIRE DATA

NUMBER PER TOWER 0
 DIAMETER 0.00 IN
 WEIGHT 0.0000 LBS/FT

SPAN DATA

MINIMUM 1000. FT
 MAXIMUM 1400. FT
 INTERVAL 100.0 FT

WEATHER DATA

MAXIMUM RAINFALL RATE 1.18 IN/HR
 MAXIMUM RAINFALL DURATION 1 HRS/YR
 AVERAGE RAINFALL RATE 0.03 IN/HR
 AVERAGE RAINFALL DURATION 636 HRS/YR
 MAXIMUM SNOWFALL RATE 1.87 IN/HR
 MAXIMUM SNOWFALL DURATION 1 HRS/YR
 AVERAGE SNOWFALL RATE 0.13 IN/HR
 AVERAGE SNOWFALL DURATION 264 HRS/YR
 RELATIVE AIR DENSITY 1.000

DEVIL CANYON-ESTER CASE II-2A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 16 AUG 79 TIME: 13:14:31

 * INPUT DATA *

SAG/TENSION DESIGN FACTORS

| | | | |
|-----------------------------------|----------------|--------------------------------|-----------------|
| EVERYDAY STRESS TEMPERATURE | 40. DEGREES F | ICE AND WIND TENSION (PCT UTS) | 50. PERCENT |
| ICE AND WIND TEMPERATURE | 0. DEGREES F | HIGH WIND TENSION (PCT UTS) | 50. PERCENT |
| HIGH WIND TEMPERATURE | 40. DEGREES F | EXTREME ICE TENSION (PCT UTS) | 70. PERCENT |
| EXTREME ICE TEMPERATURE | 30. DEGREES F | ICE THICKNESS WITH WIND | 0.50 INCHES |
| MAX DESIGN TEMP FOR GND CLEARANCE | 120. DEGREES F | WIND PRESSURE WITH ICE | 4.00 LBS/SQ.FT. |
| EDS TENSION (PCT UTS) | 20. PERCENT | HIGH WIND | 9.0 LBS/SQ.FT. |
| NESC CONSTANT | 0.31 LBS/FT | EXTREME ICE | 0.50 INCHES |

TOWER DESIGN

| | | | |
|--------------------------------|-----------------|--------------------------|----------|
| TOTAL NUMBER OF PHASES | 3 | DISTANCE BETWEEN PHASES: | |
| PHASE SPACING | 20.0 FEET | D1 | 20.00 FT |
| CONDUCTOR CONFIGURATION FACTOR | 1.02 | D2 | 20.00 FT |
| GROUND CLEARANCE | 28.0 FEET | D3 | 40.00 FT |
| NO. OF INSULATORS PER TOWER | 48 | D4 | 0.00 FT |
| INSULATOR SAFETY FACTOR | 2.50 | D5 | 0.00 FT |
| STRING LENGTH | 6.5 FEET | D6 | 0.00 FT |
| I, VEE, OR COMBINATION | 3 | | |
| FOUNDATION TYPE | 4 | | |
| TERRAIN FACTOR | 1.06 PER UNIT | | |
| LINE ANGLE FACTOR | .0864 | | |
| TOWER GROUNDING | 0 | | |
| TRANSVERSE OVERLOAD FACTOR | 2.50 | | |
| VERTICAL OVERLOAD FACTOR | 1.50 | | |
| LONGITUDINAL LOAD | 1000. LBS | | |
| MISCELLANEOUS HARDWARE WEIGHT | 0.11 TONS/TOWER | | |
| TOWER WEIGHT FACTOR | 1.02 | | |

TOWER WEIGHT ESTIMATION ALGORITHM

TOWER TYPE 9: 230KV TOWER

$$TW = 0.00016 * TH ** 2 - 3.09797 * TH ** 0.3333 - 0.08943 * EFFVDL - 0.27367 * EFFTDL + 0.00510 * TH * EFFTDL + 0.00160 * TH * EFFVDL + 18.37912 \text{ KIPS}$$

DEVIL CANYON-ESTER CASE II-2A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 16 AUG 79 TIME: 13:14:31

 * INPUT DATA *

CONDUCTOR SUMMARY

| ID NUMBER | NAME | SIZE(KCM) | STRANDING (AL/ST) | UNIT WEIGHT (LBS/FT) | OUT.DIAM. (INCHES) | TOTAL AREA (SQ.IN.) | MODULUS (EF/E6 PSI) | TEMP.COEF. ALPHA*E-6 PER DEG F |
|-----------|----------|-----------|----------------------|-------------------------|-----------------------|------------------------|------------------------|--------------------------------------|
| 35 | MALLARD | 795.0 | 30/19 | 1.2350 | 1.1400 | 0.7668 | 11.30 | 9.7 |
| 36 | RUDDY | 900.0 | 45/ 7 | 1.0150 | 1.1310 | 0.7069 | 9.40 | 11.5 |
| 37 | CANARY | 900.0 | 54/ 7 | 1.1590 | 1.1620 | 0.7985 | 10.85 | 10.9 |
| 38 | RATL | 954.0 | 45/ 7 | 1.0750 | 1.1650 | 0.8011 | 9.40 | 11.5 |
| 39 | CARDINAL | 954.0 | 54/ 7 | 1.2290 | 1.1960 | 0.8464 | 10.85 | 10.9 |
| 40 | ORTOLAN | 1033.0 | 45/ 7 | 1.1650 | 1.2130 | 0.8678 | 9.40 | 11.5 |
| 41 | CURLEW | 1033.0 | 54/ 7 | 1.3310 | 1.2460 | 0.9169 | 10.85 | 10.9 |
| 42 | BLUEJAY | 1113.0 | 45/ 7 | 1.2550 | 1.2590 | 0.9346 | 9.40 | 11.5 |
| 43 | FINCH | 1113.0 | 54/19 | 1.4310 | 1.2930 | 0.9849 | 10.30 | 10.8 |
| 44 | BUNTING | 1192.0 | 45/ 7 | 1.3440 | 1.3020 | 1.0010 | 9.40 | 11.5 |
| 45 | GRACKLE | 1192.0 | 54/19 | 1.5330 | 1.3330 | 1.0552 | 10.30 | 10.8 |
| 46 | BITTERN | 1272.0 | 45/ 7 | 1.4340 | 1.3450 | 1.0680 | 9.40 | 11.5 |
| 47 | PHEASANT | 1272.0 | 54/19 | 1.6350 | 1.3820 | 1.1256 | 10.30 | 10.8 |
| 48 | DIPPER | 1351.0 | 45/ 7 | 1.5220 | 1.3850 | 1.1350 | 9.40 | 11.5 |
| 49 | MARTIN | 1351.0 | 54/19 | 1.7370 | 1.4240 | 1.1959 | 10.30 | 10.8 |
| 50 | ROULINK | 1431.0 | 45/ 7 | 1.6130 | 1.4270 | 1.2020 | 9.40 | 11.5 |
| 51 | POLOVER | 1431.0 | 54/19 | 1.8400 | 1.4650 | 1.2663 | 10.30 | 10.8 |
| 52 | NUTHATCH | 1510.0 | 45/ 7 | 1.7020 | 1.4660 | 1.2680 | 9.40 | 11.5 |
| 53 | PAPROT | 1510.0 | 54/19 | 1.9420 | 1.5060 | 1.3366 | 10.30 | 10.8 |
| 54 | LAPKING | 1590.0 | 45/ 7 | 1.7920 | 1.5020 | 1.3350 | 9.40 | 11.5 |
| 55 | FALCON | 1590.0 | 54/19 | 2.0440 | 1.5450 | 1.4076 | 10.30 | 10.8 |

DEVIL CANYON-ESTER CASE II-2A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 16 AUG 79 TIME: 13:14:31

 * INPUT DATA *

CONDUCTOR SUMMARY

| ID NUMBER | NAME | ULT.TENS. STRENGTH(LBS) | GEOM.MEAN RADIUS(FT) | PRICE(\$/LB) | THERM.LIMIT (AMPERES) | AC RESIST. AT 25 DEG C (OHMS/MILE) | IND.REACT. (OHMS/MILE) | CAP.REACT. (MOHM-MILES) |
|-----------|-------------|----------------------------|-------------------------|--------------|--------------------------|--|---------------------------|----------------------------|
| B - 43 | 35 MALLARD | 38400.0 | 0.0392 | 0.599/1977 | 910. | 0.1162 | 0.3928 | 2.5186 |
| | 36 RUDDY | 25400.0 | 0.0374 | 0.676/1977 | 935. | 0.1082 | 0.3928 | 2.5080 |
| | 37 CANARY | 32300.0 | 0.0392 | 0.633/1977 | 950. | 0.1040 | 0.3928 | 2.5027 |
| | 38 RAIL | 26900.0 | 0.0385 | 0.671/1977 | 970. | 0.0998 | 0.3949 | 2.5027 |
| | 39 CARDINAL | 34200.0 | 0.0404 | 0.632/1977 | 990. | 0.0987 | 0.3902 | 2.4816 |
| | 40 ORTULAN | 28900.0 | 0.0401 | 0.670/1977 | 1020. | 0.0924 | 0.3902 | 2.4658 |
| | 41 CURLEW | 37100.0 | 0.0420 | 0.628/1977 | 1040. | 0.0913 | 0.3849 | 2.4446 |
| | 42 BLUEJAY | 30900.0 | 0.0416 | 0.669/1977 | 1070. | 0.0861 | 0.3860 | 2.4341 |
| | 43 FINCH | 40200.0 | 0.0436 | 0.639/1977 | 1090. | 0.0855 | 0.3802 | 2.4130 |
| | 44 BUNTING | 33200.0 | 0.0431 | 0.665/1977 | 1120. | 0.0808 | 0.3817 | 2.4077 |
| | 45 GRACKLE | 43100.0 | 0.0451 | 0.642/1977 | 1130. | 0.0797 | 0.3759 | 2.3866 |
| | 46 BITTERN | 35400.0 | 0.0445 | 0.665/1977 | 1160. | 0.0760 | 0.3780 | 2.3813 |
| | 47 PHEASANT | 44800.0 | 0.0466 | 0.638/1977 | 1180. | 0.0750 | 0.3722 | 2.3602 |
| | 48 DIPPER | 37600.0 | 0.0459 | 0.663/1977 | 1210. | 0.0723 | 0.3738 | 2.3602 |
| | 49 MARTIN | 47600.0 | 0.0480 | 0.638/1977 | 1230. | 0.0708 | 0.3680 | 2.3338 |
| | 50 ROBIN | 34800.0 | 0.0472 | 0.662/1977 | 1250. | 0.0686 | 0.3712 | 2.3338 |
| | 51 PLOVER | 50400.0 | 0.0494 | 0.637/1977 | 1270. | 0.0671 | 0.3648 | 2.3074 |
| | 52 NUTHATCH | 41600.0 | 0.0485 | 0.664/1977 | 1300. | 0.0649 | 0.3670 | 2.3126 |
| | 53 PARROT | 53200.0 | 0.0508 | 0.630/1977 | 1320. | 0.0602 | 0.3622 | 2.2862 |
| | 54 LAMPWING | 43800.0 | 0.0497 | 0.660/1977 | 1340. | 0.0623 | 0.3638 | 2.2915 |
| | 55 FALCON | 56000.0 | 0.0521 | 0.636/1977 | 1360. | 0.0612 | 0.3580 | 2.2704 |

DEVIL CANYON-ESTER CASE II-2A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 16 AUG 79 TIME: 13:14:31

 * INPUT DATA *

| UNIT MATERIALS COSTS | INPUT VALUE | REFERENCE YEAR FOR INPUT |
|------------------------------------|-----------------|--------------------------|
| PRICE OF TOWER MATERIAL | 0.957 \$/LB | 1979 |
| PRICE OF CONCRETE | 0.00 \$/CU.YD. | 1977 |
| PRICE OF GROUND WIRE | 0.000 \$/LB | 1977 |
| INSTALLED COST OF GROUNDING SYSTEM | 0.00 \$/TOWER | 1977 |
| TOWER SETUP | 1751. \$ | 1979 |
| TOWER ASSEMBLY | 0.455 \$/LB | 1979 |
| FOUNDATION SETUP | 0. \$ | 1979 |
| FOUNDATION ASSEMBLY | 4140.00 \$/TON | 1979 |
| FOUNDATION EXCAVATION | 0.00 \$/CU.YD. | 1979 |
| PRICE OF MISCELLANEOUS HARDWARE | 290.00 \$/TOWER | 1977 |

UNIT LABOR COSTS

| | | |
|---------------------------|------------------|------|
| REFERENCE YEAR LABOR COST | 24.00 \$/MANHOUR | 1979 |
| STRING GROUND WIRE | 0.0 \$/MILE | 1977 |
| STRING LABOR MARKUP | 4.2 PER UNIT | |

UNIT TRANSPORTATION COSTS

| | |
|---------------------|-------------------------|
| TOWER | 225.0 \$/TON |
| FOUNDATION CONCRETE | 225.0 \$/YD |
| FOUNDATION STEEL | 225.0 \$/TON |
| CONDUCTOR | 225.0 \$/TON |
| GROUND WIRE | 225.0 \$/TON |
| INSULATOR | 225.0 \$/TON OR \$/M**3 |
| HARDWARE | 225.0 \$/TON |

DEVIL CANYON-ESTER CASE II-2A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 16 AUG 79 TIME: 13:14:31

 *
 * AUTOMATIC CONDUCTOR SELECTION *
 * ALL QUANTITIES PER MILE *
 *

CAPITAL COST/DISCOUNT RATE OF 7.00 PERCENT

PRESENT WORTH (\$)

B - 45

| CONDUCTOR | | | INSTALLED COST | | | | | | LINE LOSSES | O&M COST | LINE COST |
|-----------|-------|----------|----------------|---------|----------|-----------|-----|----------|-------------|----------|-----------|
| NO. | KCM | SPAN(FT) | MATERIALS | TRANSP. | INSTALL. | ENGINEER. | IDC | SUBTOTAL | SUBTOTAL | SUBTOTAL | TOTAL |
| 53 | 1510. | 1300. | 77500. | 4475. | 77209. | 17510. | 0. | 176693. | 26241. | 2388. | 205322. |
| 45 | 1192. | 1300. | 71932. | 4085. | 75510. | 16668. | 0. | 168194. | 35382. | 2273. | 205849. |
| 53 | 1510. | 1400. | 79192. | 4486. | 76292. | 17597. | 0. | 177568. | 26241. | 2400. | 206209. |
| 45 | 1192. | 1400. | 73329. | 4080. | 74456. | 16705. | 0. | 168571. | 35382. | 2278. | 206231. |
| 53 | 1510. | 1200. | 76778. | 4517. | 78952. | 17627. | 0. | 177874. | 26241. | 2404. | 206519. |
| 49 | 1351. | 1300. | 75070. | 4291. | 76525. | 17148. | 0. | 173034. | 31161. | 2338. | 206533. |
| 47 | 1272. | 1300. | 73744. | 4201. | 76187. | 16954. | 0. | 171086. | 33142. | 2312. | 206540. |
| 43 | 1113. | 1300. | 70542. | 3997. | 75192. | 16476. | 0. | 166257. | 38174. | 2247. | 206678. |
| 51 | 1431. | 1300. | 76347. | 4383. | 76872. | 17342. | 0. | 174994. | 29429. | 2365. | 206787. |
| 43 | 1113. | 1400. | 71977. | 3992. | 74137. | 16512. | 0. | 166617. | 38174. | 2252. | 207043. |
| 47 | 1272. | 1400. | 75327. | 4205. | 75226. | 17023. | 0. | 171782. | 33142. | 2321. | 207245. |
| 49 | 1351. | 1400. | 76685. | 4298. | 75577. | 17222. | 0. | 173781. | 31161. | 2348. | 207290. |
| 45 | 1192. | 1200. | 71486. | 4142. | 77380. | 16831. | 0. | 169839. | 35382. | 2295. | 207516. |
| 51 | 1431. | 1400. | 78051. | 4392. | 75939. | 17422. | 0. | 175804. | 29429. | 2376. | 207608. |
| 41 | 1033. | 1300. | 69272. | 3918. | 74975. | 16298. | 0. | 164464. | 41005. | 2222. | 207692. |
| 49 | 1351. | 1200. | 74425. | 4338. | 78300. | 17277. | 0. | 174340. | 31161. | 2356. | 207857. |
| 47 | 1272. | 1200. | 73131. | 4249. | 77974. | 17089. | 0. | 172443. | 33142. | 2330. | 207916. |
| 55 | 1590. | 1300. | 79058. | 4566. | 77541. | 17728. | 0. | 178894. | 26692. | 2417. | 208003. |
| 51 | 1431. | 1200. | 75715. | 4428. | 78630. | 17465. | 0. | 176238. | 29429. | 2382. | 208048. |
| 41 | 1033. | 1400. | 70679. | 3913. | 73936. | 16338. | 0. | 164865. | 41005. | 2228. | 208098. |
| 43 | 1113. | 1200. | 70161. | 4055. | 77066. | 16641. | 0. | 167924. | 38174. | 2269. | 208368. |
| 55 | 1590. | 1400. | 80742. | 4580. | 76642. | 17821. | 0. | 179835. | 26692. | 2430. | 208957. |
| 55 | 1590. | 1200. | 78298. | 4606. | 79267. | 17839. | 0. | 180010. | 26692. | 2433. | 209134. |
| 41 | 1033. | 1200. | 68813. | 3976. | 76829. | 16458. | 0. | 166075. | 41005. | 2244. | 209324. |
| 48 | 1351. | 1300. | 76070. | 4234. | 77504. | 17359. | 0. | 175166. | 31875. | 2367. | 209408. |

DEVIL CANYON-ESTER CASE II-2A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 16 AUG 79 TIME: 13:14:31

 * COST OUTPUT PER MILE *
 * PRESENT VALUE RATE *
 * 7.00 PERCENT *

CONDUCTOR NUMBER = 53
 1510. KCMIL 1300. FT SPAN 84.9 FT TOWER

| INSTALLED COST BREAKDOWN | QUANTITY | MATERIAL COST(\$) | TONNAGE | TRANSPORTATION COST(\$) | INSTALLATION COST(\$) | TOTAL COST(\$) |
|-----------------------------|------------|----------------------|---------|----------------------------|--------------------------|-------------------|
| CONDUCTOR | 15840. FT | 49971. | 15.38 | 3461. | 45797. | 99229. |
| GROUNDWIRE | 0. FT | 0. | 0.00 | 0. | 0. | 0. |
| INSULATORS | 207. UNITS | 2957. | 1.14 | 549. | | 3507. |
| HARDWARE | | 3219. | 0.47 | 107. | | 3326. |
| TOWERS | 4.3 UNITS | 91008. | 21.11 | 4750. | 60247. | 156006. |
| FOUNDATIONS | 4.3 UNITS | 7493. | | 1211. | 50178. | 58882. |
| RIGHT OF WAY (101FT) | 12. ACRES | 19895. | | | 17667. | 37562. |
| SUB-TOTALS | | 174544. | 38.10 | 10078. | 173889. | 358511. |
| IDC | | | | | | 0. |
| ENGINEERING | | | | | | 39436. |
| | | | | | | TOTAL 397947. |
| PRESENT WORTH | | 77500. | | 4475. | 77209. | 159183. |
| IDC | | | | | | 0. |
| ENGINEERING | | | | | | 17510. |
| | | | | | | TOTAL 176693. |

PRESENT WORTH (\$)

| LOSS ANALYSIS | DEMAND LOSSES | ENERGY LOSSES | TOTAL LOSSES |
|---------------------------|---------------|---------------|--------------|
| RESISTANCE LOSSES | 13781. | 12459. | 26240. |
| CORONA LOSSES: INSULATORS | 0. | 0. | 0. |
| CONDUCTOR | - | 1. | 1. |
| TOTALS | 13781. | 12460. | 26241. |

INTERNATIONAL ENGINEERING CO. INC
SAN FRANCISCO CALIFORNIA

TRANSMISSION LINE COST ANALYSIS PROGRAM
VERSION 2: 02 AUG 1979,

WATANA-DEVIL CANYON CASE II-3A
230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
DATE: 15 AUG 79 TIME: 16:29:16

* INPUT DATA *
*

B - 47

| SYSTEM ECONOMIC FACTORS ----- | INPUT VALUE ----- | REFERENCE YEAR FOR INPUT ----- |
|----------------------------------|----------------------|-----------------------------------|
| BASE YEAR FOR PW ANALYSIS | 1979 | |
| ENDING YEAR OF STUDY | 1997 | |
| BASE YEAR FOR ESCALATION | 1977 | |
| MAXIMUM CIRCUIT LOADING | 514.0 MVA | 1992 |
| AVERAGE CIRCUIT LOADING | 282.7 MVA | 1992 |
| DEMAND COST FACTOR | 75.0 \$/KW | 1979 |
| ENERGY COST FACTOR | 13.0 MILLS/KWH | 1979 |
| VAR COST FACTOR | 0.0 \$/KVAR | 1984 |
| CAPITAL COST/DISCOUNT RATES: | | |
| | 7.0 PERCENT | 1984 |
| | 10.0 PERCENT | 1984 |
| P&M COST FACTOR | 1.5 % CAP.COST | 1984 |
| RIGHT OF WAY COST FACTOR | 715.0 \$/ACRF | 1979 |
| RIGHT OF WAY CLEARING COST | 1430.0 \$/ACRE | 1979 |
| INTEREST DURING CONSTRUCTION | 0.00 % INST.CST | |
| ENGINEERING FEE | 11.00 % INST.CST | |

WATANA-DEVIL CANYON CASE II-3A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 16:29:16

 *
 * INPUT DATA *
 *

CONDUCTOR DATA

NUMBER PER PHASE 1
 CONDUCTOR SPACING 0.0 IN
 VOLTAGE 230 KV
 VOLTAGE VARIATION 10.00 PCT
 LINE FREQUENCY 60 CPS
 FAIRWEATHER LOSSES 0.00 KW/MI
 LINE LENGTH 27.00 MILES
 POWER FACTOR 0.95

GROUNDWIRE DATA

NUMBER PER TOWER 0
 DIAMETER 0.00 IN
 WEIGHT 0.0000 LBS/FT

SPAN DATA

MINIMUM 1200. FT
 MAXIMUM 1600. FT
 INTERVAL 100.0 FT

WEATHER DATA

MAXIMUM RAINFALL RATE 1.18 IN/HR
 MAXIMUM RAINFALL DURATION 1 HRS/YR
 AVERAGE RAINFALL RATE 0.03 IN/HR
 AVERAGE RAINFALL DURATION 636 HRS/YR
 MAXIMUM SNOWFALL RATE 1.87 IN/HR
 MAXIMUM SNOWFALL DURATION 1 HRS/YR
 AVERAGE SNOWFALL RATE 0.13 IN/HR
 AVERAGE SNOWFALL DURATION 264 HRS/YR
 RELATIVE AIR DENSITY 1.000

KATANA-DEVIL CANYON CASE II-3A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 16:29:16

 * INPUT DATA *

SAG/TENSION DESIGN FACTORS

| | | | |
|-----------------------------------|----------------|--------------------------------|-----------------|
| EVERYDAY STRESS TEMPERATURE | 40. DEGREES F | ICE AND WIND TENSION (PCT UTS) | 50. PERCENT |
| ICE AND WIND TEMPERATURE | 0. DEGREES F | HIGH WIND TENSION (PCT UTS) | 50. PERCENT |
| HIGH WIND TEMPERATURE | 40. DEGREES F | EXTREME ICE TENSION (PCT UTS) | 70. PERCENT |
| EXTREME ICE TEMPERATURE | 30. DEGREES F | ICE THICKNESS WITH WIND | 0.50 INCHES |
| MAX DESIGN TEMP FOR GND CLEARANCE | 120. DEGREES F | WIND PRESSURE WITH ICE | 4.00 LBS/SQ.FT. |
| EDS TENSION (PCT UTS) | 20. PERCENT | HIGH WIND | 9.0 LBS/SQ.FT. |
| NESC CONSTANT | 0.31 LBS/FT | EXTREME ICE | 0.50 INCHES |

TOWER DESIGN

| | | | |
|--------------------------------|-----------------|--------------------------|----------|
| TOTAL NUMBER OF PHASES | 3 | DISTANCE BETWEEN PHASES: | |
| PHASE SPACING | 20.0 FEET | D1 | 20.00 FT |
| CONDUCTOR CONFIGURATION FACTOR | 1.02 | D2 | 20.00 FT |
| GROUND CLEARANCE | 28.0 FEET | D3 | 40.00 FT |
| NO. OF INSULATORS PER TOWER | 48 | D4 | 0.00 FT |
| INSULATOR SAFETY FACTOR | 2.50 | D5 | 0.00 FT |
| STRING LENGTH | 6.5 FEET | D6 | 0.00 FT |
| I, VEF, OR COMBINATION | 3 | | |
| FOUNDATION TYPE | 4 | | |
| TERRAIN FACTOR | 1.06 PER UNIT | | |
| LINE ANGLE FACTOR | .0864 | | |
| TOWER GROUNDING | 0 | | |
| TRANSVERSE OVERLOAD FACTOR | 2.50 | | |
| VERTICAL OVERLOAD FACTOR | 1.50 | | |
| LONGITUDINAL LOAD | 1000. LBS | | |
| MISCELLANEOUS HARDWARE WEIGHT | 0.11 TONS/TOWER | | |
| TOWER WEIGHT FACTOR | 1.02 | | |

TOWER WEIGHT ESTIMATION ALGORITHM

TOWER TYPE 9: 230KV TOWER

$$TW = 0.00016 * TH ** 2 - 3.09797 * TH ** 0.3333 - 0.08943 * EFFVDL - 0.27367 * EFFTDL + 0.00510 * TH * EFFTDL + 0.00160 * TH * EFFVDL + 18.37912 \text{ KIPS}$$

WATANA-DEVIL CANYON CASE II-3A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 16:29:16

 * INPUT DATA *

CONDUCTOR SUMMARY

| ID NUMBER | NAME | ULT.TENS. STRENGTH(LBS) | GEOM.MEAN RADIUS(FT) | PRICE(\$/LB) | THERM.LIMIT (AMPERES) | AC RESIST. AT 25 DEG C (OHMS/MILE) | IND.REACT. (OHMS/MILE) | CAP.REACT. (MOHM-MILES) |
|-----------|------|----------------------------|-------------------------|--------------|--------------------------|--|---------------------------|----------------------------|
| ----- | ---- | ----- | ----- | ----- | ----- | ----- | ----- | ----- |
| B - 50 | 52 | NUTHATCH | 41600.0 | 0.0485 | 0.664/1977 | 1300. | 0.0649 | 2.3126 |
| | 53 | PARROT | 53200.0 | 0.0508 | 0.630/1977 | 1320. | 0.0602 | 2.2862 |
| | 54 | LAPWING | 43800.0 | 0.0497 | 0.660/1977 | 1340. | 0.0623 | 2.2915 |
| | 55 | FALCON | 56000.0 | 0.0521 | 0.636/1977 | 1360. | 0.0612 | 2.2704 |
| | 56 | CHUKAR | 53600.0 | 0.0534 | 0.675/1977 | 1440. | 0.0560 | 2.2387 |
| | 57 | BLUEBIRD | 63400.0 | 0.0588 | 0.673/1977 | 1610. | 0.0475 | 2.1648 |
| | 58 | KIWI | 50900.0 | 0.0570 | 0.699/1977 | 1600. | 0.0480 | 2.1806 |

WATANA-DEVIL CANYON CASE 11-3A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 16:29:16

 *
 * INPUT DATA *
 *

CONDUCTOR SUMMARY

B - 51

| ID NUMBER | NAME | SIZE(KCM) | STRANDING (AL/ST) | UNIT WEIGHT (LBS/FT) | OUT.DIAM. (INCHES) | TOTAL AREA (SQ.IN.) | MODULUS (EF/E6 PSI) | TEMP.COEF. ALPHA*E-6 PER DEG F |
|-----------|----------|-----------|----------------------|-------------------------|-----------------------|------------------------|------------------------|--------------------------------------|
| ----- | ---- | ----- | ----- | ----- | ----- | ----- | ----- | ----- |
| 52 | NUTHATCH | 1510.0 | 45/ 7 | 1.7020 | 1.4660 | 1.2680 | 9.40 | 11.5 |
| 53 | PARROT | 1510.0 | 54/19 | 1.9420 | 1.5060 | 1.3366 | 10.30 | 10.8 |
| 54 | LAPWING | 1590.0 | 45/ 7 | 1.7920 | 1.5020 | 1.3350 | 9.40 | 11.5 |
| 55 | FALCON | 1590.0 | 54/19 | 2.0440 | 1.5450 | 1.4076 | 10.30 | 10.8 |
| 56 | CHICKAR | 1780.0 | 84/19 | 2.0740 | 1.6020 | 1.5120 | 9.05 | 11.3 |
| 57 | BLUEBIRD | 2156.0 | 84/19 | 2.5120 | 1.7620 | 1.8280 | 9.05 | 11.3 |
| 58 | KIWI | 2167.0 | 72/ 7 | 2.3040 | 1.7370 | 1.7760 | 9.25 | 12.0 |

WATANA-DEVIL CANYON CASE II-3A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 16:29:16

 * INPUT DATA *

| UNIT MATERIALS COSTS | INPUT VALUE | REFERENCE YEAR FOR INPUT |
|------------------------------------|-----------------|--------------------------|
| PRICE OF TOWER MATERIAL | 0.957 \$/LB | 1979 |
| PRICE OF CONCRETE | 0.00 \$/CU.YD. | 1977 |
| PRICE OF GROUND WIRE | 0.000 \$/LB | 1977 |
| INSTALLED COST OF GROUNDING SYSTEM | 0.00 \$/TOWER | 1977 |
| TOWER SETUP | 1751. \$ | 1979 |
| TOWER ASSEMBLY | 0.455 \$/LB | 1979 |
| FOUNDATION SETUP | 0. \$ | 1979 |
| FOUNDATION ASSEMBLY | 4140.00 \$/TON | 1979 |
| FOUNDATION EXCAVATION | 0.00 \$/CU.YD. | 1979 |
| PRICE OF MISCELLANEOUS HARDWARE | 290.00 \$/TOWER | 1977 |

| UNIT LABOR COSTS | | |
|---------------------------|------------------|------|
| REFERENCE YEAR LABOR COST | 24.00 \$/MANHOUR | 1979 |
| STRING GROUND WIRE | 0.0 \$/MILE | 1977 |
| STRING LABOR MARKUP | 4.2 PER UNIT | |

| UNIT TRANSPORTATION COSTS | |
|---------------------------|-------------------------|
| TOWER | 225.0 \$/TON |
| FOUNDATION CONCRETE | 225.0 \$/YD |
| FOUNDATION STEEL | 225.0 \$/TON |
| CONDUCTOR | 225.0 \$/TON |
| GROUND WIRE | 225.0 \$/TON |
| INSULATOR | 225.0 \$/TON OR \$/M**3 |
| HARDWARE | 225.0 \$/TON |

MATANA-DEVIL CANYON CASE II-3A
230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
DATE: 15 AUG 79 TIME: 16:29:16

*
* AUTOMATIC CONDUCTOR SELECTION *
* ALL QUANTITIES PFR MILE *
*

CAPITAL COST/DISCOUNT RATE OF 7.00 PERCENT

PRESENT WORTH (\$)

| B - 53 | CONDUCTOR | | | INSTALLED COST | | | | | LINE LOSSES | O&M COST | LINE COST |
|-----------|-----------|-------|----------|----------------|---------|----------|-----------|-----|-------------|----------|-----------|
| | NO. | KCM | SPAN(FT) | MATERIALS | TRANSP. | INSTALL. | ENGINEER. | IDC | SUBTOTAL | SUBTOTAL | TOTAL |
| | 57 | 2156. | 1300. | 89569. | 5100. | 80419. | 19260. | 0. | 194349. | 140540. | 337515. |
| | 57 | 2156. | 1400. | 92123. | 5155. | 79928. | 19493. | 0. | 196698. | 140540. | 339896. |
| | 57 | 2156. | 1200. | 90137. | 5212. | 82759. | 19592. | 0. | 197700. | 140540. | 340911. |
| | 58 | 2167. | 1300. | 92415. | 5120. | 82288. | 19780. | 0. | 199603. | 142049. | 344350. |
| | 57 | 2156. | 1500. | 95769. | 5263. | 80188. | 19934. | 0. | 201155. | 140540. | 344413. |
| | 58 | 2167. | 1200. | 92234. | 5199. | 84224. | 19982. | 0. | 201640. | 142049. | 346414. |
| | 58 | 2167. | 1400. | 95989. | 5221. | 82335. | 20190. | 0. | 203734. | 142049. | 348537. |
| | 57 | 2156. | 1600. | 100185. | 5417. | 81131. | 20541. | 0. | 207274. | 140540. | 350615. |
| | 56 | 1780. | 1300. | 82764. | 4674. | 78631. | 18268. | 0. | 184336. | 166266. | 353093. |
| | 56 | 1780. | 1400. | 84951. | 4709. | 77966. | 18439. | 0. | 186066. | 166266. | 354846. |
| | 58 | 2167. | 1500. | 100672. | 5381. | 83211. | 20819. | 0. | 210083. | 142049. | 354971. |
| | 56 | 1780. | 1200. | 83451. | 4792. | 81029. | 18620. | 0. | 187890. | 166266. | 356695. |
| | 53 | 1510. | 1300. | 77500. | 4475. | 77209. | 17510. | 0. | 176693. | 179055. | 358137. |
| | 56 | 1780. | 1500. | 88068. | 4795. | 78040. | 18799. | 0. | 189701. | 166266. | 358530. |
| | 53 | 1510. | 1400. | 79192. | 4486. | 76292. | 17597. | 0. | 177568. | 179055. | 359023. |
| | 53 | 1510. | 1500. | 81760. | 4545. | 76087. | 17863. | 0. | 180255. | 179055. | 361746. |
| | 53 | 1510. | 1200. | 79083. | 4637. | 80048. | 18014. | 0. | 181782. | 179055. | 363294. |
| | 55 | 1590. | 1300. | 79058. | 4566. | 77541. | 17728. | 0. | 178894. | 182109. | 363420. |
| | 58 | 2167. | 1600. | 106552. | 5599. | 84847. | 21670. | 0. | 218667. | 142049. | 363671. |
| | 56 | 1780. | 1600. | 92071. | 4927. | 78781. | 19336. | 0. | 195115. | 166266. | 364017. |
| | 55 | 1590. | 1400. | 80792. | 4580. | 76642. | 17821. | 0. | 179835. | 182109. | 364373. |
| | 53 | 1510. | 1600. | 85158. | 4649. | 76521. | 18296. | 0. | 184623. | 179055. | 366174. |
| | 55 | 1590. | 1500. | 83400. | 4641. | 76453. | 18094. | 0. | 182588. | 182109. | 367164. |
| | 52 | 1510. | 1200. | 72903. | 4183. | 77449. | 17004. | 0. | 171590. | 193430. | 367338. |
| | 55 | 1590. | 1200. | 80560. | 4724. | 80343. | 18219. | 0. | 183846. | 182109. | 368439. |

AAIANA-DEVIL CANYON CASE II-3A
 230 KV TRANSMISSION LINE COST ANALYSIS AND CONDUCTOR OPTIMIZATION
 DATE: 15 AUG 79 TIME: 16:29:16

 * COST OUTPUT PER MILE *
 * PRESENT VALUE RATE *
 * 7.00 PERCENT *

CONDUCTOR NUMBER = 57
 2156. KCMTL 1300. FT SPAN 87.4 FT TOWER

| INSTALLED COST BREAKDOWN | QUANTITY | MATERIAL COST(\$) | TONNAGE | TRANSPORTATION COST(\$) | INSTALLATION COST(\$) | TOTAL COST(\$) |
|-----------------------------|------------|----------------------|---------|----------------------------|--------------------------|-------------------|
| CONDUCTOR | 15840. FT | 69050. | 19.90 | 4476. | 48940. | 122466. |
| GROUNDWIRE | 0. FT | 0. | 0.00 | 0. | 0. | 0. |
| INSULATORS | 207. UNITS | 2957. | 1.14 | 549. | | 3507. |
| HARDWARE | | 3219. | 0.47 | 107. | | 3326. |
| TOWERS | 4.3 UNITS | 98547. | 22.86 | 5144. | 63832. | 167522. |
| FOUNDATIONS | 4.3 UNITS | 7493. | | 1211. | 50178. | 58882. |
| RIGHT OF WAY (104FT) | 13. ACRES | 20461. | | | 18170. | 38630. |
| SUB-TOTALS | | 201727. | 44.37 | 11487. | 181119. | 394333. |
| IDC | | | | | | 0. |
| ENGINEERING | | | | | | 43377. |
| | | | | | TOTAL | 437710. |
| PRESENT WORTH | | 89569. | | 5100. | 80419. | 175089. |
| IDC | | | | | | 0. |
| ENGINEERING | | | | | | 19260. |
| | | | | | TOTAL | 194349. |

PRESENT WORTH (\$)

| LOSS ANALYSTS | DEMAND LOSSES | ENERGY LOSSES | TOTAL LOSSES |
|---------------------------|---------------|---------------|--------------|
| RESISTANCE LOSSES | 73819. | 66721. | 140540. |
| CORONA LOSSES: INSULATORS | 0. | 0. | 0. |
| CONDUCTOR | - | 0. | 0. |
| TOTALS | 73819. | 66721. | 140540. |

APPENDIX C
MULTI-AREA RELIABILITY
PROGRAM (MAREL)

| | | |
|---------------------------------------|---|------------------------------------|
| POWER TECHNOLOGIES INC | MULTI AREA RELIABILITY PROGRAM (MAREL) | BULLETIN PTI/103 Page 1 of 3 |
| P.O. BOX 1058 | SCHENECTADY, NEW YORK 12301 | 518 374-1220 |

SUMMARY

The Multi-Area Reliability Program (MAREL) computes the Loss of Load Probability (LOLP) reliability index for electric generating systems of several areas interconnected by a transmission network without any restrictions on the network topology. The program permits the study of large power pools and reliability councils as well as individual utilities imbedded in an extensive interconnection. The program is intended to be used in the design and analysis of generation systems and the interconnection capability requirements needed to share reserves among the interconnected areas. The program may be used for as many as six or seven interconnected areas modeled directly. A greater number may be accommodated by developing equivalent systems. The output includes area and total system LOLP indices as well as data on the probable causes of failures and their locations in the network. The program structure is flexible so that load and capacity models may be as detailed as required and at the same time, the complex evaluation of the individual area reliability levels may be performed with efficiency.

PROGRAM
ELEMENTS
AND MODELS

The structure of MAREL is shown in block form on Figure 1. Input data may be provided for each case or partially supplied by saved case files. The program structure is set up to analyze one year at a time under the control of the user. This facilitates the development of system expansions interactively or with a series of runs on a batch basis without the risk of the possibility of using excessive computer time.




FIGURE 1

STRUCTURE OF MULTI AREA RELIABILITY PROGRAM

- Loads are modeled by area with distributions of peak loads for each 'season' of the year. A season may be of whatever length is appropriate for the study, weeks, months, or longer intervals.
 - Capacity Models are developed for each area for each season of the year and are available capacity-probability density tables.
 - Maintenance Outages are simulated either by adding the capacity on outage to the appropriate area and season load model or by modification of the proper capacity-probability table. Maintenance may be prescheduled and input or done automatically within MAREL by an algorithm designed to level available area generation reserves over the year.
 - Transmission Interconnections are modeled by the use of a linear flow network which models the limitations on individual tie line transfer capabilities considering their forced outage rates (if desired) without restrictions on the network configuration or topology.
 - Program Controls are set by the user to establish the fineness with which the loads and capacities are represented and to set tolerance levels on the LOLP computations to save unnecessary computer effort and cost.
 - Program Output may include area load and capacity models as well as maintenance schedules, three sets of both seasonal and annual area and system LOLP indices, the probabilities of various failure modes. That is, the program automatically calculates area LOLP values as though the area were isolated and then two separate LOLP values with the actual interconnection. These two LOLP indices represent the extremes of possible operating policies concerning the sharing of generation reserves, (1) sharing only available reserves, and (2) sharing load losses up to the transfer limitations imposed by the network. Failure mode probabilities show the probabilities and locations of failures caused by generation shortages or transmission limitations as well as combinations and indicate the probabilities that each individual tie may be limiting. These data are useful in developing reliable system designs.
 - System Size is not restricted except by limits on acceptable computational effort and cost. Past PTI system studies have included two interconnected reliability councils represented by nine or ten areas and incorporating approximately 500 units for a total of 100,000 mw of generation.
-
- Generation reliability level analysis which includes the effects of the interconnected system for the expansion planning of individual utilities and power pools.
 - Planning of interconnections to achieve regional integration and more widespread sharing of generation reserves.
 - Evaluation of the reliability benefits of strengthening ties vis-a-vis additions to generation reserves.

PROGRAM
APPLICATIONS

- Assistance in locating weak portions of a system in order to locate new bulk power facilities for maximum reliability improvement.
- Analysis of the reliability benefits of new jointly-owned plants located remotely or within one system's territory.
- Evaluation of the ability of individual utilities to reliably survive the postponement of new plant additions in their own and interconnected systems.

AVAILABILITY
AND SUPPORT

MAREL is available for use at PTI for studies by individual utilities or groups of systems. It may also be leased for installation on a client's computer. The lease entitles the user to:

- Complete set of source code for all modules including all MAREL activities and subroutines.
- Engineering and program reference manuals.
- Installation on a suitable PRIME 400 computer at the client's site and a training seminar.

Installation on other computers is feasible but will only be done on the basis of charging for the time and expense required.

Since PTI is a consulting engineering organization and uses MAREL in studies for clients, the program is continually being enhanced and updated.

While updates are not included in the MAREL lease price, PTI will offer all significant MAREL improvements to lessees at add-on prices.

PTI can assist MAREL users in the development of system equivalents where their use is attractive to the user.

FOR FURTHER
INFORMATION

Contact: C.K. Pang, Senior Engineer
or
A.J. Wood, Principal Engineer
Power Technologies, Inc.
P.O. Box 1058
Schenectady, N.Y. 12301

Tel. (518) 374-1220
Telex 145498 POWER TECH SCH

L/78

MULTI-AREA RELIABILITY PROGRAM (MAREL)

SAMPLE OUTPUT SHEETS

FOR

TWO-AREA RELIABILITY STUDY - YEAR 1989

Note: The following other output sheets (35 cases) are on file with Alaska Power Authority under a separate cover:

- Independent System Expansion Plans
(years 1984 through 1996)
- Interconnected System Expansion Plans
(years 1984 through 1996)
- Interconnected System Expansion, Three-Area Reliability Study
with Susitna (years 1992 through 1996)
- Interconnected System Expansion Plans, with Firm Power Transfer
(years 1984 through 1987 and 1992 through 1996)

IECREL *TIE89

01/18/79 11:01

PRT018

C - 5

```
*****
*****
:
:
:
: WWW WWW WWW WWW WWW W
: W W W W W W W
: W W W W W W W
: W WWW W WWW W
: W W W W W W
: W W W W W W W
: WWW WWW W W WWW WWW
:
:
:
: WWW WWW WWW WWW WWW
: W W W W W W W W
: WWW W W W W W W
: WW WW W W WWW WWW
: WWW W W W W W
: W W W W W W
: W WWW WWW WWW
:
:
:
*****
*****
```


POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM:

----- MULTI-AREA RELIABILITY PROGRAM - MAREL.-----

----- VERSION : NOVEMBER 15, 1978 -----

----- POWER TECHNOLOGIES, INC. -----

** 01 - 18 - 1979 **
**

S T U D Y C A S E:

** ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY **
** 2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979 **
**

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM

```

*****
**                                     **
** ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY **
**                                     **
** 2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979 **
**                                     **
*****

```

YEAR OF STUDY = 1989

PROBABILITY THRESHOLD = 0.10E-07

FAILURE PROB. THRESHOLD = 0.20E-08

PROB. RATIO FOR LOAD LEV. = 0.0100

ROUNDING MW STEP SIZE = 1

MAX. NO. OF AREAS WITH NEGATIVE
MARGIN TO BE EXAMINED = 2

MAX. OF CAPACITY STEPS = 50

----- SYSTEM DATA -----

NO. OF AREAS OR BUSES = 2

NO. OF AREAS WITH GENERATION = 2

NO. OF AREAS WITH LOADS = 2

NO. OF LINES WITH OUTAGES = 1

NO. OF FIRM LINES = 0

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY
2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

----- DATA FOR LINES WITH OUTAGES -----
--- AVAILABLE CAPACITY PROBABILITY ---

LINE NO. 1, LINK NO. 3
TIE FROM AREA 1 ANCHOR -TO- AREA 2 FAIRBA

| LEVEL | CAP(FOR) | CAP(REV) | PROBABILITY |
|-------|----------|----------|-------------|
| 1 | 0 | 0 | 0.004000 |
| 2 | 130 | 130 | 0.996000 |

----- TIME USED IN CPUS : INCREMENT = 2, ELAPSED = 2

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM

GENERATOR UNIT DATA FOR ANCHORAGE-FAIRBANKS STUDY
TWO AREA SYSTEM JANUARY 15 1979

SUMMARY ON CAPACITY, PEAK LOAD AND MAINTENANCE : AREA ANCHOR

| SEASON | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 |
|----------------------------|------|------|------|------|------|------|------|------|------|
| INSTALLED CAPACITY (MW) | 1747 | 1747 | 1747 | 1747 | 1747 | 1747 | 1747 | 1747 | 1747 |
| PEAK LOAD (MW) | 1200 | 882 | 789 | 752 | 729 | 725 | 826 | 886 | 1441 |

INSTALLED RESERVES :

| | | | | | | | | | |
|---------|-------|-------|--------|--------|--------|--------|--------|-------|-------|
| MW | 547 | 865 | 958 | 995 | 1018 | 1022 | 921 | 861 | 306 |
| PERCENT | 45.58 | 98.07 | 121.42 | 132.31 | 139.64 | 140.97 | 111.50 | 97.18 | 21.24 |

| | | | | | | | | | |
|---------------------------------|---|-----|-----|-----|-----|-----|-----|-----|---|
| CAPACITY ON MAINTENANCE (MW) | 0 | 135 | 227 | 256 | 286 | 287 | 188 | 122 | 0 |
|---------------------------------|---|-----|-----|-----|-----|-----|-----|-----|---|

RESERVES AFTER MAINTENANCE :

| | | | | | | | | | |
|---------|-------|-------|-------|-------|--------|--------|-------|-------|-------|
| MW | 547 | 730 | 731 | 739 | 732 | 735 | 733 | 739 | 306 |
| PERCENT | 45.58 | 82.77 | 92.65 | 98.27 | 100.41 | 101.38 | 88.74 | 83.41 | 21.24 |

UNIT RETIREMENTS AND INSTALLATIONS :

| NO. | UNIT | CAP(MW) | F.O.R. | RET/INST | SEASON | DATE |
|-----|--------|---------|--------|----------|--------|--------|
| 1 | COAL 2 | 200 | 0.057 | INST | 1 | 1/1989 |

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM

GENERATOR UNIT DATA FOR ANCHORAGE-FAIRBANKS STUDY
TWO AREA SYSTEM JANUARY 15 1979

SUMMARY ON CAPACITY, PEAK LOAD AND MAINTENANCE : AREA FAIRBA.

| SEASON | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 |
|----------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| INSTALLED CAPACITY (MW) | 385 | 385 | 385 | 385 | 385 | 385 | 385 | 385 | 385 |

| | | | | | | | | | |
|----------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| PEAK LOAD (MW) | 274 | 177 | 135 | 119 | 112 | 130 | 136 | 166 | 313 |
|----------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|

INSTALLED RESERVES :

| | | | | | | | | | |
|---------|-------|--------|--------|--------|--------|--------|--------|--------|-------|
| MW | 111 | 203 | 250 | 266 | 273 | 255 | 249 | 219 | 72 |
| PERCENT | 40.51 | 117.51 | 185.19 | 223.53 | 243.75 | 196.15 | 183.09 | 131.93 | 23.00 |

| | | | | | | | | | |
|---------------------------------|---|----|----|----|-----|----|----|----|---|
| CAPACITY ON MAINTENANCE (MW) | 0 | 14 | 55 | 72 | 100 | 65 | 54 | 25 | 0 |
|---------------------------------|---|----|----|----|-----|----|----|----|---|

RESERVES AFTER MAINTENANCE :

| | | | | | | | | | |
|---------|-------|--------|--------|--------|--------|--------|--------|--------|-------|
| MW | 111 | 194 | 195 | 194 | 173 | 190 | 195 | 194 | 72 |
| PERCENT | 40.51 | 109.60 | 144.44 | 163.03 | 154.46 | 146.15 | 143.38 | 116.87 | 23.00 |

UNIT RETIREMENTS AND INSTALLATIONS :

| NO. | UNIT | CAP(MW) | F.O.R. | RET/INST | SEASON | DATE |
|-----|------|---------|--------|----------|--------|------|
| --- | --- | ----- | ----- | ----- | ----- | --- |

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM

GENERATOR UNIT DATA FOR ANCHORAGE-FAIRBANKS STUDY
TWO AREA SYSTEM JANUARY 15 1979

SUMMARY ON CAPACITY AND PEAK LOAD BY AREA

| AREA | <u>ANCHOR</u> | <u>FAIRBA</u> |
|---|---------------|---------------|
| PEAK LOAD SEASON | 9 | 9 |
| INSTALLED CAPACITY (MW) AT ANNUAL PEAK | 1747 | 385 |
| ANNUAL PEAK LOAD (MW) | 1441 | 313 |
| INSTALLED RESERVES (MW) | 306 | 72 |
| RESERVES IN PERCENT OF ANNUAL PEAK LOAD | 21.24 | 23.00 |
| AREA WEIGHTED AVERAGE UNIT FOR (PERCENT) | 5.46 | 7.42 |
| AREA ANNUAL AVERAGE MAINTENANCE(PERCENT) | 9.55 | 11.11 |

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM

GENERATOR UNIT DATA FOR ANCHORAGE-FAIRBANKS STUDY
TWO AREA SYSTEM JANUARY 15 1979

-----SUMMARY BY AREAS-----

| | AREA | NO. OF UNITS | CAP. (MW) |
|---|--------|--------------|-----------|
| 1 | ANCHOR | 36 | 1747 |
| 2 | FAIRBA | 24 | 385 |

SEASONAL RESERVES IN PERCENT OF PEAK LOADS
AFTER MAINTENANCE OF UNITS FOR THE TOTAL SYSTEM

| SEASON | RESERVES | ORDER | SEASON | RESERVES |
|--------|----------|-------|--------|----------|
| 1 | 44.6404 | 1 | 9 | 21.5507 |
| 2 | 87.2521 | 2 | 1 | 44.6404 |
| 3 | 100.2164 | 3 | 2 | 87.2521 |
| 4 | 107.1182 | 4 | 8 | 89.6882 |
| 5 | 107.6100 | 5 | 7 | 96.4657 |
| 6 | 108.1871 | 6 | 3 | 100.2164 |
| 7 | 96.4657 | 7 | 4 | 107.1182 |
| 8 | 89.6882 | 8 | 5 | 107.6100 |
| 9 | 21.5507 | 9 | 6 | 108.1871 |

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM

GENERATOR UNIT DATA FOR ANCHORAGE-FAIRBANKS STUDY
TWO AREA SYSTEM JANUARY 15 1979

MAINTENANCE SUMMARY BY MW AND PERCENT OF TOTAL AREA CAPACITY :

| SEASON ----- | AREA ----- | ANCHOR ----- | AREA ----- | FAIRBA ----- |
|-----------------|---------------|-----------------|---------------|-----------------|
| 1 | 0 | 0.00 | 0 | 0.00 |
| 2 | 135 | 7.73 | 14 | 3.64 |
| 3 | 227 | 12.99 | 55 | 14.29 |
| 4 | 256 | 14.65 | 72 | 18.70 |
| 5 | 286 | 16.37 | 100 | 25.97 |
| 6 | 287 | 16.43 | 65 | 16.88 |
| 7 | 188 | 10.76 | 54 | 14.03 |
| 8 | 122 | 6.98 | 25 | 6.49 |
| 9 | 0 | 0.00 | 0 | 0.00 |

AREA EFOR 5.4550 7.4169

SYSTEM EFOR = 5.8093

EFOR : WEIGHTED EFFECTIVE FORCED OUTAGE RATE IN PERCENT.

*** END OF PROGRAM MNTCE ***

----- TIME USED IN CPUS : INCREMENT = 2, ELAPSED = 4

----- TIME USED IN CPUS : INCREMENT = 0, ELAPSED = 4

*** AREA 1 ANCHOR HAS NO UNITS ON ***
*** MAINTENANCE FOR SEASONS : 1 9 ***

*** AREA 2 FAIRBA HAS NO UNITS ON ***

*** MAINTENANCE FOR SEASONS : 1 9 ***

C - 11

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY
2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

--- LOSS OF LOAD PROBABILITY AT VARIOUS AREAS ---

| AT | AREA | PROBABILITY ISOLATED | PROBABILITY WITH LLS | PROBABILITY WITHOUT LLS |
|-------|--------|-------------------------|-------------------------|----------------------------|
| ----- | | ----- | ----- | ----- |
| 1 | ANCHOR | 0.149268E+00 | 0.798471E-01 | 0.676829E-01 |
| 2 | FAIRBA | 0.190494E+01 | 0.909675E-01 | 0.394379E-01 |
| | SYSTEM | | 0.915377E-01 | 0.915377E-01 |

NOTE : LLS = LOAD LOSS SHARING

***** ALL PROBABILITIES ARE IN DAYS/PERIOD *****

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY
2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

--- PROBABILITY OF MINIMAL CUTS ---

| CUT | PROBABILITY | CUT MEMBERS(LINKS) |
|-----|--------------|--------------------|
| 1 | 0.792771E-01 | 1 2 |
| 2 | 0.570032E-03 | 1 3 |
| 3 | 0.116904E-01 | 2 3 |

***** ALL PROBABILITIES ARE IN DAYS/PERIOD *****

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY
2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

--- MINIMAL CUTS AND DEFICIENT NODES(AREAS) ---

| CUT | PROBABILITY | NODES(AREAS) IN DEFICIENT REGION |
|-----|--------------|----------------------------------|
| 1 | 0.792771E-01 | 1 ANCHOR 2 FAIRBA |
| 2 | 0.570032E-03 | 1 ANCHOR |
| 3 | 0.116904E-01 | 2 FAIRBA |

***** ALL PROBABILITIES ARE IN DAYS/PERIOD *****

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY
2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

--- PROBABILITY THAT EACH LINE IS LIMITING ---

| LINE | LINK | DESCRIPTION | | TOTAL | FORWARD | REVERSE |
|------|------|-------------|-------------|--------------|--------------|--------------|
| --- | --- | A R E A | TO | PROBABILITY | DIRECTION | DIRECTION |
| --- | --- | --- | --- | --- | --- | --- |
| 1 | 3 | 1 ANCHOR | TO 2 FAIRBA | 0.122604E-01 | 0.116904E-01 | 0.570032E-03 |

***** ALL PROBABILITIES ARE IN DAYS/PERIOD *****

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY
2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

ISOLATED SITUATION - SUMMARY :

AREA LOLP IN DAYS/PERIOD BY SEASONS:

| <u>SEASON</u> | <u>AREA ANCHOR</u> | <u>AREA FAIRBA</u> |
|---------------|------------------------|------------------------|
| 1 | 0.0021 | 0.3096 |
| 2 | 0.0000 | 0.0071 |
| 3 | 0.0000 | 0.0000 |
| 4 | 0.0000 | 0.0000 |
| 5 | 0.0000 | 0.0000 |
| 6 | 0.0000 | 0.0000 |
| 7 | 0.0000 | 0.0000 |
| 8 | 0.0000 | 0.0000 |
| 9 | 0.1472 | 1.5882 |
| YEAR | 0.1493 | 1.9049 |

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY
2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

ISOLATED SITUATION - SUMMARY :

EXPECTED MW-DAYS LOSS BY SEASONS.

| SEASON | AREA ANCHOR | AREA FAIRBA |
|--------|----------------|----------------|
| 1 | 0.09 | 7.45 |
| 2 | 0.00 | 0.14 |
| 3 | 0.00 | 0.00 |
| 4 | 0.00 | 0.00 |
| 5 | 0.00 | 0.00 |
| 6 | 0.00 | 0.00 |
| 7 | 0.00 | 0.00 |
| 8 | 0.00 | 0.00 |
| 9 | 8.87 | 44.23 |
| YEAR | 8.9548 | 51.8097 |

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY
2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

ISOLATED SITUATION - SUMMARY :

EXPECTED MW DEFICIENCY BY SEASON.

| SEASON | AREA ANCHOR | AREA FAIRBA |
|--------|----------------|----------------|
| 1 | 42.38 | 24.04 |
| 2 | 13.57 | 19.22 |
| 3 | 0.00 | 0.00 |
| 4 | 0.00 | 0.00 |
| 5 | 0.00 | 0.00 |
| 6 | 0.00 | 0.00 |
| 7 | 0.00 | 0.00 |
| 8 | 0.00 | 0.00 |
| 9 | 60.24 | 27.85 |

INDICES FOR THE YEAR :

| | | |
|-----------|-------|-------|
| MW-DAYS | 8.95 | 51.81 |
| LOLP-DAYS | 0.15 | 1.90 |
| E(MW) | 59.99 | 27.20 |

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY
2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

INTERCONNECTED WITH LOAD LOSS SHARING :

AREA LOLP IN DAYS/PERIOD BY SEASONS.

| <u>SEASON</u> | <u>AREA ANCHOR</u> | <u>AREA FAIRBA</u> |
|---------------|------------------------|------------------------|
| 1 | 0.0004 | 0.0020 |
| 2 | 0.0000 | 0.0000 |
| 3 | 0.0000 | 0.0000 |
| 4 | 0.0000 | 0.0000 |
| 5 | 0.0000 | 0.0000 |
| 6 | 0.0000 | 0.0000 |
| 7 | 0.0000 | 0.0000 |
| 8 | 0.0000 | 0.0000 |
| 9 | 0.0794 | 0.0890 |
| YEAR | 0.0798 | 0.0910 |

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM:

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY
2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

INTERCONNECTED WITH NO LOAD LOSS SHARING :
AREA LOLP IN DAYS/PERIOD BY SEASONS.

| <u>SEASON</u> | <u>AREA ANCHOR</u> | <u>AREA FAIRBA</u> |
|---------------|------------------------|------------------------|
| 1 | 0.0003 | 0.0017 |
| 2 | 0.0000 | 0.0000 |
| 3 | 0.0000 | 0.0000 |
| 4 | 0.0000 | 0.0000 |
| 5 | 0.0000 | 0.0000 |
| 6 | 0.0000 | 0.0000 |
| 7 | 0.0000 | 0.0000 |
| 8 | 0.0000 | 0.0000 |
| 9 | 0.0673 | 0.0378 |
| YEAR | 0.0677 | 0.0394 |

POWER TECHNOLOGIES, INC.
MULTI-AREA RELIABILITY PROGRAM:

ANCHORAGE - FAIRBANKS TRANSMISSION INTERTIE ECONOMIC FEASIBILITY
2-AREA RELIABILITY STUDY - YEAR 1989 : INTERCONNECTED - 1/15/1979

--- SYSTEM RESULT SUMMARY IN PER UNIT ---

PROBABILITY OF SUCCESS EVENTS = 0.999648E+00
PROBABILITY OF FAILURE EVENTS = 0.352068E-03
PROBABILITY OF NEGLECTED UNSPECIFIED EVENTS = 0.270125E-08
SUM OF THE ABOVE 3 PROBABILITIES = 0.100000E+01
PROBABILITY OF UNCLASSIFIED FAILURE EVENTS = 0.620649E-09

*** NOTE: THE SUM OF THE FIRST 3 MUST BE 1.0000 ***
*** WITHIN REASONABLE TOLERANCE. ***

DEFINITION OF EVENTS :

SUCCESS : ALL LOADS SATISFIED.

FAILURE : ONE OR MORE AREA LOADS NOT SATISFIED.

UNSPECIFIED : NOT IDENTIFIED AS EITHER SUCCESS OR FAILURE.

UNCLASSIFIED FAILURE : CAUSE OF FAILURE NOT ESTABLISHED.
CAUSE OF FAILURE IS INDICATED BY MINIMAL CUTS.

TOTAL ELAPSED TIME IN CPUS = 20

***** END OF PROGRAM MAREL *****

416. 446. 477. 511.
 0.37390.69900.73710.76040.57490.59710.56630.51110.43240.41150.38330.37470.3587
 0.35330.33080.41770.42010.43730.46190.53190.57490.89190.93370.93491.00000.7696
 1.00000.97420.94670.94670.94530.93130.89480.86540.84290.8177
 1.00000.93670.92790.92790.90510.87980.83050.85940.82790.7891
 1.00000.99320.96670.94830.94000.92330.90330.83900.86670.8267
 1.00000.97520.96120.94510.86910.83200.82390.81100.79000.6769
 1.00000.98560.98290.95940.95300.94660.91880.90810.90170.8825
 1.00000.99790.99590.98770.97940.95820.93620.90530.89300.8827
 1.00000.98480.95010.93710.91970.89370.82070.87200.86120.8091
 1.00000.96870.96150.95190.93510.91590.83700.82220.87080.8558
 1.00000.99150.99150.99150.97160.96870.93180.89200.89200.8693
 1.00001.00000.96120.93130.92540.92810.92240.90750.90450.8955
 1.00000.99040.99040.94550.92310.91990.91670.91350.87820.8558
 1.00000.96720.95410.92790.92460.90490.89840.89510.87070.8721
 1.00000.96920.96920.95800.95890.94520.94520.93150.92120.9041
 1.00000.98960.97220.96070.95330.94790.93400.92360.92010.8507
 1.00000.96770.93870.93230.91290.90320.90320.90320.87100.8677
 1.00000.87250.87060.86760.86460.85230.84710.84410.83820.8059
 1.00000.94440.90640.90640.89470.82750.82750.82460.81870.8012
 1.00000.99720.97750.96350.96350.94940.90320.93320.91010.8904
 1.00000.99470.96810.93090.92320.90960.90690.90160.88830.8856
 1.00000.93350.93300.91450.90990.89610.88910.88450.86370.8568
 1.00000.99150.98920.97650.94920.92950.92740.91880.91450.9017
 1.00000.96690.91120.89260.88840.79890.73970.64460.61020.6028
 1.00000.97710.91050.90790.90790.89340.88950.88550.86320.8434
 1.00000.97110.8680.83050.81870.79630.79240.74510.73320.7201
 1.00000.99510.98160.97200.97170.95530.91650.88450.82430.6818
 1.00000.99840.98920.92010.89940.88920.88500.84220.81310.7971

GENERATOR UNIT DATA FOR ANCHORAGE-FAIRBANKS STUDY
 TWO AREA SYSTEM
 JANUARY 15 1979

| 1 | 1 | 1 |
|-----------|----|---------|
| 2 | 1 | 1.0E-12 |
| ANCHOR | 44 | 12 |
| 1.0 | | |
| 1 ANCH 1 | 15 | 0.055 |
| 2 ANCH 2 | 15 | 0.055 |
| 3 ANCH 3 | 19 | 0.055 |
| 4 ANCH 4 | 32 | 0.055 |
| 5 ANCH 5 | 37 | 0.055 |
| 6 ANCH 6 | 12 | 0.055 |
| 7 ANCH 7 | 73 | 0.055 |
| 8 ANCH 7S | 21 | 0.055 |
| 9 ANCH 8 | 73 | 0.055 |
| 10 BELU 1 | 15 | 0.055 |
| 11 BELU 2 | 15 | 0.055 |
| 12 BELU 3 | 54 | 0.055 |
| 13 BELU 4 | 9 | 0.055 |
| 14 BELU 5 | 54 | 0.055 |
| 15 BELU 6 | 68 | 0.055 |
| 16 BELU 7 | 68 | 0.055 |
| 17 BELU 8 | 68 | 0.055 |
| 18 BERN 1 | 8 | 0.055 |
| 19 BERN 2 | 20 | 0.055 |
| 20 BERN 3 | 24 | 0.055 |

21 INTL 1 14 0.055
 22 INTL 2 14 0.055
 23 INTL 3 19 0.055
 24 COOP 1 8 0.016
 25 COOP 2 8 0.016
 26 KHT A 15 0.059 R 1/1986
 27 INTL 4 71 0.055
 28 INTL 5 71 0.055
 29 INTL 6 71 0.055
 30 INTL 7 71 0.055
 31 HOMER 7 0.055
 32 EKLUTN 30 0.016
 33 BELU 9 71 0.055 N 1/1986
 34 ANCH 9 78 0.055 N 1/1985
 35 ANCH10 104 0.057 N 1/1986
 36 COAL 1 200 0.057 N 1/1987
 37 ANCH11 104 0.057 N 1/1993
 38 COAL 2 200 0.057 N 1/1989
 39 COAL 3 200 0.057 N 1/1990
 40 COAL 4 200 0.057 N 1/1991
 41 COAL 5 200 0.057 N 1/1992
 42 PEAKA1 78 0.055 N 1/1993
 43 GEN 1 300 0.079 N 1/1994
 44 GEN 2 300 0.079 N 1/1996
 45 PEAKA2 78 0.055 N 1/1995

-99

COOP 1
 COOP 2
 EKLUTN

-99

1

9

-99

FAIRBA 26 12

1.0

1 CHEN 1 5 0.059
 2 CHEN 2 2 0.059
 3 CHEN 3 2 0.059
 4 CHEN 4 20 0.059
 5 CHEN 5 5 0.055
 6 CHEN 6 24 0.055
 7 DIES 1 3 0.295
 8 DIES 2 3 0.295
 9 DIES 3 2 0.295
 10 ZEHN 1 17 0.055
 11 ZEHN 2 17 0.055
 12 ZEHN 3 4 0.055
 13 ZEHN 4 4 0.055
 14 ZEIND1 3 0.295
 15 ZEIND2 3 0.295
 16 ZEIND3 3 0.295
 17 ZEIND4 2 0.295
 18 ZEIND5 2 0.295
 19 HEAL 1 26 0.059
 20 HEAL D 3 0.295

| | | | | | |
|-----|--------|-----|-------|---|--------|
| 21 | NORT 1 | 65 | 0.055 | | |
| 22 | NORT 2 | 65 | 0.055 | | |
| 23 | UALASK | 5 | 0.295 | | |
| 25 | COALF1 | 100 | 0.057 | N | 1/1988 |
| 27 | COALF2 | 100 | 0.057 | N | 1/1992 |
| 28 | COALF3 | 100 | 0.057 | N | 1/1995 |
| -99 | | | | | |
| -99 | | | | | |
| 1 | | | | | |
| 9 | | | | | |
| -99 | | | | | |

APPENDIX D
DATA AND COST ESTIMATES FOR TRANSMISSION
INTERTIE AND GENERATING PLANTS

APPENDIX D

DATA AND COST ESTIMATES FOR
TRANSMISSION INTERTIE AND GENERATING PLANTS

D.1 DATA AND COST ESTIMATES FOR TRANSMISSION INTERTIE

A. Cost Summary and Disbursements for Intertie Facilities

| | Total Cost at 1979 Levels - \$1000 | | | | |
|---------------------------------------|------------------------------------|---------------|---------------|---------------|----------------|
| | Case IA | Case IB | Case IC | Case ID | Case II |
| 1. <u>Transmission Line:</u> | | | | | |
| Eng'g. & Constr. Supv. | 3,012 | 3,012 | 7,988 | 3,012 | 15,442 |
| Right-of-Way | 8,837 | 8,837 | 7,573 | 8,837 | 12,994 |
| Foundations | 8,445 | 8,445 | 12,160 | 8,445 | 22,966 |
| Towers | 21,615 | 21,615 | 33,990 | 21,615 | 64,974 |
| Hardware | 477 | 477 | 477 | 477 | 1,096 |
| Insulators | 503 | 503 | 755 | 503 | 1,396 |
| Conductor | <u>10,761</u> | <u>10,761</u> | <u>17,663</u> | <u>10,761</u> | <u>36,946</u> |
| Subtotal | 53,650 | 53,650 | 80,606 | 53,650 | 155,814 |
| 2. <u>Substations:</u> | | | | | |
| Eng'g. & Constr. Supv. | 1,352 | 1,352 | 1,855 | 2,816 | 6,902 |
| Land | 57 | 57 | 46 | 81 | 185 |
| Transformers | 1,703 | 1,703 | 3,291 | 1,703 | 11,917 |
| Circuit Breakers | 1,093 | 1,093 | 1,323 | 1,953 | 6,410 |
| Station Equipment | 1,223 | 1,223 | 1,933 | 1,345 | 4,375 |
| Structures & Accessories | <u>3,628</u> | <u>3,628</u> | <u>3,978</u> | <u>4,026</u> | <u>16,411</u> |
| Subtotal | 9,056 | 9,056 | 12,426 | 11,924 | 46,200 |
| 3. <u>Control and Communications:</u> | | | | | |
| Eng'g. & Constr. Supv. | 125 | 125 | 125 | 165 | 200 |
| Equipment | <u>2,375</u> | <u>2,375</u> | <u>2,375</u> | <u>3,135</u> | <u>3,600</u> |
| Subtotal | <u>2,500</u> | <u>2,500</u> | <u>2,500</u> | <u>3,300</u> | <u>3,800</u> |
| Total Baseline 1979 Costs | <u>65,206</u> | <u>65,206</u> | <u>95,532</u> | <u>68,874</u> | <u>205,814</u> |

Capital disbursements for each of the above cases are given on following computation sheets, these being identical to those later used for financial planning purposes with selected alternative.

CAPITAL INVESTMENT DISBURSEMENTS FOR TRANSMISSION INTERTIE CASES IA & IB

| | 1981-1 | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TOTAL |
|--------------------------------------|------------|-------------|-------------|--------------|--------------|--------------|--------------|
| 1. TRANSMISSION LINE | | | | | | | |
| ENGINEERING AND CONSTRUCTION | | | | | | | |
| SUPERVISION | 452 | 753 | 0 | 392 | 693 | 723 | 3012 |
| RIGHT OF WAY | 0 | 2209 | 6628 | 0 | 0 | 0 | 8837 |
| FOUNDATIONS | 0 | 0 | 0 | 2280 | 6165 | 0 | 8445 |
| TOWERS | 0 | 0 | 0 | 0 | 9127 | 11888 | 21615 |
| HARDWARE | 0 | 0 | 0 | 0 | 72 | 405 | 477 |
| INSULATORS | 0 | 0 | 0 | 0 | 75 | 428 | 503 |
| CONDUCTOR | 0 | 0 | 0 | 0 | 1614 | 9147 | 10761 |
| SUB-TOTAL | 452 | 2962 | 6628 | 2672 | 18346 | 22591 | 53650 |
| 2. SUBSTATIONS | | | | | | | |
| ENGINEERING & CONSTRUCTION | | | | | | | |
| SUPERVISION | 270 | 270 | 270 | 270 | 135 | 135 | 1352 |
| LAND | 57 | 0 | 0 | 0 | 0 | 0 | 57 |
| TRANSFORMERS | 0 | 0 | 341 | 596 | 596 | 170 | 1703 |
| CIRCUIT BREAKERS | 0 | 0 | 219 | 383 | 383 | 109 | 1093 |
| STATION EQUIPMENT | 0 | 0 | 245 | 428 | 428 | 122 | 1223 |
| STRUCTURES & ACCESSORIES | 0 | 0 | 726 | 1451 | 1451 | 0 | 3628 |
| SUB-TOTAL | 327 | 270 | 1800 | 3128 | 2993 | 537 | 9056 |
| 3. CONTROL AND COMMUNICATIONS | | | | | | | |
| ENGINEERING AND INSTALLATION | | | | | | | |
| SUPERVISION | 0 | 0 | 0 | 0 | 54 | 71 | 125 |
| EQUIPMENT | 0 | 0 | 0 | 0 | 950 | 1425 | 2375 |
| SUB-TOTAL | 0 | 0 | 0 | 0 | 1004 | 1496 | 2500 |
| TOTAL | 779 | 3233 | 8428 | 5800 | 22342 | 24624 | 65206 |
| TOTAL FOR YEAR | 0 | 4012 | 0 | 14228 | 0 | 46967 | 65206 |

CAPITAL INVESTMENT DISBURSEMENTS FOR TRANSMISSION INTERTIE CASE IC

| | 1981-1 | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TOTAL |
|--------------------------------------|-------------|-------------|-------------|--------------|--------------|--------------|--------------|
| 1. TRANSMISSION LINE | | | | | | | |
| ENGINEERING AND CONSTRUCTION | | | | | | | |
| SUPERVISION | 1198 | 1997 | 0 | 1038 | 1837 | 1917 | 7988 |
| RIGHT OF WAY | 0 | 1893 | 5680 | 0 | 0 | 0 | 7573 |
| FOUNDATIONS | 0 | 0 | 0 | 3283 | 8877 | 0 | 12160 |
| TOWERS | 0 | 0 | 0 | 0 | 15296 | 18695 | 33990 |
| HARDWARE | 0 | 0 | 0 | 0 | 72 | 405 | 477 |
| INSULATORS | 0 | 0 | 0 | 0 | 113 | 642 | 755 |
| CONDUCTOR | 0 | 0 | 0 | 0 | 2649 | 15014 | 17663 |
| SUB-TOTAL | 1198 | 3890 | 5680 | 4322 | 28844 | 36672 | 80606 |
| 2. SUBSTATIONS | | | | | | | |
| ENGINEERING & CONSTRUCTION | | | | | | | |
| SUPERVISION | 371 | 371 | 371 | 371 | 186 | 186 | 1855 |
| LAND | 46 | 0 | 0 | 0 | 0 | 0 | 46 |
| TRANSFORMERS | 0 | 0 | 658 | 1152 | 1152 | 329 | 3291 |
| CIRCUIT BREAKERS | 0 | 0 | 265 | 463 | 463 | 132 | 1323 |
| STATION EQUIPMENT | 0 | 0 | 387 | 677 | 677 | 193 | 1933 |
| STRUCTURES & ACCESSORIES | 0 | 0 | 796 | 1591 | 1591 | 0 | 3978 |
| SUB-TOTAL | 417 | 371 | 2476 | 4254 | 4068 | 840 | 12426 |
| 3. CONTROL AND COMMUNICATIONS | | | | | | | |
| ENGINEERING AND INSTALLATION | | | | | | | |
| SUPERVISION | 0 | 0 | 0 | 0 | 54 | 71 | 125 |
| EQUIPMENT | 0 | 0 | 0 | 0 | 950 | 1425 | 2375 |
| SUB-TOTAL | 0 | 0 | 0 | 0 | 1004 | 1496 | 2500 |
| TOTAL | 1615 | 4261 | 8156 | 8575 | 33916 | 39009 | 95532 |
| TOTAL FOR YEAR | 0 | 5876 | 0 | 16731 | 0 | 72925 | 95532 |

CAPITAL INVESTMENT DISBURSEMENTS FOR TRANSMISSION INTERTIE CASE ID

| | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TOTAL |
|--------------------------------------|-------------|-------------|-------------|--------------|--------------|--------------|
| 1. TRANSMISSION LINE | | | | | | |
| ENGINEERING AND CONSTRUCTION | | | | | | |
| SUPERVISION | 452 | 753 | 0 | 392 | 693 | 3012 |
| RIGHT OF WAY | 0 | 2209 | 6628 | 0 | 0 | 8837 |
| FOUNDATIONS | 0 | 0 | 0 | 2280 | 6165 | 8445 |
| TOWERS | 0 | 0 | 0 | 0 | 9727 | 21615 |
| HARDWARE | 0 | 0 | 0 | 0 | 72 | 477 |
| INSULATORS | 0 | 0 | 0 | 0 | 75 | 503 |
| CONDUCTOR | 0 | 0 | 0 | 0 | 1614 | 10761 |
| SUB-TOTAL | 452 | 2962 | 6628 | 2672 | 18346 | 53650 |
| 2. SUBSTATIONS | | | | | | |
| ENGINEERING & CONSTRUCTION | | | | | | |
| SUPERVISION | 563 | 563 | 563 | 563 | 282 | 2816 |
| LAND | 81 | 0 | 0 | 0 | 0 | 81 |
| TRANSFORMERS | 0 | 0 | 341 | 596 | 596 | 1703 |
| CIRCUIT BREAKERS | 0 | 0 | 391 | 684 | 684 | 1953 |
| STATION EQUIPMENT | 0 | 0 | 269 | 471 | 471 | 1345 |
| STRUCTURES & ACCESSORIES | 0 | 0 | 805 | 1610 | 1610 | 4026 |
| SUB-TOTAL | 644 | 563 | 2369 | 3924 | 3642 | 11924 |
| 3. CONTROL AND COMMUNICATIONS | | | | | | |
| ENGINEERING AND INSTALLATION | | | | | | |
| SUPERVISION | 0 | 0 | 0 | 0 | 71 | 165 |
| EQUIPMENT | 0 | 0 | 0 | 0 | 1254 | 3135 |
| SUB-TOTAL | 0 | 0 | 0 | 0 | 1325 | 3300 |
| TOTAL | 1096 | 3525 | 8996 | 6596 | 23313 | 68874 |
| TOTAL FOR YEAR | 0 | 4621 | 0 | 15592 | 0 | 68874 |

CAPITAL INVESTMENT DISBURSEMENTS FOR TRANSMISSION INTERTIE CASE II

| | 1981-1 | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TOTAL |
|--------------------------------------|-------------|--------------|--------------|--------------|--------------|---------------|---------------|
| 1. TRANSMISSION LINE | | | | | | | |
| ENGINEERING AND CONSTRUCTION | | | | | | | |
| SUPERVISION | 2316 | 3861 | 0 | 2007 | 3552 | 3706 | 15442 |
| RIGHT OF WAY | 0 | 3249 | 9746 | 0 | 0 | 0 | 12994 |
| FOUNDATIONS | 0 | 0 | 0 | 6201 | 16765 | 0 | 22966 |
| TOWERS | 0 | 0 | 0 | 0 | 29238 | 35736 | 64974 |
| HARDWARE | 0 | 0 | 0 | 0 | 164 | 932 | 1096 |
| INSULATORS | 0 | 0 | 0 | 0 | 209 | 1187 | 1396 |
| CONDUCTOR | 0 | 0 | 0 | 0 | 5542 | 31404 | 36946 |
| SUB-TOTAL | 2316 | 7109 | 9746 | 8208 | 55471 | 72964 | 155814 |
| 2. SUBSTATIONS | | | | | | | |
| ENGINEERING & CONSTRUCTION | | | | | | | |
| SUPERVISION | 1380 | 1380 | 1380 | 1380 | 690 | 690 | 6902 |
| LAND | 185 | 0 | 0 | 0 | 0 | 0 | 185 |
| TRANSFORMERS | 0 | 0 | 2383 | 4171 | 4171 | 1192 | 11917 |
| CIRCUIT BREAKERS | 0 | 0 | 1282 | 2244 | 2244 | 641 | 6410 |
| STATION EQUIPMENT | 0 | 0 | 875 | 1531 | 1531 | 438 | 4375 |
| STRUCTURES & ACCESSORIES | 0 | 0 | 3282 | 6564 | 6564 | 0 | 16411 |
| SUB-TOTAL | 1565 | 1380 | 9203 | 15890 | 15200 | 2960 | 46200 |
| 3. CONTROL AND COMMUNICATIONS | | | | | | | |
| ENGINEERING AND INSTALLATION | | | | | | | |
| SUPERVISION | 0 | 0 | 0 | 0 | 86 | 114 | 200 |
| EQUIPMENT | 0 | 0 | 0 | 0 | 1440 | 2160 | 3600 |
| SUB-TOTAL | 0 | 0 | 0 | 0 | 1526 | 2274 | 3800 |
| TOTAL | 3882 | 8489 | 18948 | 24099 | 72197 | 78198 | 205814 |
| TOTAL FOR YEAR | 0 | 12371 | 0 | 43047 | 0 | 150396 | 205814 |

B. Case IA & IB, Anchorage-Fairbanks Intertie, 230 kV s/c Transmission System, 323 Miles

1. Cost Summary

| | |
|-----------------------------------|------------------|
| T/L Cost @ \$166,104 per mile | \$53,652,000 |
| Anchorage Substation | 3,974,000 |
| Ester Substation | 5,080,000 |
| Control and Communications System | <u>2,500,000</u> |
| TOTAL | \$65,206,000 |

2. Anchorage Substation Costs

| | | |
|---|---|---------------|
| 1 | 138-kV Circuit Breaker | \$ 86,000 |
| | Structures and Accessories | 108,000 |
| 1 | 138-kV Air Disconnect Switch | 11,000 |
| | Structures and Accessories | 38,000 |
| 4 | 13.8-kV, 12-MVAR Shunt Reactor Bank | 420,000 |
| | Structures and Accessories | 315,000 |
| 4 | 13.8-kV Circuit Breaker | 154,000 |
| | Structures and Accessories | 119,000 |
| 4 | 13.8-kV Air Disconnect Switch | 31,000 |
| | Structures and Accessories | 64,000 |
| 4 | 1Ø - 48 MVA, 138/230-kV Autotransformer | 1,020,000 |
| | Structures and Accessories | 538,000 |
| 2 | 230-kV Circuit Breakers | 338,000 |
| | Structures and Accessories | 407,000 |
| 4 | 230-kV Air Disconnect Switch | 70,000 |
| | Structures and Accessories | 232,000 |
| | Land 2 acres | <u>23,000</u> |
| | TOTAL | \$3,974,000 |

3. Ester Substation Costs

| | | |
|---|--|---------------|
| 1 | 138-kV Circuit Breaker | \$ 86,000 |
| | Structures and Accessories | 108,000 |
| 1 | 138-kV Air Disconnect Switch | 11,000 |
| | Structures and Accessories | 38,000 |
| 3 | 13.8-kV, 12-MVAR Shunt Capacitor Bank | 265,000 |
| | Structures and Accessories | 198,000 |
| 3 | 13.8-kV Circuit Breaker | 116,000 |
| | Structures and Accessories | 89,000 |
| 4 | 1Ø, 46 MVA, 138/230-kV Autotransformer | 984,000 |
| | Structures and Accessories | 516,000 |
| 3 | 230-kV Circuit Breaker | 507,000 |
| | Structures and Accessories | 613,000 |
| 9 | 230-kV Air Disconnect Switch | 157,000 |
| | Structures and Accessories | 528,000 |
| 3 | 230-kV, 16-MVAR Reactor | 474,000 |
| | Structures and Accessories | 356,000 |
| | Land 3 acres | <u>34,000</u> |
| | TOTAL | \$5,080,000 |

C. Case IC, Anchorage-Fairbanks Intertie, 345 kV s/c Transmission System, 323 miles

1. Cost Summary

| | |
|-----------------------------------|------------------|
| T/L Cost @ \$249,551 per mile | \$80,606,000 |
| Anchorage Substation | 6,195,000 |
| Ester Substation | 6,231,000 |
| Control and Communications System | <u>2,500,000</u> |
| TOTAL | \$95,532,000 |

2. Anchorage Substation Costs

| | | |
|---|---|----------------------|
| 1 | 138-kV Circuit Breaker Structures and Accessories | \$ 86,000 108,000 |
| 1 | 138-kV Air Disconnect Switch Structures and Accessories | 11,000 38,000 |
| 1 | 13.8-kV 16-MVAR Shunt Reactor Bank Structures and Accessories | 112,000 84,000 |
| 1 | 13.8-kV Circuit Breaker Structures and Accessories | 39,000 30,000 |
| 1 | 13.8-kV Air Disconnect Switch Structures and Accessories | 8,000 16,000 |
| 4 | 1Ø - 48-MVA, 138/345-kV Autotransformer Structures and Accessories | 1,936,000 725,000 |
| 2 | 345-kV Circuit Breaker Structures and Accessories | 653,000 340,000 |
| 5 | 345-kV Air Disconnect Switch Structures and Accessories | 114,000 330,000 |
| 4 | 1Ø - 33-1/3-MVAR, 345-kV Shunt Reactor Structures and Accessories | 882,000 660,000 |
| | Land 2 acres | <u>23,000</u> |
| | TOTAL | \$6,195,000 |

3. Ester Substation Cost

| | | |
|---|--|----------------------|
| 1 | 138-kV Circuit Breaker Structures and Accessories | \$ 86,000 108,000 |
| 1 | 138-kV Air Disconnect Switch Structures and Accessories | 11,000 38,000 |
| 1 | 13.8-kV, 15-MVAR Shunt Capacitor Structures and Accessories | 132,000 100,000 |
| 1 | 13.8-kV Circuit Breaker Structures and Accessories | 39,000 30,000 |
| 1 | 13.8-kV Air Disconnect Switch Structures and Accessories | 8,000 16,000 |

3. Ester Substation Cost (Continued)

| | | |
|---|---|------------------------|
| 4 | 1Ø - 48 MVA, 138/345-kV Autotransformer Structures and Accessories | \$1,936,000 725,000 |
| 2 | 345-kV Circuit Breaker Structures and Accessories | 653,000 340,000 |
| 5 | 345-kV Air Disconnect Switch Structures and Accessories | 114,000 330,000 |
| 4 | 1Ø - 33-1/3-MVAR, 345-kV Shunt Reactor Structures and Accessories | 882,000 660,000 |
| | Land 2 acres | <u>23,000</u> |
| | TOTAL | \$6,231,000 |

D. Case ID, Anchorage-Fairbanks Intertie, 230 kV s/c Transmission
System, 323 miles

1. Cost Summary

| | |
|-----------------------------------|------------------|
| T/L Cost @ \$166,104 per mile | \$53,652,000 |
| Anchorage Substation | 3,976,000 |
| Palmer Substation | 1,434,000 |
| Healy Substation | 1,434,000 |
| Ester Substation | 5,080,000 |
| Control and Communications System | <u>3,300,000</u> |
| TOTAL | \$68,876,000 |

2. Anchorage-Palmer, 230 kV s/c Transmission System, 40 miles

| | |
|-----------------------------------|------------------|
| T/L Cost @ \$166,104 per mile | \$ 6,644,000 |
| Anchorage Substation | 3,976,000 |
| Palmer Substation | 717,000 |
| Control and Communications System | <u>1,450,000</u> |
| TOTAL | \$12,787,000 |

3. Palmer-Healy, 230 kV s/c Transmission System, 190.5 miles

| | |
|-----------------------------------|----------------|
| T/L Cost @ \$166,104 per mile | \$31,726,000 |
| Palmer Substation | 717,000 |
| Healy Substation | 717,000 |
| Control and Communications System | <u>400,000</u> |
| TOTAL | \$33,560,000 |

4. Healy-Ester, 230 kV s/c Transmission System, 92 miles

| | |
|-----------------------------------|------------------|
| T/L Cost @ \$166,104 per mile | \$15,282,000 |
| Healy Substation | 717,000 |
| Ester Substation | 5,080,000 |
| Control and Communications System | <u>1,450,000</u> |
| TOTAL | \$22,529,000 |

5. Anchorage Substation Costs

| | | |
|---|---|---------------|
| 1 | 138-kV Circuit Breaker | \$ 86,000 |
| | Structures and Accessories | 108,000 |
| 1 | 138-kV Air Disconnect Switch | 11,000 |
| | Structures and Accessories | 38,000 |
| 4 | 13.8-kV, 12-MVAR Shunt Reactor Bank | 420,000 |
| | Structures and Accessories | 315,000 |
| 4 | 13.8-kV Circuit Breaker | 154,000 |
| | Structures and Accessories | 119,000 |
| 4 | 13.8-kV Air Disconnect Switch | 31,000 |
| | Structures and Accessories | 64,000 |
| 4 | 1Ø - 48-MVA, 138/230-kV Autotransformer | 1,020,000 |
| | Structures and Accessories | 538,000 |
| 2 | 230-kV Circuit Breakers | 338,000 |
| | Structures and Accessories | 407,000 |
| 4 | 230-kV Air Disconnect Switch | 70,000 |
| | Structures and Accessories | 234,000 |
| | Land 2 acres | <u>23,000</u> |
| | TOTAL | \$ 3,976,000 |

6. Palmer Substation - (One Line Bay)

| | | |
|-----|--|-----------------------|
| 1.5 | 230-kV Circuit Breaker Structures and Accessories | \$ 253,000 305,000 |
| 2 | 230-kv Air Disconnect Switch Structures and Accessories | 36,000 117,000 |
| | Land | <u>6,000</u> |
| | TOTAL | \$ 717,000 |

7. Healy Substation - (One Line Bay)

| | | |
|-----|--|--------------------|
| 1.5 | 230-kV Circuit Breaker Structures and Accessories | 253,000 305,000 |
| 2 | 230-kV Air Disconnect Switch Structures and Accessories | 36,000 117,000 |
| | Land | <u>6,000</u> |
| | TOTAL | \$ 717,000 |

8. Ester Substation Costs

| | | |
|---|---|----------------------|
| 1 | 138-kV Circuit Breaker Sturctures and Accessories | \$ 86,000 108,000 |
| 1 | 138-kV Air Disconnect Switch Structures and Accessories | 11,000 38,000 |
| 3 | 13.8-kV, 12-MVAR Shunt Capacitor Bank Structures and Accessories | 265,000 198,000 |
| 3 | 13.8-kV Circuit Breaker Structures and Accessories | 116,000 89,000 |
| 4 | 1Ø - 46-MVA, 138/230-kV Autotransformer Structures and Accessories | 984,000 516,000 |
| 3 | 230-kV Circuit Breaker Structures and Accessories | 507,000 613,000 |

8. Ester Substation Costs (Continued)

| | | |
|---|--|-----------------------|
| 9 | 230-kV Air Disconnect Switch Structures and Accessories | \$ 157,000 528,000 |
| 3 | 230-kV, 16-MVAR Reactor Structures and Accessories | 474,000 356,000 |
| | Land 3 acres | <u>34,000</u> |
| | TOTAL | \$5,080,000 |

E. Case II, Anchorage - Upper Susitna - Fairbanks Intertie

| | |
|-------------------------------------|-----------|
| 345 kV 2-s/c Anchorage-Devil Canyon | 155 miles |
| 230 kV 2-s/c Devil Canyon-Ester | 189 miles |
| 230 kV 2-s/c Watana-Devil Canyon | 27 miles |

1. Cost Summary

| | |
|--|------------------|
| Anchorage - Devil Canyon T/L @ \$506,640 per mile* | \$ 78,529,000 |
| Devil Canyon - Ester T/L @ \$353,386 per mile* | 66,790,000 |
| Watana - Devil Canyon T/L @ \$388,698 per mile* | 10,495,000 |
| Anchorage Substation | 23,160,000 |
| Devil Canyon Substation | 10,109,000 |
| Ester Substation | 11,339,000 |
| Watana Substation | 1,592,000 |
| Control and Communications System | <u>3,800,000</u> |
| TOTAL | \$205,814,000 |

* Includes two single-circuit lines.

2. Anchorage Substation Cost

| | | |
|----|--|------------------------|
| 2 | 138-kV Circuit Breaker Structures and Accessories | \$ 172,000 216,000 |
| 2 | 138-kV Air Disconnect Switch Structures and Accessories | 23,000 76,000 |
| 7 | 1Ø - 210.5-MVA, 138/345-kV Autotransformer Structures and Accessories | 8,516,000 3,404,000 |
| 9 | 345-kV Circuit Breaker Structures and Accessories | 2,938,000 1,528,000 |
| 18 | 345-kV Air Disconnect Switch Structures and Accessories | 408,000 1,191,000 |
| 2 | 345-kV, 200-MVAR Shunt Capacitor Structures and Accessories | 2,647,000 1,984,000 |
| | Land 5 acres | <u>57,000</u> |
| | TOTAL | \$23,160,000 |

3. Devil Canyon Substation Cost

| | | |
|----|---|------------------------|
| 3 | 345-kV Circuit Breaker Structures and Accessories | \$ 981,000 509,000 |
| 6 | 345-kV Air Disconnect Switch Structures and Accessories | 138,000 399,000 |
| 7 | 1Ø - 90.3-MVA, 230/345-kV Autotransformer Structures and Accessories | 3,418,000 1,466,000 |
| 6 | 230-kV Circuit Breaker Structures and Accessories | 1,015,000 1,224,000 |
| 12 | 230-kV Air Disconnect Switch Structures and Accessories | 210,000 703,000 |
| | Land 4 acres | <u>46,000</u> |
| | TOTAL | \$10,109,000 |

4. Ester Substation Cost

| | | |
|----|---|------------------------|
| 2 | 138-kV Circuit Breaker Structures and Accessories | \$ 172,000 216,000 |
| 2 | 138-kV Air Disconnect Switch Structures and Accessories | 23,000 76,000 |
| 7 | 1Ø - 65-MVA, 138/345-kV Autotransformer Structures and Accessories | 2,086,000 1,253,000 |
| 6 | 13.8-kV Air Disconnects Structures and Accessories | 46,000 96,000 |
| 6 | 13.8-kV Circuit Breaker Structures and Accessories | 232,000 181,000 |
| 6 | 13.8-kV, 6-MVAR Capacitor Structures and Accessories | 264,000 200,000 |
| 9 | 230-kV Circuit Breaker Structures and Accessories | 1,523,000 1,838,000 |
| 18 | 230-kV Air Disconnect Switch Structures and Accessories | 314,000 1,055,000 |
| 2 | 230-kV, 80-MVAR Capacitor Structures and Accessories | 968,000 727,000 |
| | Land 6 acres | <u>69,000</u> |
| | TOTAL | \$11,339,000 |

5. Watana Substation Cost

| | | |
|---|--|-----------------------|
| 3 | 230-kV Circuit Breakers Structures and Accessories | \$ 508,000 613,000 |
| 6 | 230-kV Disconnect Switch Structures and Accessories | 106,000 348,000 |
| | Land | <u>17,000</u> |
| | TOTAL | \$ 1,592,000 |

D.2 DATA AND COST ESTIMATES FOR GENERATING PLANTS

B. Cost Estimates and Disbursements for Generating Plants

Note: Only specific units affected by interconnection of Anchorage and Fairbanks systems are considered:

1. Northpole #3 (NORT 3) 69 MW SCGT in Fairbanks Area.

This unit is necessary for independent system expansion.
Will not be required if interconnection assured.

Rating - 68.6 MW (net) Combustion Turbine
Fuel - Distillate from North Pole Refinery

Ref. Table B-1, Appendix B of Stanley Consultants Review Report
For 1983 Installation:

| | | | |
|------------------------------|--------------|----|----------|
| Unit Cost = | \$31,482,000 | | |
| NO _x Cost | 1,387,000 | | |
| Subtotal | \$32,869,000 | or | \$476/kW |
| Assoc. Transm. ^{1/} | 4,783,000 | | |
| TOTAL | \$37,652,000 | or | \$546/kW |

See Also: P. 45 of GVEA Power Supply Study - 1978 by Stanley Consultants & P. 28 - Table 10 Escalation Rates.

| Period | GNP Deflators | | |
|-----------|---------------|------------------|-----------|
| | Labor (≈ 20%) | Material (≈ 80%) | Composite |
| 1983-1980 | 1.085 | 1.07 | 1.075 |
| 1980-1979 | 1.095 | 1.08 | 1.085 |

Summary of Costs:

| Facility | 1979 Baseline Costs | | |
|--------------------------|---------------------|----|----------|
| Gas-Turbine Unit | \$24,385,000 | or | \$353/kW |
| Assoc. Transm. | 3,549,000 | | |
| Total Capital Investment | \$27,934,000 | or | \$405/kW |

| Disbursements - \$1000 | | | |
|------------------------|-----------------|-----------------|--|
| Pre-Operational Period | 1st Year (1983) | 2nd Year (1984) | |
| Gas-Turbine Unit | 7,315 (30%) | 17,070 (70%) | |
| Assoc. Transm. | 355 (10%) | 3,194 (90%) | |
| Total Facilities | \$7,670 | \$20,264 | |

^{1/} Relocation of facilities and expansion of existing Northpole substation.

2. Beluga #9 (BELU 9) 71 MW RCGT in Anchorage Area.

This unit will be postponed for one year by interconnection, from beginning year 1985 to 1986.

This unit will draw on Beluga gas reserves for fuel supply. Design of unit is assumed to be simple-cycle, similar to existing units on Chugach System - Ref. Beluga Units 1, 2, 4, 6, & 7.

Estimated Cost of Unit:

From Reference Cost Estimate for NORT 3 at Fairbanks

Cost at Bus-bar of 69 MW unit = \$353/kW

By comparison for 71 MW unit = \$350/kW

Now applying Alaskan construction cost location factors from Battelle Report, Table 6.3, P. 6.12

Applicable factor from Fairbanks to Beluga = $\frac{1.62}{1.2} = 1.35$

Estimated Cost = \$473/kW or \$33,548,000

Disbursements:

| <u>Pre-Operational Period</u> | <u>1st Year</u> | <u>2nd Year</u> |
|-------------------------------|-----------------|-----------------|
| Independent Expansion | 1983 | 1984 |
| Interconnected Expansion | 1984 | 1985 |
| Proportion of Total | 30% | 70% |
| Investment - \$1000 | 10,064 | 23,484 |

Associated Transmission Facilities:

Transmission Line (allow 50 miles) @ \$126,000/mile

Total Cost of Line Facilities = \$6,300,000

Substation Additions at Beluga and Knik Arm = \$2,650,000

Total Transmission Line and Substation Facilities = \$8,950,000

Disbursements:

| <u>Pre-Operational Period</u> | <u>1979 Baseline Costs</u> | |
|-------------------------------|----------------------------|---------------------|
| | <u>1st Year</u> | <u>2nd Year</u> |
| Independent Expansion | 1983 | 1984 |
| Interconnected Expansion | 1984 | 1985 |
| Proportion of Total | 10% | 90% |
| Investment - \$1000 | | |
| Transm. & Substations | 895 | 8,055 |
| Total Facilities | | <u>\$42,490,000</u> |

3. Northpole #4 (NORT 4) 69 MW SCGT in Fairbanks Area.

This unit is necessary for independent system expansion.

Will not be required with an interconnected system.

Scheduled In-Service Beginning Year 1990

Unlike NORT 3, no transmission additions will be required, with completion of relocation and expansion of the substation.

Considering only cost of unit with assoc. transf. and swgr.

For 1979 Baseline Cost Levels:

Total Capital Investment = \$25,185,000 or \$365/kW

Disbursements:

| <u>Pre-Operational Period</u> | <u>1st Year (1988)</u> | <u>2nd Year (1989)</u> |
|-------------------------------|------------------------|------------------------|
| GT unit, transf. & swgr. | 7,555 (30%) | 17,630 (70%) |

4. Anchorage Peaking Unit #2 (PEAK A2) 78 MW SCGT

This unit is required for both independent and interconnected systems but in-service date is advanced one year with intertie.

Basing cost of addition on Northpole Unit 4 installation -
i.e. SCGT unit with associated transformer and switching.

Estimated cost based on rating, with allowance for scale.

For 1979 Baseline Cost Levels:

69 MW GT Unit Total Cost = \$25,185,000 or \$365/kW

78 MW GT Unit Total Cost = \$28,080,000 or \$360/kW

Now applying Alaskan construction cost location adjustment factor
from Battelle Report Table 6.3 P. 6.12

Applicable factor from Fairbanks to Anchorage = $1/1.2 = 0.83$

Total Capital Investment = \$23,400,000 or \$300/kW

Disbursements:

| <u>Year</u> | <u>Independent</u> | <u>Interconnected</u> | <u>% Total</u> | <u>Cost - \$1000</u> |
|-------------|--------------------|-----------------------|----------------|--------------------------|
| 1 | 1994 | 1993 | 30 | 7,020 |
| 2 | 1995 | 1994 | 70 | 16,380 |

5. Northpole #5 (NORT 5) 69 SCGT in Fairbanks Area.

This unit is necessary for independent system expansion.

Will not be required with an interconnected system.

Scheduled In-Service Beginning Year 1997

The addition of this unit completes the expansion for the independent systems of the Railbelt Area, the time frame is such that for interconnected expansion, with the staged increments of hydro capacity from the Susitna development, the last unit at Devil Canyon would be on-line beginning year 1997.

Similar to NORT 4, no transmission additions are assumed to be required, such that power would be delivered from the expanded Northpole Substation to the existing system.

Considering only cost of unit, with associated transf. and swgr.

For 1979 Baseline Cost Levels:

Total Capital Investment = \$25,185,000 or \$365/kW

Disbursements:

| <u>Pre-Operational Period:</u> | <u>(\$1000)</u> | |
|--------------------------------|------------------------|------------------------|
| | <u>1st Year (1995)</u> | <u>2nd Year (1996)</u> |
| GT unit, transf. & swgr. | 7,555 (30%) | 17,630 (70%) |

6. Anchorage #11 (ANCH 11) 104 MW Coal-Fired Steam-Electric Plant.

This unit will be required for independent system expansion but will be postponed, with interconnection, from in-service 1988 to 1993.

Cost estimate for this plant is based on Healy Unit 2 estimate prepared by Stanley Consultants, with applicable Alaskan construction cost location adjustment factor.

From Stanley Consultants Report to GVEA, Appendix A, P. A-1.

For 1984 Installation Date (1978 Cost Levels):

Healy Unit 2 Plant (Without FGD):

| | | | |
|---|----------------------|----|-----------|
| Plant and Equipment | \$102,924,000 | or | \$ 990/kW |
| Contingency | <u>3,088,000</u> | | |
| Total Construction Cost | \$107,012,000 | or | \$1029/kW |
| Eng'g., Legal & Overhead | <u>14,982,000</u> | | |
| TOTAL | \$121,994,000 | or | \$1173/kW |
| Escalating @ 10% to 1979 Cost Level | | | \$1290/kW |
| Total Baseline 1979 Cost without FGD = | <u>\$134,160,000</u> | | |

Now Including Cost of Desulphurization:

| | | | |
|--|----------------------|----|-----------|
| Plant and Equipment | \$111,174,000 | or | \$1069/kW |
| Contingency | <u>3,335,000</u> | | |
| Total Construction Cost | \$114,509,000 | or | \$1101/kW |
| Eng'g., Legal & Overhead | <u>16,031,000</u> | | |
| TOTAL | \$130,540,000 | or | \$1255/kW |
| Escalating @ 10% to 1979 Cost Level | | | \$1380/kW |
| Total Baseline 1979 Cost with FGD = | <u>\$143,520,000</u> | | |

Associated Transmission Facilities:

Assuming relatively short transmission line with substation facilities required, for connection to existing AML&P transmission system in Anchorage area.

Cost Estimate for Transmission Line:

Transmission Line (allow 30 miles) @ \$126,000/mile
Total Cost of Line Facilities = \$3,780,000

Cost Estimate for Substation Facilities:

| | |
|-------------------------------------|--------------------|
| Equipment | \$2,700,000 |
| Contingency | <u>203,000</u> |
| Total Construction Cost | \$2,903,000 |
| Eng'g., Legal & Overhead | <u>377,000</u> |
| TOTAL | \$3,280,000 |
| Escalating @ 10% to 1979 Cost Level | |
| Total 1979 Baseline Cost | <u>\$3,608,000</u> |

Summary of Costs:

| | <u>WO/FGD</u> | <u>W/FGD</u> |
|---------------------------|------------------|------------------|
| Coal-Fired Plant (104 MW) | \$134,160,000 | \$143,520,000 |
| Transmission Line | 3,780,000 | 3,780,000 |
| Substation Facilities | <u>3,608,000</u> | <u>3,608,000</u> |
| TOTAL | \$141,548,000 | \$150,908,000 |

Now applying Alaskan construction cost location adjustment factor from Table 6.3 P. 6.12 of Battelle Study Report:

From Healy to Anchorage - Location Factor = $1.7/2.42 = 0.70$

Applying this factor, Total Costs = \$99,084,000 \$105,636,000
or = \$953/kW \$1016/kW

Disbursements - \$1000

Coal-Fired Plant (ANCH 11)

| | | | <u>1979 Baseline Costs</u> | | |
|------------------------------|--------------------|-----------------------|----------------------------|---------------|--------------|
| <u>Pre-Operational Year:</u> | | | <u>% Total</u> | <u>WO/FGD</u> | <u>W/FGD</u> |
| | <u>Independent</u> | <u>Interconnected</u> | | | |
| 1. | 1982 | 1987 | 2 | 1,878 | 2,009 |
| 2. | 1983 | 1988 | 8 | 7,513 | 8,037 |
| 3. | 1984 | 1989 | 30 | 28,174 | 30,139 |
| 4. | 1985 | 1990 | 37 | 34,747 | 37,172 |
| 5. | 1986 | 1991 | 20 | 18,783 | 20,093 |
| 6. | 1987 | 1992 | 3 | 2,817 | 3,014 |

Associated Transmission Facilities

| | | | | | |
|----|------|------|----|-------|-------|
| 5. | 1986 | 1991 | 20 | 1,034 | 1,034 |
| 6. | 1987 | 1992 | 80 | 4,138 | 4,138 |

7. Coal-Fired Unit F2 (COAL F2) 100 MW in Fairbanks Area.

This unit will be required for both the independent and inter-connected system expansions, with generation reserve sharing only. However, with both reserve sharing and firm power transfer, it is replaced, together with COAL 5, by a 300 MW unit (COAL 6).

This unit will be very similar to ANCH 11, which in turn was based on the Healy Unit 2 Plant, as reported by Stanley Consultants. The unit costs will be increased proportionately, to allow for the change of unit size from 104 MW to 100 MW. This has been economically scaled using the nomograph (Figures D-1 and D-2) in this appendix.

For Generating Plant COAL F2:

| <u>Plant Cost Estimates:</u> | <u>1979 Baseline Cost Levels</u> |
|------------------------------|----------------------------------|
| Without FGD | \$120,000,000 or \$1200/kW |
| With FGD | \$130,000,000 or \$1300/kW |

Associated Transmission Facilities:

Assuming a plant site location at or near Healy, the transmission line and substation requirements are similar to those required for Healy Unit 2. Reference Stanley Consultants Review Report to GVEA, Appendix A, P. A-1:

Transmission Facility Costs:

| | <u>1979 Cost Levels (1.1 x 1978 Costs)</u> | |
|--------------------------|--|----------------------------------|
| | <u>Transmission Line</u> | <u>Substation Facilities</u> |
| Equipment and Material | \$15,510,000 | \$3,348,000 |
| Contingency | <u>465,000</u> | <u>100,000</u> |
| Construction Cost | \$15,975,000 | \$3,448,000 |
| Eng'g., Legal & Overhead | <u>2,455,000</u> | <u>102,000</u> |
| TOTAL | <u>\$18,430,000</u> | <u>\$3,550,000</u> |

Disbursements - \$1000

Coal-Fired Unit (COAL F2):

| <u>Pre-Operational Year:</u> | <u>1979 Baseline Costs</u> | | |
|------------------------------|----------------------------|---------------|--------------|
| | <u>% Total</u> | <u>WO/FGD</u> | <u>W/FGD</u> |
| 1. 1986 | 2 | 2,400 | 2,600 |
| 2. 1987 | 8 | 9,600 | 10,400 |
| 3. 1988 | 30 | 36,000 | 39,000 |
| 4. 1989 | 37 | 44,400 | 48,100 |
| 5. 1990 | 20 | 24,000 | 26,000 |
| 6. 1991 | 3 | 3,600 | 3,900 |

Associated Transmission Facilities:

| | | | |
|---------|----|--------|--------|
| 5. 1990 | 20 | 4,400 | 4,400 |
| 6. 1991 | 80 | 17,580 | 17,580 |

8. Coal-Fired Unit 5 (COAL 5) 200 MW in Anchorage Area.

This unit will be required for both the independent and inter-connected system expansions, with generation reserve sharing only. However, with both reserve sharing and firm power transfer, it is replaced, together with COAL F2, by a 300-MW unit (COAL 6).

The cost estimate for this generating plant was obtained by scaling costs from a base reference of 100 MW to 200 MW, using the nomograph (Figures D-1 and D-2) contained in this Appendix. Then Alaskan construction cost location adjustment factors were used to determine the cost relevant to the Beluga site in the Anchorage Area.

From Healy to Beluga - Location Factor = $2.75/2.42 = 1.14$

For Generating Plant COAL 5

Plant Cost Estimates:

| | <u>1979 Baseline Cost Levels (\$1000)</u> | |
|-------------|---|------------------------|
| | <u>Healy Site</u> | <u>Beluga Site</u> |
| Without FGD | \$165,000 or \$825/kW | \$188,000 or \$ 940/kW |
| With FGD | \$175,000 or \$875/kW | \$200,000 or \$1000/kW |

Associated Transmission Facilities:

Assuming a section of transmission line and substation facilities, for connection to existing transmission system in Anchorage area.

| | |
|---|------------------|
| Transmission Line (allow 50 miles) @ \$174,000/mile | |
| Total Cost of Line Facilities = | \$ 8,700,000 |
| Substation Terminal at Knik Arm = | <u>3,545,000</u> |
| Total Transmission Facilities | \$12,245,000 |

Disbursements - \$1000

Coal-Fired Unit (COAL 5)

| <u>Pre-Operational Year:</u> | <u>1979 Baseline Costs</u> | | |
|------------------------------|----------------------------|---------------|--------------|
| | <u>% Total</u> | <u>WO/FGD</u> | <u>W/FGD</u> |
| 1. 1986 | 2 | 3,760 | 4,000 |
| 2. 1987 | 8 | 15,040 | 16,000 |
| 3. 1988 | 30 | 56,400 | 60,000 |
| 4. 1989 | 37 | 69,560 | 74,000 |
| 5. 1990 | 20 | 37,600 | 40,000 |
| 6. 1991 | 3 | 5,640 | 6,000 |

Associated Transmission Facilities:

| | | | |
|---------|----|-------|-------|
| 5. 1990 | 20 | 2,450 | 2,450 |
| 6. 1991 | 80 | 9,795 | 9,795 |

9. Coal-Fired Unit 6 (COAL 6) 300 MW in Anchorage Area.

This unit will not be required either for independent or inter-connected system expansion for generation reserve sharing only. However, with reserve capacity sharing and firm power transfer, it will replace both COAL F2 and COAL 5.

The cost estimate for this plant has been derived from the cost for the reference 100 MW plant, using the nomograph (Figures D-1 and D-2) contained in this Appendix. This enabled consideration of economies of scale obtained when the unit capacity is changed from 100 to 300 MW and the differential costs associated with the two sites, according to the Alaskan construction cost location adjustment factor, similar to that developed for COAL 5.

Plant Cost Estimates:

| | 1979 Baseline Cost Levels (\$1000) | |
|-------------|------------------------------------|-----------------------|
| | Healy Site | Beluga Site |
| Without FGD | \$200,000 or \$667/kW | \$228,000 or \$760/kW |
| With FGD | \$240,000 or \$800/kW | \$274,000 or \$913/kW |

Associated Transmission Facilities:

Assuming a section of transmission line and substation facilities,
for connection to existing transmission system in Anchorage area.

| | |
|---|------------------|
| Transmission Line (allow 50 miles) @ \$240,000/mile | |
| Total Cost of Line Facilities = | \$12,000,000 |
| Substation Terminal at Knik Arm = | <u>6,250,000</u> |
| Total Transmission Facilities | \$18,250,000 |

Disbursements - \$1000

Coal-Fired Unit (COAL 6)

| <u>Pre-Operational Year:</u> | 1979 Baseline Costs | | |
|------------------------------|---------------------|---------------|--------------|
| | <u>% Total</u> | <u>WO/FGD</u> | <u>W/FGD</u> |
| 1. 1986 | 2 | 4,560 | 5,480 |
| 2. 1987 | 8 | 18,240 | 21,920 |
| 3. 1988 | 30 | 68,400 | 82,200 |
| 4. 1989 | 37 | 84,360 | 101,380 |
| 5. 1990 | 20 | 45,600 | 54,800 |
| 6. 1991 | 3 | 6,840 | 8,220 |

Associated Transmission Facilities:

| | | | |
|---------|----|--------|--------|
| 5. 1990 | 20 | 3,650 | 3,650 |
| 6. 1991 | 80 | 14,600 | 14,600 |

10. Coal-Fired Unit 2 (GEN 2) 300 MW at New Site in Anchorage Area.

This unit is required for both independent and interconnected systems but in-service date postponed one year with intertie.

For Generating Plant COAL 6:

It is assumed that site will be near to previous plant location at Beluga, in sufficient proximity to assume cost basis to be identical, with difference only in the time frame for construction.

Cost estimate for plant and associated transmission facilities are then identical to that for COAL 6.

Disbursements - \$1000

Coal-Fired Unit (GEN 2)

| <u>Pre-Operational Year:</u> | | <u>1979 Baseline Costs</u> | | |
|------------------------------|-----------------------|----------------------------|---------------|--------------|
| | | <u>% Total</u> | <u>WO/FGD</u> | <u>W/FGD</u> |
| <u>Independent</u> | <u>Interconnected</u> | | | |
| 1. 1989 | 1990 | 2 | 4,560 | 5,480 |
| 2. 1990 | 1991 | 8 | 18,240 | 21,920 |
| 3. 1991 | 1992 | 30 | 68,400 | 82,200 |
| 4. 1992 | 1993 | 37 | 84,360 | 101,380 |
| 5. 1993 | 1994 | 20 | 45,600 | 54,800 |
| 6. 1994 | 1995 | 3 | 6,840 | 8,220 |

Associated Transmission Facilities:

| | | | | |
|---------|------|----|--------|--------|
| 5. 1993 | 1994 | 20 | 3,650 | 3,650 |
| 6. 1994 | 1995 | 80 | 14,600 | 14,600 |

D.3 DATA AND COST ESTIMATES FOR SUPPLY OF CONSTRUCTION POWER TO UPPER SUSITNA PROJECT SITES

The requirements of the combined Railbelt area generation expansion, with inclusion of both Watana and Devil Canyon power from the Susitna development, schedules Unit 1 from Devil Canyon in January 1995, only 3 years after the first unit goes on line at Watana Damsite. Assuming as a first construction schedule that of the U.S. Army Corps of Engineers, the construction periods are 6 and 5 years, respectively, for Watana earthfill dam and the concrete arch dam at Devil Canyon. Thus, with the generation staging of the plan for interconnection, the total construction period would be 11 years, with pre-operational construction periods of 6 years for Watana and 5 years for Devil Canyon. There would be concurrent construction during 2 years.

Prior to the first unit on-line at Watana, construction power would be required for 6 years at Watana and 2 years at Devil Canyon. It is assumed, for purposes of analysis, that separate provision would need to be made for the full construction power needs at both sites. From estimates by the Consultants:

Connected Load

| | |
|--------------|--------------------------------|
| Watana | 4000 kW (estimated at 3750 kW) |
| Devil Canyon | 3400 kW (estimated at 3350 kW) |

Operational Assumptions for Both Sites:

| | |
|---------------------------------|-----------|
| 6 months/yr intensive operation | @ 0.65 LF |
| 6 months/yr light loading | @ 0.30 LF |

Corresponding to construction planning assumptions of U.S. Corps of Engineers.

Figure 7-1 of Chapter 7 shows the recommended sites at Watana and Devil Canyon for the Susitna development and the routing of the tap line to the sites from the transmission tap station, located on the main transmission corridor for the Anchorage-Fairbanks Intertie. The tap line can later be used also for a subtransmission circuit for distribution in the area, following the completion of the construction program.

A. Alternative 1 - Cost of Construction Power by Diesel Generation
(This will constitute benefits for B/C analysis)

Basic Assumptions:

1. Diesel units purchased for Watana will be used for a period of 6 years and then sold at depreciated value.
2. Diesel units purchased for Devil Canyon will be used for a period of 5 years and then sold at depreciated value.
3. No provision will be made at Devil Canyon for tapping 230-kV line from Watana once energized, due to prior purchase of diesel units for construction power.
4. Diesel units will be installed in multiples of 675 kW net/unit.
 - 6 units at Watana 4050 kW net capacity
 - 5 units at Devil Canyon 3375 kW net capacity

From previous construction power estimates for diesel unit installations:

$$1979 \text{ Cost} = \$700/\text{kW}$$

Installation for Watana construction power units would be made in 1985, ready for service in January 1986.

Escalating @ 7% through 1985 - Cost Level = \$1050/kW.

Installation for Devil Canyon construction power units would be made in 1989, ready for service in January 1990.

Escalating @ 7% through 1989 - Cost Level = \$1377/kW.

Cost of Diesel Installations:

$$\text{Watana} = \$1050 \times 4050 = \$4,252,500$$

$$\text{Devil Canyon} = \$1377 \times 3355 = \$4,647,375$$

This capital investment would be disbursed in 1985 and 1989, respectively, for Watana and Devil Canyon.

Cost of Diesel Operation During Construction

Basic Assumption: Maximum Coincident Demand = Connected Load

This, incidentally, introduces a measure of maximum loading which tends to compensate for an initial lower estimate of construction power requirements by a factor equivalent to projected diversity.

Average Energy Usage Per Year:

$$\text{Watana} \quad 3750 (0.65 + 0.30) \frac{8760}{2} \text{ kWh} = 15,603,750 \text{ kWh}$$

Say 15.60 GWh/yr for 6 yrs.

$$\text{Devil Canyon} \quad 3350 (0.65 + 0.30) \frac{8760}{2} \text{ kWh} = 13,939,350 \text{ kWh}$$

Say 13.94 GWh/yr for 5 yrs.

Operating Characteristics of Diesel Units:

Fuel Rate Assumed - 13 kWh/gal (diesel fuel)

Base Price for Diesel Fuel - 41.2 ¢/gal (1977 actual)

Plus 5% Allowance for Lube Oil - 43.3 ¢/gal

To be escalated @ 11% to 1980 and 7% thereafter.

O&M for diesel units estimated at 5% of total cost of incremental generation.

| <u>Year</u> | <u>Watana Dam</u> | <u>Year</u> | <u>Devil Canyon</u> |
|-------------|-------------------|-------------|---------------------|
| 1986 | \$1,118,500 | | |
| 1987 | 1,198,100 | | |
| 1988 | 1,280,800 | | |
| 1989 | 1,371,200 | | |
| 1990 | 1,468,000 | 1990 | \$1,311,800 |
| 1991 | 1,569,400 | 1991 | 1,402,400 |
| | | 1992 | 1,501,300 |
| | | 1993 | 1,607,300 |
| | | 1994 | 1,708,800 |

DIESEL GENERATION OPERATING COSTS

| Year | <u>Diesel Fuel Including Lube Oil</u> | | <u>O&M</u> (mills/kWh) | <u>Total Operating Cost</u> (mills/kWh) |
|------|---------------------------------------|------------------|-------------------------------|--|
| | <u>¢/gal</u> | <u>mills/kWh</u> | | |
| 1977 | 43.3 | 33.3 | 1.7 | 35.0 |
| 1978 | 48.1 | 37.0 | 1.9 | 38.9 |
| 1979 | 53.3 | 41.0 | 2.1 | 43.1 |
| 1980 | 59.2 | 45.5 | 2.3 | 47.8 |
| 1981 | 63.3 | 48.7 | 2.4 | 51.1 |
| 1982 | 67.8 | 52.2 | 2.6 | 54.8 |
| 1983 | 72.5 | 55.8 | 2.8 | 58.6 |
| 1984 | 77.6 | 59.7 | 3.0 | 62.7 |
| 1985 | 83.0 | 63.8 | 3.2 | 67.0 |
| 1986 | 88.8 | 68.3 | 3.4 | 71.7 |
| 1987 | 95.1 | 73.2 | 3.6 | 76.8 |
| 1988 | 101.7 | 78.2 | 3.9 | 82.1 |
| 1989 | 108.8 | 83.7 | 4.2 | 87.9 |
| 1990 | 116.5 | 89.6 | 4.5 | 94.1 |
| 1991 | 124.6 | 95.8 | 4.8 | 100.6 |
| 1992 | 133.3 | 102.5 | 5.2 | 107.7 |
| 1993 | 142.7 | 109.8 | 5.5 | 115.3 |
| 1994 | 152.6 | 117.4 | 5.9 | 123.3 |

Depreciated Value of Diesel Units:

Basic Assumption of 15-Year Service Life.

Assume Straight-Line Depreciation

1. Watana Installation

Installed Cost (new) = \$4,252,500 (1985)

Depreciation/Year = 283,500

Depreciated Value (1991) 6-Year Period = \$2,551,500

2. Devil Canyon Installation

Installed Cost (new) = \$4,647,375 (1989)

Depreciation/Year = 309,825

Depreciated Value (1994) 5-Year Period = \$3,098,250

Discounted Value of Benefits (Diesel Generation Alternative)

Base Year 1979 (Discounted @ 7%)

| <u>Year</u> | <u>PWF¹</u> | <u>Construction Cost (\$)</u> | <u>Operating Cost (\$)</u> | <u>Total Cost (\$)</u> | <u>Present Value (\$)</u> |
|-------------|------------------------|-----------------------------------|--------------------------------|----------------------------|-------------------------------|
| 1979 | 1.00000 | | | | |
| 1985 | 0.66634 | 4,252,500 | | 4,252,500 | 2,833,611 |
| 1986 | 0.62274 | | 1,118,500 | 1,118,500 | 696,535 |
| 1987 | 0.58200 | | 1,198,100 | 1,198,100 | 697,294 |
| 1988 | 0.54393 | | 1,280,800 | 1,280,800 | 696,666 |
| 1989 | 0.50834 | 4,647,375 | 1,371,200 | 6,018,575 | 3,059,482 |
| 1990 | 0.47509 | | 2,779,800 | 2,779,800 | 1,320,655 |
| 1991 | 0.44401 | -2,551,500 | 2,971,800 | 420,300 | 186,617 |
| 1992 | 0.41496 | | 1,501,300 | 1,501,300 | 622,979 |
| 1993 | 0.38781 | | 1,607,300 | 1,607,300 | 623,327 |
| 1994 | 0.36244 | -3,098,250 | 1,718,800 | -1,379,450 | -499,968 |
| | | | | TOTAL PW ¹ | 10,237,198 |

(- sign denotes assumed resale value)

B. Alternative 2 - Cost of Construction Power by Temporary Tapline
(This will represent costs for B/C analysis)

Basic Assumptions:

1. Same loading conditions and time frame as per Alternative 1.
2. Sequence of temporary construction as per previous assumptions.
3. Reuse of substation equipment possible after construction program completed but no salvage value on line material. (Note: Possible reuse as distribution line to recreational areas.) Assume resale value of substation equipment to be depreciated value based on 25-year life of facilities.
4. Cost of power based on wholesale rates in Railbelt area.
From previous estimates for line and substation facilities:

Construction Costs:

69-kV subtransmission line - \$3,200,000 (1985 level)

Susitna tap station + Watana substation facilities

Baseline cost level = \$26.50/kVA (1979)

Escalating @ 7% to 1985 (6 yrs)

Construction Cost = \$40/kVA (1985)

Total Construction Cost = \$400,000

69/4.16 kW, 5 MVA, Substation at Devil Canyon (1979 levels)

Transformer - \$45,000 fob factory (Virginia)

Allowing 5% for shipping and handling, etc.

At jobsite cost = \$47,250

Fused Disc. Sw. = 2,750

Structure, Conc, pad, etc. = 5,000

TOTAL \$55,000

Construction Costs:

| | | | |
|-----------|-----|--------------|----------------------|
| Equipment | 60% | \$55,000 | |
| Labor | 30% | 28,000 | |
| Design | 10% | <u>9,000</u> | |
| TOTAL | | \$92,000 | or \$18.4/kVA (1979) |

Substation would be installed in 1989.

Escalated at 7% from 1979 levels.

1989 Construction Cost = \$36.2/kVA

Total Construction Cost = \$181,000

O&M For Temporary Construction Power Line Maintenance

69 kV Wood Pole line - Approximately 40 miles long (11 + 29 M)

| | <u>Year</u> | <u>\$/M</u> | <u>Total O&M Costs (\$)</u> |
|--------------|-------------|-------------|-------------------------------------|
| 40 M Total { | 1986 | 330 | 13,200 |
| | 1987 | 345 | 13,800 |
| | 1988 | 360 | 14,400 |
| | 1989 | 380 | 15,200 |
| | 1990 | 400 | 16,000 |
| | 1991 | 420 | 16,800 |
| 29 M Total { | 1992 | 440 | 12,800 |
| | 1993 | 460 | 13,300 |
| | 1994 | 485 | 14,000 |

Note: That due to overlap in construction schedules for Watana and Devil Canyon the capacity of the Susitna tap station will need to be doubled by addition of second 5 MVA transfer. This will be moved to spares inventory after 2 years.

Cost of Construction Power Supplied over Temporary Line Facility

Based on information from RWRA 2/1/79

Wholesale rates for Railbelt area, with combination of Susitna

Hydropower and large coal-fired plant feeding interconnection.

| <u>Year</u> | <u>Rate of Change</u> | <u>Wholesale Rate (mills/kWh)</u> | <u>Cost of Energy (mills/kWh)</u> | |
|-------------|-----------------------|---------------------------------------|-----------------------------------|-------------------|
| | | | <u>Bus-Bar</u> | <u>Substation</u> |
| 1979 | 10% | 17 | Note: <u>1977 Cost Levels</u> | |
| 1980 | | 18 | | |
| 1981 | | 20 | | |
| 1982 | | 22 | | |
| 1983 | 8% | 24 | 27.3 | 30.2 |
| 1984 | | 26 | | |
| 1985 | | 28 | | |
| 1986 | | 30 | | |
| 1987 | 7% | 32 | 31.0 | 33.5 |
| 1988 | | 34 | | |
| 1989 | | 37 | | |
| 1990 | | 39 | | |
| 1991 | 5% | 42 | 33.2 | 36.6 |
| 1992 | | 45 | | |
| 1993 | | 47 | | |
| 1994 | | 50 | | |
| 1995 | | | 36.2 | 39.1 |
| 2000 | | | | |

Conversion of Total Energy Rate to 2-Part Tariff

Assumption: 100 MW Power Transfer at 0.6 LF is 525.6 GWh/yr.

| Year | Bulk Rate (mills/kWh) | Total Revenue for Bulk Rate (\$1000) | 50/50 Revenue From: | | Equivalent Tariff | |
|------|--------------------------|--|---------------------|--------------------|-------------------------|----------------------------|
| | | | Demand (\$1000) | Energy (\$1000) | Demand Rate (\$/kWh) | Energy Rate (mills/kWh) |
| 1979 | 17 | 8,935.2 | 4,467.6 | | 74.5 | 8.5 |
| 1980 | 18 | 9,460.8 | 4,730.4 | | 78.8 | 9.0 |
| 1981 | 20 | 10,512.0 | 5,256.0 | | 87.6 | 10.0 |
| 1982 | 22 | 11,563.2 | 5,781.6 | | 96.4 | 11.0 |
| 1983 | 24 | 12,614.4 | 6,307.2 | | 105.1 | 12.0 |
| 1984 | 26 | 13,665.6 | 6,832.8 | | 113.9 | 13.0 |
| 1985 | 28 | 14,716.8 | 7,358.4 | | 122.6 | 14.0 |
| 1986 | 30 | 15,768.0 | 7,884.0 | | 131.4 | 15.0 |
| 1987 | 32 | 16,819.2 | 8,409.6 | | 140.2 | 16.0 |
| 1988 | 34 | 17,870.4 | 8,935.2 | | 148.9 | 17.0 |
| 1989 | 37 | 19,447.2 | 9,723.6 | | 162.1 | 18.5 |
| 1990 | 39 | 20,498.4 | 10,249.2 | | 170.8 | 19.5 |
| 1991 | 42 | 22,075.2 | 11,037.6 | | 184.0 | 21.0 |
| 1992 | 45 | 23,652.0 | 11,826.0 | | 197.1 | 22.5 |
| 1993 | 47 | 24,703.2 | 12,351.6 | | 205.9 | 23.5 |
| 1994 | 50 | 26,280.0 | 13,140.0 | | 219.0 | 25.0 |

Allow 5% adder for line and substation losses - assume the resulting rates are applicable to price construction power.

Cost Estimate for Construction Power

Assuming same loading as for diesel generation alternative.

1. Watana Damsite (3750 kW, 15.6 GWh/yr)

| Year | Demand Rate (\$/kW) | Energy Rate (mills/kWh) | Construction Power Costs | | |
|------|------------------------|----------------------------|--------------------------|-------------|------------|
| | | | Demand (\$) | Energy (\$) | Total (\$) |
| 1986 | 138.0 | 15.8 | 517,500 | 246,480 | 763,980 |
| 1987 | 147.2 | 16.8 | 552,000 | 262,080 | 814,080 |
| 1988 | 156.3 | 17.9 | 586,125 | 279,240 | 865,365 |
| 1989 | 170.2 | 19.4 | 638,250 | 302,640 | 940,890 |
| 1990 | 179.3 | 20.5 | 672,375 | 319,800 | 992,175 |
| 1991 | 193.2 | 22.1 | 724,500 | 344,760 | 1,069,260 |

2. Devil Canyon Damsite (3350 kW, 13.94 GWh/yr)

| Year | Demand Rate (\$/kW) | Energy Rate (mills/kWh) | Construction Power Costs | | |
|------|------------------------|----------------------------|--------------------------|-------------|------------|
| | | | Demand (\$) | Energy (\$) | Total (\$) |
| 1990 | 179.3 | 20.5 | 600,655 | 285,770 | 886,425 |
| 1991 | 193.2 | 22.1 | 647,220 | 308,074 | 955,294 |
| 1992 | 207.0 | 23.6 | 693,450 | 328,984 | 1,022,434 |
| 1993 | 216.2 | 24.7 | 724,270 | 344,318 | 1,068,588 |
| 1994 | 230.0 | 26.3 | 770,500 | 366,622 | 1,137,122 |

Depreciated Value of Substation Facilities

Basic Assumption of 25-Year Service Life

Assume Straight Line Depreciation

1. Watana Substation

Installed Cost (new) = \$ 27.6/kVA (1985)
= \$138,000
Depreciation/Year = \$ 5,520
Depreciated Value = \$104,880 (1991) (6-year period)

2. Devil Canyon Substation

Installed Cost (new) = \$ 36.2/kVA (1989)
= \$ 181,000
Depreciation/Year = \$ 7,240
Depreciated Value = \$ 144,800 (1994) (5-year period)

3. Susitna Tap Station/Watana Bus Tap

Installed Cost (new) = \$ 262,000 (1985)
Depreciation/Year = \$ 10,480
Depreciated Value = \$ 167,680 (1994) (7-year period)

To transfer 5 MVA facility from Susitna Tap to Watana.

Cost of removal and transfer = \$30,000 (1991)

Cost of second 5 MVA step-down facility at Susitna tap.

In 1989 for Supplementary power to Devil Canyon = \$343,400

Depreciated value after 2 years = \$315,900

Discounted Value of Costs (Sub-Transmission Tapline Alternative)

Base Year 1979 (Discounted @ 7%)

| <u>Year</u> | <u>PWF¹</u> | <u>Construction Cost (\$)</u> | <u>O&M (\$)</u> | <u>Cost of Power (\$)</u> | <u>Total Cost (\$)</u> | <u>Present Value (\$)</u> |
|-------------|------------------------|-----------------------------------|---------------------|-------------------------------|----------------------------|-------------------------------|
| 1979 | 1.00000 | | | | | |
| 1985 | 0.66634 | 400,000 | | | 400,000 | 266,536 |
| 1986 | 0.62274 | | 13,200 | 763,980 | 777,180 | 483,981 |
| 1987 | 0.58200 | | 13,800 | 814,080 | 827,880 | 481,826 |
| 1988 | 0.54393 | | 14,400 | 865,365 | 879,765 | 478,531 |
| 1989 | 0.50834 | 524,400 | 15,200 | 940,890 | 1,480,490 | 752,592 |
| 1990 | 0.47509 | | 16,000 | 1,878,600 | 1,894,600 | 900,106 |
| 1991 | 0.44401 | -390,780* | 16,800 | 2,024,554 | 1,650,574 | 732,871 |
| 1992 | 0.41496 | | 12,800 | 1,022,434 | 1,035,234 | 429,581 |
| 1993 | 0.38781 | | 13,300 | 1,068,588 | 1,081,888 | 419,567 |
| 1994 | 0.36244 | -312,480 | 14,000 | 1,137,122 | 838,642 | <u>303,957</u> |
| | | | | | TOTAL PW ¹ | 5,249,548 |

* Including one-time cost of transfer of tap facilities and resale value of 5-MVA substation.

B/C Ratio for Construction Power Supply by Tapline.

$$\begin{aligned}
 \text{B/C Ratio} &= \frac{\text{Discounted Cost of Diesel Generation Alternative}}{\text{Discounted Cost of Tapline Alternative}} \\
 &= \frac{10,237,198}{5,249,548} \\
 &= \underline{1.95}
 \end{aligned}$$

DERIVATION
OF
INPUT COST DATA FOR ECONOMIC ANALYSIS
TO OBTAIN
BASELINE COSTS ASSOCIATED WITH THE TWO CONSTRUCTION POWER ALTERNATIVES

| <u>Year</u> | <u>7% Deflator</u> | <u>Alternative I</u> | | <u>Alternative II</u> | |
|-------------|--------------------|--------------------------|-----------------|-----------------------|-----------------|
| | | <u>Diesel Generation</u> | | <u>Tapline Supply</u> | |
| | | <u>Escalated</u> | <u>Deflated</u> | <u>Escalated</u> | <u>Deflated</u> |
| 1979 | 1.00 | | | | |
| 1980 | 1.07 | | | | |
| 1981 | 1.14 | | | | |
| 1982 | 1.23 | | | | |
| 1983 | 1.31 | | | | |
| 1984 | 1.40 | | | | |
| 1985 | 1.50 | 4,252,500 | 2,835,000 | 400,000 | 266,670 |
| 1986 | 1.61 | 1,118,500 | 694,720 | 777,180 | 482,720 |
| 1987 | 1.72 | 1,198,100 | 696,570 | 827,880 | 481,330 |
| 1988 | 1.84 | 1,280,800 | 696,090 | 879,765 | 478,130 |
| 1989 | 1.97 | 6,018,575 | 3,055,110 | 1,480,490 | 751,520 |
| 1990 | 2.10 | 2,779,800 | 1,323,710 | 1,894,600 | 902,190 |
| 1991 | 2.25 | 420,300 | 186,800 | 1,650,574 | 733,590 |
| 1992 | 2.41 | 1,501,300 | 622,950 | 1,035,234 | 429,560 |
| 1993 | 2.58 | 1,607,300 | 622,980 | 1,081,888 | 419,340 |
| 1994 | 2.76 | -1,379,450 | -499,800 | 838,642 | 303,860 |

SUMMARY

BASELINE COSTS (1979) ASSOCIATED WITH TWO CONSTRUCTION POWER ALTERNATIVES

| Year | <u>\$1000 (1979)</u> | |
|------|----------------------|------------------|
| | (Independent) | (Interconnected) |
| | Diesel | Tapline |
| | <u>Generation</u> | <u>Supply</u> |
| 1985 | 2,835 | 267 |
| 1986 | 695 | 483 |
| 1987 | 697 | 481 |
| 1988 | 696 | 478 |
| 1989 | 3,055 | 752 |
| 1990 | 1,324 | 902 |
| 1991 | 187 | 734 |
| 1992 | 623 | 430 |
| 1993 | 623 | 419 |
| 1994 | -500 ^{1/} | 304 |

^{1/} Negative sign indicates net resale value predominates over costs.

D.4 ALTERNATIVE GENERATING PLANT FUEL COSTS

The year-by-year analysis of comparative fuel costs follows:

A. First Period (1984-87) - Firm Power Transfer of 30 MW, 145 GWh

| <u>Year</u> | <u>Interconnected System Expansion</u> | <u>Independent System Expansion</u> |
|-------------|--|---|
| 1984 | The number and type of generating plants is identical to that for each system operating independently. | Each independent system would be supplied by operational units on basis of economic dispatch to meet individual area needs. |

The determination of relative economic advantage to either system, of a firm power transfer, would require a detailed analysis, necessitating production costing of economically dispatched units for the Anchorage and Fairbanks systems. It is a reasonable measure to delete the comparison of marginal advantages accruing for this year of operation.

| | | |
|------|--|--|
| 1985 | ANCH 9 - 78 MW SCGT is added to AML&P system, obviating the need for both NORT 3 and BELU 9. | Two units are required in Anchorage area, ANCH 9 - 78 MW SCGT and BELU 9 - 71 MW RCGT, together with NORT 3 - 69 MW SCGT unit at the Northpole Station in Fairbanks. |
|------|--|--|

As a first approximation, the relative generation cost advantage may be determined by estimating the respective fuel costs associated with the generation of 145 GWh of energy by either ANCH 9 or NORT 3, taking into consideration different primary fuel costs and thermal efficiencies. The unit ratings are sufficiently close to justify this analytical approach, on the basic assumption that equivalent energy would be generated during the year by the two units. An adjustment would then be made to allow for the differential cost of supplying line losses in the transmission intertie, which would amount to 1.5 GWh/yr.

Comparative Fuel Costs:

ANCH 9 - 78 MW SCGT

From Battelle Report (see Figure D-3)

See Figure D-1

Trend Curve for HR8444 New Gas
with 8% inflation and escalation

1985 Fuel Cost = \$3.60/MBTU

Net Heat Rate = 14,500 BTU/kWh

Annual Cost of Fuel (ACF)

to generate 145 GWh:

$$\begin{aligned}\text{ACF @ } 0.21 \text{ PCF}^{2/} &= \$3.60 \times 145 \times 14,500 \\ &= \$7,569,000\end{aligned}$$

NORT 3 - 69 MW SCGT

From Stanley Consultants Report P. 21

1978 Fuel Cost = \$1.98/MBTU

Escalating @ 10% per year^{1/}:

1985 Fuel Cost = \$3.86/MBTU

For distillate from North Pole refinery

From Table 6, P. 22:

Net Heat Rate = 15,130 BTU/kWh

Annual Cost of Fuel (ACF)

to generate 145 GWh:

$$\begin{aligned}\text{ACF @ } 0.24 \text{ PCF}^{2/} &= \$3.86 \times 145 \times 15,130 \\ &= \$8,468,000\end{aligned}$$

The total cost comparison is in favor of ANCH 9 generation to supply Fairbanks.

Total cost of generation, including loss component = \$7,648,000.

1986 BELU 9 - 71 MW SCGT is added to CEA system, the inter-connection having served to delay the in-service of the combustion turbine by one year. It is assumed that this unit will be operated for supply to CEA system only during first year of operation.

ANCH 10 - 104 MW coal-fired plant is added to AML&P system for both independent and interconnected system expansions. KNIK A - 15 MW thermal power plant (CEA) is also retired from both expansions.

The relative economic advantage is attributable to the fuel cost differential between distillate for NORT 3 generation and Beluga gas for generation by either ANCH 9 or BELU 9. Selecting ANCH 9 as in the previous analysis for 1985:

^{1/} 7% inflation + 3% escalation.

^{2/} PCF = Plant Capacity Factor.

Comparative Fuel Costs:

ANCH 9 - 79 MW SCGT

1986 Fuel Cost = \$4.00/MBTU
Net Heat Rate = 14,500 BTU/kWh
Annual Cost of Fuel (ACF)
to generate 145 GWh:
ACF @ 0.21 PCF = \$8,410,000

NORT 3 - 69 MW SCGT

1986 Fuel Cost = \$4.25/MBTU
Net Heat Rate = 15,130 BTU/kWh
Annual Cost of Fuel (ACF)
to generate 145 GWh:
ACF @ 0.24 PCF = \$9,324,000

The cost comparison is once again in favor of ANCH 9 generation to supply the equivalent amount of energy over intertie, as would otherwise be generated locally in Fairbanks.

Total cost of ANCH 9 generation, including transmission loss = \$8,498,000.

1987 This is the first year of operation of COAL 1 - 200 MW coal-fired plant on the Anchorage system. As this would be the first year of operation for the first major coal-fired plant in the Railbelt, for either independent or interconnected expansions, it would be thus common to the two alternatives. The relative cost advantages would then again be determined by consideration of the relative generation cost for ANCH 9 and NORT 3.

Comparative Fuel Costs:

ANCH 9 - 79 MW SCGT

1987 Fuel Cost = \$4.25/MBTU
Net Heat Rate = 14,500 BTU/kWh
Annual Cost of Fuel (ACF)
to generate 145 GWh:
ACF @ 0.21 PCF = \$8,936,000

NORT 3 - 69 MW SCGT

1987 Fuel Cost = \$4.68/MBTU
Net Heat Rate = 15,130 BTU/kWh
Annual Cost of Fuel (ACF)
to generate 145 GWh:
ACF @ 0.21 PCF = \$10,267,000

Total cost of ANCH 9 generation, including transmission loss = \$9,029,000.

B. Second Period (1992-96) - Firm Power Transfer of 70 MW, 337 GWh

| <u>Year</u> | <u>Interconnected System Expansion</u> | <u>Independent System Expansion</u> |
|-------------|---|---|
| 1992 | Interconnected operation obviates the need for COAL 5 - 200 MW unit in Anchorage area and COAL F2 - 100 MW unit in Fairbanks area. Comparable generation is maintained by COAL 6 - 300 MW unit in Anchorage area. | COAL 5 would have to be added to Anchorage system and COAL F2 to Fairbanks. |

Comparative economic advantage is determined by relative magnitude of fuel costs, for either COAL 6 or COAL F2, to generate same energy.

Comparative Fuel Costs:

| | ● <u>COAL 6 - 300 MW</u> | ● <u>COAL F2 - 100 MW</u> |
|---------------------------------------|--------------------------|---------------------------|
| From Battelle Report (see Figure D-4) | | |
| Fuel Cost in 1992 | \$2.60/MBTU | \$1.90/MBTU |
| Net Heat Rate | 9,500 BTU/kWh | 10,700 BTU/kWh |
| ACF to generate 337 GWh | \$8,324,000 | \$6,851,000 |

The comparative advantage in this case moves to the use of Healy coal. However, as with interconnection, the unit COAL F2 will be eliminated in favor of the economies of scale associated with the COAL 6 unit. Without production costing, it is not possible to determine the overall economic advantage of introducing COAL 6, so for present analysis it is assumed that no economic energy transfer is possible. However, as a first approximation, the fuel costs for this year will be entered into economic analysis to consider the effect of the differential.

| | | |
|------|---|---|
| 1993 | <p>ANCH 11 - 104 MW coal-fired unit added to AML&P system in this year for interconnected expansion, after an interval of five years following the in-service date for same unit with independent expansion. PEAK A1 - 78 MW combustion turbine also in-service from beginning of year.</p> | <p>PEAK A1 - 78 MW combustion turbine in-service from beginning of year, for independent expansion of Anchorage system.</p> |
|------|---|---|

Of interest in this year is a comparison between the cost of energy generation for ANCH 11 and COAL F2 using the same source of fuel, Healy coal. Thus, the relative advantage of either generating at the existing plant site at Healy or in the vicinity of Anchorage may be examined for similar capacity units having the same thermal efficiency, to determine the economies of energy transfer by intertie.

Comparative Fuel Costs:

| | ● <u>ANCH 11</u> | ● <u>COAL F2</u> |
|----------------------------|--------------------------|---------------------------|
| Cost of Healy coal in 1993 | \$2.4/MBTU ^{1/} | \$2.00/MBTU ^{2/} |
| Net Heat Rate | 10,700 BTU/kWh | 10,700 BTU/kWh |
| ACF to generate 337 GWh | \$8,654,000 | \$7,212,000 |

Once again the comparative advantage lies with the generation of energy at the Healy site. However, with interconnection the need for COAL F2 disappears in favor of the economies of scale attendant on COAL 6. It may be noted that the cost differential in favor of Healy disappears if the COAL F2 site would be moved away from Healy for environmental reasons to say Nenana. In this case, the cost of generation would be approximately the same whether coal were transported either to Anchorage or Nenana, as the transmission loss, associated with ANCH 11 (104 MW) generation and transfer over the intertie, would be compensated for by the slightly higher heat rate to be expected with the 100 MW unit of COAL F2.

^{1/} Delivered to Anchorage plant site.

^{2/} Delivered to Healy plant site.

1994 As GEN 1 - 300 MW coal-fired generating plant added for both independent and interconnected system expansions, the previous combination of ANCH 11 and COAL F2 can again be examined to determine the differential cost of fuel.

Comparative Fuel Costs:

| | ● <u>ANCH 11</u> | ● <u>COAL F2</u> |
|--|------------------|------------------|
| Cost of Healy coal in 1994 (Minemouth Generation, FOB Tipple) | \$2.5/MBTU | \$2.2/MBTU |
| Net Heat Rate | 10,700 BTU/kWh | 10,700 BTU/kWh |
| ACF to generate 337 GWh | \$9,015,000 | \$7,933,000 |

It may be noted that due to divergence of fuel cost trends after 1993, for coal delivered to either Anchorage or Nenana, rather than minemouth, the economic advantage moves progressively towards generation at an Anchorage location, with transfer of the equivalent energy over the intertie. However, in 1994, it is possible to transmit energy generated economically at Healy to Anchorage over the intertie.

Total cost of COAL F2 generation, including transmission loss = \$8,016,000.

| | | |
|------|---|---|
| 1995 | COAL F3 - 100 MW coal-fired plant is introduced to the Fairbanks area and PEAK A2 - 78 MW combustion turbine is added to the AML&P system. Interconnection results in the postponement by one year of the 300 MW GEN 2 in the Anchorage area. | GEN 2 - 300 MW coal-fired plant is introduced to the Anchorage area with independent system expansion but the 78 MW combustion turbine PEAK A2 is not required in addition to the large coal-fired plant. COAL F3 is added to the system in the Fairbanks area. |
|------|---|---|

As COAL F3 is common to both the independent and interconnected system expansions, it is of interest whether the gas-fired PEAK A2 in Anchorage could economically displace the equivalent energy generated by the coal-fired unit COAL F3 in the Fairbanks area.

Comparative Fuel Costs:

| | ● <u>PEAK A2</u> | ● <u>COAL F3</u> |
|---|------------------|------------------|
| Cost of New Gas in 1995 (HR 8444 - 8% infl. + esc.) | \$7.70/MBTU | |
| Cost of Healy Coal in 1995 (Minemouth Plant, FOB Tipple) | | \$2.40/MBTU |
| Net Heat Rate | 14,500 BTU/kWh | 10,700 BTU/kWh |
| ACF to generate 337 GWh | \$37,626,000 | \$8,654,000 |

There is a definite economic advantage to coal generation at Healy and energy transfer over the intertie to displace gas-fired generation in Anchorage.

Total cost of COAL F3 generation, including transmission loss = \$8,745,000.

1996 GEN 2 - 300 MW coal-fired plant is introduced to the Anchorage area, the inter-connection serving to postpone its in-service date by one year.

PEAK A2 - 78 MW combustion turbine is introduced to the AML&P system in Anchorage.

In this final year of analysis, it is of interest to compare the relative economic advantages of coal-fired generation at either the Fairbanks (Healy) or Anchorage (Beluga) sites.

Comparative Fuel Costs:

| | ● <u>GEN 2</u> | ● <u>COAL F3</u> |
|-----------------------------|----------------|------------------|
| Cost of Beluga Coal in 1996 | \$3.3/MBTU | |
| Cost of Healy Coal in 1996 | | 2.5/MBTU |
| Net Heat Rate | 9,500 BTU/kWh | 10,700 BTU/kWh |
| ACF to generate 337 GWh | \$10,565,000 | \$9,015,000 |

Once again it is more economical to generate in the Fairbanks area and transfer energy south over the intertie to Anchorage.

Total cost of COAL F3 generation, including transmission loss = \$9,109,000.

Nomogram calculates economy of scale in power plants

By JAMES McALISTER, Arkansas Power & Light Co.

Historically, the per unit cost of larger power plants has been less than that of smaller plants. The proportionality was examined in some detail in the article "Economy of Scale in Power Plants" in the August 1977 issue of POWER ENGINEERING Magazine, p. 51

The basic equation is:

$$(C_1/C_2) = (MW_1/MW_2)^P$$

Where:

- C_1 cost of plant 1
- C_2 cost of plant 2
- MW_1 capability of plant 1
- MW_2 capability of plant 2
- P proportionality factor

For many years, this proportionality factor averaged about 0.6, which led to the so-called "Six-tenths Power Law." However, as explained in the article referred to above, extended project schedules and inflation cause the factor to increase

This nomogram solves the equation and permits a cost comparison of plants of different sizes. It assumes, of course, that they are essentially identical in construction technique, design and time frame, and that the only significant difference is in size.

Example: A 200-MW plant can be built for \$200 million. Find the cost of a similar 1000-MW plant.

Solution: (1) Connect unit ratings of 200 MW and 1000 MW on the MW_1 and MW_2 scales, and mark intersection with Reference Line X. (2) Align this point with assumed scaling factor $P = 0.6$ and extend to cut Reference Line Y. (3) Connect this point with 0.2 on C_1 scale and extend to C_2 scale. Read answer as \$0.53 billion. **END**

To obtain an extra copy of this article, circle 206 on Reader Service Card








FIGURE D-2





ESTIMATES OF FUTURE NATURAL GAS PRICES

(Source: Battelle Final Report 'Alaskan Electric Power', March 1978/Figure 6-6)



ESTIMATES OF FUTURE COAL PRICES

(Source: Battelle Final Report 'Alaskan Electric Power', March 1978/Figure 6-7)

APPENDIX E

TRANSMISSION LINE ECONOMIC ANALYSIS PROGRAM (TLEAP)



APPENDIX E
TRANSMISSION LINE ECONOMIC
ANALYSIS PROGRAM (TLEAP)

| | |
|--------------|---------|
| TABLE 8-1 | CASE IA |
| TABLE 8-1x | CASE IA |
| TABLE 8-1-LL | CASE IA |
| TABLE 8-2 | CASE IC |
| TABLE 8-3 | CASE IB |
| TABLE 8-3x | CASE IB |
| TABLE 8-3-LL | CASE IB |
| TABLE 8-4 | CASE IB |
| TABLE 8-4x | CASE IB |
| TABLE 8-5 | CASE ID |
| TABLE 8-5x | CASE ID |
| TABLE 8-6 | CASE ID |
| TABLE 8-6x | CASE ID |
| TABLE 8-7 | CASE IC |

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERTIE
ECONOMIC FEASIBILITY STUDY

DISCOUNTED VALUE OF BASE YEAR (1979) INDEPENDENT SYSTEM COSTS
IN \$1000

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 244,472 | 354,109 | 388,978 | 427,474 | 469,977 | 516,903 | 568,712 | 625,909 | 689,048 | 758,736 |
| 8.25 | 239,365 | 346,235 | 380,203 | 417,695 | 459,079 | 504,760 | 555,184 | 610,839 | 672,263 | 740,046 |
| 8.50 | 234,394 | 338,581 | 371,675 | 408,193 | 448,493 | 492,967 | 542,048 | 596,209 | 655,972 | 721,910 |
| 8.75 | 229,556 | 331,140 | 363,386 | 398,960 | 438,209 | 481,513 | 529,292 | 582,005 | 640,159 | 704,309 |
| 9.00 | 224,847 | 323,904 | 355,328 | 389,987 | 428,217 | 470,386 | 516,903 | 568,213 | 624,808 | 687,225 |
| 9.25 | 220,262 | 316,868 | 347,495 | 381,266 | 418,507 | 459,576 | 504,870 | 554,820 | 609,903 | 670,641 |
| 9.50 | 215,798 | 310,024 | 339,878 | 372,787 | 409,070 | 449,073 | 493,181 | 541,812 | 595,430 | 654,541 |
| 9.75 | 211,451 | 303,368 | 332,471 | 364,545 | 399,897 | 438,867 | 481,824 | 529,177 | 581,375 | 638,909 |
| 10.00 | 207,217 | 296,892 | 325,267 | 356,530 | 390,981 | 428,947 | 470,789 | 516,903 | 567,724 | 623,729 |
| 10.25 | 203,093 | 290,591 | 318,259 | 348,736 | 382,312 | 419,305 | 460,066 | 504,978 | 554,464 | 608,986 |
| 10.50 | 199,076 | 284,461 | 311,443 | 341,156 | 373,883 | 409,932 | 449,644 | 493,390 | 541,581 | 594,667 |
| 10.75 | 195,162 | 278,494 | 304,810 | 333,783 | 365,686 | 400,820 | 439,513 | 482,129 | 529,065 | 580,757 |
| 11.00 | 191,348 | 272,687 | 298,357 | 326,611 | 357,714 | 391,959 | 429,665 | 471,185 | 516,903 | 567,244 |
| 11.25 | 187,631 | 267,034 | 292,076 | 319,632 | 349,960 | 383,343 | 420,091 | 460,546 | 505,084 | 554,114 |
| 11.50 | 184,008 | 261,530 | 285,963 | 312,842 | 342,417 | 374,963 | 410,781 | 450,204 | 493,596 | 541,355 |
| 11.75 | 180,476 | 256,172 | 280,013 | 306,234 | 335,078 | 366,811 | 401,728 | 440,149 | 482,429 | 528,955 |
| 12.00 | 177,033 | 250,953 | 274,220 | 299,802 | 327,936 | 358,882 | 392,923 | 430,372 | 471,574 | 516,903 |

DISCOUNTED VALUE OF BASE YEAR (1979) INTERCONNECTED SYSTEM COSTS
IN \$1000

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 233,560 | 351,674 | 390,188 | 433,136 | 481,019 | 534,389 | 593,859 | 660,105 | 733,874 | 815,988 |
| 8.25 | 228,191 | 343,033 | 380,460 | 422,186 | 468,698 | 520,531 | 578,278 | 642,594 | 714,202 | 793,899 |
| 8.50 | 222,980 | 334,654 | 371,028 | 411,573 | 456,758 | 507,104 | 563,184 | 625,633 | 695,151 | 772,510 |
| 8.75 | 217,922 | 326,528 | 361,883 | 401,284 | 445,186 | 494,092 | 548,560 | 609,202 | 676,699 | 751,797 |
| 9.00 | 213,011 | 318,646 | 353,015 | 391,309 | 433,969 | 481,482 | 534,389 | 593,284 | 658,825 | 731,736 |
| 9.25 | 208,242 | 311,000 | 344,414 | 381,636 | 423,094 | 469,260 | 520,656 | 577,860 | 641,509 | 712,304 |
| 9.50 | 203,610 | 303,582 | 336,072 | 372,257 | 412,551 | 457,412 | 507,346 | 562,914 | 624,731 | 693,479 |
| 9.75 | 199,112 | 296,385 | 327,980 | 363,160 | 402,327 | 445,925 | 494,445 | 548,429 | 608,474 | 675,241 |
| 10.00 | 194,743 | 289,401 | 320,129 | 354,336 | 392,412 | 434,788 | 481,938 | 534,389 | 592,720 | 657,569 |
| 10.25 | 190,497 | 282,623 | 312,511 | 345,776 | 382,796 | 423,988 | 469,812 | 520,779 | 577,450 | 640,444 |
| 10.50 | 186,373 | 276,043 | 305,118 | 337,471 | 373,468 | 413,513 | 458,054 | 507,585 | 562,649 | 623,847 |
| 10.75 | 182,364 | 269,656 | 297,943 | 329,412 | 364,418 | 403,354 | 446,652 | 494,792 | 548,300 | 607,760 |
| 11.00 | 178,469 | 263,455 | 290,979 | 321,592 | 355,638 | 393,499 | 435,593 | 482,386 | 534,389 | 592,166 |
| 11.25 | 174,682 | 257,434 | 284,218 | 314,002 | 347,119 | 383,938 | 424,867 | 470,355 | 520,900 | 577,048 |
| 11.50 | 171,000 | 251,587 | 277,654 | 306,634 | 338,851 | 374,661 | 414,461 | 458,686 | 507,819 | 562,389 |
| 11.75 | 167,421 | 245,908 | 271,281 | 299,482 | 330,826 | 365,659 | 404,365 | 447,367 | 495,132 | 548,174 |
| 12.00 | 163,941 | 240,392 | 265,091 | 292,538 | 323,036 | 356,923 | 394,569 | 436,386 | 482,827 | 534,389 |

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERTIE
ECONOMIC FEASIBILITY STUDY

TABLE 8-1X

DISCOUNTED VALUE OF BASE YEAR (1979) INDEPENDENT SYSTEM COSTS
IN \$1000

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 244,472 | 354,109 | 388,978 | 427,474 | 469,977 | 516,903 | 568,712 | 625,909 | 689,048 | 758,736 |
| 8.25 | 239,365 | 346,235 | 380,203 | 417,695 | 459,079 | 504,760 | 555,184 | 610,839 | 672,263 | 740,046 |
| 8.50 | 234,304 | 338,581 | 371,675 | 408,193 | 448,493 | 492,967 | 542,048 | 596,209 | 655,972 | 721,910 |
| 8.75 | 229,556 | 331,140 | 363,386 | 398,960 | 438,209 | 481,513 | 529,292 | 582,005 | 640,159 | 704,309 |
| 9.00 | 224,847 | 323,904 | 355,328 | 389,987 | 428,217 | 470,386 | 516,903 | 568,213 | 624,808 | 687,225 |
| 9.25 | 220,262 | 316,668 | 347,495 | 381,266 | 418,507 | 459,576 | 504,870 | 554,820 | 609,903 | 670,641 |
| 9.50 | 215,798 | 310,024 | 339,878 | 372,787 | 409,070 | 449,073 | 493,181 | 541,812 | 595,430 | 654,541 |
| 9.75 | 211,451 | 303,368 | 332,471 | 364,545 | 399,897 | 438,867 | 481,824 | 529,177 | 581,375 | 638,909 |
| 10.00 | 207,217 | 296,892 | 325,267 | 356,530 | 390,981 | 428,947 | 470,789 | 516,903 | 567,724 | 623,729 |
| 10.25 | 203,093 | 290,591 | 318,259 | 348,736 | 382,312 | 419,305 | 460,066 | 504,978 | 554,464 | 608,986 |
| 10.50 | 199,076 | 284,461 | 311,443 | 341,156 | 373,883 | 409,932 | 449,644 | 493,390 | 541,581 | 594,667 |
| 10.75 | 195,162 | 278,494 | 304,810 | 333,783 | 365,686 | 400,820 | 439,513 | 482,129 | 529,065 | 580,757 |
| 11.00 | 191,348 | 272,687 | 298,357 | 326,611 | 357,714 | 391,959 | 429,665 | 471,185 | 516,903 | 567,244 |
| 11.25 | 187,631 | 267,034 | 292,076 | 319,632 | 349,960 | 383,343 | 420,091 | 460,546 | 505,084 | 554,114 |
| 11.50 | 184,008 | 261,530 | 285,963 | 312,842 | 342,417 | 374,963 | 410,781 | 450,204 | 493,596 | 541,355 |
| 11.75 | 180,476 | 256,172 | 280,013 | 306,234 | 335,078 | 366,811 | 401,728 | 440,149 | 482,429 | 528,955 |
| 12.00 | 177,033 | 250,953 | 274,220 | 299,802 | 327,936 | 358,882 | 392,923 | 430,372 | 471,574 | 516,903 |

DISCOUNTED VALUE OF BASE YEAR (1979) INTERCONNECTED SYSTEM COSTS
IN \$1000

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 245,883 | 365,887 | 404,905 | 448,371 | 496,785 | 550,701 | 610,731 | 677,551 | 751,908 | 834,625 |
| 8.25 | 240,411 | 357,126 | 395,053 | 437,293 | 484,332 | 536,706 | 595,008 | 659,893 | 732,084 | 812,379 |
| 8.50 | 235,098 | 348,629 | 385,499 | 426,553 | 472,261 | 523,143 | 579,773 | 642,786 | 712,882 | 790,834 |
| 8.75 | 229,939 | 340,386 | 376,233 | 416,139 | 460,559 | 509,997 | 565,009 | 626,211 | 694,281 | 769,967 |
| 9.00 | 224,928 | 332,389 | 367,245 | 406,040 | 449,213 | 497,254 | 550,701 | 610,150 | 676,259 | 749,753 |
| 9.25 | 220,061 | 324,629 | 358,527 | 396,245 | 438,212 | 484,900 | 536,832 | 594,586 | 658,798 | 730,171 |
| 9.50 | 215,332 | 317,098 | 350,067 | 386,744 | 427,543 | 472,922 | 523,388 | 579,500 | 641,876 | 711,197 |
| 9.75 | 210,737 | 309,789 | 341,859 | 377,527 | 417,195 | 461,306 | 510,353 | 564,877 | 625,477 | 692,811 |
| 10.00 | 206,272 | 302,695 | 333,894 | 368,585 | 407,157 | 450,042 | 497,715 | 550,701 | 609,581 | 674,994 |
| 10.25 | 201,933 | 295,807 | 326,162 | 359,907 | 397,419 | 439,116 | 485,458 | 536,956 | 594,172 | 657,724 |
| 10.50 | 197,714 | 289,120 | 316,658 | 351,486 | 387,971 | 428,517 | 473,572 | 523,628 | 579,233 | 640,985 |
| 10.75 | 193,614 | 282,626 | 311,372 | 343,312 | 378,802 | 418,234 | 462,042 | 510,703 | 564,748 | 624,756 |
| 11.00 | 189,626 | 276,319 | 304,298 | 335,378 | 369,905 | 408,257 | 450,857 | 498,167 | 550,701 | 609,022 |
| 11.25 | 185,749 | 270,193 | 297,429 | 327,676 | 361,268 | 398,576 | 440,005 | 486,007 | 537,078 | 593,766 |
| 11.50 | 181,978 | 264,242 | 290,757 | 320,197 | 352,885 | 389,180 | 429,476 | 474,211 | 523,865 | 578,970 |
| 11.75 | 178,310 | 258,461 | 284,277 | 312,935 | 344,746 | 380,059 | 419,258 | 462,765 | 511,048 | 564,820 |
| 12.00 | 174,742 | 252,843 | 277,983 | 305,881 | 336,844 | 371,206 | 409,541 | 451,659 | 498,612 | 550,701 |

28 AUGUST 79

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERTIE
ECONOMIC FEASIBILITY STUDY

TABLE 8-1-LL

| | CAPITAL DISBURSEMENTS IN \$1000 FOR ALTERNATIVE SYSTEM EXPANSIONS | | FUEL COMPONENT OF OPERATING COSTS IN \$1000 FOR ALTERNATIVE SYSTEM EXPANSIONS | |
|------|---|--------------------------------|---|--------------------------------|
| | INDEPENDENT COSTS - \$79 | INTERCONNECTED COSTS - \$79 | INDEPENDENT ESCALATED \$ | INTERCONNECTED ESCALATED \$ |
| 1979 | | | | |
| 1980 | | | | |
| 1981 | | 4,011 | | |
| 1982 | | 14,228 | | |
| 1983 | 18,629 | 46,967 | | |
| 1984 | 58,823 | 11,515 | | |
| 1985 | 16,380 | 32,062 | | |
| 1986 | | 492 | | |
| 1987 | | 463 | | |
| 1988 | | 436 | | |
| 1989 | 2,600 | 410 | | |
| 1990 | 23,435 | 2,986 | | |
| 1991 | 78,550 | 23,799 | | |
| 1992 | 130,300 | 78,892 | | |
| 1993 | 131,780 | 130,623 | | |
| 1994 | 79,930 | 132,084 | | |
| 1995 | 30,375 | 80,216 | | |
| 1996 | 17,630 | 23,090 | | |
| 1997 | | 254 | | |

| | ADDITIONAL DISBURSEMENTS IN \$1000 FOR UNDERLYING TRANSMISSION SYSTEM | | SUSITNA CONSTRUCTION POWER COSTS IN \$1000 FOR ALTERNATIVE MODES OF SUPPLY | |
|------|---|--------------------------------|--|----------------------------------|
| | INDEPENDENT COSTS - \$79 | INTERCONNECTED COSTS - \$79 | DIESEL GENERATION COSTS - \$79 | INTERTIE TAPLINE COSTS - \$79 |
| 1979 | | | | |
| 1980 | | | | |
| 1981 | | | | |
| 1982 | | | | |
| 1983 | | | | |
| 1984 | | | | |
| 1985 | | | | |
| 1986 | | | | |
| 1987 | | | | |
| 1988 | | | | |
| 1989 | | | | |
| 1990 | | | | |
| 1991 | | | | |
| 1992 | | | | |
| 1993 | | | | |
| 1994 | | | | |
| 1995 | | | | |
| 1996 | | | | |
| 1997 | | | | |

23 AUGUST 79

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERTIE
ECONOMIC FEASIBILITY STUDY

TABLE 8-2

CAPITAL DISBURSEMENTS
IN \$1000 FOR
ALTERNATIVE SYSTEM EXPANSIONS

FUEL COMPONENT OF OPERATING COSTS
IN \$1000 FOR
ALTERNATIVE SYSTEM EXPANSIONS

INDEPENDENT INTERCONNECTED INDEPENDENT INTERCONNECTED
COSTS - \$79 COSTS - \$79 ESCALATED \$ ESCALATED \$

1979
1980
1981 4,872
1982 2,009 18,056
1983 26,666 72,604
1984 81,942 11,326
1985 37,172 31,886
1986 21,127 328
1987 7,152 2,319
1988 7,555 8,529
1989 23,110 30,604
1990 21,920 43,092
1991 82,200 43,463
1992 101,380 89,973
1993 58,450 108,988
1994 29,840 75,387
1995 23,935 23,347
1996 17,630 499
1997 473

ADDITIONAL DISBURSEMENTS
IN \$1000 FOR
UNDERLYING TRANSMISSION SYSTEM

SUSITNA CONSTRUCTION POWER COSTS
IN \$1000 FOR
ALTERNATIVE MODES OF SUPPLY

INDEPENDENT INTERCONNECTED DIESEL GENERATION INTERTIE TAPLINE
COSTS - \$79 COSTS - \$79 COSTS - \$79 COSTS - \$79

1979
1980
1981
1982
1983
1984
1985
1986
1987
1988
1989
1990
1991
1992
1993
1994
1995
1996
1997

ALASKA POWER AUTHORITY
 ANCHORAGE - FAIRBANKS INTERTIE
 ECONOMIC FEASIBILITY STUDY

 DISCOUNTED VALUE OF BASE YEAR (1979) INDEPENDENT SYSTEM COSTS
 IN \$1000

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|---------|---------|---------|---------|---------|-----------|-----------|-----------|-----------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 450,441 | 646,867 | 708,932 | 777,234 | 852,386 | 935,064 | 1,026,007 | 1,126,021 | 1,235,993 | 1,356,889 |
| 8.25 | 440,558 | 632,130 | 692,045 | 759,218 | 832,456 | 913,013 | 1,001,606 | 1,099,020 | 1,206,114 | 1,323,827 |
| 8.50 | 430,938 | 617,813 | 676,806 | 741,701 | 813,080 | 891,578 | 977,892 | 1,072,784 | 1,177,086 | 1,291,712 |
| 8.75 | 421,574 | 603,877 | 661,401 | 724,667 | 794,242 | 870,742 | 954,844 | 1,047,287 | 1,148,882 | 1,260,512 |
| 9.00 | 412,458 | 590,320 | 646,415 | 708,101 | 775,923 | 850,484 | 932,439 | 1,022,507 | 1,121,474 | 1,230,199 |
| 9.25 | 403,582 | 577,128 | 631,838 | 691,987 | 758,109 | 830,787 | 910,658 | 998,420 | 1,094,838 | 1,200,744 |
| 9.50 | 394,939 | 564,292 | 617,654 | 676,312 | 740,783 | 811,632 | 889,481 | 975,006 | 1,068,948 | 1,172,120 |
| 9.75 | 386,522 | 551,799 | 603,854 | 661,063 | 723,929 | 793,004 | 868,888 | 952,241 | 1,043,783 | 1,144,300 |
| 10.00 | 378,323 | 539,640 | 590,424 | 646,225 | 707,534 | 774,885 | 848,863 | 930,107 | 1,019,317 | 1,117,258 |
| 10.25 | 370,337 | 527,804 | 577,353 | 631,787 | 691,583 | 757,260 | 829,386 | 908,583 | 995,530 | 1,090,971 |
| 10.50 | 362,558 | 516,282 | 564,630 | 617,737 | 676,063 | 740,113 | 810,441 | 887,650 | 972,400 | 1,065,414 |
| 10.75 | 354,978 | 505,063 | 552,246 | 604,061 | 660,959 | 723,430 | 792,011 | 867,290 | 949,907 | 1,040,564 |
| 11.00 | 347,592 | 494,139 | 540,188 | 590,749 | 646,260 | 707,196 | 774,081 | 847,485 | 928,031 | 1,016,399 |
| 11.25 | 340,394 | 483,501 | 528,448 | 577,791 | 631,952 | 691,398 | 756,635 | 828,218 | 906,752 | 992,899 |
| 11.50 | 333,379 | 473,141 | 517,016 | 565,174 | 618,025 | 676,022 | 739,658 | 809,472 | 886,052 | 970,041 |
| 11.75 | 326,542 | 463,049 | 505,883 | 552,889 | 604,467 | 661,056 | 723,136 | 791,231 | 865,913 | 947,807 |
| 12.00 | 319,876 | 453,218 | 495,040 | 540,925 | 591,265 | 646,486 | 707,055 | 773,480 | 846,318 | 926,177 |

 DISCOUNTED VALUE OF BASE YEAR (1979) INTERCONNECTED SYSTEM COSTS
 IN \$1000

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|---------|---------|---------|---------|---------|-----------|-----------|-----------|-----------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 425,715 | 623,551 | 686,899 | 756,982 | 834,493 | 920,193 | 1,014,914 | 1,119,573 | 1,235,172 | 1,362,807 |
| 8.25 | 415,880 | 608,574 | 670,250 | 738,473 | 813,914 | 897,313 | 989,478 | 1,091,297 | 1,203,742 | 1,327,880 |
| 8.50 | 406,320 | 594,025 | 654,080 | 720,498 | 793,933 | 875,100 | 964,786 | 1,063,852 | 1,173,242 | 1,293,990 |
| 8.75 | 397,026 | 579,890 | 638,372 | 703,040 | 774,529 | 853,533 | 940,815 | 1,037,212 | 1,143,640 | 1,261,101 |
| 9.00 | 387,990 | 566,157 | 623,113 | 686,083 | 755,684 | 832,590 | 917,541 | 1,011,350 | 1,114,906 | 1,229,183 |
| 9.25 | 379,204 | 552,811 | 608,287 | 669,610 | 737,380 | 812,251 | 894,942 | 986,242 | 1,087,013 | 1,198,201 |
| 9.50 | 370,660 | 539,842 | 593,880 | 653,606 | 719,599 | 792,496 | 872,995 | 961,861 | 1,059,933 | 1,168,127 |
| 9.75 | 362,351 | 527,236 | 579,881 | 638,056 | 702,325 | 773,307 | 851,680 | 938,186 | 1,033,639 | 1,138,930 |
| 10.00 | 354,269 | 514,983 | 566,274 | 622,945 | 685,542 | 754,666 | 830,976 | 915,192 | 1,008,106 | 1,110,582 |
| 10.25 | 346,407 | 503,071 | 553,049 | 608,259 | 669,233 | 736,555 | 810,863 | 892,859 | 983,310 | 1,083,055 |
| 10.50 | 338,758 | 491,489 | 540,192 | 593,985 | 653,384 | 718,957 | 791,323 | 871,165 | 959,226 | 1,056,323 |
| 10.75 | 331,315 | 480,228 | 527,693 | 580,110 | 637,981 | 701,855 | 772,338 | 850,089 | 935,832 | 1,030,360 |
| 11.00 | 324,073 | 469,277 | 515,540 | 566,621 | 623,008 | 685,235 | 753,889 | 829,612 | 913,106 | 1,005,142 |
| 11.25 | 317,025 | 458,626 | 503,723 | 553,507 | 608,453 | 669,081 | 735,960 | 809,715 | 891,027 | 980,644 |
| 11.50 | 310,166 | 448,266 | 492,230 | 540,755 | 594,303 | 653,378 | 718,535 | 790,379 | 869,573 | 956,844 |
| 11.75 | 303,488 | 438,189 | 481,052 | 528,354 | 580,544 | 638,112 | 701,597 | 771,586 | 848,726 | 933,720 |
| 12.00 | 296,988 | 428,385 | 470,179 | 516,294 | 567,165 | 623,270 | 685,131 | 753,321 | 828,465 | 911,250 |

ALASKA POWER AUTHORITY
 ANCHORAGE - FAIRBANKS INTERTIE
 ECONOMIC FEASIBILITY STUDY

 DISCOUNTED VALUE OF BASE YEAR (1979) INDEPENDENT SYSTEM COSTS
 IN \$1000

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|---------|---------|---------|---------|---------|-----------|-----------|-----------|-----------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 450,441 | 640,867 | 708,932 | 777,234 | 852,386 | 935,064 | 1,026,007 | 1,126,021 | 1,235,993 | 1,356,889 |
| 8.25 | 440,558 | 632,139 | 692,645 | 759,218 | 832,456 | 913,013 | 1,001,606 | 1,099,020 | 1,206,114 | 1,323,827 |
| 8.50 | 430,938 | 617,813 | 676,806 | 741,701 | 813,080 | 891,578 | 977,892 | 1,072,784 | 1,177,086 | 1,291,712 |
| 8.75 | 421,574 | 603,877 | 661,401 | 724,667 | 794,242 | 870,742 | 954,844 | 1,047,287 | 1,148,882 | 1,260,512 |
| 9.00 | 412,458 | 590,320 | 646,415 | 708,101 | 775,923 | 850,484 | 932,439 | 1,022,507 | 1,121,474 | 1,230,199 |
| 9.25 | 403,582 | 577,128 | 631,838 | 691,987 | 758,109 | 830,787 | 910,658 | 998,420 | 1,094,838 | 1,200,744 |
| 9.50 | 394,939 | 564,292 | 617,654 | 676,312 | 740,783 | 811,632 | 889,481 | 975,006 | 1,068,948 | 1,172,120 |
| 9.75 | 386,522 | 551,799 | 603,854 | 661,063 | 723,929 | 793,004 | 868,888 | 952,241 | 1,043,783 | 1,144,300 |
| 10.00 | 378,323 | 539,640 | 590,424 | 646,225 | 707,534 | 774,885 | 848,863 | 930,107 | 1,019,317 | 1,117,258 |
| 10.25 | 370,337 | 527,804 | 577,353 | 631,787 | 691,583 | 757,260 | 829,386 | 908,583 | 995,530 | 1,090,971 |
| 10.50 | 362,558 | 516,282 | 564,630 | 617,737 | 676,063 | 740,113 | 810,441 | 887,650 | 972,400 | 1,065,414 |
| 10.75 | 354,978 | 505,063 | 552,246 | 604,061 | 660,959 | 723,430 | 792,011 | 867,290 | 949,907 | 1,040,564 |
| 11.00 | 347,592 | 494,139 | 540,188 | 590,749 | 646,260 | 707,196 | 774,081 | 847,485 | 928,031 | 1,016,399 |
| 11.25 | 340,394 | 483,501 | 528,448 | 577,791 | 631,952 | 691,398 | 756,635 | 828,218 | 906,752 | 992,899 |
| 11.50 | 333,379 | 473,141 | 517,016 | 565,174 | 618,025 | 676,022 | 739,658 | 809,472 | 886,052 | 970,041 |
| 11.75 | 326,542 | 463,049 | 505,883 | 552,889 | 604,467 | 661,056 | 723,136 | 791,231 | 865,913 | 947,807 |
| 12.00 | 319,876 | 453,218 | 495,040 | 540,925 | 591,265 | 646,486 | 707,055 | 773,480 | 846,318 | 926,177 |

E - 12

 DISCOUNTED VALUE OF BASE YEAR (1979) INTERCONNECTED SYSTEM COSTS
 IN \$1000

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|---------|---------|---------|---------|---------|-----------|-----------|-----------|-----------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 438,030 | 637,754 | 701,606 | 772,207 | 850,250 | 936,495 | 1,031,776 | 1,137,008 | 1,253,195 | 1,381,433 |
| 8.25 | 428,091 | 622,658 | 684,834 | 753,570 | 829,539 | 913,478 | 1,006,197 | 1,108,585 | 1,221,613 | 1,346,349 |
| 8.50 | 418,429 | 607,491 | 668,541 | 735,469 | 809,426 | 891,129 | 981,365 | 1,080,995 | 1,190,963 | 1,312,303 |
| 8.75 | 409,035 | 593,739 | 652,713 | 717,886 | 789,892 | 869,427 | 957,255 | 1,054,211 | 1,161,211 | 1,279,261 |
| 9.00 | 399,899 | 579,891 | 637,334 | 700,805 | 770,919 | 848,351 | 933,843 | 1,028,207 | 1,132,331 | 1,247,190 |
| 9.25 | 391,015 | 566,431 | 622,390 | 684,209 | 752,488 | 827,881 | 911,108 | 1,002,957 | 1,104,292 | 1,216,058 |
| 9.50 | 382,374 | 553,349 | 607,867 | 668,084 | 734,582 | 807,996 | 889,026 | 978,437 | 1,077,067 | 1,185,834 |
| 9.75 | 373,968 | 540,631 | 593,751 | 652,414 | 717,183 | 788,679 | 867,578 | 954,624 | 1,050,631 | 1,156,490 |
| 10.00 | 365,790 | 528,268 | 580,030 | 637,184 | 700,277 | 769,910 | 846,742 | 931,494 | 1,024,957 | 1,127,996 |
| 10.25 | 357,834 | 516,246 | 566,691 | 622,381 | 683,847 | 751,673 | 826,499 | 909,026 | 1,000,021 | 1,100,325 |
| 10.50 | 350,091 | 504,557 | 553,723 | 607,991 | 667,878 | 733,951 | 806,831 | 887,199 | 975,800 | 1,073,450 |
| 10.75 | 342,557 | 493,188 | 541,113 | 594,001 | 652,355 | 716,726 | 787,718 | 865,991 | 952,269 | 1,047,346 |
| 11.00 | 335,223 | 482,131 | 528,850 | 580,399 | 637,265 | 699,984 | 769,143 | 845,383 | 929,408 | 1,021,988 |
| 11.25 | 328,085 | 471,376 | 516,924 | 567,172 | 622,594 | 683,709 | 751,089 | 825,357 | 907,195 | 997,352 |
| 11.50 | 321,135 | 460,913 | 505,324 | 554,309 | 608,328 | 667,887 | 733,540 | 805,893 | 885,609 | 973,415 |
| 11.75 | 314,370 | 450,733 | 494,040 | 541,798 | 594,455 | 652,503 | 716,480 | 786,974 | 864,631 | 950,456 |
| 12.00 | 307,782 | 440,828 | 483,062 | 529,628 | 580,963 | 637,544 | 699,893 | 768,583 | 844,241 | 927,552 |

ALASKA POWER AUTHORITY
 ANCHORAGE - FAIRBANKS INTERTIE
 ECONOMIC FEASIBILITY STUDY

 DISCOUNTED VALUE OF BASE YEAR (1979) INDEPENDENT SYSTEM COSTS
 IN \$1000

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 237,690 | 352,449 | 389,849 | 431,534 | 477,981 | 529,713 | 587,311 | 651,414 | 722,726 | 802,024 |
| 8.25 | 232,026 | 343,607 | 379,955 | 420,460 | 465,585 | 515,836 | 571,777 | 634,027 | 703,268 | 780,253 |
| 8.50 | 226,529 | 335,031 | 370,360 | 409,724 | 453,568 | 502,386 | 556,724 | 617,180 | 684,417 | 759,164 |
| 8.75 | 221,192 | 326,713 | 361,055 | 399,312 | 441,917 | 489,349 | 542,134 | 600,855 | 666,153 | 738,734 |
| 9.00 | 216,009 | 318,642 | 352,029 | 389,216 | 430,621 | 476,710 | 527,992 | 585,033 | 648,454 | 718,939 |
| 9.25 | 210,977 | 310,812 | 343,274 | 379,423 | 419,667 | 464,455 | 514,283 | 569,698 | 631,302 | 699,759 |
| 9.50 | 206,090 | 303,214 | 334,779 | 369,924 | 409,043 | 452,572 | 500,992 | 554,833 | 614,678 | 681,172 |
| 9.75 | 201,342 | 295,840 | 326,537 | 360,709 | 398,739 | 441,049 | 488,105 | 540,421 | 598,564 | 663,157 |
| 10.00 | 196,730 | 288,683 | 318,539 | 351,769 | 388,743 | 429,872 | 475,608 | 526,448 | 582,943 | 645,696 |
| 10.25 | 192,250 | 281,735 | 310,777 | 343,093 | 379,045 | 419,031 | 463,487 | 512,899 | 567,798 | 628,769 |
| 10.50 | 187,896 | 274,990 | 303,242 | 334,674 | 369,636 | 408,514 | 451,732 | 499,759 | 553,112 | 612,359 |
| 10.75 | 183,665 | 268,441 | 295,928 | 326,503 | 360,506 | 398,310 | 440,328 | 487,015 | 538,871 | 596,447 |
| 11.00 | 179,552 | 262,082 | 288,827 | 318,572 | 351,645 | 388,409 | 429,265 | 474,653 | 525,059 | 581,018 |
| 11.25 | 175,555 | 255,906 | 281,932 | 310,872 | 343,044 | 378,801 | 418,531 | 462,661 | 511,663 | 566,054 |
| 11.50 | 171,669 | 249,908 | 275,237 | 303,396 | 334,696 | 369,476 | 408,115 | 451,026 | 498,667 | 551,541 |
| 11.75 | 167,890 | 244,081 | 268,734 | 296,138 | 326,591 | 360,425 | 398,006 | 439,736 | 486,060 | 537,463 |
| 12.00 | 164,216 | 238,420 | 262,419 | 289,089 | 318,722 | 351,639 | 388,195 | 428,781 | 473,827 | 523,806 |

 DISCOUNTED VALUE OF BASE YEAR (1979) INTERCONNECTED SYSTEM COSTS
 IN \$1000

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 238,419 | 347,569 | 383,059 | 422,582 | 466,586 | 515,562 | 570,053 | 630,659 | 698,037 | 772,913 |
| 8.25 | 233,022 | 339,177 | 373,675 | 412,087 | 454,846 | 502,429 | 555,362 | 614,225 | 679,657 | 752,361 |
| 8.50 | 227,783 | 331,036 | 364,574 | 401,911 | 443,464 | 489,698 | 541,122 | 598,299 | 661,848 | 732,450 |
| 8.75 | 222,695 | 323,138 | 355,747 | 392,041 | 432,428 | 477,356 | 527,320 | 582,865 | 644,591 | 713,158 |
| 9.00 | 217,753 | 315,474 | 347,182 | 382,468 | 421,725 | 465,389 | 513,939 | 567,904 | 627,865 | 694,463 |
| 9.25 | 212,953 | 308,036 | 338,873 | 373,182 | 411,345 | 453,784 | 500,965 | 553,401 | 611,654 | 676,346 |
| 9.50 | 208,290 | 300,818 | 330,810 | 364,172 | 401,276 | 442,530 | 488,386 | 539,340 | 595,940 | 658,787 |
| 9.75 | 203,759 | 293,811 | 322,985 | 355,431 | 391,508 | 431,614 | 476,187 | 525,707 | 580,705 | 641,766 |
| 10.00 | 199,356 | 287,009 | 315,390 | 346,948 | 382,032 | 421,026 | 464,355 | 512,486 | 565,935 | 625,265 |
| 10.25 | 195,078 | 280,405 | 308,018 | 338,716 | 372,836 | 410,753 | 452,878 | 499,665 | 551,612 | 609,268 |
| 10.50 | 190,919 | 273,992 | 300,861 | 330,725 | 363,913 | 400,786 | 441,745 | 487,229 | 537,722 | 593,756 |
| 10.75 | 186,876 | 267,764 | 293,912 | 322,968 | 355,252 | 391,115 | 430,944 | 475,166 | 524,250 | 578,713 |
| 11.00 | 182,946 | 261,715 | 287,164 | 315,437 | 346,845 | 381,729 | 420,463 | 463,463 | 511,183 | 564,124 |
| 11.25 | 179,124 | 255,839 | 280,610 | 308,125 | 338,685 | 372,619 | 410,293 | 452,108 | 498,506 | 549,974 |
| 11.50 | 175,407 | 250,130 | 274,245 | 301,025 | 330,761 | 363,776 | 400,422 | 441,090 | 486,208 | 536,247 |
| 11.75 | 171,792 | 244,584 | 268,062 | 294,129 | 323,068 | 355,191 | 390,841 | 430,397 | 474,274 | 522,930 |
| 12.00 | 168,276 | 239,194 | 262,055 | 287,431 | 315,597 | 346,856 | 381,541 | 420,019 | 462,694 | 510,010 |

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERTIE
ECONOMIC FEASIBILITY STUDY

TABLE 8-4X

| CAPITAL DISBURSEMENTS IN \$1000 FOR ALTERNATIVE SYSTEM EXPANSIONS | | FUEL COMPONENT OF OPERATING COSTS IN \$1000 FOR ALTERNATIVE SYSTEM EXPANSIONS | |
|---|--------------------------------|---|--------------------------------|
| INDEPENDENT COSTS - \$79 | INTERCONNECTED COSTS - \$79 | INDEPENDENT ESCALATED \$ | INTERCONNECTED ESCALATED \$ |

| | | | |
|------|---------|---------|--------|
| 1979 | | | |
| 1980 | | | |
| 1981 | | 5,014 | |
| 1982 | 2,009 | 17,785 | |
| 1983 | 26,666 | 58,709 | |
| 1984 | 81,942 | 11,551 | |
| 1985 | 37,172 | 32,097 | 8,468 |
| 1986 | 27,727 | 6,006 | 9,324 |
| 1987 | 33,552 | 24,420 | 10,267 |
| 1988 | 106,555 | 90,673 | |
| 1989 | 145,210 | 135,940 | |
| 1990 | 94,760 | 115,716 | |
| 1991 | 119,475 | 113,198 | |
| 1992 | 101,380 | 89,694 | 6,851 |
| 1993 | 58,450 | 108,723 | 7,212 |
| 1994 | 29,840 | 75,134 | 7,933 |
| 1995 | 23,935 | 23,106 | 8,654 |
| 1996 | 17,630 | 270 | 9,015 |
| 1997 | | 254 | |

| ADDITIONAL DISBURSEMENTS IN \$1000 FOR UNDERLYING TRANSMISSION SYSTEM | | SUSITNA CONSTRUCTION POWER COSTS IN \$1000 FOR ALTERNATIVE MODES OF SUPPLY | |
|---|--------------------------------|--|----------------------------------|
| INDEPENDENT COSTS - \$79 | INTERCONNECTED COSTS - \$79 | DIFSEL GENERATION COSTS - \$79 | INTERTIE TAPLINE COSTS - \$79 |

| | | | |
|------|-------|-------|-----|
| 1979 | | | |
| 1980 | | | |
| 1981 | | | |
| 1982 | | | |
| 1983 | | | |
| 1984 | | | |
| 1985 | | 2,835 | 267 |
| 1986 | | 695 | 483 |
| 1987 | 6,646 | 697 | 481 |
| 1988 | | 696 | 478 |
| 1989 | | 3,055 | 752 |
| 1990 | | 1,324 | 902 |
| 1991 | | 187 | 734 |
| 1992 | 2,004 | 623 | 430 |
| 1993 | | 623 | 419 |
| 1994 | | -500 | 304 |
| 1995 | | | |
| 1996 | | | |
| 1997 | | | |

ALASKA POWER AUTHORITY
ANCHORAGE - FAIRBANKS INTERTIE
ECONOMIC FEASIBILITY STUDY

TABLE 8-5

| | CAPITAL DISBURSEMENTS IN \$1000 FOR ALTERNATIVE SYSTEM EXPANSIONS | | FUEL COMPONENT OF OPERATING COSTS IN \$1000 FOR ALTERNATIVE SYSTEM EXPANSIONS | |
|------|---|--------------------------------|---|--------------------------------|
| | INDEPENDENT COSTS - \$79 | INTERCONNECTED COSTS - \$79 | INDEPENDENT ESCALATED \$ | INTERCONNECTED ESCALATED \$ |
| 1979 | | | | |
| 1980 | | | | |
| 1981 | | 4,621 | | |
| 1982 | 2,009 | 15,594 | | |
| 1983 | 26,666 | 48,874 | | |
| 1984 | 81,942 | 11,515 | | |
| 1985 | 37,172 | 32,062 | | |
| 1986 | 21,127 | 492 | | |
| 1987 | 7,152 | 2,472 | | |
| 1988 | 7,555 | 8,473 | | |
| 1989 | 23,110 | 30,549 | | |
| 1990 | 21,920 | 43,038 | | |
| 1991 | 82,200 | 43,411 | | |
| 1992 | 101,380 | 89,694 | | |
| 1993 | 58,450 | 108,723 | | |
| 1994 | 29,840 | 75,134 | | |
| 1995 | 23,935 | 23,106 | | |
| 1996 | 17,630 | 270 | | |
| 1997 | | 254 | | |

| | ADDITIONAL DISBURSEMENTS IN \$1000 FOR UNDERLYING TRANSMISSION SYSTEM | | SUSITNA CONSTRUCTION POWER COSTS IN \$1000 FOR ALTERNATIVE MODES OF SUPPLY | |
|--|---|--------------------------------|--|----------------------------------|
| | INDEPENDENT COSTS - \$79 | INTERCONNECTED COSTS - \$79 | DIESEL GENERATION COSTS - \$79 | INTERTIE TAPLINE COSTS - \$79 |

1979
1980
1981
1982
1983
1984
1985
1986
1987
1988
1989
1990
1991
1992
1993
1994
1995
1996
1997

6,646 1,356

2,004

ALASKA POWER AUTHORITY
 ANCHORAGE - FAIRBANKS INTERTIE
 ECONOMIC FEASIBILITY STUDY

TABLE 8-6

 DISCOUNTED VALUE OF BASE YEAR (1979) INDEPENDENT SYSTEM COSTS
 IN \$1000

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 261,027 | 381,019 | 419,402 | 461,886 | 508,913 | 560,973 | 618,607 | 682,411 | 753,044 | 831,230 |
| 8.25 | 255,466 | 372,366 | 409,734 | 451,083 | 496,843 | 547,488 | 603,542 | 665,583 | 734,247 | 810,239 |
| 8.50 | 250,057 | 363,958 | 400,344 | 440,594 | 485,127 | 534,401 | 588,925 | 649,258 | 716,017 | 789,885 |
| 8.75 | 244,795 | 355,789 | 391,222 | 430,408 | 473,752 | 521,698 | 574,740 | 633,419 | 698,335 | 770,146 |
| 9.00 | 239,676 | 347,851 | 382,360 | 420,515 | 462,706 | 509,367 | 560,973 | 618,051 | 681,181 | 751,002 |
| 9.25 | 234,694 | 340,136 | 373,750 | 410,905 | 451,980 | 497,394 | 547,610 | 603,137 | 664,538 | 732,432 |
| 9.50 | 229,846 | 332,636 | 365,382 | 401,568 | 441,562 | 485,769 | 534,638 | 588,663 | 648,389 | 714,417 |
| 9.75 | 225,127 | 325,346 | 357,250 | 392,497 | 431,442 | 474,479 | 522,043 | 574,613 | 632,717 | 696,937 |
| 10.00 | 220,534 | 318,257 | 349,346 | 383,681 | 421,610 | 463,513 | 509,813 | 560,973 | 617,506 | 679,976 |
| 10.25 | 216,062 | 311,364 | 341,661 | 375,114 | 412,057 | 452,862 | 497,936 | 547,730 | 602,741 | 663,515 |
| 10.50 | 211,707 | 304,660 | 334,190 | 366,786 | 402,774 | 442,514 | 486,400 | 534,870 | 588,406 | 647,538 |
| 10.75 | 207,466 | 298,140 | 326,925 | 358,691 | 393,753 | 432,459 | 475,194 | 522,381 | 574,488 | 632,028 |
| 11.00 | 203,336 | 291,796 | 319,860 | 350,820 | 384,984 | 422,688 | 464,307 | 510,251 | 560,973 | 616,971 |
| 11.25 | 199,312 | 285,625 | 312,988 | 343,167 | 376,459 | 413,193 | 453,730 | 498,468 | 547,847 | 602,351 |
| 11.50 | 195,392 | 279,620 | 306,303 | 335,724 | 368,171 | 403,963 | 443,450 | 487,020 | 535,099 | 588,154 |
| 11.75 | 191,573 | 273,776 | 299,799 | 328,484 | 360,112 | 394,990 | 433,461 | 475,897 | 522,714 | 574,366 |
| 12.00 | 187,851 | 268,088 | 293,471 | 321,442 | 352,275 | 386,267 | 423,750 | 465,089 | 510,682 | 560,973 |

 DISCOUNTED VALUE OF BASE YEAR (1979) INTERCONNECTED SYSTEM COSTS
 IN \$1000

| DISCOUNT RATE | -----ESCALATION RATES----- | | | | | | | | | |
|------------------|----------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| | 0% | 4% | 5% | 6% | 7% | 8% | 9% | 10% | 11% | 12% |
| 8.00 | 239,682 | 359,652 | 398,725 | 442,277 | 490,812 | 544,888 | 605,121 | 672,193 | 746,854 | 829,934 |
| 8.25 | 234,223 | 350,883 | 388,857 | 431,175 | 478,325 | 530,849 | 589,342 | 654,466 | 726,946 | 807,588 |
| 8.50 | 228,923 | 342,378 | 379,289 | 420,413 | 466,223 | 517,245 | 574,055 | 637,294 | 707,665 | 785,948 |
| 8.75 | 223,777 | 334,130 | 370,010 | 409,978 | 454,493 | 504,061 | 559,243 | 620,658 | 688,989 | 764,990 |
| 9.00 | 218,781 | 326,128 | 361,012 | 399,861 | 443,121 | 491,282 | 544,888 | 604,539 | 670,896 | 744,690 |
| 9.25 | 213,929 | 318,360 | 352,284 | 390,051 | 432,095 | 478,895 | 530,976 | 588,919 | 653,367 | 725,025 |
| 9.50 | 209,216 | 310,834 | 343,818 | 380,535 | 421,404 | 466,886 | 517,491 | 573,782 | 636,381 | 705,974 |
| 9.75 | 204,637 | 303,525 | 335,604 | 371,306 | 411,036 | 455,242 | 504,418 | 559,110 | 619,920 | 687,514 |
| 10.00 | 200,190 | 296,431 | 327,634 | 362,353 | 400,981 | 443,951 | 491,744 | 544,888 | 603,967 | 669,625 |
| 10.25 | 195,868 | 289,546 | 319,900 | 353,666 | 391,227 | 433,001 | 479,455 | 531,100 | 588,504 | 652,289 |
| 10.50 | 191,668 | 282,862 | 312,393 | 345,237 | 381,764 | 422,380 | 467,537 | 517,732 | 573,513 | 635,486 |
| 10.75 | 187,566 | 276,373 | 305,107 | 337,058 | 372,583 | 412,078 | 455,979 | 504,769 | 558,980 | 619,198 |
| 11.00 | 183,618 | 270,072 | 298,034 | 329,119 | 363,674 | 402,083 | 444,768 | 492,198 | 544,888 | 603,407 |
| 11.25 | 179,761 | 263,953 | 291,167 | 321,413 | 355,029 | 392,385 | 433,893 | 480,005 | 531,223 | 588,096 |
| 11.50 | 176,011 | 258,010 | 284,499 | 313,933 | 346,638 | 382,974 | 423,341 | 468,178 | 517,969 | 573,250 |
| 11.75 | 172,364 | 252,237 | 278,023 | 306,670 | 338,493 | 373,842 | 413,103 | 456,704 | 505,114 | 558,852 |
| 12.00 | 168,817 | 246,629 | 271,734 | 299,617 | 330,585 | 364,977 | 403,168 | 445,572 | 492,644 | 544,888 |

APPENDIX F
TRANSMISSION LINE FINANCIAL ANALYSIS

APPENDIX F
TRANSMISSION LINE FINANCIAL ANALYSIS

ANCHORAGE-FAIRBANKS INTERCONNECTION
SEMI-ANNUAL DISBURSEMENTS
FOR
TRANSMISSION INTERTIE FACILITIES
(TLFAP)
1979
BASE-LINE
AND
ESCALATED
COSTS

16 AUGUST 79

ANCHORAGE - FAIRBANKS INTERCONNECTION
SEMI-ANNUAL DISBURSEMENTS FOR TRANSMISSION INTERTIE FACILITIES
UNINFLATED 1979 LEVEL COSTS

| LINE NO | 1981-1 | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TOTAL |
|-------------------------------------|--------|--------|--------|--------|--------|--------|-------|
| 102.0 1. TRANSMISSION LINE | | | | | | | |
| 104.0 ENGINEERING AND CONSTRUCTION | | | | | | | |
| 105.0 SUPERVISION | 452 | 753 | 0 | 392 | 693 | 723 | 3012 |
| 106.0 RIGHT OF WAY | 0 | 2209 | 6628 | 0 | 0 | 0 | 8837 |
| 108.0 FOUNDATIONS | 0 | 0 | 0 | 2280 | 6165 | 0 | 8445 |
| 110.0 TOWERS | 0 | 0 | 0 | 0 | 9727 | 11888 | 21615 |
| 112.0 HARDWARE | 0 | 0 | 0 | 0 | 72 | 405 | 477 |
| 114.0 INSULATORS | 0 | 0 | 0 | 0 | 75 | 428 | 503 |
| 116.0 CONDUCTOR | 0 | 0 | 0 | 0 | 1614 | 9147 | 10761 |
| 119.0 | ----- | ----- | ----- | ----- | ----- | ----- | ----- |
| 120.0 SUB-TOTAL | 452 | 2962 | 6628 | 2672 | 18346 | 22591 | 53650 |
| 122.0 | | | | | | | |
| 130.0 2. SUBSTATIONS | | | | | | | |
| 132.0 ENGINEERING & CONSTRUCTION | | | | | | | |
| 133.0 SUPERVISION | 563 | 563 | 563 | 563 | 282 | 282 | 2816 |
| 134.0 LAND | 81 | 0 | 0 | 0 | 0 | 0 | 81 |
| 136.0 TRANSFORMERS | 0 | 0 | 341 | 596 | 596 | 170 | 1703 |
| 138.0 CIRCUIT BREAKERS | 0 | 0 | 391 | 684 | 684 | 195 | 1953 |
| 140.0 STATION EQUIPMENT | 0 | 0 | 269 | 471 | 471 | 135 | 1345 |
| 141.0 STRUCTURES & ACCESSORIES | 0 | 0 | 805 | 1610 | 1610 | 0 | 4026 |
| 145.0 | ----- | ----- | ----- | ----- | ----- | ----- | ----- |
| 146.0 SUB-TOTAL | 644 | 563 | 2369 | 3924 | 3642 | 782 | 11924 |
| 149.0 | | | | | | | |
| 150.0 3. CONTROL AND COMMUNICATIONS | | | | | | | |
| 152.0 ENGINEERING AND INSTALLATION | | | | | | | |
| 153.0 SUPERVISION | 0 | 0 | 0 | 0 | 71 | 94 | 165 |
| 154.0 EQUIPMENT | 0 | 0 | 0 | 0 | 1254 | 1881 | 3135 |
| 156.0 | ----- | ----- | ----- | ----- | ----- | ----- | ----- |
| 158.0 SUB-TOTAL | 0 | 0 | 0 | 0 | 1325 | 1975 | 3300 |
| 160.0 | | | | | | | |
| 162.0 TOTAL | 1096 | 3525 | 8996 | 6596 | 23313 | 25348 | 68874 |
| 164.0 | | | | | | | |
| 166.0 TOTAL FOR YEAR | 0 | 4621 | 0 | 15592 | 0 | 48661 | 68874 |

16 AUGUST 79

ANCHORAGE - FAIRBANKS INTERCONNECTION
FUNDING SOURCES AND
INTEREST DURING CONSTRUCTION

40-60 REA-FFB

| LINE NO | 1981-1 | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TOTAL |
|------------------------------------|--------|--------|--------|--------|--------|--------|-------|
| 400.0 FUNDING SOURCES | | | | | | | |
| 401.0 APA BOND | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 402.0 REA LOAN | 307 | 1027 | 2725 | 2077 | 7636 | 8635 | 22407 |
| 403.0 CFC LOAN | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 404.0 FFB LOAN | 460 | 1540 | 4087 | 5116 | 11455 | 12953 | 33610 |
| 405.0 AMU SHORT TERM LOAN | 197 | 660 | 1751 | 1335 | 4909 | 5551 | 14404 |
| 406.0 FMU SHORT TERM LOAN | 132 | 440 | 1168 | 890 | 3273 | 3701 | 9603 |
| 408.0 | | | | | | | |
| 409.0 TOTAL | 1096 | 3666 | 9730 | 7419 | 27273 | 30839 | 80024 |
| 410.0 | | | | | | | |
| 411.0 INTEREST DURING CONSTRUCTION | | | | | | | |
| 412.0 APA BOND | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 413.0 REA LOAN | 4 | 21 | 67 | 127 | 249 | 452 | 920 |
| 414.0 CFC LOAN | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 415.0 FFB LOAN | 11 | 57 | 187 | 354 | 691 | 1255 | 2554 |
| 416.0 AMU SHORT TERM LOAN | 10 | 53 | 173 | 328 | 640 | 1163 | 2366 |
| 417.0 FMU SHORT TERM LOAN | 7 | 35 | 116 | 218 | 427 | 775 | 1578 |
| 420.0 | | | | | | | |
| 421.0 TOTAL | 31 | 165 | 543 | 1027 | 2006 | 3645 | 7418 |
| 422.0 | | | | | | | |

16 AUGUST 79

ANCHORAGE - FAIRBANKS INTERCONNECTION
DEBT TABLE AND
COMPOSITE INTEREST RATE

40-60 REA-FFB

| LINE NO | 1981-1 | 1981-2 | 1982-1 | 1982-2 | 1983-1 | 1983-2 | TOTAL |
|--------------------------------------|--------|--------|--------|--------|--------|--------|-------|
| 430.0 % DEBT ASSUMED BY EACH UTILITY | | | | | | | |
| 432.0 AML & P | 18 | 0 | 0 | 0 | 0 | 0 | 18 |
| 434.0 CFA | 11 | 0 | 0 | 0 | 0 | 0 | 11 |
| 436.0 MEA | 3 | 0 | 0 | 0 | 0 | 0 | 3 |
| 438.0 HEA | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 442.0 FMUS | 12 | 0 | 0 | 0 | 0 | 0 | 12 |
| 444.0 GVEA | 56 | 0 | 0 | 0 | 0 | 0 | 56 |
| 446.0 CVEA | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 447.0 | | | | | | | |
| 448.0 | | | | | | | |
| 449.0 | | | | | | | |
| 450.0 DEBT ASSUMED BY EACH UTILITY | | | | | | | |
| 452.0 AML & P | 197 | 660 | 1751 | 1335 | 4909 | 5551 | 14404 |
| 454.0 CEA | 121 | 403 | 1070 | 816 | 3000 | 3392 | 8803 |
| 456.0 MEA | 33 | 110 | 292 | 223 | 818 | 925 | 2401 |
| 458.0 HEA | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 462.0 FMUS | 132 | 440 | 1168 | 890 | 3273 | 3701 | 9603 |
| 464.0 GVEA | 614 | 2053 | 5449 | 4155 | 15273 | 17270 | 44814 |
| 466.0 CVEA | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 468.0 | | | | | | | |
| 470.0 TOTAL DEBT | 1096 | 3666 | 9730 | 7419 | 27273 | 30839 | 80024 |
| 472.0 | | | | | | | |
| 474.0 | | | | | | | |
| 476.0 | | | | | | | |
| 510.0 COMPOSITE INTEREST RATE | 0.083 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.083 |

